

**MG3710A**  
**Vector Signal Generator**  
**MG3740A**  
**Analog Signal Generator**  
**Operation Manual**

**11th Edition**

**For safety and warning information, please read this manual before attempting to use the equipment.  
Keep this manual with the equipment.**

**ANRITSU CORPORATION**

# Safety Symbols

To prevent the risk of personal injury or loss related to equipment malfunction, Anritsu Corporation uses the following safety symbols to indicate safety-related information. Ensure that you clearly understand the meanings of the symbols BEFORE using the equipment. Some or all of the following symbols may be used on all Anritsu equipment. In addition, there may be other labels attached to products that are not shown in the diagrams in this manual.

## Symbols used in manual

 **DANGER**

This indicates a very dangerous procedure that could result in serious injury or death if not performed properly.

 **WARNING**

This indicates a hazardous procedure that could result in serious injury or death if not performed properly.

 **CAUTION**

This indicates a hazardous procedure or danger that could result in light-to-severe injury, or loss related to equipment malfunction, if proper precautions are not taken.

## Safety Symbols Used on Equipment and in Manual

The following safety symbols are used inside or on the equipment near operation locations to provide information about safety items and operation precautions. Ensure that you clearly understand the meanings of the symbols and take the necessary precautions BEFORE using the equipment.



This indicates a prohibited operation. The prohibited operation is indicated symbolically in or near the barred circle.



This indicates an obligatory safety precaution. The obligatory operation is indicated symbolically in or near the circle.



This indicates a warning or caution. The contents are indicated symbolically in or near the triangle.



This indicates a note. The contents are described in the box.



These indicate that the marked part should be recycled.

MG3710A Vector Signal Generator  
MG3740A Analog Signal Generator  
Operation Manual

20 January 2012 (First Edition)  
21 April 2014 (11th Edition)

Copyright © 2012-2014, ANRITSU CORPORATION.

All rights reserved. No part of this manual may be reproduced without the prior written permission of the publisher.

The contents of this manual may be changed without prior notice.

Printed in Japan

# For Safety

## **WARNING**



- ALWAYS refer to the operation manual when working near locations at which the alert mark shown on the left is attached. If the advice in the operation manual is not followed, there is a risk of personal injury or reduced equipment performance. The alert mark shown on the left may also be used with other marks and descriptions to indicate other dangers.

- Overvoltage Category

This equipment complies with overvoltage category II defined in IEC 61010. DO NOT connect this equipment to the power supply of overvoltage category III or IV.

### **Electric Shock**

- To ensure that the equipment is grounded, always use the supplied 3-pin power cord, and insert the plug into an outlet with a ground terminal. If power is supplied without grounding the equipment, there is a risk of receiving a severe or fatal electric shock or causing damage to the internal components.

### **Repair**



- Only qualified service personnel with a knowledge of electrical fire and shock hazards should service this equipment. This equipment cannot be repaired by the operator. DO NOT attempt to remove the equipment covers or unit covers or to disassemble internal components. There are high-voltage parts in this equipment presenting a risk of severe injury or fatal electric shock to untrained personnel. In addition, there is a risk of damage to precision components.

### **Calibration**



- The performance-guarantee seal verifies the integrity of the equipment. To ensure the continued integrity of the equipment, only Anritsu service personnel, or service personnel of an Anritsu sales representative, should break this seal to repair or calibrate the equipment. Be careful not to break the seal by opening the equipment or unit covers. If the performance-guarantee seal is broken by you or a third party, the performance of the equipment cannot be guaranteed.

# For Safety

## **WARNING**

### **Falling Over**

- This equipment should always be positioned in the correct manner. If the cabinet is turned on its side, etc., it will be unstable and may be damaged if it falls over as a result of receiving a slight mechanical shock.

Always set up the equipment in a position where the power switch can be reached without difficulty.

### **Replacing Battery**



- When replacing the battery, use the specified battery and insert it with the correct polarity. If the wrong battery is used, or if the battery is inserted with reversed polarity, there is a risk of explosion causing severe injury or death.

### **Battery Fluid**

- DO NOT short the battery terminals and never attempt to disassemble the battery or dispose of it in a fire. If the battery is damaged by any of these actions, the battery fluid may leak. This fluid is poisonous.

DO NOT touch the battery fluid, ingest it, or get in your eyes. If it is accidentally ingested, spit it out immediately, rinse your mouth with water and seek medical help. If it enters your eyes accidentally, do not rub your eyes, rinse them with clean running water and seek medical help. If the liquid gets on your skin or clothes, wash it off carefully and thoroughly.

### **Battery Disposal**

- DO NOT expose batteries to heat or fire. Do not expose batteries to fire. This is dangerous and can result in explosions or fire. Heating batteries may cause them to leak or explode.

### **LCD**

- This equipment uses a Liquid Crystal Display (LCD). DO NOT subject the equipment to excessive force or drop it. If the LCD is subjected to strong mechanical shock, it may break and liquid may leak.

This liquid is very caustic and poisonous.

DO NOT touch it, ingest it, or get in your eyes. If it is ingested accidentally, spit it out immediately, rinse your mouth with water and seek medical help. If it enters your eyes accidentally, do not rub your eyes, rinse them with clean running water and seek medical help. If the liquid gets on your skin or clothes, wash it off carefully and thoroughly.



# For Safety



## CAUTION

### Cleaning

- Always remove the main power cable from the power outlet before cleaning dust around the power supply and fan.
- Clean the power inlet regularly. If dust accumulates around the power pins, there is a risk of fire.
- Keep the cooling fan clean so that the ventilation holes are not obstructed. If the ventilation is obstructed, the cabinet may overheat and catch fire.

### Check Terminal



- Never input a signal of more than the indicated value between the measured terminal and ground. Input of an excessive signal may damage the equipment.

# For Safety

## CAUTION

### **Replacing Memory Back-up Battery**

This equipment uses a Poly-carbomonofluoride lithium battery to backup the memory. This battery must be replaced by service personnel when it has reached the end of its useful life; contact the Anritsu sales section or your nearest representative.

Note: The battery used in this equipment has a maximum useful life of 7 years. It should be replaced before this period has elapsed.

### **External Storage Media**

This equipment uses the USB memory as external storage media for storing data and programs.

If this media is mishandled or becomes faulty, important data may be lost. To prevent this chance occurrence, all important data and programs should be backed-up.

Anritsu will not be held responsible for lost data.

Pay careful attention to the following points.

- Never remove the USB memory from the instrument while it is being accessed.
- The external storage media may be damaged by static electric charges.
- Anritsu has thoroughly tested all external storage media shipped with this equipment. Users should note that external storage media not shipped with this equipment may not have been tested by Anritsu, thus Anritsu cannot guarantee the performance or suitability of such media.

# For Safety

## CAUTION

### **Hard disk**

The equipment is equipped with an internal hard disk from which, as with any hard disk, data may be lost under certain conditions. To prevent this chance occurrence, all important data and programs should be backed-up.

Anritsu will not be held responsible for lost data.

To reduce the possibility of data loss, particular attention should be given to the following points.

- The equipment should only be used within the recommend temperature range, and should not be used in locations where the temperature may fluctuate suddenly.
- Always follow the guidelines to ensure that the equipment is set up in the specified manner.
- Always ensure that the fans at the rear and side of the equipment are not blocked or obstructed in any way.
- Exercise care not to bang or shake the equipment whilst the power is on.
- Never disconnect the mains power at the plug or cut the power at the breaker with the equipment turned on.

### **Notes on Handling (When Rubidium Reference Oscillator Option is Installed)**

Please use the carrying case or the original packing materials when you transport it.

Because Rubidium Reference Oscillator frequency changes by the magnet, please do not set the one to have the magnetism (more than 0.5 Gauss) such as magnets near it.

### **Use in a Residential environment**

This equipment is designed for an industrial environment.

In a residential environment this equipment may cause radio interference in which case the user may be required to take adequate measures.

### **Use in Corrosive Atmospheres**

Exposure to corrosive gases such as hydrogen sulfide, sulfurous acid, and hydrogen chloride will cause faults and failures.

Note that some organic solvents release corrosive gases.

---

# Equipment Certificate

Anritsu Corporation certifies that this equipment was tested before shipment using calibrated measuring instruments with direct traceability to public testing organizations recognized by national research laboratories, including the National Institute of Advanced Industrial Science and Technology, and the National Institute of Information and Communications Technology, and was found to meet the published specifications.

## Anritsu Warranty

Anritsu Corporation will repair this equipment free-of-charge if a malfunction occurs within one year after shipment due to a manufacturing fault. However, software fixes will be made in accordance with the separate Software End-User License Agreement. Moreover, Anritsu Corporation will deem this warranty void when:

- The fault is outside the scope of the warranty conditions separately described in the operation manual.
- The fault is due to mishandling, misuse, or unauthorized modification or repair of the equipment by the customer.
- The fault is due to severe usage clearly exceeding normal usage.
- The fault is due to improper or insufficient maintenance by the customer.
- The fault is due to natural disaster, including fire, wind, flooding, earthquake, lightning strike, or volcanic ash, etc.
- The fault is due to damage caused by acts of destruction, including civil disturbance, riot, or war, etc.
- The fault is due to explosion, accident, or breakdown of any other machinery, facility, or plant, etc.
- The fault is due to use of non-specified peripheral or applied equipment or parts, or consumables, etc.
- The fault is due to use of a non-specified power supply or in a non-specified installation location.
- The fault is due to use in unusual environments<sup>(Note)</sup>.
- The fault is due to activities or ingress of living organisms, such as insects, spiders, fungus, pollen, or seeds.

In addition, this warranty is valid only for the original equipment purchaser. It is not transferable if the equipment is resold.

Anritsu Corporation shall assume no liability for injury or financial loss of the customer due to the use of or a failure to be able to use this equipment.

Note:

For the purpose of this Warranty, "unusual environments" means use:

- In places of direct sunlight
- In dusty places
- Outdoors
- In liquids, such as water, oil, or organic solvents, and medical fluids, or places where these liquids may adhere
- In salty air or in places where chemically active gases (sulfur dioxide, hydrogen sulfide, chlorine, ammonia, nitrogen dioxide, or hydrogen chloride etc.) are present
- In places where high-intensity static electric charges or electromagnetic fields are present
- In places where abnormal power voltages (high or low) or instantaneous power failures occur
- In places where condensation occurs
- In the presence of lubricating oil mists
- In places at an altitude of more than 2,000 m
- In the presence of frequent vibration or mechanical shock, such as in cars, ships, or airplanes

## **Anritsu Corporation Contact**

In the event that this equipment malfunctions, contact an Anritsu Service and Sales office. Contact information can be found on the last page of the printed version of this manual, and is available in a separate file on the CD version.

## Notes On Export Management

---

This product and its manuals may require an Export License/Approval by the Government of the product's country of origin for re-export from your country.

Before re-exporting the product or manuals, please contact us to confirm whether they are export-controlled items or not.

When you dispose of export-controlled items, the products/manuals need to be broken/shredded so as not to be unlawfully used for military purpose.

## Trademark and Registered Trademark

---

IQproducer™ is a registered trademark of Anritsu Corporation.

## Lifetime of Parts

---

The life span of certain parts used in this instrument is determined by the operating time or the power-on time. Due consideration should be given to the life spans of these parts when performing continuous operation over an extended period. These parts must be replaced at the customer's expense even if within the guaranteed period described in Warranty at the beginning of this manual.

LCD	:	50 000 hours
Hard disk	:	600 000 (Load/Unload)
Hard disk connector	:	500 (Insertion/Removal)
Cooling fan	:	40 000 hours

## Crossed-out Wheeled Bin Symbol

Equipment marked with the Crossed-out Wheeled Bin Symbol complies with council directive 2002/96/EC (the “WEEE Directive”) in European Union.



For Products placed on the EU market after August 13, 2005, please contact your local Anritsu representative at the end of the product's useful life to arrange disposal in accordance with your initial contract and the local law.

# Software End-User License Agreement (EULA)

Please read this Software End-User License Agreement (hereafter this EULA) carefully before using (includes executing, copying, registering, etc.) this software (includes programs, databases, scenarios, etc., used to operate, set, etc., Anritsu electronic equipment). By reading this EULA and using this software, you are agreeing to be bound by the terms of its contents and Anritsu Corporation (hereafter Anritsu) hereby grants you the right to use this Software with the Anritsu-specified equipment (hereafter Equipment) for the purposes set out in this EULA.

## 1. Grant of License and Limitations

1. Regardless of whether this Software was purchased from or provided free-of-charge by Anritsu, you agree not to rent, lease, lend, or otherwise distribute this Software to third parties and further agree not to disassemble, recompile, reverse engineer, modify, or create derivative works of this Software.
2. You may make one copy of this Software for backup purposes only.
3. You are not permitted to reverse engineer this software.
4. This EULA allows you to install one copy of this Software on one piece of Equipment.

## 2. Disclaimers

To the extent not prohibited by law, in no event shall Anritsu be liable for personal injury, or any incidental, special, indirect or consequential damages whatsoever, including, without limitation, damages for loss of profits, loss of data, business interruption or any other commercial damages or losses, arising out of or related to your use or inability to use this Software.

## 3. Limitation of Liability

- a. If a fault (bug) is discovered in this Software, preventing operation as described in the operation manual or specifications whether or not the customer uses this software as described in the manual, Anritsu shall at its own discretion, fix the bug, or exchange the software, or suggest a workaround, free-of-charge. However, notwithstanding the above, the following items shall be excluded from repair and warranty.
  - i) If this Software is deemed to be used for purposes not described in the operation manual or specifications.
  - ii) If this Software is used in conjunction with other non-Anritsu-approved software.
  - iii) Recovery of lost or damaged data.
  - iv) If this Software or the Equipment has been modified, repaired, or otherwise altered without Anritsu's prior approval.
  - v) For any other reasons out of Anritsu's direct control and responsibility, such as but not limited to, natural disasters, software virus infections, etc.
- b. Expenses incurred for transport, hotel, daily allowance, etc., for on-site repairs by Anritsu engineers necessitated by the above faults shall be borne by you.
- c. The warranty period for faults listed in article 3a above covered by this EULA shall be either 6 months from the date of purchase of this Software or 30 days after the date of repair, whichever is longer.



#### **4. Export Restrictions**

You may not use or otherwise export or re-export directly or indirectly this Software except as authorized by Japanese and United States law. In particular, this software may not be exported or re-exported (a) into any Japanese or US embargoed countries or (b) to anyone on the Japanese or US Treasury Department's list of Specially Designated Nationals or the US Department of Commerce Denied Persons List or Entity List. By using this Software, you warrant that you are not located in any such country or on any such list. You also agree that you will not use this Software for any purposes prohibited by Japanese and US law, including, without limitation, the development, design and manufacture or production of missiles or nuclear, chemical or biological weapons of mass destruction.

#### **5. Termination**

Anritsu shall deem this EULA terminated if you violate any conditions described herein. This EULA shall also be terminated if the conditions herein cannot be continued for any good reason, such as violation of copyrights, patents, or other laws and ordinances.

#### **6. Reparations**

If Anritsu suffers any loss, financial or otherwise, due to your violation of the terms of this EULA, Anritsu shall have the right to seek proportional damages from you.

#### **7. Responsibility after Termination**

Upon termination of this EULA in accordance with item 5, you shall cease all use of this Software immediately and shall as directed by Anritsu either destroy or return this Software and any backup copies, full or partial, to Anritsu.

#### **8. Dispute Resolution**

If matters of dispute or items not covered by this EULA arise, they shall be resolved by negotiations in good faith between you and Anritsu.

#### **9. Court of Jurisdiction**

This EULA shall be interpreted in accordance with Japanese law and any disputes that cannot be resolved by negotiation described in Article 8 shall be settled by the Japanese courts.

## Using VISA Driver for Remote Control of This Equipment

When controlling this measuring equipment remotely using the Ethernet port, a VISA\*<sup>1</sup> driver must be installed in the PC controller. We recommend using NI-VISA™\*<sup>2</sup> from National Instruments™ (NI hereafter) as the VISA driver.

Although a license is generally required to use NI-VISA™, the licensed NI-VISA™ driver is provided free-of-charge for use when performing remote control <sup>(Note)</sup> of this measuring equipment.

The NI-VISA™ driver can be downloaded from the NI website at:

<http://sine.ni.com/psp/app/doc/p/id/psp-411>

Be sure to comply with the NI license agreement for the usage and license scope.

**Be sure to uninstall the NI-VISA™ driver when disposing of this measuring equipment or transferring it to a third party, etc., when ceasing to use NI-VISA™, or upon completion of the contract term when using this equipment on a rental contract.**

(Notes)

Although the NI-VISA™ driver itself can be downloaded free-of-charge from the web, an implementation license is required for legal reasons when some requirements are not met. (Check the NI web page for the detailed requirements.)

If these requirements are not met, permission is not granted to use NI hardware and software and an NI implementation license must be purchased. However, since this measuring equipment incorporates NI hardware (GPIB ASIC), the NI-VISA™ driver can be downloaded and used free-of-charge.

Glossary of Terms:

\*1: VISA: Virtual Instrument Software Architecture

I/O software specification for remote control of measuring instruments using interfaces such as GPIB, Ethernet, USB, etc.

\*2: NI-VISA™

World *de facto* standard I/O software interface developed by NI and standardized by the VXI Plug&Play Alliance.

Trademarks:

- National Instruments™, NI™, NI-VISA™ and National Instruments Corporation are all trademarks of National Instruments Corporation.

## Notice

---

The following actions are strictly prohibited for all of the software installed in this product or otherwise provided by Anritsu:

1. Copying, except for archival purposes.
2. Transferring to a third party separately from this product.
3. Analyzing the incorporated software including but not limited to modifying, decompiling, disassembling, and reverse engineering.

## Cautions against computer virus infection

---

- Copying files and data  
Only files that have been provided directly from Anritsu or generated using Anritsu equipment should be copied to the instrument.  
All other required files should be transferred by means of USB or CompactFlash media after undergoing a thorough virus check.
- Adding software  
Do not download or install software that has not been specifically recommended or licensed by Anritsu.
- Network connections  
Ensure that the network has sufficient anti-virus security protection in place.

# CE Conformity Marking

Anritsu affixes the CE conformity marking on the following product(s) in accordance with the Council Directive 93/68/EEC to indicate that they conform to the EMC and LVD directive of the European Union (EU).

## CE marking



### 1. Product Model

Model: MG3710A Vector Signal Generator  
MG3740A Analog Signal Generator

### 2. Applied Directive

EMC: Directive 2004/108/EC  
LVD: Directive 2006/95/EC

### 3. Applied Standards

- EMC: Emission: EN 61326-1: 2006 (Class A)  
Immunity: EN 61326-1: 2006 (Table 2)

	Performance Criteria*
IEC 61000-4-2 (ESD)	B
IEC 61000-4-3 (EMF)	A
IEC 61000-4-4 (Burst)	B
IEC 61000-4-5 (Surge)	B
IEC 61000-4-6 (CRF)	A
IEC 61000-4-8 (RPFMF)	A
IEC 61000-4-11 (V dip/short)	B, C

\*: Performance Criteria

- A: During testing, normal performance within the specification limits.
- B: During testing, temporary degradation, or loss of function or performance which is self-recovering.
- C: During testing, temporary degradation, or loss of function or performance which requires operator intervention or system reset occurs.

Harmonic current emissions:

EN 61000-3-2: 2006 +A1:2009 A2:2009

: No limits apply for this equipment with an active input power under 75 W.

- LVD: EN 61010-1: 2010 (Pollution Degree 2)

#### **4. Authorized representative**

Name: Murray Coleman  
Head of Customer Service EMEA  
ANRITSU EMEA Ltd.  
Address, city: 200 Capability Green, Luton  
Bedfordshire, LU1 3LU  
Country: United Kingdom

# C-Tick Conformity Marking

Anritsu affixes the C-Tick mark on the following product(s) in accordance with the regulation to indicate that they conform to the EMC framework of Australia/New Zealand.

## C-Tick marking



### 1. Product Model

Model: MG3710A Vector Signal Generator  
MG3740A Analog Signal Generator

### 2. Applied Standards

EMC: Emission: EN 61326-1: 2006 (Class A equipment)

## About Eco label



The label shown on the left is attached to Anritsu products meeting our environmental standards.

Details about this label and the environmental standards are available on the Anritsu website at <http://www.anritsu.com>





# About This Manual

## Composition of Operation Manuals

The operation manuals for the MG3710A Vector Signal Generator MG3740A Analog Signal Generator are comprised as shown in the figure below. Details on the software application IQproducer™ and the standard waveform pattern are provided in each operation manual separately. Read them when needed in addition to this manual.



## Scope of This Manual

This manual mainly describes operation, maintenance, and remote control of the MG3710A Vector Signal Generator. Description of the basic functions and the outline of operation start from Chapter 3 onwards.

# Table of Contents

<b>For Safety .....</b>	<b>iii</b>
<b>About This Manual.....</b>	<b>I</b>
<b>Chapter 1 Outline .....</b>	<b>1-1</b>
1.1 Product Overview.....	1-2
1.2 Product Configuration .....	1-3
<b>Chapter 2 Preparation.....</b>	<b>2-1</b>
2.1 Installation Location .....	2-2
2.2 Items to Check Before Use .....	2-4
2.3 Power Connection .....	2-8
<b>Chapter 3 Operation.....</b>	<b>3-1</b>
3.1 Part Names.....	3-2
3.2 Power On/Off.....	3-12
3.3 Screen Layout.....	3-15
3.4 Top Function Menu.....	3-34
3.5 Common Setting Operations.....	3-38
<b>Chapter 4 Frequency .....</b>	<b>4-1</b>
4.1 Frequency .....	4-2
4.2 Frequency Setting Method: Frequency.....	4-6
4.3 Frequency Setting Items .....	4-12
4.4 Channel Setting .....	4-20
4.5 Channel Table: Edit Table .....	4-26
4.6 Frequency-Related Functions.....	4-41

<b>Chapter 5</b>	<b>Output Level.....</b>	<b>5-1</b>
5.1	Output Level.....	5-2
5.2	Output Level Setting Method: Level.....	5-7
5.3	Output Level Setting Item .....	5-14
5.4	User Correction: Correction .....	5-30
5.5	Use Power Sensor .....	5-45
<b>Chapter 6</b>	<b>Sweep/List.....</b>	<b>6-1</b>
6.1	Sweep/List Function.....	6-2
6.2	Setting Item .....	6-5
6.3	Sweep Function .....	6-18
6.4	List Function: Configure Step Sweep .....	6-29
6.5	Point Trigger .....	6-46
<b>Chapter 7</b>	<b>Modulation .....</b>	<b>7-1</b>
7.1	Setting Modulation Analysis.....	7-2
7.2	Analog Modulation: Analog/Pulse.....	7-12
7.3	Baseband Mode.....	7-71
7.4	Route Connectors .....	7-203
7.5	AWGN.....	7-228
7.6	I/Q Modulation.....	7-236
<b>Chapter 8</b>	<b>BER Measurement.....</b>	<b>8-1</b>
8.1	Function, Performance, and Communication .....	8-2
8.2	Display Description .....	8-6
8.3	Performing BER Measurement.....	8-12
8.4	PN Fix Pattern.....	8-35
8.5	User Defined Pattern .....	8-43
8.6	BER Log.....	8-54
8.7	About BER Measurement Operations .....	8-61

<b>Chapter 9 Other Functions .....</b>	<b>9-1</b>
9.1 Auxiliary Function.....	9-2
9.2 Power Meter.....	9-3
9.3 Alarm History .....	9-20
9.4 Utility Function .....	9-24
9.5 Panel Keys .....	9-52
9.6 Touch Panel.....	9-78
9.7 Setting Windows .....	9-79
<b>Chapter 10 Performance Test .....</b>	<b>10-1</b>
10.1 Overview of Performance Test .....	10-2
10.2 Frequency Performance Test .....	10-4
10.3 Output Level Performance Test.....	10-7
10.4 Vector Modulation Performance Test.....	10-11
<b>Chapter 11 Maintenance.....</b>	<b>11-1</b>
11.1 Daily Maintenance and Storage.....	11-2
11.2 Repacking and Transportation upon Return.....	11-4
11.3 Disposal .....	11-5
11.4 Calibration.....	11-6
11.5 How to Replace Hard Disk.....	11-10
11.6 Troubleshooting .....	11-12
<b>Appendix A Specifications .....</b>	<b>A-1</b>
<b>Appendix B Error Messages.....</b>	<b>B-1</b>
<b>Appendix C Default Value List .....</b>	<b>C-1</b>

<b>Appendix D Performance Test Report Form</b> .....	<b>D-1</b>
<b>Appendix E Remote Control.....</b>	<b>E-1</b>
<b>Appendix F Native Device Message Details</b> .....	<b>F-1</b>
<b>Appendix G SCPI Compatible Command ..</b>	<b>G-1</b>
<b>Appendix H Panel Keys and Keyboard Operations .....</b>	<b>H-1</b>
<b>Appendix I Scanning for Virus.....</b>	<b>I-1</b>
<b>Appendix J MG3641A/42A Compatible Command .....</b>	<b>G-1</b>
<b>Index .....</b>	<b>Index-1</b>



# *Chapter 1 Outline*

---

This section provides an outline of the product and describes the product composition.

1.1	Product Overview .....	1-2
1.2	Product Configuration .....	1-3
1.2.1	Standard configuration .....	1-3
1.2.2	Options .....	1-4
1.2.3	Applicable parts .....	1-8
1.2.4	Application software .....	1-10

## 1.1 Product Overview

The MG3710A is a vector signal generator that includes an arbitrary waveform generator. It can be used for a wide range of applications, from R&D to manufacturing of digital mobile communication systems, devices, and equipment.

The MG3710A has the following features, and one MG3710A can address from the current major mobile communications to the next-generation mobile communications.

- Frequency range covered: 100 kHz to 6000 MHz (with option installed)
- RF modulation bandwidth during internal modulation: 120 MHz
- Internal memory: 1024 M samples (with option installed)
- High-capacity memory included: provides ability of accelerating signals from multiple communication systems and outputting them for interference signals.

The MG3740A is an analog signal generator. It can be used for a wide range of applications, from R&D to manufacturing of analog radio base stations, devices, and equipment.

The MG3740A has the following features, and one MG3740A can address from the current major analog communications to the digitization of the conventional analog radio.

- Outstanding signal purity
- High output power
- High frequency stability
- Analog/pulse modulation supported
- Two SG units installed in one chassis available (with option added)
- Additional narrow band digital modulation function available

The supplied CD contains application software. This application software allows baseband waveform data generation supporting communication systems, external data conversion, and transmission to the mainframe.

The MG3710A/MG3740A is equipped with the hardware product made by National Instruments and comes with the license for NI-VISA. NI-VISA can be used for the purpose of controlling the MG3710A/MG3740A.



## 1.2 Product Configuration

### 1.2.1 Standard configuration

Table 1.2.1-1 lists the standard composition of the MG3710A/MG3740A. At unpacking, check that all items are included. If anything is missing or damaged, contact an Anritsu Service and Sales office.

**Table 1.2.1-1 Standard Composition**

Items	Model/ Symbol	Product Name	Q'ty	Remarks
Main unit	MG3710A MG3740A	Vector signal generator Analog signal generator	1	
Accessories		Power cord	1	
	P0031A	USB memory	1	256 MB or more USB 2.0 Flash Driver
	---	Installation CD-ROM	1	Application software, operation manual CD-ROM

## 1.2.2 Options

Tables 1.2.2-1 through 1.2.2-3 list the options for MG3710A. Tables 1.2.2-4 through 1.2.2-6 list the options for MG3740A. They are all sold separately.

**Note:**

There is a risk of losing the data when adding additional option(s), so **back up the data** stored on the hard disk, in advance. Anritsu is not responsible for any loss of data.

**Table 1.2.2-1 Additional Options at Shipping (MG3710A)**

Option No.	Product Name	Remarks
MG3710A-001	Rubidium Reference Oscillator	$\pm 1 \times 10^{-10}$ /month
MG3710A-002	High Stability Reference Oscillator	$\pm 1 \times 10^{-7}$ /year
MG3710A-011	2ndary HDD	
MG3710A-017	Universal Input/Output	
MG3710A-018	Analog IQ Input/Output	
MG3710A-021	BER Test Function	
MG3710A-029	OS Upgrade to Windows7	
MG3710A-032	1st RF 100kHz to 2.7GHz	Once this option is installed, you cannot change the frequency range.
MG3710A-034	1st RF 100kHz to 4GHz	
MG3710A-036	1st RF 100kHz to 6GHz	
MG3710A-041	High Power Extension for 1st RF	
MG3710A-042	Low Power Extension for 1st RF	
MG3710A-043	Reverse Power Protection for 1st RF	
MG3710A-045	ARB Memory Upgrade 256M sample for 1st RF	
MG3710A-046	ARB Memory Upgrade 1024M sample for 1st RF	
MG3710A-048	Combination of Baseband Signal for 1st RF	
MG3710A-049	AWGN for 1st RF	
MG3710A-050	Additional Analog Modulation Input for 1st RF	
MG3710A-062	2nd RF 100kHz to 2.7GHz	Once this option is installed, you cannot change the frequency range.
MG3710A-064	2nd RF 100kHz to 4GHz	
MG3710A-066	2nd RF 100kHz to 6GHz	
MG3710A-071	High Power Extension for 2nd RF	
MG3710A-072	Low Power Extension for 2nd RF	
MG3710A-073	Reverse Power Protection for 2nd RF	
MG3710A-075	ARB Memory Upgrade 256M sample for 2nd RF	
MG3710A-076	ARB Memory Upgrade 1024M sample for 2nd RF	

Table 1.2.2-1 Additional Options at Shipping (MG3710A) (Cont'd)

Option No.	Product Name	Remarks
MG3710A-078	Combination of Baseband Signal for 2nd RF	
MG3710A-079	AWGN for 2nd RF	
MG3710A-080	Additional Analog Modulation Input for 2nd RF	
MG3710A-313	Removable HDD	

Table 1.2.2-2 Additional Options after Shipping (MG3710A)

Option No.	Product Name	Remarks
MG3710A-101	Rubidium Reference Oscillator Retrofit	$\pm 1 \times 10^{-10}$ /month
MG3710A-102	High Stability Reference Oscillator Retrofit	$\pm 1 \times 10^{-7}$ /year
MG3710A-111	2ndary HDD Retrofit	
MG3710A-117	Universal Input/Output Retrofit	
MG3710A-118	Analog IQ Input/Output	
MG3710A-121	BER Test Function Retrofit	
MG3710A-141	High Power Extension for 1st RF Retrofit	
MG3710A-142	Low Power Extension for 1st RF Retrofit	
MG3710A-143	Reverse Power Protection for 1st RF Retrofit	
MG3710A-145	ARB Memory Upgrade 256M sample for 1st RF Retrofit	
MG3710A-146	ARB Memory Upgrade 1024M sample for 1st RF Retrofit	
MG3710A-148	Combination of Baseband Signal for 1st RF Retrofit	
MG3710A-149	AWGN for 1st RF Retrofit	
MG3710A-150	Additional Analog Modulation Input Retrofit for 1st RF	
MG3710A-162	2nd RF 100kHz to 2.7GHz Retrofit	Available only when 2nd RF is not installed. Once this option is installed, you cannot change the frequency range.
MG3710A-164	2nd RF 100kHz to 4GHz Retrofit	
MG3710A-166	2nd RF 100kHz to 6GHz Retrofit	
MG3710A-171	High Power Extension for 2nd RF Retrofit	
MG3710A-172	Low Power Extension for 2nd RF Retrofit	
MG3710A-173	Reverse Power Protection for 2nd RF Retrofit	
MG3710A-175	ARB Memory Upgrade 256M sample for 2nd RF Retrofit	
MG3710A-176	ARB Memory Upgrade 1024M sample for 2nd RF Retrofit	
MG3710A-178	Combination of Baseband Signal for 2nd RF Retrofit	
MG3710A-179	AWGN for 2nd RF Retrofit	
MG3710A-180	Additional Analog Modulation Input Retrofit for 2nd RF	

**Table 1.2.2-3 Warranty Period Extension Options (MG3710A)**

Option No.	Product Name	Remarks
MG3710A-ES210	Extended 2-year warranty service	
MG3710A-ES310	Extended 3-year warranty service	
MG3710A-ES510	Extended 5-year warranty service	

**Table 1.2.2-4 Additional Options at Shipping (MG3740A)**

Option No.	Product Name	Remarks
MG3740A-001	Rubidium Reference Oscillator	$\pm 1 \times 10^{-10}$ /month
MG3740A-002	High Stability Reference Oscillator	$\pm 1 \times 10^{-7}$ /year
MG3740A-011	2ndary HDD	
MG3740A-017	Universal Input/Output	
MG3740A-020	Digital Modulation	
MG3740A-021	BER Test Function	
MG3740A-029	OS Upgrade to Windows7	
MG3740A-032	1st RF 100kHz to 2.7GHz	Once this option is installed, you cannot change the frequency range.
MG3740A-034	1st RF 100kHz to 4GHz	
MG3740A-036	1st RF 100kHz to 6GHz	
MG3740A-041	High Power Extension for 1st RF	
MG3740A-042	Low Power Extension for 1st RF	
MG3740A-043	Reverse Power Protection for 1st RF	
MG3740A-045	ARB Memory Upgrade 256M sample for 1st RF	
MG3740A-048	Combination of Baseband Signal for 1st RF	
MG3740A-050	Additional Analog Modulation Input for 1st RF	
MG3740A-062	2nd RF 100kHz to 2.7GHz	Once this option is installed, you cannot change the frequency range.
MG3740A-064	2nd RF 100kHz to 4GHz	
MG3740A-066	2nd RF 100kHz to 6GHz	
MG3740A-071	High Power Extension for 2nd RF	
MG3740A-072	Low Power Extension for 2nd RF	
MG3740A-073	Reverse Power Protection for 2nd RF	
MG3740A-075	ARB Memory Upgrade 256M sample for 2nd RF	
MG3740A-078	Combination of Baseband Signal for 2nd RF	
MG3740A-080	Additional Analog Modulation Input for 2nd RF	
MG3740A-313	Removable HDD	

Table 1.2.2-5 Additional Options after Shipping (MG3740A)

Option No.	Product Name	Remarks
MG3740A-101	Rubidium Reference Oscillator Retrofit	$\pm 1 \times 10^{-10}$ /month
MG3740A-102	High Stability Reference Oscillator Retrofit	$\pm 1 \times 10^{-7}$ /year
MG3740A-111	2ndary HDD Retrofit	
MG3740A-117	Universal Input/Output Retrofit	
MG3740A-120	Digital Modulation Retrofit	
MG3740A-121	BER Test Function Retrofit	
MG3740A-141	High Power Extension for 1st RF Retrofit	
MG3740A-142	Low Power Extension for 1st RF Retrofit	
MG3740A-143	Reverse Power Protection for 1st RF Retrofit	
MG3740A-145	ARB Memory Upgrade 256M sample for 1st RF Retrofit	
MG3740A-148	Combination of Baseband Signal for 1st RF Retrofit	
MG3740A-150	Additional Analog Modulation Input Retrofit for 1st RF	
MG3740A-162	2nd RF 100kHz to 2.7GHz Retrofit	Available only when 2nd RF is not installed. Once this option is installed, you cannot change the frequency range.
MG3740A-164	2nd RF 100kHz to 4GHz Retrofit	
MG3740A-166	2nd RF 100kHz to 6GHz Retrofit	
MG3740A-171	High Power Extension for 2nd RF Retrofit	
MG3740A-172	Low Power Extension for 2nd RF Retrofit	
MG3740A-173	Reverse Power Protection for 2nd RF Retrofit	
MG3740A-175	ARB Memory Upgrade 256M sample for 2nd RF Retrofit	
MG3740A-178	Combination of Baseband Signal for 2nd RF Retrofit	
MG3740A-180	Additional Analog Modulation Input Retrofit for 2nd RF	

Table 1.2.2-6 Warranty Period Extension Options (MG3740A)

Option No.	Product Name	Remarks
MG3740A-ES210	Extended 2-year warranty service	
MG3740A-ES310	Extended 3-year warranty service	
MG3740A-ES510	Extended 5-year warranty service	

### 1.2.3 Applicable parts

Table 1.2.3-1 lists the applicable parts for MG3710A/MG3740A. They are all sold separately.

**Table 1.2.3-1 Applicable Parts**

Model/Symbol	Product Name	Remarks
W3580AE	MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (Mainframe)	Printed version
W2496AE	MG3700A/MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)	Printed version
W3581AE	MG3710A Operation Manual (Standard Waveform Pattern)	Printed version
K240B	Power divider (K connector)	DC to 26.5 GHz, 50 Ω K-J, 1 W max
MA1612A	Four-port junction pad	5 MHz to 3 GHz, N-J
MP752A	Termination	DC to 12.4 GHz, 50 Ω N-P
MA2512A	Bandpass filter	Supports W-CDMA, Passband: 1.92 to 2.17 GHz
J0576B	Coaxial cord	Length: Approx. 1 m (N-P·5D-2W·N-P)
J0576D	Coaxial cord	Length: Approx. 2 m (N-P·5D-2W·N-P)
J0127A	Coaxial cord	Length: Approx. 1 m (BNC-P·RG58A/U·BNC-P)
J0127B	Coaxial cord	Length: Approx. 2 m (BNC-P·RG58A/U·BNC-P)
J0127C	Coaxial cord	Length: Approx. 0.5 m (BNC-P·RG58A/U·BNC-P)
J0322A	Coaxial Cable	DC to 18 GHz, Length: Approx. 0.5 m (SMA-P·50 Ω SUCOFLEX104·SMA-P)
J0322B	Coaxial Cable	DC to 18 GHz, Length: Approx. 1 m (SMA-P·50 Ω SUCOFLEX104·SMA-P)
J0322C	Coaxial Cable	DC to 18 GHz, Length: Approx. 1.5 m (SMA-P·50 Ω SUCOFLEX104·SMA-P)
J0322D	Coaxial Cable	DC to 18 GHz, Length: Approx. 2 m (SMA-P·50 Ω SUCOFLEX104·SMA-P)
J0004	Coaxial adapter	DC to 12.4 GHz, 50 Ω N-P, SMA-J
J1261B	Shielded Ethernet cable	Straight cable, length: Approx. 3 m
J1261D	Shielded Ethernet cable	Cross cable, length: Approx. 3 m
J0008	GPIB connection cable	Length: Approx. 2 m
J1539A	Aux Conversion Adaptor	BNC-J — DX30A-50P (50)

Table 1.2.3-1 Applicable Parts (Continued)

Model/Symbol	Product Name	Remarks
B0635A	Rack mount kit (EIA)	
B0657A	Rack mount kit (JIS)	
B0636A	Carrying case (hard type)	With casters
B0645A	Soft carrying case	
MA24106A	USB Power Sensor	(50 MHz to 6 GHz, With USB/Mini B cable)
MA24118A	USB Power Sensor	(10 MHz to 18 GHz, With USB/Micro B cable)
MA24126A	USB Power Sensor	(10 MHz to 26 GHz, With USB/Micro B cable)
Z0975A	Keyboard (USB)	
Z1594A	Standard Waveform Pattern for Backup	DVD 5-disc set

## 1.2.4 Application software

For the latest information on the application software, either visit the MG3710A/MG3740A page on the Anritsu website or contact an Anritsu sales representative.

Application software is sold separately.

Anritsu homepage: <http://www.anritsu.com/>

Table 1.2.4-1 lists examples of application software that are available for the MG3710A. Table 1.2.4-2 lists examples of application software that are available for the MG3740A (required to install option-020/120). They are all sold separately.

**Table 1.2.4-1 Application Software (MG3710A)**

Option No.	Product Name	Remarks
MX370101A	HSDPA IQproducer™	CD-ROM containing a license and operation manual
MX370102A	TDMA IQproducer™	
MX370103A	CDMA2000 1xEV-DO IQproducer™	
MX370104A	Multi-carrier IQproducer™	
MX370105A	Mobile WiMAX IQproducer™	
MX370106A	DVB-T/H IQproducer™	
MX370107A	Fading IQproducer™	
MX370108A	LTE IQproducer™	
MX370109A	XG-PHS IQproducer™	
MX370110A	LTE TDD IQproducer™	
MX370111A	WLAN IQproducer™	
MX370112A	TD-SCDMA IQproducer™	

**Table 1.2.4-2 Application Software (MG3740A installed option-020/120)**

Option No.	Product Name	Remarks
MX370102A	TDMA IQproducer™	CD-ROM containing a license and operation manual
MX370107A	Fading IQproducer™	



## *Chapter 2 Preparation*

---

This section describes items that you should know before using the MG3710A/MG3740A. Be sure to read this section at least once as it contains safety tips and cautions for avoiding equipment failure during use.

2.1	Installation Location .....	2-2
2.1.1	Installation orientation.....	2-2
2.1.2	Distance from surrounding objects.....	2-3
2.1.3	Installation location conditions.....	2-3
2.2	Items to Check Before Use.....	2-4
2.2.1	Safety labels .....	2-4
2.2.2	Reverse power .....	2-4
2.2.3	Electrostatic .....	2-5
2.3	Power Connection .....	2-8
2.3.1	Power requirements .....	2-8
2.3.2	Connecting power cord .....	2-9

## 2.1 Installation Location

### 2.1.1 Installation orientation

Set the MG3710A/MG3740A horizontally as shown in the figure below.




Figure 2.1.1-1 Installation Orientation

### CAUTION

---

If the MG3710A/MG3740A is not installed in a “good” direction as above, a small shock may turn it over and harm the user.

---

### 2.1.2 Distance from surrounding objects

A fan is installed at the back of the MG3710A/MG3740A to prevent the internal temperature from rising. When installing the MG3710A/MG3740A, be sure to keep its sides at a distance of 10 cm or more from surrounding objects such as walls and peripheral units, to secure sufficient space around the fan.




Figure 2.1.2-1 Distance From Surrounding Objects

### 2.1.3 Installation location conditions

The MG3710A/MG3740A can operate in locations with temperatures between 5°C and 45°C, but it should not be used in locations such as the following or failure may result.

- Location with a lot of vibration
- Location with high moisture or a lot of dust
- Location exposed to direct sunlight
- Location where exposure to active gases may occur
- Location where large fluctuations in power voltage occur

## 2.2 Items to Check Before Use

### 2.2.1 Safety labels

To ensure the safety of the operator, the WARNING labels shown below are affixed on the back panel, as shown. Be sure to observe the instructions on these labels.




Figure 2.2.1-1 WARNING Label

### 2.2.2 Reverse power

The maximum reverse power input of the RF output connector of the MG3710A/MG3740A is as follows for both 1st RF and 2nd RF. Be careful not to apply reverse input power which exceeds the following.

DC input

±50 V DC Max

AC input

When both 1st RF and 2nd RF do not have the

Option-043/143/073/173 installed.

2W (nominal)

When the Option-043/143/073/173 installed.

20 W (1 MHz < Reverse input power frequency ≤ 1 GHz) (nominal)

20 W (1 GHz < Reverse input power frequency ≤ 2 GHz) (nominal)

10 W (2 GHz < Reverse input power frequency ≤ 6 GHz) (nominal)

Installing the Option-043/143/073/173 (Reverse power protection) does not guarantee the protection from damages by reverse power. Be careful not to apply reverse power.

### 2.2.3 Electrostatic


#### CAUTION

---

- 1 Always use the supplied 3-pin power cord to ground both the mainframe and DUT (included in test circuit). After confirming that both the mainframe and DUT are grounded, use coaxial cables to connect them.

**NEVER** connect the mainframe and DUT without grounding, otherwise electrostatic discharge may damage the mainframe.

- 2 Do not touch the core conductor of the coaxial cable connected to the input connector or bring it into contact with metal. Doing so may damage the input circuit of the mainframe.
- 




 **CAUTION**

---

Do not touch the core conductor to the metal when connecting the coaxial cable to the connector.

Doing so may damage the input circuit of the mainframe.

---



 **CAUTION**

---


Do not touch the core conductor to the metal when connecting the coaxial cable to the connector.

Doing so may damage the input circuit of the mainframe.

---

*2.2 Items to Check Before Use*

---



## 2.3 Power Connection

This section describes the procedures for supplying power.

### 2.3.1 Power requirements

For normal operation of the instrument, observe the power voltage range described below.

Power supply	Voltage range	Frequency
100 Vac system	100 to 120 V	50 to 60 Hz
200 Vac system	200 to 240 V	50 to 60 Hz

Vac-system changeover is automatically made between 100 Vac and 200 Vac.



### CAUTION

---


Supplying power exceeding the above range may result in electrical shock, fire, failure, or malfunction.

---



### 2.3.2 Connecting power cord

Insert the power plug into a grounded outlet, and connect the other end to the power inlet on the rear panel. To ensure that the instrument is properly grounded, always use the supplied 3-pin power cord.



#### **WARNING**

Always connect the instrument to a properly grounded outlet. Do not use the instrument with an extension cord or transformer that does not have a ground wire.

If the instrument is connected to an ungrounded outlet, there is a risk of receiving a fatal electric shock. In addition, the peripheral devices connected to the instrument may be damaged.

Unless otherwise specified, the signal-connector ground terminal, like an external conductor of the coaxial connector, of the instrument is properly grounded when connecting the power cord to a grounded outlet. Connect the ground terminal of DUT to a ground having the same potential before connecting with the instrument. Failure to do so may result in an electric shock, fire, failure, or malfunction.

 **CAUTION**

---

If an emergency arises causing the instrument to fail or malfunction, disconnect the instrument from the power supply by disconnecting either end of the power cord.

When installing the instrument, arrange the power inlet and outlet so that an operator may easily connect or disconnect the power cord. Moreover, **DO NOT** fix the power cord around the plug and the power inlet with a holding clamp or similar device.

If the instrument is mounted in a rack, a power switch for the rack or a circuit breaker may be used for power disconnection.

It should be noted that, the power switch on the front panel of the instrument is a standby switch, and cannot be used to cut the main power.

---

## Chapter 3 Operation

---

This chapter describes information you should know to operate the MG3710A/MG3740A, including names of parts and how to set basic parameters.

### Note on remote command:

When the language mode is SCPI, the target SG can be selected with the beginning node of commands for controlling individual functions. Refer to Appendix E.7.6 “Selecting SG1/2” for details.

3.1	Part Names .....	3-2
3.1.1	Front panel .....	3-2
3.1.2	Rear panel .....	3-7
3.2	Power On/Off .....	3-12
3.2.1	Power on .....	3-12
3.2.2	Power off .....	3-13
3.3	Screen Layout.....	3-15
3.3.1	Common indicator frame .....	3-17
3.3.2	Frequency information frame .....	3-22
3.3.3	Level information frame .....	3-22
3.3.4	Active function frame .....	3-23
3.3.5	Function display frame .....	3-25
3.3.6	Resident frame .....	3-27
3.3.7	Footer frame .....	3-28
3.3.8	Function menu frame.....	3-29
3.3.9	Display of 2SG.....	3-31
3.3.10	RPP .....	3-32
3.4	Top Function Menu .....	3-34
3.4.1	Modulation .....	3-35
3.4.2	RF Output .....	3-36
3.4.3	SG Port.....	3-37
3.5	Common Setting Operations .....	3-38
3.5.1	Specifying parameters as numeric values .....	3-38
3.5.2	Setting character strings.....	3-40
3.5.3	Setting file names .....	3-42

## 3.1 Part Names

### 3.1.1 Front panel

This section describes the front-panel keys and connectors.














Figure 3.1.1-1 Front Panel

- |   |   |  |
|---|---|--|
| 1 | <br><br> | <p><b>Power switch</b></p> <p>Press to switch between the standby state (AC power supplied) and power-on state. The Power lamp  lights orange at Standby and green at Power On. Press the power switch for about 2 seconds.</p> |
| 2 |    | <p><b>Hard disk access lamp</b></p> <p>Lights when accessing the internal hard disk</p>  |
| 3 |    | <p><b>Copy key</b></p> <p>Press to capture display screen and save to file.</p>  |
| 4 |    | <p><b>Recall key</b></p> <p>Press to display the function menu to recall the parameter file.</p>   |
| 5 |    | <p><b>Save key</b></p> <p>Press to display the function menu to save the parameter file.</p>   |
| 6 |    | <p><b>Cal key</b></p> <p>Press to display the Calibration menu.</p>  |



**Remote lamp/Local key**

**Remote lamp**

Lights when in remote-control state

**Local key**

Press to reset the remote-control state with GPIB, Ethernet, or USB (B) to the local-control state and enable the panel setting.



**Preset key**

Press to display the Preset menu. Resets parameters to initial settings



**Function keys**

Selects or configures function menu displayed on the right of the screen. The function menu is provided in multiple pages and layers.

The number on the bottom of the screen indicates the menu page number.



**Top key**

Press to go back to the uppermost (top) layer.



**Next key**

Press to go to the next page.




**Back key**

Press to go back to the previous layer within the function menu.




**SG1/SG2/IQ Pro key**



Press to set and control SG1.



Press to set and control SG2.




Press to load IQproducer.

Sometimes, there may be a delay of several to 20 or so seconds until IQproducer starts after pressing the **IQpro** key. Subsequent key presses are ignored until IQproducer is running.



**Main function keys**


Display function menus to set and execute main functions




Press to set items of Frequency.











Press to set items of Level.







Press to set items of Sweep/List.









Press to set items of Mode of the Baseband function.

-  Press to set items of AM modulation.
-  Press to set items of FM/φM modulation.
-  Press to set items of Pulse modulation.
-  Press to set items of I/Q signals.
-  Press to recall the Load function of ARB/Waveform function menu.
-  Press to recall the Select function of ARB/Waveform function menu.
-  Press to recall the Auxiliary function.
-  Press to recall the Utility function.










**Numeric keypad**  
 Enters numbers on parameter setup screens. [A] to [F] in hexadecimal formats can be entered by pressing  to  sequentially while  lights.



- Tab/Alt/BS/Ctrl/Shift/Alt-Tab keys**
-  Behaves same as the **Tab** key.
  -  Behaves same as the **Alt** key.
  -  Press to delete the last entered digit or character.
  -  Behaves same as the **Ctrl** key.
  -  Operates keys with functions in blue characters on panel. Press the **Shift** key so the key lamp is green and then press the target key.
  -  Behaves same as the **Alt-Tab** key.



- Arrow keys/Enter/Cancel/Help/Incr Set/Context key**
- Arrow keys**  
    Press to select items or change settings.
-  Press to cancel the entered or selected data.
  -  Pressing this key while pressing a function key displays the **Help** for the pressed function key.
  -  Press to set the entered or selected data.



Press to set a resolution for each parameter.



Context: Behaves same as right-click.  
Windows: Behaves same as pressing **Windows** key.



**Rotary knob**

Rotate the knob to select an item or change a setting. Spin faster to increase the amount of change.



**I Input connector**

Inputs signals of I-phase when executing vector modulation of external baseband signals.  
MG3740A is not equipped with this connector.



**Q Input connector**

Inputs signals of Q-phase when executing vector modulation of external baseband signals.  
MG3740A is not equipped with this connector.



**RF Output**



**Modulation control key**

This command sets the SG1 Modulation On/Off. The lamp lights when RF signals are being modulated.



**RF Output Control key**

This command sets the SG1 Output On/Off. The lamp lights when RF signals are being modulated.



**RF Output connector**

Outputs RF signal.



**2nd RF Output (Option)**



**Modulation control key**

This command sets the SG2 Modulation On/Off. The lamp lights when RF signals are being modulated.



**RF Output control key**

This command sets the SG2 Output On/Off. The lamp lights when RF signals are being output.




**RF Output connector**

Outputs RF signal.



20



**USB connector (type A)**

Connect the accessory USB keyboard, mouse or USB memory.



### 3.1.2 Rear panel

This section describes the rear-panel connectors.







Figure 3.1.2-1 Rear Panel

- 1 LO Input  
  
 50Ω  
 -10 to +1dBm

Local Input connector  
 Outputs external local signal.  
 This connector cannot be used in MG3740A.

- 2 LO Output  
  
 50Ω  
 $\leq +1\text{dBm}$

Local Output connector  
 Outputs Local signal.  
 This connector cannot be used in MG3740A.

- 3 BB REF CLK Input  
  
 50Ω  
 $\geq 0.2\text{Vp-p}$

Baseband Reference Clock Input connector  
 Inputs clock signals that is the reference values for sampling clocks of the internal arbitrary waveform generator.  
 This connector cannot be used in MG3740A.

- 4 BB REF CLK Output  
  
 50Ω  
 0.8Vp-p

Baseband Reference Clock Output connector  
 Outputs sampling clock signals of the internal arbitrary waveform generator.  
 This connector cannot be used in MG3740A.

**5** Sweep Output



0 to 10V

**Sweep Output connector**

Outputs 10 V Sweep Signal or Sweep Status signal synchronized with Sweep operations.

**6** I Output



**I Output connector**

Outputs I-phase signals of internal baseband signals. This connector cannot be used in MG3740A.

**7** Q Output



**Q Output connector**

Outputs Q-phase signals of internal baseband signals. This connector cannot be used in MG3740A.

**8**  $\bar{I}$  Output



**$\bar{I}$  (Inverted I) Output connector**

Outputs I-phase signals of internal baseband signals. This connector cannot be used in MG3740A.

**9**  $\bar{Q}$  Output



**$\bar{Q}$  (Inverted Q) Output connector**

Outputs Q-phase signals of internal baseband signals. This connector cannot be used in MG3740A.

**10** REF Input  
5/10/13MHz  
50 $\Omega$



**Reference Input connector (reference frequency signal input connector)**

Inputs external reference frequency signal (5 MHz/10 MHz/13 MHz). It is for inputting reference frequency signals with higher accuracy than the instrument's internal reference signal, or for synchronizing the frequency of the MG3710A/MG3740A to that of other equipment.

**11** Buffer Output  
10MHz  
 $\geq 0$ dBm



**Buffer Output connector (reference frequency signal output connector)**









Outputs the internal reference frequency signal (10 MHz). It is for synchronizing frequencies between other equipment and the MG3710A/MG3740A.

**12** Start Frame TRIG Input  
TTL



**Start Frame Trigger Input connector**

Inputs external signals to be used for trigger signals. The setting of input signals is based on the Table 7.4.1-1 “Input Connectors Function Menu”. This connector is pulled up internally.

- 13**  **Marker1 Output connector**  
Outputs Marker signal.  
The setting of output signals is based on the Table 7.4.2-1 “Output Connectors Function Menu”.
- 14**  **Pattern Trigger1 Input connector**  
Inputs external signals to be used for trigger signals.  
The setting of input signals is based on the Table 7.4.1-1 “Input Connector Function Menu”.  
This connector is pulled up internally.
- 15**  **GPIB connector**  
For external control via GPIB
- 16**  **USB connector (type A)**  
Connect the accessory USB keyboard, mouse or USB memory.
- 17**  **USB connector (type B)**  
For external control via USB
- 18**  **Ethernet connector**  
Connects PC or Ethernet network.
- 19**  **Monitor Out connector**  
This is a RGB connector to connect an external display.
- 20**  **AUX connector**  
This is a complex connector to input baseband clock reference or error rate measurement of vector signal generator option. See Table 3.1.2-1 for internal pin assignment.

21



~Line Input  
50-60Hz 350VA Max  
100-120V/200-240V

AC inlet  
Supplies power.

22

**HDD**

HDD slot  
This is a hard disk slot.

23

**HDD(Opt)**

HDD slot for options  
This is a hard disk slot for the options.

24

SG1



2Vp-p

External Modulation Input SG1 connector  
This is an option connector for additional analog modulation input for the SG1.

25

SG2



2Vp-p

External Modulation Input SG2 connector  
This is an option connector for additional analog modulation input for the SG2.

26

Reserve 1



Reserve 1  
Terminal for future extension

27

Reserve 2



Reserve 2  
Terminal for future extension

Table 3.1.2-1 AUX Connectors

Function	Terminal No.	In/Out	Signal Name
SG	2	In	Pattern Status1 *2
	6		GND
	15	In	Pattern Trigger3/Pattern Status3 *2
	16		GND
	26		GND
	27	Out	Pulse Video
	28	Out	Pulse Sync
	29	Out	Sync Trigger Out
	31		GND
	36		GND
	38	Out	Marker 2
	39	Out	Marker 3
	40	In	Pattern Trigger2/Pattern Status2 *2
	41		GND
	42	In	Pulse Mod *1
45		GND	
BER	23		GND
	24	In	BER CLK *2
	48	In	BER Enable *2
	49	In	BER Data *2
	50		GND

Because terminals not included in Table 3.1.2-1 are interfaces for maintaining equipment, do not connect them to any.

For signal setting details, refer to Table 7.4.1-1 “Input Connectors Function Menu” and Table 7.4.2-1 “Output Connectors Function Menu”.




\*1: This connector is pulled down internally.

\*2 This connector is pulled up internally.

## 3.2 Power On/Off

### 3.2.1 Power on

The procedure for turning the power on is as follows:

1. Connect the jack-side end of power cord to the AC power inlet on the rear panel. Plug in the cord deep into the inlet.
2. Connect the plug-side end of power cord to the AC power outlet. The MG3710A/MG3740A goes into the standby state, and  lamp on the power switch lights orange.
3. When you press the power switch, the power turns on, and  lamp lights green, and loading starts.  lamp (orange) goes off.

When the power turns on, Windows starts, and then the software of the MG3710A/MG3740A starts. While it is starting, the start screen below is displayed. Do not press the power switch when the start screen is displayed. Pressing the switch may prevent the software from starting successfully.




Figure 3.2.1-1 Start Screen

### 3.2.2 Power off

The procedure for turning the power off is as follows:



#### To use panel keys to turn the power off:

1. When you press the power switch, the applications start closing, shutdown starts, the lamp (green) of the power switch goes off,  lamp lights orange, and the power turns off. The MG3710A/MG3740A goes into the standby state.



#### Note:

Do not press the power switch for more than 4 seconds. If you do so, a forced-end is performed when exiting the software.

#### To use the mouse connected to the MG3710A/MG3740A to turn the power off:

1. Connect the provided mouse to the MG3710A/MG3740A, and open the Start menu on the Windows task bar.
2. Select **Shut down**.
3. Select **Shut down**.
4. Shutdown starts, the Power lamp (green) of the power switch  goes off,  lamp lights orange, and the power turns off. The MG3710A/MG3740A goes into the standby state.

#### To perform a forced-end:

1. Press the power switch for more than 4 seconds. The Power lamp (green) of the power switch  goes off,  lamp lights orange, and the power turns off. The MG3710A/MG3740A goes into the standby state.

#### Note:

1. You should perform a forced-end as an emergency operation only when keys, mouse, or keyboard cannot be controlled for any reason. If you press the power switch for more than 4 seconds, and the power does not turn off, a failure may have occurred. Unplug it, and contact an Anritsu Service and Sales office.
2. Unplugging while you are accessing to the hard disk may cause a failure of the hard disk. You must unplug the MG3710A/MG3740A when the power is off.

Restoring parameters

After the power on, parameters are restored to the state of the last time the power was off or the state of defaults setting.



## 3.3 Screen Layout

After the power turns on and Self Check completes, the basic screen (Figure 3.3-1) is displayed.

1SG:




Figure 3.3-1 Basic Screen (1SG)

### Title frame

Displays a model, name (Vector Signal Generator/Analog Signal Generator), and window minimize switch.

### Common indicator frame

Displays the status of SG common settings.

### Frequency information frame

Displays the information of frequencies.

### Level information frame

Displays the information of levels.

### Active function frame

Displays input dialog boxes for setting parameters.

Function display frame

Displays the current setting of SG in a block diagram and displays necessary information for each function.

Resident frame

Displays Power Meter and measured results of BER.

Footer frame

Displays error messages, error information, and the current time.

Function menu frame

The function menu frame on the right-side of the screen displays the function menu. The content depends on a screen.

2SG:

Displays 2SG-specific functions.




Figure 3.3-2 Basic Screen (2SG)

Summary frame

Displays the information of uncontrolled SG frequencies, levels, output status, and alarms.

### 3.3.1 Common indicator frame

The common indicator frame displays indicators described in Table 3.3.1-1 and Table 3.3.1-2 to indicate the current status.

**Table 3.3.1-1 Common Indicators Alarm Information**

Indicator	Display	Description
Alarm information	May be displayed even when there is no error.	
<b>ALC</b>	ALC Auto Level Control	Indicates that the output level may not have been reached a certain value.
<b>BBDAC</b>	BBDAC Baseband Digital to Analog Converter	Indicates that clipping occurred in Baseband DAC or the digital block due to overflow.
<b>OVENCOLD</b>	OVEN COLD	Indicates that the internal reference oscillator frequency may not be stable within three minutes after the power is turned on.
Alarm information	Displayed for errors.	
<b>UNLOCK</b>	UNLOCK	Indicates that Baseband Reference Clock is not synchronized, that the internal reference oscillator has stopped synchronizing after 3 minutes or more since the power is turned on, or that the external reference oscillator is not synchronized.
<b>EXTMOD</b>	EXTMOD	Indicates that the level of signal input to the External Modulation Input connector is greater than 2.03 Vp-p.

For handling when the alarm information is displayed, refer to 11.6 “Troubleshooting”.

## ALC Alarm

**Remote command**

**Query the status of ALC**

**Query**

[ :SOURce [1] | 2 ] :POWer:ALC:ERRor?

**Response**

<status>

**Parameter**

<status>	Status
ALAR	Alarm
NORM	Normal

**Programming Example**

To query the status of ALC.

POW:ALC:ERR?

> NORM

## BBDAC Alarm

**Remote command**

**Query the status of BBDAC**

**Query**

[ :SOURce [1] | 2 ] :DM:DAC:ERRor?

**Response**

<status>

**Parameter**

<status>	Status
CLIP	Clipped
NORM	Normal

**Programming Example**

To query the status of BBDAC.

DM:DAC:ERR?

> NORM

## UNLOCK Alarm

**Remote command****UNLOCK: Query the status of Baseband Reference Query**

[:SOURce[1]|2]:RADio:ARB:CLOCK:REFerence:ERRor?

**Response**

&lt;status&gt;

**Parameter**

<status>	Status
LINT	Lock BB Int Clock
UINT	Unlock BB Int Clock
LEXT	Lock BB Ext Clock
UEXT	Unlock BB Ext Clock

**Programming Example**

To query the status of Baseband Reference.

RAD:ARB:CLOC:REF:ERR?

&gt; LINT

## UNLOCK/OVEN COLD Alarm

**Remote command****UNLOCK/OVEN COLD: Query the status of the reference oscillator Query**

[:SOURce]:ROScillator:STATus?

**Response**

&lt;status&gt;

**Parameter**

<status>	Status
0	Lock
1	Unlock
2	Oven Cold

**Programming Example**

To query the status of the reference oscillator.

ROSC:STAT?

&gt; 2

## EXTMOD Alarm

### Remote command

**EXTMOD: Check the external modulation input for “clipping” caused by overflow.**

### Query

`[ :SOURCE[1] | 2 ] :EXTMod:ERRor?`

### Response

`<boolean>`                    NORM (Normal) or CLIP (Clipping)

### Programming Example

To check the external modulation input for “clipping” caused by overflow.

```
EXTM:ERR?
```

```
> NORM
```

Table 3.3.1-2 Common Indicator Status Information

Status information		
<b>ARB</b>	ARB	Indicates that the ARB function is being used.
<b>SWEEP</b>	SWEEP	Indicates that the SWEEP function is being used.
<b>AM</b>	AM	Indicates AM modulation is being executed.
<b>FM</b>	FM	Indicates FM modulation is being executed.
<b>φM</b>	φM	Indicates φM modulation is being executed.
<b>PULSE</b>	PULSE	Indicates Pulse modulation is being executed.
<b>CORR</b>	CORR User Correction	Indicates that the User Correction function is on.
<b>AWGN</b>	AWGN Additive White Gaussian Noise	Indicates AWGN signals are being output.
<b>PLAY</b>	PLAY	Indicates waveform patterns are being output.
<b>WAIT</b>	WAIT	Indicates waveform patterns has stopped.
<b>WIDE</b>	WIDE Wideband	Indicates that the bandwidth characteristic of RF output is Wideband mode.
<b>INTCORR</b>	INTCORR Internal Channel Correction	Indicates that correction in the baseband bandwidth is enabled.

### 3.3.2 Frequency information frame

The frequency information frame displays the information of frequencies.

There are two modes: frequency display and channel display.  
Refer to Chapter 4 “Frequency”.



Figure 3.3.2-1 Frequency Information Frame (Frequency Display)



Figure 3.3.2-2 Frequency Information Frame (Channel Display)

### 3.3.3 Level information frame

The level information frame displays the information of levels.  
Refer to Chapter 5 “Output Level”.



Figure 3.3.3-1 Level Information Frame



### 3.3.4 Active function frame

On the active function frame, you can enter numbers and characters for setting all parameters. When you select a parameter on the function menu, a dialog box is displayed. This frame is not displayed when there is no parameter to be set or when it is in the remote-control state.




Figure 3.3.4-1 Numeric Input Dialog Box




Figure 3.3.4-2 Character Input Dialog Box (Except for File Names)



Figure 3.3.4-3 Character Input Dialog Box (File Names)

1. SG number  
Displays SG1 or SG2 to be set.
2. Function name  
Displays a function name to be set.
3. Text box  
Inputs or changes numeric values or character strings to be set.
4. Increment  
Displays a unit of step for setting with rotary knob or arrow keys.
5. Touch panel display switch  
Displays a touch panel for input.  
Refer to 3.5.1 “Specifying parameters as numeric values” and 3.5.2 “Setting character strings”.
6. Rotary knob switch  
Enables/locks the rotary knob.  
Refer to 3.5.1 “Specifying parameters as numeric values”.
7. Character pallet

Displays available characters. The character selection cursor and the mouse can be used for input.


Refer to 3.5.2 “Setting character strings”.

**Note:**

Character types available for file names and for names other than file names are different.

### 3.3.5 Function display frame

The function display frame displays the information of each function and setting in block diagrams and controls on the screen. This is not displayed in the remote-control state.



**Figure 3.3.5-1 Function Display Frame Example**

#### Hardware Block Chart

Displays the setting of the MG3710A/MG3740A, signal flow, and the current I/O setting status.

#### ARB Info

Shows the current waveform output status.

#### Sweep/List Info

Shows the setting status and progress of Sweep and List function.

#### BER

Shows the BER measurement status.



#### Table

Includes the channel table, correction table, and list table.

#### List


Includes the waveform file list, BER Log, and Alarm History.

**Table 3.3.5-1 Keys Available for Creating and Editing Lists and Tables**

Key name	Function
Rotary knob	Clockwise Moves the cursor from the left top to the right bottom sequentially. Counter clockwise Moves the cursor in reverse to the above.
	Moves the cursor horizontally.
	Moves the cursor vertically.
Enter key	Opens the setting dialog box of the item selected with the cursor.
Cancel key	Cancels the entered value and closes the setting dialog box.

### 3.3.6 Resident frame

The resident frame displays parameters of ARB, Power Meter, BER setting, and measured results.



**Figure 3.3.6-1 Resident Frame**

ARB (Refer to Table 7.1.1-2 “Resident Display Frame ARB”.)

- 1 ARB On/Off information
- 2 Displays the combination of the waveform memory, CW, AWGN, and others output from ARB.
- 3 Rate Mismatch display
- 4 FIR Error display

Power Meter

- 5 A: On/Off/Disconnect information/Measured value
- 6 B: On/Off/Disconnect information/Measured value

BER Test

- 7 Status Stopped  
Sync  
Measuring
- 8 Error Clock ERR (Input clock error)  
Enable ERR (Input enable signal error)  
Sync Loss (Sync Loss occurred)
- 9 Rate An index is displayed.
- 10 Rate % display
- 11 Count Error count
- 12 Count Measured bits

### 3.3.7 Footer frame

The footer frame displays reasons and time of error messages or error information of indicators.



**Figure 3.3.7-1 Footer Frame**

- 1 Displays the error message ID.
- 2 Displays the error message.  
(Ex: Data out of range)
- 3 Displays the error information (cause of the error).  
(Ex: Setting value out of range)
- 4 Displays the current time.

For explanations of error messages, refer to Appendix B “Error Messages”.

### 3.3.8 Function menu frame

The function menu frame is displayed on the right side of the screen and contains the following items. Items on the menu depend on the screen.






	<p><b>Function menu name</b>  <b>Frequency</b> Others</p> <p><b>Top key</b>  </p> <p><b>Function menu</b>  </p> <p><b>Back key</b>  </p> <p><b>Page</b>  <b>1 of 2</b></p>	<p>Displays the current function menu name.</p> <p>Press to open the top function menu.</p> <p>Maximum 8 menus. Grayed out items cannot be used.</p> <p>Press to display the next page of the Function menu.</p> <p>Press to go back to the previous layer within the function menu.</p> <p>Indicates the page of the function menu.</p>
--	---	--

Figure 3.3.8-1 Function Menu

The symbol on the upper right of each function menu key represents a behavior when pressing the function key. The meanings of each symbol are explained below.

-  Press the soft function key to display the function menu on the next layer.




Figure 3.3.8-2 Function Key with  Symbol

- Function key without a symbol. There are 2 types.  
The function key with multiple options:  
Each time you press the function key, the underline of option moves in the function menu.





Figure 3.3.8-3 Function Key without a Symbol

The function key to execute operation immediately:  
Press the soft function key to execute the menu immediately. The display does not change.



Figure 3.3.8-4 Function Key without a Symbol

-  Press the soft function key to display an input dialog box in the active function frame.




Figure 3.3.8-5 Function Key with  Symbol



### 3.3.9 Display of 2SG

When two SGs are installed, SG that is not selected for control is displayed in the summary frame as below. The figure below shows the summary frame when SG2 is not selected.



Figure 3.3.9-1 Summary Frame

- 1 **Displays frequency**  
Displays the specified frequency. The relative display or the value with the offset is displayed.
- 2 **Displays output level**  
Displays the specified output. The relative display or the value with the offset is displayed.
- 3 **Output status**  
Displays the RF output status.
 

Mod	When it lights green, the RF output signals are modulated.
RF	When it lights orange, the RF signals are output.
- 4 **Alarm**  
Displays the alarm information of the common indicator only.

### 3.3.10 RPP



Figure 3.3.10-1 RPP Message

RPP (Reverse Power Protection) is a function to protect the internal circuit of the MG3710A/MG3740A against the reverse input signals. When the external high level RF signal is input to the RF Output terminal, the excessive reverse input is blocked by the relay circuit to prevent from being input to the MG3710A/MG3740A.

The RPP function is available only when the Option 043/143 and 073/173 are installed.

When the RPP function has worked, the message above is displayed. The RPP function menu is displayed, too.

Table 3.3.10-1 RPP Function Menu

Page	Key No.	Menu Display	Function
1	F1	Resume SG1&SG2 RPP	Unblocks signals and recovers to the normal operation if RPP blocks signals.

**Remote command**

**Cancel the signal-block executed by RPP**

**Command**

:OUTPut:PROTection:RESume

**Details**

This command recovers both SG1 and SG2.

**Programming Example**

To cancel the signal-block executed by RPP.

OUTP:PROT:RES

**Remote command****Query RPP Status****Query**

```
:OUTPut[1]|2:PROTection:ERRor?
```

**Response**

```
<boolean>
```

**Parameter**

```
<boolean>
```

RPP Status

0

RPP does not block signals.

1

RPP blocks signals.

**Programming Example**

To query RPP Status of SG1.

```
OUTP:PROT:ERR?
```

```
> 1
```

**Remote command****Query the count of RPP****Query**

```
:OUTPut[1]|2:PROTection:COUNT?
```

**Response**

```
<integer>
```

Count of RPP

Range

0 to 4294967295 ( $=2^{32} - 1$ )

Resolution

1


**Programming Example**

To query the RPP count of SG2.

```
OUTP2:PROT:COUN?
```

```
> 10
```

### 3.4 Top Function Menu

Press  to display the top function menu.

**Table 3.4-1 Top Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Frequency	Displays the Frequency function menu. Refer to Chapter 4 “Frequency”
	F2	Level	Displays the Level function menu. Refer to Chapter 5 “Level”
	F3	Sweep/List	Displays the Sweep/List function menu. Refer to Chapter 6 “Sweep/List”
	F4	Mode	Displays the Mode function menu. Refer to Chapter 7 “Modulation”
	F6	Modulation <u>Off</u> On	Turns On/Off the RF signal modulation. When Off is selected, carrier waves (CW) are output. Refer to 3.4.1 “Modulation”
	F7	RF Output <u>Off</u> On	Enables/disables the RF signal output. Refer to 3.4.2 “RF Output”
	F8	SG Port <u>1</u> 2	Selects the SG to be controlled. Refer to 3.4.3 “SG Port”
2	F1	AWGN	Displays the AWGN function menu. They are not displayed in MG3740A Refer to 7.5 “AWGN”
	F2	I/Q	Displays the I/Q function menu. Refer to 7.6 “I/Q Modulation”.
	F3	Analog/Pulse	Displays the Analog/Pulse function menu. Refer to 7.2 “Analog Modulation: Analog/Pulse”.
	F4	Route Connectors	Displays the Route Connectors function menu. Refer to 7.4 “Route Connectors”.
	F5	Auxiliary	Displays the Auxiliary function menu. Refer to 9.1 “Auxiliary Function”.
	F6	Utility	Displays the Utility function menu. Refer to 9.4 “Utility Function”.

### 3.4.1 Modulation

 or **Top>Modulation**

Turns On/Off the RF signal modulation .

Press **F6 Modulation** to set the SG output signal modulation to On/Off. This behaves same as **Mod On/Off** on the front panel.

Off	Turns the modulation of SG output signals Off (no modulation, Default).
On	Modulates SG output signals. The <b>Mod On/Off</b> LED (green) on the front panel and "Mod" of the output status (green) in the level information frame light.

#### Remote command

#### Toggle On/Off RF signal modulation

##### Command

```
:OUTPut [1] | 2:MODulation[:STATe] <boolean>
```

##### Query

```
:OUTPut [1] | 2:MODulation[:STATe] ?
```

##### Response

```
<boolean>                    0 or 1
```

##### Parameter

<boolean>	Modulation On/Off
OFF 0	Modulation Off (Default)
ON 1	Modulation On

#### Programming Example

To turn the modulation On.

```
OUTP:MOD ON
```

```
OUTP:MOD?
```

```
> 1
```

### 3.4.2 RF Output

On/Off  or **Top>RF Output**

Enables/disables the RF signal output.

Press **F7 RF Output** to turn the output of SG signals On/Off. When RF Output is On, the **SG On/Off** LED (yellow) on the front panel and "RF" display of the output status (yellow) in the level information frame light. This behaves same as **RF On/Off** on the front panel.

Off	Stops outputting RF signals (Default).
On	Outputs RF signals from the connector on the front panel. The <b>SG On/Off</b> LED (yellow) on the front panel and "RF" display of the output status (yellow) in the level information frame light.

#### Remote command

#### Toggle On/Off RF signal output

##### Command

```
:OUTPut[1]|2[:STATe] <boolean>
```

##### Query

```
:OUTPut[1]|2[:STATe]?
```

##### Response

```
<boolean> 0 or 1
```

##### Parameter



<boolean>	Output On/Off
OFF 0	Output Off (Default)
ON 1	Output On

#### Programming Example

To turn the output On.

```
OUTP ON
OUTP?
> 1
```

### 3.4.3 SG Port

  or **Top>SG Port**

Selects the SG to be controlled.

Press **F8 SG Port** to select SG to be controlled. This is available when SG2 (Option 062/162, 064/164, 066/166) is installed. These behave same as **SG1** and **SG2** on the front panel.

- 1 Controls SG1 (Default).
- 2 Controls SG2.

#### Remote command

#### Select SG to be controlled

##### Command

```
[ :SOURce ] :PORT 1 | 2
```

##### Query

```
[ :SOURce ] :PORT?
```

##### Response

```
<port>
```

##### Parameter

<port>	Controlled
1	SG1 (Default)
2	SG2

#### Programming Example

To control SG2.

```
PORT 2
```

```
PORT?
```

```
> 2
```

## 3.5 Common Setting Operations

This section describes basic operations common to each screens.

### 3.5.1 Specifying parameters as numeric values

When you press a function key, the active function frame displays a numeric input dialog box where you can set parameters such as frequencies or output levels.



Figure 3.5.1-1 Numeric Input Dialog Box

A text box for numeric input is displayed in the upper part of the dialog box, while the increment step specified with rotary knob or arrow keys is displayed in the lower part.

The touch panel or the numeric keypad can be used for numeric input.

To input a numeric value using the touch panel:

The display of the MG3710A/MG3740A is a touch panel. Press the arrow key on the upper right of the numeric input dialog box to display the numeric keypad panel. Touch a number on the display to input the value. You can also enter a number by clicking it with a mouse.



Displays the numeric keypad panel.



Hides the numeric keypad panel.





Figure 3.5.1-2 Numeric Keypad



To input a numeric value using the numeric keypad:

When you enter a numeric value using the numeric keypad, the value you entered is displayed in the text box. After inputting a numeric value, press the **Enter**, **Enter Item**, or unit key on the function menu to finalize it. When you press **Cancel** during the input process, the entered value becomes invalid and returns to the state before your input.

To increase/decrease a numeric values using the rotary knob:

Select a highlighted resolution using an arrow key  , and then rotate the rotary knob to the right to increase the digit. Rotate the rotary knob to the left to decrease the digit. Rotating the rotary knob specifies a number in real time.

**Note:**

The rotary knob has the lock function to avoid a misoperation. Pressing the lock key on the upper left allows you to lock the rotary knob. This function can be set only from the screen.



Enables the rotary knob.





Locks the rotary knob.



**Figure 3.5.1-3 Locked Rotary Knob**

To increase/decrease a numeric values using arrow keys:

Increase/decrease a numeric value using  . The step in which a numeric value is increased/decreased each time a step key is pressed varies according to the parameter. Handling arrow keys specifies a value in real time.

### 3.5.2 Setting character strings

When you set a character string, the active function frame displays a dialog box to input character strings.

When you enter Group Name, the **Group Name** dialog box is displayed.




Figure 3.5.2-1 Character String Input Dialog Box

A text box for character string input is displayed in the upper part of the dialog box, while the character pallet containing available characters is displayed in the lower part. You can enter characters by directly clicking on the character pallet with the mouse.

Press the arrow key on the upper right of the numeric input dialog box to display the character string input panel. Touch a character on the display to input it. You can also enter a character by clicking it with the mouse.



Displays the character string input panel.



Hides the character string input panel.





Figure 3.5.2-2 Character String Input Panel

Keys available for character string input are as follows:

**Table 3.5.2-2 Keys Available for Character String Input**

Key name	Function
Rotary knob	Moves character string input pallet/panel character selection cursor horizontally
Arrow keys, 	Moves character string input text box input cursor horizontally
Numeric keypad	Directly inputs numbers (from 0 to 9), ".", and "-". After pressing <b>Shift</b> , you can input alphabets (from A to F).
<b>Enter</b>	Inserts the character selected by the character selection cursor on the position where the input cursor locates.
<b>BS</b>	Deletes the character before the input cursor.
<b>Cancel</b>	Stops inputting character strings and closes the window.

**Note:**

The maximum of 100 characters can be input as character strings.

Characters available for character strings are displayed on the character pallet.

The following characters cannot be used: \

### 3.5.3 Setting file names

When a file name such as a channel table must be set, the active function frame displays a dialog box to input file names, for example **Channel Table Save** dialog box.




Figure 3.5.3-1 File Name Input Dialog Box

A text box for character string input is displayed in the upper part of the dialog box, while the character pallet containing available characters is displayed in the lower part.

You can also enter characters by directly clicking it on the character pallet with the mouse.

Refer to Table 3.5.2-2 “Keys Available for Character String Input” for keys available for character string input.

**Note:**

When you input a file name, an extension is automatically added.

You cannot specify an extension.

The maximum 100 characters are allowed for a file name.

Example of a destination path:

Anritsu\MG3710A\User Data\XXXXX\

Example of a default destination name:

XXXXXX\_[Date]\_[Additional number].xxx

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

XXXXXX and xxx depend on file types.

Characters available for file names are displayed on the character palette.

The following characters cannot be used:

\ / : \* ? " " \ ' < > |

A space or dot “.” at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.



## Chapter 4 Frequency

---

This chapter describes the functions for setting frequencies.

Note on remote command:

When the language mode is SCPI, the target SG can be selected with the beginning node of commands for controlling individual functions. Refer to Appendix E.7.6 “Selecting SG1/2” for details.

4.1	Frequency .....	4-2
4.1.1	Display description .....	4-3
4.1.2	Frequency indicator .....	4-4
4.2	Frequency Setting Method: Frequency .....	4-6
4.2.1	Frequency setting .....	4-7
4.2.2	Changing frequencies with rotary knob .....	4-8
4.2.3	Changing frequencies with arrow keys .....	4-9
4.2.4	Frequency setting resolution .....	4-10
4.3	Frequency Setting Items .....	4-12
4.3.1	Frequency relative display .....	4-14
4.3.2	Frequency offset .....	4-16
4.3.3	Frequency offset multiplier .....	4-18
4.4	Channel Setting .....	4-20
4.4.1	Frequency/channel display: Display .....	4-21
4.4.2	Frequency display: Frequency .....	4-22
4.4.3	Channel selection: Channel .....	4-23
4.4.4	Channel Group .....	4-25
4.5	Channel Table: Edit Table .....	4-26
4.5.1	Registering channel groups .....	4-28
4.5.2	Adding channel groups: Insert Row .....	4-33
4.5.3	Deleting channel groups: Delete Row .....	4-34
4.5.4	Deleting channel tables: Clear .....	4-35
4.5.5	Recalling channel tables: Open .....	4-36
4.5.6	Saving channel tables: Save .....	4-38
4.6	Frequency-Related Functions .....	4-41
4.6.1	Frequency synchronization: Freq Sync .....	4-41
4.6.2	Phase noise optimization:	
	Phase Noise Optimize .....	4-44
4.6.3	Spectrum reverse: RF Spectrum .....	4-45
4.6.4	Reference oscillator .....	4-47
4.6.5	Local signal source .....	4-49
4.6.6	Ref Clock Adjustment .....	4-53

## 4.1 Frequency

 or **Top>Frequency**

When you press **Frequency** of the main function key or **F1 Frequency** on the top function menu, the MG3710A/MG3740A becomes the frequency setting mode and the **Frequency** or **Channel** dialog box is displayed in the active function frame. The Frequency function menu is displayed, too.

This chapter assumes that you press **Frequency** or **F1 Frequency** on the top function menu and the MG3710A/MG3740A is in the frequency setting mode, unless otherwise specified.

### Frequency setting range and resolution

#### Frequency setting range

9 kHz to 2700 GHz (With MG3710A/MG3740A-032)

9 kHz to 4000 MHz (With MG3710A/MG3740A-034)

9 kHz to 6000 MHz (With MG3710A/MG3740A-036)

9 kHz to 2700 MHz (With MG3710A/MG3740A-062/162)

9 kHz to 4000 MHz (With MG3710A/MG3740A-064/164)

9 kHz to 6000 MHz (With MG3710A/MG3740A-066/166)

Frequency setting resolution      0.01 Hz

A frequency out of the range cannot be set or finalized, and the error screen is displayed.

Frequency setting methods are as follows:

- Frequency setting with the numeric keypad
- Frequency setting with the rotary knob
- Frequency setting with step keys



### 4.1.1 Display description

This section describes screens of the frequency information frame.




Figure 4.1.1-1 Frequency Setting Screen

Table 4.1.1-1 Items of Frequency Setting Screen

Display	Description
Display frequency	Indicates the specified frequency. A value is changed by enabling/disabling Freq Ref or Freq Offset.
RF output frequency	Indicates the actually output frequency.
Channel	Indicates the currently selected channel number.
Channel group number	Indicates a number of the channel group.
Display channel frequency	Indicates the frequency corresponding to the channel number.
Frequency indicator	Indicates the status of frequency setting.

### 4.1.2 Frequency indicator

Items of frequency indicators are as follows:

**Table 4.1.2-1 Frequency Indicator**

Display	Name	Description
<b>OFFS</b>	Offset	Indicates that the frequency offset function is on.
<b>REF</b>	Reference	Indicates that the frequency relative value display function is on.
<b>MULT</b>	Multiplier	Indicates that the frequency offset multiplier function is on.
<b>OSYNC</b>	Offset	Indicates that the frequency of either one of SGs is out of the specified range and cannot be synchronized when frequency synchronization is executed for SG1 and SG2.
<b>EXTREF</b>	Reference	Indicates that an external signal is used as a reference signal source.

Remote commands for items in the frequency indicator frame are as follows:

## Out of specified range: OSYNC

**Remote command**      **OSYNC: Query the status of frequency synchronization for SG 1 and SG2**

**Query**

```
[ :SOURce[1] | 2 ] :FREQuency:SYNC:STATus?
```

**Response**

```
<status>
```

**Parameter**

<status>		Synchronization of frequencies
OOS	Out of Sync	Cannot synchronize frequencies because it stands out of the specified range.
NORM	Normal	Normal

**Programming Example**

To query the information of frequency synchronization for SG1 and SG2.

```
FREQ:SYNC:STAT?
```

```
> NORM
```

## External reference signal: EXTREF

**Remote command**      **EXTREF: Query the setting of the reference oscillator**

**Query**

```
[ :SOURce ] :ROSCillator:SOURce?
```

**Response**

```
<status>
```

**Parameter**

<status>	Status
When the language mode is SCPI/MG3700:	
INT	Internal reference signal source
EXT	External reference signal source
When the language mode is MS269X/MS2830:	
INT	Internal reference signal source
INTU	Internal reference signal source (Unlock state)
EXT	External reference signal source
EXTU	External reference signal source (Unlock state)

**Programming Example**

To query the setting of the reference oscillator.

```
ROSC:SOUR?
```

```
> INT
```

## 4.2 Frequency Setting Method: Frequency

 or **Top>Frequency**

When you press **Frequency** of the main function key or **F1 Frequency** on the top function menu, the MG3710A/MG3740A becomes the frequency setting mode and the **Frequency** dialog box is displayed in the active function frame. Enter numbers in the **Frequency** dialog box to set frequencies.

### Remote command

#### Set Frequencies

##### Command

```
[ :SOURce [1] | 2 ] :FREQuency [ :CW | :FIXed ] <freq>
```

##### Query

```
[ :SOURce [1] | 2 ] :FREQuency [ :CW | :FIXed ] ?
```

##### Response

```
<freq>                                Unit: Hz
```

##### Parameter

```
<freq>                                Frequency
Range                                  Refer to 4.1 "Frequency".
Resolution                              0.01 Hz
Default                                 1 GHz
Suffix code                             HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ
When omitted                             Hz
```

#### Programming Example

To set the frequency to 800 MHz.

```
FREQ 800MHZ
FREQ?
> 800000000.00
```

## 4.2.1 Frequency setting

Enter numbers in the Frequency dialog box. with numeric keypad

### Setting method

The procedure for setting frequencies with the numeric keypad is as follows.

Example: To set the frequency to 360.3 MHz

1. Press “3”, “6”, “0”, “.”, and “3” using number buttons of the numeric keypad or numbers on the screen. The screen below is displayed.



Figure 4.2.1-1 Frequency Dialog Box

2. Press the unit **F2 MHz** on the function key to finalize the numbers and the unit. The “360.300 000 00 MHz” is displayed in the **Frequency** dialog box and in the frequency information frame.





Figure 4.2.1-2 Frequency Dialog Box

360.3 MHz can be also set using one of the following:

- “0”, “.”, “3”, “6”, “0”, “3”, F1 GHz
- “3”, “6”, “0”, “3”, “0”, “0”, F3 kHz
- “3”, “6”, “0”, “3”, “0”, “0”, “0”, “0”, “0”, “0”, F4 Hz

Digits of 0.01 Hz or smaller are truncated.

## 4.2.2 Changing frequencies with rotary knob



The rotary knob allows you to increase or decrease a digit of resolution selected by arrow keys  . The cursor shows the position of the digit.

Default value of the digit of resolution (the position of the cursor): 0.01 Hz.

### Setting method

**The procedure for setting frequencies with the rotary knob is as follows:**

Example: To change the frequency from 360.3 MHz to 360.7 MHz by 100 kHz.





1. Use the arrow keys   to place the cursor on the digit of 100 kHz.



**Figure 4.2.2-1 Frequency Dialog Box**

2. Rotate the rotary knob to the right to increase a frequency by 100 kHz step. Rotate it to the left to decrease the frequency by 100 kHz. Using this method, rotate the rotary knob to the right and specify the frequency to 360.7 MHz.

### 4.2.3 Changing frequencies with arrow keys

Arrow keys   enable you to increase or decrease a digit of resolution selected by arrow keys  . The cursor shows the position of the digit.

Default value of frequency step: 100 kHz

#### Setting method

**The procedure for setting frequencies with the arrow keys is as follows:**

Example: To change the frequency from 360.3 MHz to 360.7 MHz by 100 kHz.





1. Set the frequency to 360.3 MHz.
2. Use the arrow keys   to place the cursor on the digit of 100 kHz.





Figure 4.2.3-1 Frequency Dialog Box

3. Use the arrow keys   to increase or decrease the frequency by 100 kHz step.

## 4.2.4 Frequency setting resolution

 or **Top>Frequency** 

Sets a resolution of arrow keys   for setting frequencies.

When the MG3710A/MG3740A is in the frequency setting mode, press **Incr Set** of the main function key to display the **Increment** dialog box. Enter numbers in the **Increment** dialog box to specify a resolution of arrow keys  .

### Remote command

#### Specify a frequency setting resolution

##### Command

```
[ :SOURce [1] | 2 ] :FREQuency:STEP [ :INCRement ] <freq>
```

##### Query

```
[ :SOURce [1] | 2 ] :FREQuency:STEP [ :INCRement ] ?
```

##### Response

```
<freq> Unit: Hz
```

##### Parameter

<freq>	Step level
Range	0.01 Hz to 1 GHz
Resolution	0.01 Hz
Default	100 kHz
Suffix code	HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ When omitted Hz

#### Programming Example

To set the frequency step level to 200 kHz.

```
FREQ:STEP 200KHZ
```

```
FREQ:STEP?
```

```
>200000.00
```

### Setting method

#### The procedure for specifying frequency setting resolution with the arrow keys is as follows:

Example: To change the frequency with the frequency setting resolution 9 kHz.

1. When the MG3710A/MG3740A is in the frequency setting mode, press **Incr Set** of the main function key to display the **Increment** dialog box in the active function frame.



- Set the numeric value “9” to set the step frequency to 9 kHz.





Figure 4.2.4-1 Increment Dialog Box

- Press the unit key “kHz” of the function key to set the step frequency to 9 kHz.



Figure 4.2.4-2 Increment Dialog Box

- Use the arrow keys   to increase or decrease the frequency by 9 kHz step.

## 4.3 Frequency Setting Items

 or **Top>Frequency**

When you press **Frequency** of the main function key or **F1 Frequency** on the main function menu, the MG3710A/MG3740A becomes the frequency setting mode and the Frequency function menu is displayed.

**Table 4.3-1 Frequency Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Freq Ref <u>Off</u> On	Enables/disables the frequency relative display. Refer to 4.3.1 “Frequency relative display”.
	F2	Freq Offset <u>Off</u> On	Enables/disables the frequency offset. Refer to 4.3.2 “Frequency offset”.
	F3	Offset Value 0.00 Hz	Sets the frequency offset value. Refer to 4.3.2 “Frequency offset”.
	F4	Freq Multiplier <u>Off</u> On	Enables/disables the frequency offset multiplier. Refer to 4.3.3 “Frequency offset multiplier”.
	F5	Multiplier Value 1.000 x	Sets the value of the frequency offset multiplier. Refer to 4.3.3 “Frequency offset multiplier”.
	F7	Channel Settings	Displays the channel setting function menu. Refer to 4.4 “Channel Setting”.
	F8	Freq Sync	Sets the frequency synchronization of SG1 and SG2. Refer to 4.6.1 “Frequency synchronization: Freq Sync”.

Table 4.3-1 Frequency Function Menu (Cont'd)

Page	Key No.	Menu Display	Function
2	F1	Phase Noise Opt. <200 kHz >300 kHz	Sets the phase noise optimization. Refer to 4.6.2 "Phase noise optimization: Phase Noise Optimize".
	F2	RF Spectrum <u>Normal</u> Reverse	Inverts the spectrum of RF output. This is available in MG3740A only when option-020/120 is installed. Refer to 4.6.3 "Spectrum reverse: RF Spectrum".
	F3	Ref Source <u>Auto</u> Int	Sets reference frequency source. Refer to 4.6.4 "Reference oscillator".
	F4	Ref Freq 10 MHz	Selects a frequency of external reference signal from 5 MHz, 10 MHz, and 13 MHz. Refer to 4.6.4 "Reference oscillator".
	F5	LO Source <u>Int</u> Ext/Sync	Sets a local signal source. This is available when the MG3710A-017/117 is installed. This is not available in MG3740A. Refer to 4.6.5 "Local signal source".
	F6	LO Out <u>Off</u> On	Adjusts the phase of a local signal. This is available when the MG3710A-017/117 is installed. This is not available in MG3740A. Refer to 4.6.5 "Local signal source".
	F7	LO Phase 0.00 deg	Displays the LO Phase screen and adjusts the LO phase. This is not available in MG3740A. Refer to 4.6.5 "Local signal source".
	F8	Ref Clock Adjustment	Displays the Freq Adjustment function menu and adjusts the frequency of the internal reference frequency signal. Refer to 4.6.6 "Ref Clock Adjustment".

### 4.3.1 Frequency relative display

**Frequency** or **Top>Frequency, >Freq Ref: Freq Ref**  
 Enables/disables the frequency relative display.

The frequency relative display shows a difference from the reference output frequency.

When you turn the frequency relative display from Off to On, a difference from 0 Hz, which is the reference frequency, is displayed. Above it, the actual output frequency is displayed.

RF output frequency = display frequency + output frequency in the relative value display

**Table 4.3.1-1 Frequency Relative Display Setting Example**

	Example 1	Example 2	Example 3	Example 4
Output frequency	1.000 GHz	1.000 GHz	1.010 GHz	0.990 GHz
Frequency relative display	Off	0.00 Hz	10 MHz	-10 MHz
Displayed frequency	1.000 GHz	0.00 Hz	10 MHz	-10 MHz

Press **F1 Freq Ref** to switch the frequency relative display.

Off Displays frequencies in absolute values (Default).

On Display frequencies in relative values. The “REF” is displayed in the frequency indicator.

**Remote command**

**Enable/disable the frequency relative display**

**Command**

`[ :SOURCE[1] | 2 ] :FREQUENCY:REFERENCE:STATE <boolean>`

**Query**

`[ :SOURCE[1] | 2 ] :FREQUENCY:REFERENCE:STATE?`

**Response**

`<boolean>` 0 or 1

**Parameter**

`<boolean>` Frequency relative display On/Off

OFF | 0 In absolute values (Default)

ON | 1 In relative values

**Programming Example**

To enable the frequency relative display.

```
FREQ:REF:STAT ON
```

```
FREQ:REF:STAT?
```

```
> 1
```

### 4.3.2 Frequency offset

#### Freq Offset

 or **Top>Frequency, >Freq Offset**

Enables/disables the frequency offset.

When the frequency offset is on, the frequency offset value specified with **F3 Offset Value** is added to the display frequency, and the actual output frequency is displayed above it.

**Table 4.3.2-1 Frequency Offset Setting Example**

	<b>Example 1</b>	<b>Example 2</b>	<b>Example 3</b>
Output frequency	1.000 GHz	1.000 GHz	1.000 GHz
Frequency offset	Off	10 MHz	-10 MHz
Displayed frequency	1.000 GHz	1.010 GHz	0.990 GHz

Press **F2 Freq Ref** to toggle On/Off of the frequency offset.

Off Does not use the frequency offset (Default).

On Uses the frequency offset. The “OFFS” is displayed in the frequency indicator.

#### Remote command

#### Enable/disable the frequency offset

##### Command

`[ :SOURce [1] | 2 ] :FREQuency:OFFSet:STATe <boolean>`

##### Query

`[ :SOURce [1] | 2 ] :FREQuency:OFFSet:STATe?`

##### Response

`<boolean>` 0 or 1

##### Parameter

`<boolean>` Frequency offset On/Off  
 OFF|0 Does not use the frequency offset (Default).  
 ON|1 Uses the frequency offset.

#### Programming Example

To use the frequency offset.

```
FREQ:OFFS:STAT ON
FREQ:OFFS:STAT?
> 1
```

## Frequency Offset Value: Offset Value

 or **Top>Frequency, >Offset Value**

Sets the frequency offset value.

Press F3 Offset Value to set a frequency offset value in the Offset Value dialog box in the active function frame.

Setting range	-200 GHz to 200 GHz
Resolution	0.01 Hz
Default	0 Hz

**Remote command****Set the frequency offset value****Command**

```
[ :SOURce[1] | 2 ] :FREQuency:OFFSet <freq>
```

**Query**

```
[ :SOURce[1] | 2 ] :FREQuency:OFFSet?
```

**Response**

```
<freq> Unit: Hz
```

**Parameter**

<freq>	Offset value
Setting range	-200 GHz to 200 GHz
Resolution	0.01 Hz
Default	0 Hz
Suffix code	HZ, KHZ, MHZ, GHZ, KZ, MZ, GZ When omitted: HZ

**Programming Example**

To set the frequency to 50 MHz.

```
FREQ:OFFS 50MHZ
```

```
FREQ:OFFS?
```

```
> 50000000.00
```

### 4.3.3 Frequency offset multiplier

Frequency offset multiplier: Freq Multiplier

 or **Top>Frequency, >Freq Multiplier**

Sets a frequency offset multiplier.

When this function is on, the actual output frequency is multiplied by a frequency offset multiplier and the result is displayed. Above the result, the actual output frequency is displayed.

**Table 4.3.3-1 Frequency Offset Multiplier Setting Example**

	Example 1	Example 2	Example 3
Output frequency	1.000 GHz	1.000 GHz	1.000 GHz
Frequency offset multiplier	Off	2	-2
Displayed frequency	1.000 GHz	2.000 GHz	-2.000 GHz

Press **F4 Freq Multiplier** to enable/disable the frequency offset multiplier.

Off Does not use the frequency offset multiplier.  
(Default)

On Uses the frequency offset multiplier. The  
“MULT” is displayed in the frequency indicator.

**Remote command**

**Enable/disable the frequency offset multiplier**

**Command**

`[ :SOURce [1] | 2 ] :FREQuency:MUlTIplIer:STATe <boolean>`

**Query**

`[ :SOURce [1] | 2 ] :FREQuency:MUlTIplIer:STATe?`

**Response**

`<boolean>` 0 or 1

**Parameter**

`<boolean>` Frequency offset multiplier On/Off  
`OFF | 0` Does not use the frequency offset multiplier.  
 (Default)  
`ON | 1` Uses the frequency offset multiplier.



**Programming Example**

To enable the frequency offset multiplier.

```
FREQ:MULT:STAT 1
FREQ:MULT:STAT?
> 1
```

**Frequency offset multiplier: Multiplier Value**

 or **Top>Frequency, >Multiplier Value**

Sets the value of the frequency offset multiplier.

Press F5 Multiplier Value to set a value in the Multiplier Value dialog box in the active function frame.

Setting range	-1000 to -0.001, 0.001 to 1000
Resolution	0.001
Default	1

**Remote command****Set a frequency offset multiplier****Command**

```
[ :SOURce[1] | 2 ] :FREQuency:MULTiplier <ext_numeric>
```

**Query**

```
[ :SOURce[1] | 2 ] :FREQuency:MULTiplier?
```

**Response**

```
<ext_numeric>
```

**Parameter**

```
<ext_numeric>
```

Setting range	-1000 to -0.001, 0.001 to 1000
Resolution	0.001
Default	1

**Programming Example**

To set a frequency offset multiplier to 0.5.

```
FREQ:MULT 0.5
FREQ:MULT?
> 0.500
```

## 4.4 Channel Setting

 or **Top>Frequency, >Channel Settings**

When you press Frequency of the main function key or F1 Frequency on the main function menu, the MG3710A/MG3740A becomes the frequency setting mode. When you press F7 Channel Settings on the Frequency function menu, the Channel Setting function menu is displayed and the MG3710A/MG3740A becomes the channel setting mode. Refer to 4.5 “Channel Table: Edit Table” for the explanation about channels.

This section assumes that you press **F7 Channel Settings** and the MG3710A/MG3740A is in the channel setting mode, unless otherwise specified.

**Table 4.4-1 Channel Settings Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Display <u>Freq</u> Channel	Selects either frequency or channel for inputting and displaying the RF frequency. Refer to 4.4.1 “Frequency/channel display: Display”.
	F2	Frequency Off <u>On</u>	Selects whether or not to display the frequency when Channel is selected by <b>F1 Display</b> . Refer to 4.4.2 “Frequency display: Frequency”.
	F3	Channel 0	Selects a Channel number when Channel is selected by <b>F1 Display</b> . Refer to 4.4.3 “Channel selection: Channel”.
	F4	Channel Group No Group	Selects a Channel Group. Refer to 4.4.4 “Channel Group”.
	F8	Edit Table	Creates and edits a channel table. Refer to 4.5 “Channel Table: Edit Table”.

### 4.4.1 Frequency/channel display: Display

**Frequency** or **Top>Frequency, >Channel Settings >Display**

Selects either frequency or channel for inputting and displaying the RF frequency.

Press **F1 Display** on the Channel Settings function menu to switch “Freq” and “Channel”.

Freq	Frequency display (Default)
Channel	Channel display




Figure 4.4.1-1 Channel Display

#### Remote command

Select either frequency or channel for inputting and displaying the RF frequency

#### Command

```
[ :SOURCE[1] | 2 ] :FREQUENCY:TYPE FREQUENCY|CHANNEL
```

#### Query

```
[ :SOURCE[1] | 2 ] :FREQUENCY:TYPE?
```

#### Response

<mode>

#### Parameter

<mode>

FREQUENCY	Frequency display (Default)
CHANNEL	Channel display

#### Programming Example

To set channel for inputting and displaying the RF frequency.

```
FREQ:TYPE CHAN
```

```
FREQ:TYPE?
```

```
> CHAN
```

### 4.4.2 Frequency display: Frequency

**Frequency** or **Top>Frequency, >Channel Settings>Frequency**

Displays/hides the frequency when a channel number is displayed on the screen. This function is available only in the channel setting mode.

Press **F2 Frequency** on the Channel Settings function menu to toggle On/Off.

- Off Does not display Frequency
- On Displays frequency (Default)




Figure 4.4.2-1 Channel and Frequency Display

#### Remote command

**Display/hide the frequency in the channel setting mode**

##### Command

```
[ :SOURce [1] | 2 ] :FREQuency:CHANnels:DISPlay <boolean>
```

##### Query

```
[ :SOURce [1] | 2 ] :FREQuency:CHANnels:DISPlay?
```

##### Response

```
<boolean> 0 or 1
```

##### Parameter

- <boolean> Frequency display
- OFF | 0 Does not display Frequency
- ON | 1 Displays frequency (Default)

#### Programming Example

To display the frequency.

```
SOUR2:FREQ:CHAN:DISP ON
SOUR2:FREQ:CHAN:DISP?
> ON
```

### 4.4.3 Channel selection: Channel

 or **Top>Frequency, >Channel Settings>Channel** Sets a channel specified in the channel table.

This function is available only in the channel setting mode.

Press **F3 Channel** on the Channel Settings function menu to set a channel in the **Channel** dialog box in the active function frame.

#### Remote command

#### Set a channel number

##### Command

```
[ :SOURce [1] | 2 ] :FREQuency:CHANnels:NUMBer <ext_integer>
```

##### Query

```
[ :SOURce [1] | 2 ] :FREQuency:CHANnels:NUMBer?
```

##### Response

```
<ext_integer>
```

##### Parameter

<ext_integer>	Channel number
Setting range	The channel range of a channel group (Up to 20000)
Resolution	1
Default	0

#### Programming Example

To set a channel number to 100.

```
FREQ:CHAN:NUMB 100
```

```
FREQ:CHAN:NUMB?
```

```
> 100
```

#### Setting method

#### Using the rotary knob or arrow keys









Use the arrow keys   to place the cursor on the digit to be changed, and use the rotary knob or the arrow keys   to specify a number. Rotate the rotary knob to the right or press  to increase the channel number. Rotate the rotary knob to the left or press  to decrease the channel number.



Figure 4.4.3-1 Channel Dialog Box

If the rotary knob is turned clockwise or  is pressed with the end channel number selected, the cursor moves to the start channel of the

next channel group. This rule, however, does not apply to the end channel number of the end channel group.

If the rotary knob is turned counterclockwise or  is pressed with the start channel number selected, the cursor moves to the end channel of the previous channel group. This rule, however, does not apply to the start channel number of the start channel group.

#### Using the numeric keypad

Enter a number in the **Channel** dialog box using the numeric keypad, and then press **F1 Enter** to finalize the value. The channel is displayed in the SG information display frame. If you press **Cancel** before pressing **F1 Enter**, the entered value becomes invalid and returns to the state before your input.


Only a channel belonging to the same group as the current channel can be specified using the numeric keypad.

#### 4.4.4 Channel Group

 or **Top>Frequency, >Channel Settings>Channel Group**

Sets a channel group specified in the channel table.

This function is available only in the channel setting mode.

Press **F4 Channel Group** on the Channel Settings function menu to display the Channel Group function menu and select Channel Group to be used. Press  to display page 2 and 3.

Setting range 1 to 19

#### Remote command

#### Set a channel group

##### Command

```
[ :SOURce [1] | 2 ] :FREQuency:CHANnels:GROup <ext_integer>
```

##### Query

```
[ :SOURce [1] | 2 ] :FREQuency:CHANnels:GROup?
```

##### Response

```
<ext_integer>
```

##### Parameter

```
<ext_integer>
```

Channel group number

Setting range

1 to groups of the channel group table (up to 19)

#### Programming Example

To set a channel group to 2.

```
FREQ:CHAN:GRO 2
```

```
FREQ:CHAN:GRO?
```

```
> 2
```

## 4.5 Channel Table: Edit Table

**Frequency** or **Top>Frequency, >Channel Settings>Edit Table**

This function is available only in the channel setting mode.

On the MG3710A/MG3740A, you can assign a channel number to any frequency. In addition, channels with a certain frequency interval can be registered as a channel group. The maximum 19 channel groups can be registered as a channel table.

Press **F8 Edit Table** on the Channel Settings function menu to display the Channel Table and the Channel Table Edit function menus.

Select items to set using the cursor on the table and press **F1 Edit Item** to enter values in the displayed dialog boxes. Refer to 4.5.1 “Registering channel groups” for setting methods.

	Group Name	Start	End	Start Frequency	Channel Spacing
1	Group01	1	10	800.00000000 MHz	10.00000 kHz
2	Group02	11	20	810.00000000 MHz	10.00000 kHz
3	Group03	21	30	820.00000000 MHz	10.00000 kHz
4	Group04	31	40	830.00000000 MHz	10.00000 kHz
▶ 5	Group	0	0	1.0000000000 GHz	16.00000 kHz

Figure 4.5-1 Channel Table Dialog Box

Table 4.5-1 Display Items of Channel Table


Display	Description
Group Name	Channel group name
Start	The beginning channel number of the channel group
End	The last channel number of the channel group
Start Frequency	The beginning channel frequency
Channel Spacing	The interval in frequency between channels



Table 4.5-2 Channel Table Edit Function Menu

Page	Key No.	Menu Display	Function
1	F1	Edit Item	Displays input dialog boxes for items selected by the cursor in the Channel Table of the active function frame where you can enter appropriate numbers. Refer to 4.5.1 "Registering channel groups".
	F2	Insert Row	Adds a channel group row above the Channel Table. Refer to 4.5.2 "Adding channel groups: Insert Row".
	F3	Delete Row	Deletes one row of Channel Group selected by cursor on Channel Table. Refer to 4.5.3 "Deleting channel groups: Delete Row".
	F4	Clear	Clears the data of all channel groups in the Channel Table. Refer to 4.5.4 "Deleting channel groups: Clear".
	F7	Open	Recalls the data of the Channel Table. Refer to 4.5.5 "Recalling channel tables: Open".
	F8	Save	Saves the data of the Channel Table. Refer to 4.5.6 "Saving channel tables: Save".

### 4.5.1 Registering channel groups

 or **Top>Frequency, >Channel Settings>Edit Table**

Registers channel groups for setting channels.

**Remote command**

**Register channel groups**

**Command**

```
[ :SOURce [1] | 2 ] :FREQuency:CHANnels:EDIT
<ext_integer1>,<string>,<ext_integer2>,<ext_integer3>,<freq1>,<freq2>
```

**Parameter**

<ext_integer1>	Group Number
Setting range	1 to 19
Default	1
<string>	Group Name
	Character string within 100 characters enclosed by double quotes (“ ”) or single quotes (‘ ’)
Default	Group
<ext_integer2>	Start Channel
Setting range	0 to 20000
Resolution	1
Default	0
<ext_integer3>	End Channel
	The End Channel setting must be larger than the Start Channel setting.
Setting range	0 to 20000
Resolution	1
Default	0
<freq1>	Start Frequency
Setting range	Refer to 4.1 “Frequency”.
Resolution	0.01 Hz
Default	1 GHz
<freq2>	Channel Spacing
Setting range	1 Hz to 999.999999 MHz
Resolution	1 Hz
Default	16 kHz

**Details**

A blank row before the specified row position is padded with default values.

**Programming Example**

To set Group Number 03: Group Name 802.11b, Start Channel 1, End Channel 13, Start Freq. 2.412 GHz, and Channel Space 5 MHz.

```
FREQ:CHAN:EDIT 3,"802.11b",1,13,2.412GHZ,5MHZ
```


**Setting method**

**The procedure for registering channel groups is as follows:**

Example: To create a channel group on the fifth row of the channel table under the following condition:

- Group name: 802.11b
- Channels to be used: 1 to 13 channels
- The beginning channel frequency: 2.412 GHz
- The interval in frequency between channels: 5 MHz

(1) Specifying a group name



**Figure 4.5.1-1 Group Name Dialog Box**

1. Press **F2 Insert Row** to add an input row and place the cursor on the “Group Name” of the fifth row.
2. When you press **F1 Edit Item**, the **Group Name** dialog box and the Enter Item function menu is displayed in the active function frame.

**Table 4.5.1-1 Enter Item Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Enter Item	Edits values and returns to the previous menu.
	F8	Cancel	Returns to the previous menu.

3. Enter a group name, “802.11b”, in the **Group Name** dialog box.
4. Press **F1 Enter Item** to set the group name specified in the Channel Table and close the **Group Name** dialog box.

**Note:**

The maximum 100 characters are allowed for a group name. Characters in the character palette are available for group names.

The following restrictions apply to group names with long character strings:

Channel Setting, Channel Group Function Menus

If the display range is exceeded, the display is zoomed-out. If the display range is still exceeded after zooming-out, the out-of-range parts are omitted.

Group Name Display of Frequency Data Frame

If the display range is exceeded, the out-of-range parts are omitted.

(2) Specifying channels to be used



Figure 4.5.1-2 Start Number Dialog Box

1. Place the cursor on the “Start” of the first row.
2. Press **F1 Edit Item** to display the **Start Number** dialog box in the active function frame.
3. Use the numeric keypad to enter “1” in the **Start Number** dialog box.
4. Press **F1 Enter** to set the Start channel in the Channel Table and close the **Start Number** dialog box.




Figure 4.5.1-3 End Number Dialog Box

5. Place the cursor on the “End” of the first row.
6. Press **F1 Edit Item** to display the **End Number** dialog box in the active function frame.

7. Use the numeric keypad to enter “13” in the **End Number** dialog box.
8. Press **F1 Enter** Item to set the End channel in the Channel Table and close the **End Number** dialog box.

**Note:**

The channel setting ranges 0 to 20000. The End channel, however, must be set to a number same as or more than the Start channel.

- (3) Specifying the Start channel frequency and a frequency interval



Figure 4.5.1-4 Start Frequency Dialog Box

1. Place the cursor on the “Start Frequency” of the first row.
2. Press **F1 Edit Item** to display the **Start Frequency** dialog box in the active function frame.  
 Settable range Refer to 4.1 “Frequency”.  
 Resolution 0.01 Hz  
 Default 1 GHz
3. Use the numeric keypad to enter “2.412” in the **Start Frequency** dialog box.
4. Press the unit **F1 GHz** on the function menu to set a frequency of the Start channel in the Channel Table and close the **Start Frequency** dialog box.




Figure 4.5.1-5 Channel Spacing Dialog Box

5. Place the cursor on the “Channel Spacing” of the first row.
6. Press **F1 Edit Item** to display the **Channel Spacing** dialog box in the active function frame.

Settable range	1 Hz to 999.999999 MHz
Resolution	1 Hz
Default	16 kHz
7. Use the numeric keypad to enter “5” in the **Channel Spacing** dialog box.
8. Press the unit **F2 MHz** on the function menu to set a frequency interval and close the **Channel Spacing** dialog box.

## 4.5.2 Adding channel groups: Insert Row

**Frequency** or **Top**>**Frequency**, >**Channel Settings**>**Edit Table**>**Insert Row**  
 Adds a row to create a channel group.

Use the following procedure to add a row using **F2 Insert Row**.

- When editing by creating a new setting, a row is added to the top of the Channel Group selected by the cursor on the Channel Table.
- When editing by reading an existing Channel Table using **F7 Open**, a row is added to the final row irrespective of the cursor position.

The procedure for inserting a row in the channel table is as follows:

Operation Example: To read existing Channel Table and insert new row

1. After loading the existing channel table by pressing **F7 Open**, press **F2 Insert Row** to insert a new row on the 6th row which is the last row.

The figure shows two screenshots of a 'Channel Table' interface. The top screenshot shows a table with 5 rows. The second row, 'Group02', is selected. A large black arrow points down to the second screenshot, which shows the same table but with a new row, 'Group', added at the bottom (row 6). The 'Group' row has values: Start: 0, End: 0, Start Frequency: 1.0000000000 GHz, Channel Spacing: 16.00000 kHz.


	Group Name	Start	End	Start Frequency	Channel Spacing
1	Group01	1	10	800.00000000 MHz	10.00000 kHz
▶ 2	Group02	11	20	810.00000000 MHz	10.00000 kHz
3	Group03	21	30	820.00000000 MHz	10.00000 kHz
4	Group04	31	40	830.00000000 MHz	10.00000 kHz
5	802.11 b	1	13	2.4120000000 GHz	5.00000000 MHz

	Group Name	Start	End	Start Frequency	Channel Spacing
1	Group01	1	10	800.00000000 MHz	10.00000 kHz
2	Group02	11	20	810.00000000 MHz	10.00000 kHz
3	Group03	21	30	820.00000000 MHz	10.00000 kHz
4	Group04	31	40	830.00000000 MHz	10.00000 kHz
5	802.11 b	1	13	2.4120000000 GHz	5.00000000 MHz
▶ 6	Group	0	0	1.0000000000 GHz	16.00000 kHz

Figure 4.5.2-1 Inserted New Row

### 4.5.3 Deleting channel groups: Delete Row

 or **Top>Frequency, >Channel Settings>Edit Table>Delete Row**  
 Deletes the selected channel group.

Use the cursor to select a group to delete, and press **F3 Delete Row** to delete it.

**Remote command**

**Delete a channel group**

**Command**

`[ :SOURce [1] | 2 ] :FREQuency:CHANnels:DELeTe <integer>`

**Parameter**

<integer>                      No.  
 Setting range                  1 to 19


**Programming Example**

To delete the 2nd channel group.

`FREQ:CHAN:DEL 2`

**Setting method**

Example: To delete the “Group” channel group on the 2nd row of the channel group

1. Press  once and place the cursor on the “Group” of the 2nd row.
2. Press **F3 Delete Row** to delete a channel group on the 2nd row.

The existing channel groups move up and are placed on the 2nd row or later.




Figure 4.5.3-1 Deleted Channel Group



#### 4.5.4 Deleting channel tables: Clear

**Frequency** or **Top>Frequency, >Channel Settings>Edit Table>Clear**

Press **F4 Clear** to delete all data in the channel table.

##### Remote command

**Delete a channel table**

##### Command

```
[ :SOURce [ 1 ] | 2 ] :FREQuency:CHANnels:DELeTe:ALL
```

##### Programming Example

To delete all data of the channel table.

```
FREQ:CHAN:DEL:ALL
```

##### Setting method

**Press F4 Clear to delete all data in the channel table.**


Channel Table					
	Group Name	Start	End	Start Frequency	Channel Spacing
1	Group01	1	10	800.00000000 MHz	10.00000 kHz
2	Group02	11	20	810.00000000 MHz	10.00000 kHz
3	Group03	21	30	820.00000000 MHz	10.00000 kHz
4	Group04	31	40	830.00000000 MHz	10.00000 kHz

Channel Table					
	Group Name	Start	End	Start Frequency	Channel Spacing

Figure 4.5.4-1 Deleted Channel Table

### 4.5.5 Recalling channel tables: Open

 or **Top >Frequency, >Channel Settings>Edit Table>Open**  
 Recalls the saved channel table file.

**Remote command**

**Recalls a channel table file**

**Command**

:MMEMory[1] | 2:LOAD:FREQuency:CHANnels <string>[, <device>]

**Parameter**

<string> File name without an extension  
 Character string within 100 characters enclosed by double quotes ( " ") or single quotes ( ' ') (excluding extension)  
 <device> Drive number  
 Options A to Z, currently selected drive when omitted

**Programming Example**

To recall the "ABC" channel table file from D drive.  
 MMEM:LOAD:FREQ:CHAN "ABC",D

**Setting method**

**The procedure is as follows:**

1. Press **F7 Open** to open the Channel Table Recall function menu.



**Table 4.5.5-1 Channel Table Recall Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Specifies the Drive containing the channel table to recall.
	F7	Open	Recalls the channel table file in the folder specified in Drive.
	F8	Cancel	Returns to the previous menu.

2. Press **F1 Drive** to select a drive containing the channel table file to recall.
3. The **Channel Table Recall** dialog box is displayed in the active function frame, and File List is displayed in the function display frame.



Figure 4.5.5-1 Channel Table Recall Dialog Box

4. Use the rotary knob or arrow keys   to select a channel table file to recall.
5. Press **F7 Open** to recall the selected channel table file. Press **F8 Chancel** to return to the previous screen without recall the channel table file.

**Note:**

File names are listed in alphanumeric order.

If no channel table file exists, "File not found" is displayed.

## 4.5.6 Saving channel tables: Save

 or **Top>Frequency, >Channel Settings>Edit Table>Save**

Saves a channel table containing the specified parameters.

### Remote command

#### Save a channel table

##### Command

```
:MMEMory[1] | 2:STORe:FREQuency:CHANnels  
[<string>[, <device>]]
```

##### Parameter

<string>

File name without an extension

Character string within 100 characters enclosed by double quotes (" ") or single quotes (' ') (excluding extension)

The following characters cannot be used:

\ / : \* ? " ' < > |

Automatically named as

"Channel\_[Date]\_[Additional number].ch" when omitted.

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

<device>

Drive number

Options

A to Z, currently selected drive when omitted

##### Details

A space or dot "." at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

A destination path to save the file will be the following directory in the specified drive.

Anritsu\MG3710A\User Data\ChannelTable\

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

##### Programming Example

To save the "ABC" channel table file in D drive.

```
MMEM2:STOR:FREQ:CHAN "ABC", D
```

### Setting method

**The procedure for saving a channel table is as follows:**


Example: To name the channel table file currently displayed as "W-LAN" and save it

1. Press **F8 Save** to open the Save function menu.

**Table 4.5.6-1 Channel Table Save Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Specifies a Drive where the channel table is saved.
	F4	Change Focus	Moves the cursor between dialog box and file list.
	F7	Save	Saves the channel table in the folder specified in Drive.
	F8	Cancel	Returns to the previous menu.

2. The **Channel Table Save** dialog box is displayed in the active function frame.
3. Press **F1 Drive** to select a destination drive. File List of the selected drive is displayed in the function display frame.



**Figure 4.5.6-1 Channel Table Save Dialog Box**

4. Enter a file name in the **Channel Table Save** dialog box. By default, the “Channel\_Date\_Additional number” is displayed in the text box.
5. Enter "W-LAN" in the dialog box and press **F7 Save**. The channel table file with the entered file name is saved, and the **Channel Table Save** dialog box closes.

**Note:**

When you input a file name, an extension is automatically added. You cannot specify an extension.

The maximum 100 characters are allowed for a file name.

Destination path:

Anritsu\MG3710A\User Data\ChannelTable\

Default destination name:

Channel\_[Date]\_[Additional number].ch

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

Characters available for file names are displayed on the character palette.

The following characters cannot be used:

\ / : \* ? " ' < > |

A space or dot “.” at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

## 4.6 Frequency-Related Functions

When you press **Frequency** of the main function key or **F1 Frequency** on the main function menu, the MG3710A/MG3740A becomes the frequency setting mode. This section assumes that you press **Frequency** and the MG3710A/MG3740A is in the Frequency Setting mode, unless otherwise specified.

### 4.6.1 Frequency synchronization: Freq Sync

 or **Top>Frequency, >Freq Sync**

Sets the frequency synchronization of SG1 and SG2.

When you change the SG-side frequency specified for SG Port, the changed value is added to (Parallel) or decreased from (Symmetry) the other SG-side frequency.

Press **F8 Freq Sync** to display the Freq Sync function menu. Set the frequency synchronization of SG1 and SG2 and adjust frequencies.

This is available when the MG3710A/MG3740A-062/064/066/162/164/166 is installed.

**Table 4.6.1-1 Freq Sync Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Freq Sync with SG <u>Off</u> On	Sets the frequency synchronization of SG1 and SG2. Synchronization cannot be enabled by a change such as the frequency offset.
	F2	Freq Sync Mode <u>Parallel</u> Symmetry	Sets a frequency synchronization mode when Freq Sync is On.

### Frequency synchronization On/Off: Freq Sync

 or **Top>Frequency, >Freq Sync>Freq Sync with SG**

Enables/disables the frequency synchronization of SG1 and SG2.

Press **F1 Freq Sync** on the Freq Sync function menu to set the frequency synchronization of SG1 and SG2.

Off	Does not synchronize frequencies (Default).
On	Synchronizes frequencies.

#### Remote command

#### Enable/disable the frequency synchronization of SG1 and SG2

##### Command

`[ :SOURce ] :FREQuency:SYNC <boolean>`

##### Query

`[ :SOURce ] :FREQuency:SYNC?`

##### Response

`<boolean>`                      0 or 1

##### Parameter

<code>&lt;boolean&gt;</code>	Frequency synchronization
<code>OFF   0</code>	Does not synchronize frequencies (Default)
<code>ON   1</code>	Synchronizes frequencies

##### Details

This is available when the MG3710A/MG3740A-062/064/066/162/164/166 is installed.

##### Programming Example

To synchronize frequencies of SG1 and SG2.


```
FREQ:SYNC ON
```

```
FREQ:SYNC?
```

```
> 1
```



## Frequency synchronization: Freq Sync Mode

 or **Top>Frequency, >Freq Sync>Freq Sync Mode**

Sets a frequency synchronization mode when Freq Sync with SG is On.  
Press **F2 Freq Sync Mode** on the Freq Sync function menu to set values.

Parallel	Parallel mode (Default) When you change the SG-side frequency specified for SG Port, the changed value is added to the other SG-side frequency.
Symmetry	Symmetry mode When you change the SG-side frequency specified for SG Port, the changed value is decreased from the other SG-side frequency.

**Example:**

Parallel	When you add 100 MHz to the frequency of SG1 Port, 100 MHz is also added to the SG2 Port frequency.
Symmetry	When you add 100 MHz to the frequency of SG1 Port, 100 MHz is decreased from the SG2 Port frequency.

**Remote command****Set a frequency synchronization mode****Command**

```
[ :SOURCE ] : FREQUENCY : SYNC : MODE PARALLEL | SYMMETRY
```

**Query**

```
[ :SOURCE ] : FREQUENCY : SYNC : MODE ?
```

**Response**

```
<mode> 1 or 0
```

**Parameter**

<mode>	Frequency synchronization
PARALLEL	Parallel mode (Default)
SYMMETRY	Symmetry mode

**Details**

This is available when the MG3710A/MG3740A-062/064/066/162/164/166 is installed.

**Programming Example**

To set the frequency synchronization mode to Parallel.

```
FREQ:SYNC:MODE PAR
```

```
FREQ:SYNC:MODE?
```

```
> PAR
```

## 4.6.2 Phase noise optimization: Phase Noise Optimize

**Frequency** or **Top>Frequency, >** **Phase Noise Opt.**

Switching a loop character of PLL synthesizer circuit allows you to select a character of phase noise between Close-in Phase and Wide-Offset Phase.

Press **→** to switch the function menu to page 2.

Press **F1 Phase Noise Opt.** to select a character of phase noise.

Offset < 200 kHz	Best Close-in Phase noise (Default) Optimizes the Close-in Phase noise (Offset < 200 kHz).
Offset > 300 kHz	Best Wide-Offset Phase noise Optimizes the Wide-Offset Phase noise (Offset > 300 kHz).

### Remote command

#### Select a character of phase noise

##### Command

```
[ :SOURCE[1] | 2 ] :FREQUENCY:SYNTHESIS [ :STATE ] 1 | 2
```

##### Query

```
[ :SOURCE[1] | 2 ] :FREQUENCY:SYNTHESIS [ :STATE ] ?
```

##### Response

```
<mode>
```

##### Parameter

<mode>	Character of phase noise
1	Optimized Close-in Phase noise (Default)
2	Optimized Wide-Offset Phase noise

#### Programming Example

To set the phase noise character of SG2 to Best Wide-Offset Phase noise.

```
SOUR2:FREQ:SYNT 2
SOUR2:FREQ:SYNT?
> 2
```

### 4.6.3 Spectrum reverse: RF Spectrum

**Frequency** or **Top>Frequency, >** **RF Spectrum**

You can use the spectrum reverse function when reversed modulation signals must be input, for example evaluating DUT for IF.

In MG3740A, you can use the spectrum reverse function only when option-020/120 is installed.

When the modulation is on, this function swaps I and Q and inverts the spectrum of RF signals. For both the waveform memory A and B, the spectrum is inverted.

Similar to this, **F6 Spectrum A** and **F7 Spectrum B** of the ARB Setup function menu on page 2 invert the spectrum of the waveform memory A and the waveform memory B, respectively. Reversing RF Spectrum and Spectrum A or B simultaneously returns the status of output waveform to Normal.

Press **→** to switch the function menu to page 2.

Press **F2 RF Spectrum** to select spectrum of RF signals.

Normal	Does not invert the spectrum of output waveform. (Default)
Reverse	Inverts the spectrum of output waveform.

#### Remote command

#### Enable/disable the spectrum reverse

##### Command

```
[ :SOURce[1] | 2 ] :DM:POLarity[:ALL] NORMal | INVert
```

##### Query

```
[ :SOURce[1] | 2 ] :DM:POLarity[:ALL] ?
```

##### Response

```
<mode>
```

##### Parameter

<mode>	Whether to invert output waveform
NORMal	Normal: Do not invert (Default)
INVert	Reverse: Invert

#### Programming Example

To invert the output waveform of SG1.

```
DM:POL INV
```

```
DM:POL?
```

```
> INV
```




Figure 4.6.3-1 RF Spectrum: Two Waves Not Added





Figure 4.6.3-2 RF Spectrum: Two Waves Added

## 4.6.4 Reference oscillator

Reference oscillator: Ref Source

 or **Top>Frequency, >**  **Ref Source**

Sets reference frequency source.

Press  to switch the function menu to page 2.

Press **F3 Ref Source** to select a reference frequency source between Int and Auto. The “EXTREF” is displayed in the frequency indicator when the external signal is used as the reference frequency source.

Int	Uses the internal frequency source of the MG3710A/MG3740A as the reference frequency source.
Auto	Uses the internal frequency source of the MG3710A/MG3740A as the reference frequency source, when a reference signal is not detected from the REF IN connector on the rear panel. Uses an external frequency source as the reference frequency source, when a reference signal is detected from the REF IN connector on the rear panel. (Default)

### Remote command

#### Set a reference frequency source

##### Command

```
[ :SOURce ] :ROScillator :SOURce :AUTO <boolean>
```

##### Query

```
[ :SOURce ] :ROScillator :SOURce :AUTO?
```

##### Response

```
<boolean> 0 or 1
```

##### Parameter

```
<boolean> Frequency reference signal source
OFF | 0 Sets a source to Int.
ON | 1 Sets a source to Auto (Default).
```

#### Programming Example

To invert the output waveform.


```
ROSC : SOUR : AUTO OFF
ROSC : SOUR : AUTO?
> 0
```

External signal frequency: Ref Freq

 or **Top>Frequency, >**  **Ref Freq**

Set a frequency of external reference signal for the MG3710A/MG3740A.

When an external signal is used for a reference signal source, the frequency of the external signal must be set for the MG3710A/MG3740A.

Press  to switch the function menu to page 2.

Press **F4 Ref Freq** to display the Ref Oscillator Freq function menu and select a frequency of the signal from 5 MHz, 10 MHz (default), and 13 MHz.

**Remote command**

**Set a frequency of the external reference signal**

**Command**

`[ :SOURCE ] :ROSCillator:FREQuency:EXTernal <freq>`

**Query**

`[ :SOURCE ] :ROSCillator:FREQuency:EXTernal?`

**Response**

`<freq>` Unit: Hz

**Parameter**

<code>&lt;freq&gt;</code>	Frequency of the external signal
Setting range	Either value of 5 MHz, 10 MHz (Default), or 13 MHz
Suffix code	HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ
	When omitted: HZ

**Programming Example**

To set the frequency of the reference frequency signal to 13 MHz.

```
ROSC:FREQ:EXT 13MHZ
ROSC:FREQ:EXT?
> 13000000
```

## 4.6.5 Local signal source

Local signal source: LO Source


 or **Top>Frequency, >**  **LO Source**

Sets a Local signal source.

This is available when the MG3710A-017/117 is installed.

This is not available in MG3740A.

This is an independent parameter for each SG. It can be set when in the modulation output status (when either AM, FM,  $\phi$ M, or Pulse modulation is On, or when the selected waveform setting is Mod=On).

Press  to switch the function menu to page 2.

Press **F5 LO Source** to select a signal source.

**Int** Uses the internal Local signal source (Default).

**Ext/Sync** SG1:Ext

Uses the external Local signal source.

SG2:Sync

Uses the same local signal source of SG1.

### Remote command

#### Set a Local signal source

##### Command

SG1: [:SOURCE[1]]:LOCAL:SOURCE INT|EXT

SG2: [:SOURCE2]:LOCAL:SOURCE INT|SYNC

##### Query

SG1: [:SOURCE[1]]:LOCAL:SOURCE?

SG2: [:SOURCE2]:LOCAL:SOURCE?

##### Response

<mode>

##### Parameter

<mode>

Local signal source

INT

Uses the internal Local signal source (Default).

EXT

Uses the external Local signal source.

This is available only for SG1.

SYNC

Uses the Local of SG1. This is available only for SG2.

##### Details

This is available when the MG3710A-017/117 is installed.

**Programming Example**

To set a Local signal source to the external Local signal source.

```
LOC:SOUR EXT
LOC:SOUR?
> EXT
```

Local signal output: LO Out

 or **Top>Frequency**, >  **LO Out**

Selects the external output of Local signal between On and Off.


This is available when the 017/117 is installed.

This is not available in MG3740A.

This is a shared parameter for each SG. It can be set when the installed SG1 and SG2 are in the modulation status (when either AM, FM,  $\phi$ M, or Pulse modulation is On, or when the selected waveform setting is Mod=On).

**Note:**

When the MG3710A/MG3740A output signal EVM is to be measured, set LO Out to Off. If LO Out is set to On while the LO Out connector is opened, the MG3710A/MG3740A output signal EVM is degraded because of reflection.

Press  to switch the function menu to page 2.

Press **F6 LO Out** to select the external output between On and Off.

Off Does not externally output Local signals (Default).

On Externally outputs Local signals.

**Remote command**

**Select the external output of Local signal between On and Off**

**Command**

```
[ :SOURce ] :LOCAl :OUT <boolean>
```

**Query**

```
[ :SOURce ] :LOCAl :OUT?
```

**Response**

```
<boolean> 0 or 1
```



**Parameter**

<boolean>	Local signal source
OFF   0	Does not externally output Local signals (Default).
ON   1	Externally outputs Local signals.

**Details**

This is available when the MG3710A-017/117 is installed.

**Programming Example**

To externally output Local signals.


```
LOC:OUT ON
LOC:OUT?
> 1
```

Local phase adjustment: LO Phase

 or **Top>Frequency, >**  **>LO Phase**

Adjusts phases of Local signals.

This is not available in MG3740A.

Press  to switch the function menu to page 2.

Press **F7 LO Phase** to display the **LO Phase** dialog box and set a phase.



**Figure 4.6.5-1 LO Phase Dialog Box**

Set a phase of RF output.

Setting range	-180.00 deg to 180.00 deg.
Resolution	0.01
Default	0

If the Local synchronization of the Baseband function is changed to On:  
 A phase cannot be set when the Local signal source of SG1 is External.  
 A phase cannot be set when the Local signal source of SG2 is Sync.

**Remote command**

**Adjust a phase of Local signals**

**Command**

`[ :SOURce[1] | 2 ] :PHASe[ :ADJust ] <phase>`

**Query**

`[ :SOURce[1] | 2 ] :PHASe[ :ADJust ] ?`

**Response**

`<phase>`

**Parameter**

<code>&lt;phase&gt;</code>	Phase of Local signals
Setting range	-180.00 deg to 180.00 deg
Resolution	0.01
Default	0

**Programming Example**



To set a phase of the Local signal to 4.25 deg.

`PHAS 4.25`


`PHAS?`

`> 4.25`

### 4.6.6 Ref Clock Adjustment

 or **Top>Frequency, >>Ref Clock Adjustment**

Used for frequency calibration. For the calibration method, refer to 11.4 “Calibration”.

Press  to switch the function menu to page 2.

Press **F8 Ref Clock Adjustment** to display the Freq Adjustment function menu and adjust frequencies of the internal reference frequency signals.

**Table 4.6.6-1 Freq Adjustment Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Reference Clock 0	Adjusts the frequency of the internal reference frequency signal.
	F2	Preset Reference Clock	Resets the internal reference frequency signal to factory shipment defaults.

Reference clock frequency: Reference Clock

 or **Top>Frequency, >>Ref Clock Adjustment>Reference Clock**

Adjusts the internal reference frequency signals.

Press **F1 Reference Clock** on the Freq Adjustment function menu to display the **Reference Clock** dialog box. Adjust the internal reference frequency signals.

Setting range            0 to 1023  
 Resolution              1  
 Default                    Factory shipment defaults



**Figure 4.6.6-1 Reference Clock Dialog Box**

**Remote command**

**Set the adjustment value of the internal reference frequency signals**

**Command**

:CALibration:RCLock[:VALue] <integer>

**Query**

:CALibration:RCLock[:VALue]?

**Response**

<integer>

**Parameter**

<integer>	Adjustment value
Setting range	0 to 1023
Resolution	1
Default	Factory shipment defaults

**Programming Example**

To set the adjustment value of the internal reference frequency signal to 511.

```
CAL:RCL 511
```

```
CAL:RCL?
```

```
> 511
```

**Preset reference clock: Preset Reference Clock**

 or **Top>Frequency, >**  **>Ref Clock Adjustment>Preset Reference Clock**

Resets adjustments of the internal reference frequency signal to factory shipment defaults.

Press **F2 Preset Reference Clock** on the Freq Adjustment function menu to reset values.

**Remote command**

**Reset adjustment values of the internal reference frequency signal to factory shipment defaults**

**Command**

:CALibration:RCLock[:VALue]:PRESet

**Programming Example**

To reset adjustment values of the internal reference frequency signal to factory shipment defaults.

```
CAL:RCL:PRES
```

# Chapter 5 Output Level

---

This chapter describes the functions related to the level setting.

Note on remote command:

When the language mode is SCPI, the target SG can be selected with the beginning node of commands for controlling individual functions. Refer to Appendix E.7.6 “Selecting SG1/2” for details.

5.1	Output Level.....	5-2
5.1.1	Display description .....	5-3
5.1.2	Level indicator .....	5-5
5.2	Output Level Setting Method: Level .....	5-7
5.2.1	Output level setting with numeric keypad.....	5-9
5.2.2	Changing output level with rotary knob .....	5-10
5.2.3	Changing output level with arrow keys.....	5-11
5.2.4	Output level setting resolution .....	5-12
5.3	Output Level Setting Item .....	5-14
5.3.1	Relative level display: Reference .....	5-16
5.3.2	Level offset: Offset.....	5-19
5.3.3	Output level limit .....	5-22
5.3.4	ATT Hold .....	5-25
5.3.5	Level synchronization: Sync.....	5-27
5.3.6	Calibrate Level.....	5-28
5.3.7	Optimize S/N .....	5-29
5.4	User Correction: Correction .....	5-30
5.4.1	User correction setting: Configure Correction .....	5-32
5.4.2	Edit Item .....	5-34
5.4.3	Adding correction data: Insert Row .....	5-37
5.4.4	Deleting correction data: Delete Row.....	5-38
5.4.5	Deleting correction table: Clear .....	5-39
5.4.6	Recalling user correction table: Open .....	5-40
5.4.7	Saving user correction table: Save.....	5-42
5.5	Use Power Sensor .....	5-45
5.5.1	Connection Settings .....	5-46
5.5.2	Settings.....	5-49
5.5.3	Zero adjustment: Zero Sensor.....	5-57
5.5.4	Creating correction table: Create Correction File.....	5-58

## 5.1 Output Level

 or **Top>Level**

When you press **Level** of the main function key or **F2 Level** on the top function menu, the MG3710A/MG3740A enters the output level setting mode and the **Level** dialog box is displayed in the active function frame.

This section assumes that you press **Level** and the MG3710A/MG3740A is in the output level setting mode, unless otherwise specified.

### Output level setting range and resolution

The output level setting range varies depending on the options as follows:

**Table 5.1-1 Output Level Setting Range**

MG3710A/MG3740A-options				Setting range
SG1		SG2		
<b>043/143 not installed</b>		<b>073/173 not installed</b>		<b>Setting range</b>
<b>042/142</b>	<b>041/141</b>	<b>072/172</b>	<b>071/171</b>	
Not installed	Not installed	Not installed	Not installed	-110 dBm to +17 dBm
Installed	Not installed	Installed	Not installed	-144 dBm to +17 dBm
Not installed	Installed	Not installed	Installed	-110 dBm to +30 dBm
Installed	Installed	Installed	Installed	-144 dBm to +30 dBm
<b>043/143 installed</b>		<b>073/173 installed</b>		<b>Setting range</b>
<b>042/142</b>	<b>041/141</b>	<b>072/172</b>	<b>071/171</b>	
Not installed	Not installed	Not installed	Not installed	-110 dBm to +17 dBm
Installed	Not installed	Installed	Not installed	-144 dBm to +17 dBm
Not installed	Installed	Not installed	Installed	-110 dBm to +25 dBm
Installed	Installed	Installed	Installed	-144 dBm to +25 dBm

Output level resolution 0.01 dB

An output level out of the range cannot be set, and the error screen is displayed.

Output level setting methods are as follows:

- Output level setting with the numeric keypad
- Output level setting with the rotary knob
- Output level setting with the step keys

The setting methods are explained in the following pages.

### 5.1.1 Display description

**Level** or **Top>Level**

This section describes screens of the level information frame.




Figure 5.1.1-1 Output Level Setting Screen

Table 5.1.1-1 Output Level Setting Screen Display Item

Display	Description
Displayed output level	Indicates the output level setting value. A value is changed by enabling/disabling Ref (relative level display) or Offset.
RF output level	Indicates the actually output level.
Level indicator	Indicates the current status/warning of output level setting.
Output status display	Mod Green light indicates the output is a modulated signal. RF Orange light indicates the signal is being output.

#### Remote command

#### Query the RF output level

##### Query

[ :SOURce[1] | 2 ] :POWer:CURRent?

##### Response

<amp;l> Unit: dBm

##### Parameter

<amp;l> Current output level  
 Range Depends on the range set in Table 5.1-1 “Output Level Setting Range”.  
 Resolution 0.01 dB  
 Default Depends on the range set in Table 5.1-1 “Output Level Setting Range”.

**Example of Use**

To query the actual output level.

```
POW:CURR?
```

```
> 10.00
```



## 5.1.2 Level indicator

Shows the display items of the level indicator.

**Table 5.1.2-1 Level Indicator**

Display	Name	Description
<b>OFFS</b>	Level Offset	Indicates the level offset function is On.
<b>REF</b>	Reference	Indicates the relative level display function is On.
<b>ATTHLD</b>	Attenuator Hold	Indicates the ATT Hold function is On.
<b>UNLVL</b>	Unleveled	Indicates the level is out of the guaranteed range.*1
<b>ORNG</b>	Out of Range	Indicates the level is out of the setting range.
<b>LMT</b>	Limit	Indicates the Limit Level function is On.
<b>OSYNC</b>	Out of Sync	Indicates that levels of SG1 and SG2 cannot be synchronized due to out of the specified range.

\*1: No display of “UNLVL” does not guarantee that the level is within the specification.

Remote commands for items in the level indicator frame are as follows:

### Remote command

#### Query the status of UNLEVEL

##### Query

```
[ :SOURce[ 1 ] | 2 ] :POWer:UNLeveled:ERRor?
```

##### Response

```
<status>
```

##### Parameter

```
<status>           Measurement status
OOL                Out of Level: The output level is out of the
                   guaranteed range.
NORM               Normal: Not unlevel
```

##### Example of Use

To query the current operation status.

```
POW:UNL:ERR?
```

```
> NORM
```

**Remote command**

**Query the status of OSYNC**

**Query**

[ :SOURce[1] | 2 ] :POWer:SYNC:ERRor?

**Response**

<status>

**Parameter**

<status>

Measurement status

OOS

Out of Sync: The level synchronization has been disabled.

NORM

Normal: The level synchronization is enabled or the synchronization setting is Off.

**Example of Use**

To query the current operation status.

POW:SYNC:ERR?

> NORM

**Remote command**

**Query the status of ORNG**

**Query**

[ :SOURce[1] | 2 ] :POWer:RANGe:ERRor?

**Response**

<status>

**Parameter**

<status>

Measurement status

OOR

Out of Range: The level is out of the setting range.

NORM

Normal: The level is within the setting range.

**Example of Use**

To query the current operation status.

POW:RANG:ERR?

> NORM

## 5.2 Output Level Setting Method: Level

 or **Top>Level**

When you press **Level** of the main function menu or **F2 Level** on the top function menu, the **Level** dialog box is displayed in the active function frame. Enter numbers in the **Level** dialog box to set levels.

### Remote command

#### Set the display level

##### Command

```
[ :SOURce[1] | 2 ] :POWer [ :LEVel ] [ :IMMediate ] [ :AMPLitude ]
<ampl>
```

##### Query

```
[ :SOURce[1] | 2 ] :POWer [ :LEVel ] [ :IMMediate ] [ :AMPLitude ] ?
```

##### Response

```
<ampl> Unit: dBm
```

##### Parameter

<ampl>	Output level
Range	Output level setting range of MG3710A/MG3740A
Resolution	0.01 dB
Default	Minimum output level of MG3710A/MG3740A
Suffix code	DBM, DM, DBUV, DBUVE DBM when omitted

#### Example of Use

To set the SG2 output level to -30.00 dBm.

```
SOUR2:POW -30.00
SOUR2:POW?
> -30.00
```

### Remote command

#### Set the output level unit

##### Command

```
:UNIT[1] | 2 :POWer <unit>
```

##### Query

```
:UNIT[1] | 2 :POWer?
```

##### Response

```
<unit>
```

**Parameter**

<unit>	Output level unit
DBM	dBm (Default)
DBUV	dB $\mu$ V (Termination voltage display)
DBUVEMF	dB $\mu$ Vemf (Open voltage display)

**Details**

Only the unit changes.

**Example of Use**

To set the level setting unit to dB $\mu$ Vemf (open voltage display).

```
UNIT:POW DBUVEMF
UNIT:POW?
> DBUVEMF
```

**Remote command**

**Set the displayed output level with the relative level when the relative level display is On**

**Command**

```
[ :SOURce[1] | 2 ] :POWer:REFerence:AMPLitude <rel_ampl>
```

**Query**

```
[ :SOURce[1] | 2 ] :POWer:REFerence:AMPLitude?
```

**Response**

```
<rel_ampl> Unit: dB
```

**Parameter**

<rel_ampl>	Relative output level
Range	Output level setting range of MG3710A/MG3740A
Resolution	0.01 dB
Default	Minimum output level of MG3710A/MG3740A

**Example of Use**

To set the relative output to +10.00 dB.

```
POW:REF:AMPL 10.00DB
POW:REF:AMPL?
> 10.00
```

### 5.2.1 Output level setting with numeric keypad

Enter numbers in the **Level** dialog box.

**Setting method**

The procedure for setting output levels with the numeric keypad is as follows.

Example: To set the output level to -47 dBm.

1. Press “-”, “4”, and “7” using number buttons of the numeric keypad or numbers on the screen. The screen below is displayed.



Figure 5.2.1-1 Level Dialog Box

2. Press the unit **F1 dBm** on the function key to finalize the numbers and the unit. The “-47.00 dBm” is displayed in the **Level** dialog box and in the frequency information frame.





Figure 5.2.1-2 Level Dialog Box

The output level setting allows the setting and display with dBm of the power unit and dB $\mu$ V (termination voltage display)/dB $\mu$ Vemf (open voltage display).

- “-”, “1”, “2”, “.”, “3”, **F2 dB $\mu$ V**                      -12.3 dB $\mu$ V is set.  
(Termination voltage display)
- “-”, “1”, “2”, “.”, “3”, **F3 dB $\mu$ Vemf**                      -12.3 dB $\mu$ Vemf is set.  
(Open voltage display)

The digit less than 0.01 dB is rounded.




## 5.2.2 Changing output level with rotary knob

The rotary knob allows you to increase or decrease a digit of resolution selected by arrow keys  . The cursor shows the position of the digit.

### Setting method

**The procedure for setting the output level with the rotary knob is as follows.**

Example: To change the output level from the current  $-47$  dBm to  $-37$  dBm by 1 dB.

1. Use the arrow keys   to place the cursor on the digit of 1 dB (Press  twice to move it to 1 dB).








Figure 5.2.2-1 Level Dialog Box

2. Rotate the rotary knob to the right to increase the frequency by 1 dB step. Rotate it to the left to decrease the frequency by 1 dB. Using this method, rotate the rotary knob to the right and specify the output level to  $-37$  dBm.

### 5.2.3 Changing output level with arrow keys

Arrow keys   enable you to increase or decrease a digit of resolution selected by arrow keys  . The cursor shows the position of the digit.

Default value of output level step: 0.1 dB

#### Setting method

The procedure for setting output level with the arrow keys is as follows.

Example: To increase/decrease the output level from -47 dBm to -55 dBm by 1 dB step.





1. Set the output level to -47 dBm.
2. Use the arrow keys   to place the cursor on the digit of 1 dB.



Figure 5.2.3-1 Level Dialog Box



3. Use the arrow keys   to increase or decrease the frequency by 1 dB step.

## 5.2.4 Output level setting resolution

 or **Top>Level**, 

Sets a resolution of arrow keys   for setting the output level.

When the MG3710A/MG3740A is in the output level setting mode, press **Incr Set** of the main function key to display the **Increment** dialog box.

Enter numbers in the **Increment** dialog box to specify a resolution of arrow keys  .

### Remote command

#### Set the level setting resolution

##### Command

```
[ :SOURce ] :POWer [ :LEVel ] [ :IMMediate ] :STEP [ :INCRement ]
<rel_ampl>
```

##### Query

```
[ :SOURce ] :POWer [ :LEVel ] [ :IMMediate ] :STEP [ :INCRement ] ?
```

##### Response

```
<rel_ampl> Unit: dB
```

##### Parameter

```
<rel_ampl> Step level
Range 0.01 dB to 100 dB
Resolution 0.01 dB
Default 0.1 dB
```

##### Example of Use

To set the level step to 3 dB.

```
POW:STEP 3.00DB
POW:STEP?
> 3.00
```

### Setting method

#### The procedure for specifying level setting resolution with the arrow keys is as follows:

Example: To change the output level with 0.3 dB of the level setting resolution.



1. Press **Incr Set** while in the Output Level Setting mode to display the **Increment** dialog box in the active function frame.



2. Set 0.3 dB.



Figure 5.2.4-1 Increment Dialog Box

3. Press **F1 dB** to set the level setting resolution and return to the **Level** dialog box.
4. Use the arrow keys   to increase or decrease the frequency by 0.3 dB step.

## 5.3 Output Level Setting Item

 or **Top>Level**

When you press **Level** of the main function key or **F2 Level** in the top function menu, the MG3710A/MG3740A enters the output level setting mode and the **Level** function menu is displayed.

**Table 5.3-1 Level Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Reference <u>Off</u> On	Enables/disables the level relative display. Refer to 5.3.1 "Relative level display: Reference".
	F2	Offset <u>Off</u> On	Enables/disables the level offset value. Refer to 5.3.2 "Level offset: Offset".
	F3	Offset Value 0.00 dB	Sets the level offset value. Refer to 5.3.2 "Level offset: Offset".
	F4	Limit Level <u>Off</u> On	Enables/disables the Limit Level function. Refer to 5.3.3 "Output level limit".
	F5	Limit Value 25.00 dBm	Sets the maximum output level. Refer to 5.3.3 "Output level limit".
	F7	ATT Hold <u>Off</u> On	Sets On/Off of the ATT Hold function. Refer to 5.3.4 "ATT Hold".
	F8	Sync <u>Off</u> On	Function to synchronize the 1st SG with 2nd SG output level settings. It is used when the levels of SG1 and SG2 are to be changed simultaneously. Refer to 5.3.5 "Level synchronization: Sync".
2	F1	Correction <u>Off</u> On	Enables/disables the User Correction function. Function to adjust the RF output level of arbitrary frequency points to correct the external loss or external gain. Refer to 5.4 "User Correction: Correction".
	F2	Configure Correction	Opens the User Correction function menu to set the user correction table. Refer to 5.4.1 "User correction setting: Configure Correction".
	F3	Calibrate Level	Performs the level calibration. Refer to 5.3.6 "Calibrate Level".
	F4	Optimize S/N <u>Off</u> On	Enables/disables the Optimize S/N mode. When it is set to On, CW is output with S/N priority. When it is set to Off, CW is output with distortion characteristic priority. When modulated waves are output, this function has no effect. Refer to 5.3.7 "Optimize S/N".

Table 5.3-1 Level Function Menu (Cont'd)

Page	Key No.	Menu Display	Function
2	F6	Start BER Measurement	Starts the BER measurement. If MeasureStart is executed during measurement, the measurement is stopped once and restarted. It is displayed when the BER measurement function option is installed. Refer to Chapter 8 "BER Measurement".
	F7	Stop BER Measurement	Stops the BER measurement. It is displayed when the BER measurement function option is installed. Refer to Chapter 8 "BER Measurement".
	F8	Clear BER Count	Clears ErrorCount and SyncLossCount (The measurement is continued).It is displayed when the BER measurement function option is installed. Refer to Chapter 8 "BER Measurement".

### 5.3.1 Relative level display: Reference

 or **Top>Level, >Reference**

Enables/disables the relative level display.

The relative level display displays the output level difference from the reference output level.

When you turn the relative level display from Off to On, a difference from 0 dB, which is the reference level of output level, is displayed. Above it, the actual output level is displayed.

RF output level = display level

+ output level when the relative level display is enabled

Press **F1 Reference** to switch the level display.

Off Displays output level in absolute values (Default).

On Display output level in relative values. The “REF” is displayed in the level indicator.

#### Remote command

#### Enable/disable the relative level display

##### Command

[ :SOURce[1] | 2 ] :POWer:REFerence:STATe <boolean>

##### Query

[ :SOURce[1] | 2 ] :POWer:REFerence:STATe?

##### Response

<boolean> 0 or 1

##### Parameter

<boolean> Output level display  
 OFF | 0 Switches to the absolute value display (Default).  
 ON | 1 Switches to the relative display.

#### Example of Use

To switch the output level display to the relative display.

POW:REF:STAT ON

POW:REF:STAT?

> 1

**Remote command**      **Query the reference level (output level when the relative level display is set to ON) for relative level display**

**Query**

[ :SOURce[1] | 2 ] :POWer:REFerence?

**Response**

<ampl>                      Unit: dBm

**Parameter**

<ampl>	Reference level
Range	Output level setting range of MG3710A/MG3740A
Resolution	0.01 dB
Default	Minimum output level of MG3710A/MG3740A

**Example of Use**

To query the reference level for relative output level.

```
POW:REF?
> -5.00
```

**Setting method**

**The relative level setting procedure is as follows.**

Example: To increase by 7.5 dB with -47 dBm as the reference.

1. Set the output level to -47 dBm.
2. Press **F1 Reference** to switch the relative level display to On, and then the relative level display is enabled with -47 dBm of the current output level as the reference. The displayed output level value is changed from “-47.00 dBm” to “+0.00 dB”, and the RF output level (actual output level) is displayed above it. In addition, “REF” is displayed in the level indicator of the screen to indicate the relative level display is enabled.





Figure 5.3.1-1 Relative Level Display

3. Set the relative level to 7.5 dB. At this time the displayed level is also “7.50 dB”, however, the actual level output from SG is  $-47 \text{ dBm} + 7.5 \text{ dB} = -39.5 \text{ dBm}$  as the RF output level.

### 5.3.2 Level offset: Offset

#### Offset

 or **Top>Level, >Offset**

Enables/disables the output level offset.


When the frequency offset is on, the output level offset value specified with **F3 Offset Value** is added to the display output level, and the actual output level is displayed above it.

Press **F2 Offset** to toggle On/Off of the output level offset.

- Off Does not use the output level offset (Default).
- On Uses the output level offset. The “OFFS” is displayed in the level indicator.

When this function is used, the displayed output level is offset with the value specified to LevelOffsetValue. This function is used when the path loss or gain from SG to DUT is corrected.

$$\text{Output level after offset} = \text{RF output level} + \text{offset level}$$



**Table 5.3.2-1 Overview of Offset Level**

The level offset function cannot perform settings that have frequency characteristics. To change the offset level for each frequency, refer to 5.4 “User Correction: Correction”.

#### Remote command

#### Enable/disable the output level offset

##### Command

```
[ :SOURce[1] | 2 ] :POWer[ :LEVel ] [ :IMMediate ] :OFFSet :STATe
<boolean>
```

##### Query

```
[ :SOURce[1] | 2 ] :POWer[ :LEVel ] [ :IMMediate ] :OFFSet :STATe?
```

##### Response

```
<boolean> 0 or 1
```

##### Parameter

<boolean>	Output level offset On/Off
OFF   0	Off (Default)
ON   1	On

**Example of Use**

To set the output level offset to ON.

```
POW:OFFS:STAT ON
POW:OFFS:STAT?
> 1
```

Offset level: Offset Value

 or **Top>Level, >Offset Value**

Sets the output offset level.

Press **F3 Offset Value** to set a offset level in the **Offset Value** dialog box in the active function frame.

Setting range	-100 to +100 dB
Resolution	0.01 dB
Default	0 dB

**Remote command**

**Set the output offset level**

**Command**

```
[ :SOURce[1] | 2 ] :POWer[ :LEVel ] [ :IMMediate ] :OFFSet
<rel_ampl>
```

**Query**

```
[ :SOURce[1] | 2 ] :POWer[ :LEVel ] [ :IMMediate ] :OFFSet?
```

**Response**

```
<rel_ampl> Unit: dB
```

**Parameter**

<rel_ampl>	Output offset level
Setting range	-100 to +100 dB
Resolution	0.01 dB
Default	0.00 dB
Suffix code	DB, handled as DB when omitted.

**Example of Use**

To set the output offset level to -15.00 dB.

```
POW:OFFS -15.00
POW:OFFS?
> -15.00
```




**Setting method**

The output offset level setting procedure is as follows.


Example: To set for the offset level to be  $-1.7$  dB and output level after offset to be  $-47$  dBm.

1. Press **F3 Offset Value** to display the **Offset Value** dialog box in the active function frame.



**Figure 5.3.2-2 Offset Level Setting**

2. Press **-, 1, ., 7,** and **F1 dB** to set the offset level to  $-1.7$  dB.
3. Press **F2 Offset** to set the offset mode to On. The “OFFS” is displayed in the level indicator to indicate the offset setting is enabled.
4. Press **Level** to set the Level setting mode in the active function area, and press **-, 4, 7,** and **F1 dBm** to set the output level to  $-47$  dBm. The “ $-47.00$  dBm” is displayed in the displayed output level. At this time, the actual level output from SG is  $-45.3$  dBm as shown in the RF output level.



**Figure 5.3.2-3 Output Level Confirmation**

### 5.3.3 Output level limit

Output level limit: Limit Level

 or **Top>Level, >Limit Level**

Enables/disables the Limit Level function to limit the output level.

Press **F4 Limit Level** to set the Limit Level function to On/Off.

Selecting “On” displays “LMT” in the level indicator.

Off	Sets the Limit Level function to Off (Default).
On	The output level is limited to the level set with <b>F5 Limit Value</b> . The “LMT” is displayed in the level indicator.

#### Remote command

#### Set the Limit Level function On/Off

##### Command

```
[ :SOURce[1] | 2 ] :POWer:USER:ENABle <boolean>
```

##### Query

```
[ :SOURce[1] | 2 ] :POWer:USER:ENABle?
```

##### Response

```
<boolean> 0 or 1
```

##### Parameter

<boolean>	Limit Level function On/Off
OFF   0	Off (Default)
ON   1	On

#### Example of Use

To set the Limit Level function to ON.

```
POW:USER:ENAB ON
```

```
POW:USER:ENAB?
```

```
> 1
```

## Output limit level: Limit Value

 or **Top>Level, >Limit Value**

Sets the output level limit value (Limit Level).

Press **F5 Limit Value** to set the Limit Level in the **Limit Value** dialog box in the active function frame.

Setting range	RFLevelMin + LevelOffset + UnitCoef to RFLevelMax + LevelOffset + UnitCoef (with the output level display) RFLevelMax: Maximum output level of MG3710A/MG3740A RFLevelMin: Minimum output level of MG3710A/MG3740A LevelOffset: Offset level The UnitCoef value is as follows: When LevelUnit is dBm: UnitCoef = 0 When LevelUnit is dB $\mu$ V (Term): UnitCoef = 106.99 When LevelUnit is dB $\mu$ V (EMF): UnitCoef = 113.01
Resolution	0.01 dB
Default	RFLevelMax + LevelOffset + UnitCoef

## Remote command

**Set the output level limit value (Limit Level)****Command**

[ :SOURce[1] | 2 ] :POWer:USER:MAX <ampl>

**Query**

[ :SOURce[1] | 2 ] :POWer:USER:MAX?

**Response**

<ampl>

**Parameter**

<ampl>	Maximum output level
Setting range	See above.
Resolution	See above.
Default	See above.
Suffix code	DBM, DM, DBUV, DBUVEMF Handled as DBM when omitted.

**Example of Use**

To set the Limit Level to 30 dBm.


```
POW:USER:MAX 30
POW:USER:MAX?
> 30.00
```

**Setting method**

**The Limit Level setting procedure is as follows.**

Example: To set the Limit Level to 10 dBm.

1. Press **F5 Limit Value** to display the **Limit Value** dialog box in the active function frame.



**Figure 5.3.3-1 Output Limit Level**

2. Press **1, 0,** and **F1 dBm** to set the Limit Value to 10 dBm.
3. Press **F4 Limit Level** to set the Limit Level function to On. The “LMT” is displayed in the level indicator to indicate the Limit Level is set.

### 5.3.4 ATT Hold

 or **Top>Level, >ATT Hold**

Enables/disables the ATT Hold function to prevent the signal dropout on ATT switching.

Press **F7 ATT Hold** to set the ATT Hold function to On.

- |     |   |
|-----|---|
| Off | Sets the ATT Hold function to Off(Default).<br>Signal dropouts occur on ATT switching.  |
| On  | Sets the ATT Hold function to On. Signal dropouts do not occur on ATT switching, however, the settable level range is limited to $\pm 10$ dB. The “ATTHLD” is displayed in the level indicator. |

Signal dropouts which occur on ATT switching may generate the following problems.

- Increase in BER
- Damage with spike noise entry to devices
- Level gap by ATT switching within VSG (Even if a change by 0.01 dB is given, the level is not changed by 0.01 dB due to ATT switching errors).

This function fixes ATT and adjust the output level to prevent these problems.

This function is restricted as follows:

- CAL is not executed automatically each time the output level is changed.
- The level adjustable range is  $\pm 10$  dB to the output level when this function is set to On.
- IQ Calibration function (refer to 7.6.1 “IQ Calibration”) is not available.
- This setting is not available in the following case(s).
  - Output level is less than  $-127$  dBm
  - Optimize S/N is On
  - Sweep/List is in use
  - Sequence Mode waveform file is in use

#### Remote command

#### Set the ATT Hold function On/Off

##### Command

```
[ :SOURCE[1] | 2 ] :POWER:ATTenuation:AUTO <boolean>
```

##### Query

```
[ :SOURCE[1] | 2 ] :POWER:ATTenuation:AUTO?
```

##### Response

```
<boolean> 0 or 1
```

**Parameter**

<boolean>	On/Off status of ATT Hold function
OFF   0	Off (Default)
ON   1	On

**Example of Use**


To set the ATT Hold function to ON.

```
POW:ATT:AUTO ON
```

```
POW:ATT:AUTO?
```

```
> 1
```

### 5.3.5 Level synchronization: Sync

 or **Top>Level, >Sync**

Enables/disables the function to synchronize the 1st SG with 2nd SG output level settings. It is used when the levels of SG1 and SG2 are to be changed simultaneously.

This is available when the MG3710A/MG3740A-062/162/064/164/066/166 is installed.

Press **F8 Sync** to set the level synchronization function to On.

The level synchronization function is parallel. When you change the SG-side level specified for SG Port, the changed value is added to the other SG-side level.

Off	Sets the level synchronization function to Off (Default).
On	Sets the level synchronization function to On. The output level settings are synchronized between SG1 and SG2.

#### Remote command

#### Enable/disable the level synchronization function

##### Command

```
[ :SOURCE ] :POWER:SYNC:STATE <boolean>
```

##### Query

```
[ :SOURCE ] :POWER:SYNC:STATE?
```

##### Response

```
<boolean> 0 or 1
```




##### Parameter

<boolean>	On/Off of the level synchronization function
OFF   0	Off (Default)
ON   1	On


#### Example of Use

```
To set the level synchronization function to ON.
POW:SYNC:STAT ON
POW:SYNC:STAT?
> 1
```

### 5.3.6 Calibrate Level

 or **Top>Level, >**  **Calibrate Level,**  
or  **> Calibrate Level**

Calibrates the output level.

Pressing  switches the function menu to the second page, and pressing **F3 Calibrate Level** calibrates the output level.

In the normal operation status, signals with the stable level are always output by the ALC loop circuit.

However, when the modulation is set to On, the ALC loop circuit is held and becomes nonfunctional. If the MG3710A/MG3740A is used with the same setting for a long period, level calibration is recommended to eliminate fluctuations with temperature drift.

In addition, even when the modulation is set to On, if any of the following operations is executed, the level is calibrated automatically.

- Frequency change
- Output level change
- Pattern selection

**Note:**

Execute Calibrate Level while the device to be tested is connected to the RF connector of the MG3710A/MG3740A.

Executing Calibrate Level with the RF connector opened may degrade the level accuracy of output signals because of reflection.

**Remote command**

**Calibrate the output level**

**Command**

[ :SOURce[ 1 ] | 2 ] :POWer:ALC:SEARch [ ONCE ]



**Example of Use**

To calibrate the output level.


POW:ALC:SEAR



### 5.3.7 Optimize S/N

 or **Top>Level, >**  **Optimize S/N**

The function to improve the S/N of CW signals. When it is set to On, CW is output with S/N priority. When it is set to Off, CW is output with distortion characteristic priority. When modulated waves are output, this function has no effect.

Press  to switch the function menu to the second page, and press **F4 Optimize S/N** to set the Optimize S/N function to On.

Off	Distortion characteristic has priority (Default).
On	S/N has priority.

#### Remote command

**Enables/disables the Optimize S/N function**

#### Command

```
[ :SOURCE[ 1 ] | 2 ] :POWER:NOISE[ :STATE ] <boolean>
```

#### Query

```
[ :SOURCE[ 1 ] | 2 ] :POWER:NOISE[ :STATE ] ?
```

#### Response

```
<boolean> 0 or 1
```

#### Parameter

<boolean>	On/Off of the Optimize S/N function
OFF   0	Off (Default)
ON   1	On

#### Example of Use

To set the Optimize S/N function to ON.

```
POW:NOIS ON
```

```
POW:NOIS?
```

```
> 1
```

## 5.4 User Correction: Correction

**Level** or **Top>Level, >** **→** **Correction**

This function is to adjust the RF output level of arbitrary frequency points to correct the external loss or external gain.

Interpolate the correction value linearly with a logarithm. When it becomes the value between resolutions, drop the digits less than the resolution.

For the frequency which is smaller than the minimum frequency of the correction value data, use the correction value data of the minimum frequency.

For the frequency which is higher than the maximum frequency of the correction value data, use the correction value of the maximum frequency.

For correction for the baseband, use the correction value corresponding to the center frequency of the baseband. (Even if multiple correction points exist in the baseband, use the correction value corresponding to 0 Hz of the baseband.)

When this function is used, the output level is offset with the value specified to the correction level and used for correction of path loss or gain from SG to DUT.

Output level after correction = RF output level + correction level





Figure 5.4-1 Overview of User Correction

Press  to switch the function menu to the second page, and press **F1 Correction** to set the user correction function to On.

**Off** Sets the user correction function to Off.  
(Default)

**On** Sets the user correction set with **F2 Configure Correction** to On. The “CORR” is displayed on the common indicator.

**Remote command****Set the user correction to On/Off****Command**

```
[ :SOURce[1] | 2 ] :CORRection[ :STATe ] <boolean>
```

**Query**

```
[ :SOURce[1] | 2 ] :CORRection[ :STATe ] ?
```

**Response**

```
<boolean> 0 or 1
```

**Parameter**

```
<boolean> On/Off of the user correction function  
OFF | 0 Off (Default)  
ON | 1 On
```

**Example of Use**

To set the user correction function to ON.

```
CORR ON
```

```
CORR?
```

```
> 1
```

### 5.4.1 User correction setting: Configure Correction

**Level** or **Top>Level, >** **Configure Correction**

Sets the user correction value.

Press **→** to switch the function menu to the second page, and press **F2 Configure Correction** to display the Correction Table and Correction function menu.

To set the user correction value, you can set the correction value measured in advance to the Correction Table or measure the correction value with the power sensor connected to the MG3710A/MG3740A to create the correction table.

Selecting the item to be set with the cursor on the Table and pressing **F1 Edit Item** displays the dialog box for setting. For the setting method, refer to 5.4.2 “Edit Item”.




Figure 5.4.1-1 Correction Table

Table 5.4.1-1 Correction Function Menu

Page	Key No.	Menu Display	Function
1	F1	Edit Item	Sets the user correction table correction value. Refer to 5.4.2 "Edit Item".
	F2	Insert Row	Adds the correction value to the user correction table. Refer to 5.4.3 "Adding correction data: Insert Row".
	F3	Delete Row	Deletes the correction value in the user correction table. Refer to 5.4.4 "Deleting correction data: Delete Row".
	F4	Clear	Deletes the user correction table expanded in the memory. Refer to 5.4.5 "Deleting correction table: Clear".
	F5	Use Power Sensor	Displays the Use Power Sensor function menu. They are not displayed when the Power Sensor is not connected. Refer to 5.5 "Use Power Sensor".
	F7	Open	Recalls the saved user correction table. Refer to 5.4.6 "Recalling user correction table: Open".
	F8	Save	Saves the user correction table. Refer to 5.4.7 "Saving user correction table: Save".

## 5.4.2 Edit Item

 or **Top>Level, >**  **Configure Correction>Edit Item**

Sets the correction value of the user correction table.

### Remote command

#### Add the correction value to the correction table

##### Command

`[ :SOURCE[1] | 2 ] :CORRection:FLATness:PAIR <freq> , <rel_ampl>`

##### Parameter

<code>&lt;freq&gt;</code>	Frequency
Setting range	Frequency setting range of MG3710A/MG3740A
Resolution	0.01 Hz
Default	1 GHz
Suffix code	HZ, KHZ, MHZ, GHZ, KZ, MZ, GZ Handled as HZ when omitted.

`<rel_ampl>`

Setting range	-100 dB to +100 dB
Resolution	0.01 dB
Default	-999.00 (Undefined) Undefined is displayed when the value has not been set.  -999.00 dB can be assigned as a numeric value but the Undefined row is not used at correction.
Suffix code	Handled as DB when omitted.

##### Example of Use

To add 1 GHz of the frequency and 4 dB of the correction value to the correction table.

`CORR:FLAT:PAIR 1GHZ,4`

## Setting method

The user correction value setting procedure is as follows.

Example: To create a user correction table under the following conditions.

- Frequency: 2.412 GHz
- Correction value: 3 dB

## (1) Setting the frequency




Figure 5.4.2-1 Frequency Setting

1. Align the cursor with row 1 and press **F2 Insert Row** to copy only the frequency and add a new input row under the cursor row. The cursor moves to the new row automatically.
2. Confirm that the cursor is at "Frequency". Press **F1 Edit Item** to display **Frequency** dialog box and **Enter Item** function menu.

Table 5.4.2-1 Enter Item Function Menu

Page	Key No.	Menu Display	Function
1	F1	Enter Item	Edits values and returns to the previous menu.
	F8	Cancel	Returns to the previous menu.

3. Enter “2.412” of frequency to the **Frequency** dialog box.
  4. Press the unit **F1 GHz** on the function menu to set a frequency and close the **Correction Table** dialog box. At this time the order of user correction tables changes in the order of frequencies. In this case, moves to row 6.
- (2) Setting the correction level




Figure 5.4.2-2 Correction Level Setting

1. Place the cursor on the “Correction” of the sixth row.
2. Press **F1 Edit Item** to display **Correction** dialog box and Enter Item function menu.
3. Enter “3” of correction level to the **Correction** dialog box.
4. Press the unit **F1 dB** on the function menu to set a correction level and close the **Correction** dialog box.



### 5.4.3 Adding correction data: Insert Row

**Level** or **Top>Level, >** **→** **Configure Correction>Insert Row**

Inserts a row to add the correction value to the correction table.

Press **F2 Insert Row** at the User Correction function menu to copy only the frequency and add a correction data setting row at the row under the Correction Table cursor row. Also the Correction function menu-related switch is displayed additionally.

The figure illustrates the 'Insert Row' function in a correction table. It shows two states of the table, separated by a large downward-pointing arrow.

**Initial State:**

	Frequency	Correction
1	1.0000000000 GHz	3.00 dB
2	1.1000000000 GHz	3.10 dB
▶ 3	1.2000000000 GHz	3.20 dB
4	1.4000000000 GHz	3.40 dB
5	1.5000000000 GHz	3.50 dB

**Final State:**

	Frequency	Correction
1	1.0000000000 GHz	3.00 dB
2	1.1000000000 GHz	3.10 dB
3	1.2000000000 GHz	3.20 dB
▶ 4	1.2000000000 GHz	Undefined
5	1.4000000000 GHz	3.40 dB
6	1.5000000000 GHz	3.50 dB

Figure 5.4.3-1 Adding Correction Data

### 5.4.4 Deleting correction data: Delete Row

**Level** or **Top>Level, >** **→** **Configure Correction>Delete Row**

One row of the correction value of the correction table expanded in the memory is deleted.

Press **F3 Delete Row** at the User Correction function menu to delete the correction data of the Correction Table cursor row.

The rows below the deleted row will move up to the upper rows in sequence.

The figure illustrates the deletion of a row from a correction table. It shows two states of the table: before and after the deletion of row 4.

Correction		
	Frequency	Correction
1	1.0000000000 GHz	3.00 dB
2	1.1000000000 GHz	3.10 dB
3	1.2000000000 GHz	3.20 dB
▶ 4	1.3000000000 GHz	3.30 dB
5	1.4000000000 GHz	3.40 dB
6	1.5000000000 GHz	3.50 dB

↓

Correction		
	Frequency	Correction
1	1.0000000000 GHz	3.00 dB
2	1.1000000000 GHz	3.10 dB
3	1.2000000000 GHz	3.20 dB
▶ 4	1.4000000000 GHz	3.40 dB
5	1.5000000000 GHz	3.50 dB

Figure 5.4.4-1 Deleting Correction Data

### 5.4.5 Deleting correction table: Clear

**Level** or **Top>Level, >** **Configure Correction>Clear**

Deletes all of the correction table expanded in the memory.

**Remote command**

**Delete all of the correction table**

**Command**

`[ :SOURCE[1] | 2 ] :CORRection:FLATness:PRESet`

**Example of Use**

To delete all of the correction table.

`CORR:FLAT:PRES`

**Setting method**

**Press F4 Clear to delete all data in the correction table.**





Figure 5.4.5-1 Deleting Correction Table

### 5.4.6 Recalling user correction table: Open

 or **Top>Level, >**  **Configure Correction>Open**  
 Recalls the saved user correction table.

**Remote command**

**Recall the user correction table**

**Command**

:MMEMory [1] | 2:LOAD:CORRection:FLATness  
 <string>[, <device>]

**Parameter**

<string> File name without an extension  
 Character string within 100 characters enclosed by double quotes ( " ") or single quotes ( ' ') (excluding extension)  
 <device> Drive number  
 Options A to Z, currently selected drive when omitted

**Example of Use**

To recall the user correction table file with the file name of “ABC” from the D drive.

MMEM:LOAD:CORR:FLAT "ABC",D

**Setting method**

**The recalling procedure is as follows.**

1. Press **F7 Open** to open the Recall function menu.

**Table 5.4.6-1 Correction Recall Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Specifies the Drive containing the user correction table to recall.
	F7	Open	Recalls the user correction table file in the folder specified in Drive and expands it in the memory.
	F8	Cancel	Returns to the previous menu.

2. Press **F1 Drive** to select a drive containing the user correction table file is saved to recall.
3. The **Correction Recall** dialog box is displayed in the active function frame, and File List is displayed in the function display frame.






Figure 5.4.6-1 Correction Recall Dialog Box


4. Use the rotary knob or arrow keys   to select the user correction table file to recall.
5. Press **F7 Open** to recall the selected user correction table file. Press **F8 Cancel** to return to the previous screen without recalling the channel table file.

**Note:**

File names are listed in alphanumeric order.

If no channel table file exists, "File not found" is displayed.

### 5.4.7 Saving user correction table: Save

 or Top>Level, >  >Configure Correction>Save

Saves the user correction table with set parameters.

#### Remote command

#### Save the user correction table

##### Command

```
:MMEMory[1] | 2:STORe:CORRection:FLATness  
[<string>[, <device>]]
```

##### Parameter

<string>

File name without an extension

Character string within 100 characters enclosed by double quotes (" ") or single quotes (' ') (excluding extension)

The following characters cannot be used:

\ / : \* ? " ' \ ' < > |

Automatically named as "Corr[Date]\_[Additional number].csv" when omitted.

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

<device>

Drive number

Options

A to Z, currently selected drive when omitted

##### Details

A space or dot "." at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

A destination path to save the file is the following directory in the specified drive.

Anritsu\MG3710A\User Data\Corrections\

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

##### Example of Use

To save the user correction table file with the file name of "ABC" to the D drive.

```
MMEM:STOR:CORR:FLAT "ABC",D
```

**Setting method**

The user correction table saving procedure is as follows.


Example: To name the user correction table currently displayed as “W-LAN” and save it.

1. Press **F8 Save** to open the Correction Save function menu.

**Table 5.4.7-1 Correction Save Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Specifies a Drive where the user correction table is saved.
	F4	Change Focus	Moves the cursor between dialog box and file list.
	F7	Save	Saves the user correction table in the folder specified with Drive in csv format.
	F8	Cancel	Returns to the previous menu.

2. The **Correction Save** dialog box is displayed in the active function frame.
3. Press **F1 Drive** to select a destination drive. File List of the selected drive is displayed in the function display frame.



**Figure 5.4.7-1 Correction Save Dialog Box**

4. Enter a file name in the **Correction Save** dialog box. By default, the “CorrDate\_Additional number” is displayed in the text box.
5. Enter “W-LAN” in the dialog box and press **F7 Save**. The user correction table file with the entered file name is saved, and the **Correction Save** dialog box closes.

**Note:**

When you input a file name, an extension is automatically added.  
You cannot specify an extension.

The maximum 100 characters are allowed for a file name.

Destination path:

Anritsu\MG3710A\User Data\Corrections\

Default destination name:

Corr[Date]\_[Additional number].csv

The additional number will be the minimum  
three-digit numerical number within 000 to 999  
which does not exist.

Characters available for file names are displayed on the character  
palette.

The following characters cannot be used:

\ / : \* ? " ' < > |

A space or dot “.” at the beginning or the end of a file name causes a  
file name error, and the file cannot be saved.

Up to 1000 files can be saved in a single folder. Saving more than  
1000 files in a folder cause an error, and the file cannot be saved.



## 5.5 Use Power Sensor

 or **Top>Level, >**  **>Configure Correction>Use Power Sensor**

The power sensor to be used for the user correction is set.

Press **F5 Use Power Sensor** in the Correction function menu to open the USB Power Sensor function menu.

**Table 5.5-1 USB Power Sensor Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Connection Setting	Displays the PM Connection function menu. Refer to 5.5.1 "Connection Settings".
	F2	Settings	Displays the Settings function menu. Refer to 5.5.2 "Settings".
	F4	Zero Sensor	Executes the zero level adjustment for the power sensor. Refer to 5.5.3 "Zero adjustment: Zero Sensor".
	F6	Create Correction File	Executes the calibration measurement with the power sensor and creates the correction table file. Refer to 5.5.4 "Creating correction table: Create Correction File".

### 5.5.1 Connection Settings



 or **Top>Level, >**  **Configure Correction>Use Power Sensor>Connection Settings**

Press **F1 Connection Settings** in the Use Power Sensor function menu to open the PM Connection function menu.

**Table 5.5.1-1 PM Connection Function Menu**

Page	Key No.	Menu Display	Function
1	F1	COM Port 2	Sets the COM Port number allocated to the power sensor.
	F2	Model MA24106A	Displays the Model function menu for selection of the model name of the power sensor to be used.
	F3	Open Device Manager	Displays Windows Device Manager. This is used for checking the COM port number of connected power sensor.

#### COM Port setting: COM Port

 or **Top>Level, >**  **Configure Correction>Use Power Sensor>Connection Settings>COM Port**

Sets the COM Port number of the power sensor.

Press **F1 COM Port** to display the **COM Port** dialog box in the active function frame. Enter numbers and press **F1 Enter** to set the COM Port number.

Setting range	2 to 8
Resolution	1
Default	2

#### Remote command

#### Set the COM Port number

##### Command

```
[ :SOURCE[1] | 2 ] :CORRection:PMETer:COMMUnicate:USB:PORT
<ext_integer>
```

##### Query

```
[ :SOURCE[1] | 2 ] :CORRection:PMETer:COMMUnicate:USB:PORT?
```

##### Response

```
<ext_integer>
```

**Parameter**

<ext_integer>	COM Port number
Setting range	2 to 8
Resolution	1
Default	2

**Example of Use**

To set the COM Port number of SG1 power sensor to 8.

```
CORR:PMET:COMM:USB:PORT 8
```

```
CORR:PMET:COMM:USB:PORT?
```

```
> 8
```

Model setting :Model

 or **Top>Level, >**  **>Configure Correction>Use Power Sensor>Connection Settings>Model**

Selects the model name of the power sensor.

Press **F2 Model** to display the Model function menu, and press the function key of the power sensor to be used to set the model.

**Table 5.5.1-2 Model Function Menu**

Page	Key No.	Menu Display	Function
1	F1	MA24104A	600 MHz to 4 GHz
	F2	MA24105A	350 MHz to 4 GHz
	F3	MA24106A	50 MHz to 6 GHz (Default)
	F4	MA24108A	10 MHz to 8 GHz
	F5	MA24118A	10 MHz to 18 GHz
	F6	MA24126A	10 MHz to 26 GHz

**Note:**

The range of frequencies that can be used for user correction are listed in Table 5.5.2-2 Frequency Setting Range.

If Windows Device Manager does not display the available USB power sensor, the older version of PowerXpert software may be the cause.

Download and install the latest PowerXpert software from Anritsu website.

Use PowerXpert Ver. 2.11 or later for MA24105A, use PowerXpert Ver. 2.00 or later for other sensor.

**Remote command**

**Select the model name**

**Command**

```
[ :SOURce[1] | 2 ] :CORRection:PMETer:MODEl  
MA24104A | MA24105A | MA24106A | MA24108A | MA24118A | MA24126A
```

**Query**

```
[ :SOURce[1] | 2 ] :CORRection:PMETer:MODEl?
```

**Response**

```
<model>
```

**Parameter**

```
<model>
```

Power sensor model name

Options

MA24104A, MA24105A, MA24106A (Default),  
MA24108A, MA24118A, MA24126A

**Example of Use**



To select the MA24118A for the power sensor of SG1.

```
CORR:PMET:MOD MA24118A
```

```
CORR:PMET:MOD?
```

```
> MA24118A
```

## 5.5.2 Settings

 or **Top>Level, >**  **Configure Correction>Use Power Sensor>Settings**

Press **F2 Settings** in the Use Power Sensor function menu to open the Settings function menu.

**Table 5.5.2-1 Settings Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Start Freq 1.0000000000 GHz	Specifies the start frequency when the correction table is created with the power sensor.
	F2	Stop Freq 1.0000000000 GHz	Specifies the stop frequency when the correction table is created with the power sensor.
	F3	Level Offset <u>Off</u> On	Sets the level offset adding On/Off for the power sensor reading.
	F4	Level Offset Value 0.00 dB	Sets the offset level value to be added to the power sensor reading.
	F5	Correction Points 2	Sets the measurement point number when the correction table is created with the power sensor.
	F6	Averaging <u>Off</u> On	Sets the averaging On/Off for the measurement values with the power sensor.
	F7	Averaging Count 10	Sets the averaging count for the measurement values with the power sensor.

Start Freq

 or **Top>Level, >**  **Configure Correction>Use Power Sensor>Settings>Start Freq**

Sets the start frequency when the correction table is created with the power sensor.

Press **F1 Start Freq** in the Settings function menu to display the **Start Freq** dialog box in the active function frame. Enter the numbers and press the unit key of the Unit function menu to set the start frequency.

Setting range                      See Table 5.5.2-2 Frequency Setting Range.  
 Resolution                          0.01 Hz  
 Default                                1 GHz

**Table 5.5.2-2 Frequency Setting Range**

Power Sensor	Minimum Value	Maximum Value		
		MG3710A/MG3740A Options		
		032/062/162	034/064/164	036/066/166
MA24104A	600 MHz	2.7 GHz	4 GHz	4 GHz
MA24105A	350 MHz	2.7 GHz	4 GHz	4 GHz
MA24106A	50 MHz	2.7 GHz	4 GHz	6 GHz
MA24108A	10 MHz	2.7 GHz	4 GHz	6 GHz
MA24118A	10 MHz	2.7 GHz	4 GHz	6 GHz
MA24126A	10 MHz	2.7 GHz	4 GHz	6 GHz

**Remote command                      Set the start frequency**

**Command**

[ :SOURCE[1] | 2 ] :CORRection:FLATness:STEP:START <freq>

**Query**

[ :SOURCE[1] | 2 ] :CORRection:FLATness:STEP:START?

**Response**

<freq>                                      In Hz

**Parameter**

<freq>                                      Start frequency  
 Setting range                          Refer to Table 5.5.2-2 Frequency Setting Range.  
 Resolution                                0.01 Hz  
 Default                                    1 GHz  
 Suffix code                                HZ, KHZ, MHZ, GHZ, KZ, MZ, GZ  
     Handled as HZ when omitted.

**Example of Use**


To set the start frequency to 600 MHz.

```
CORR:FLAT:STEP:STAR 600MHZ
```

```
CORR:FLAT:STEP:STAR?
```

```
> 600000000.00
```

## Stop Freq

 or **Top>Level**, >  **Configure Correction>Use Power Sensor>Settings>Stop Freq**

Sets the stop frequency when the correction table is created with the power sensor.

Press **F2 Stop Freq** in the Settings function menu to display the **Stop Freq** dialog box in the active function frame. Enter the numbers and press the unit key of the Unit function menu to set the stop frequency.

Setting range	Refer to Table 5.5.2-2 Frequency Setting Range.
Resolution	0.01 Hz
Default	1 GHz

**Remote command****Set the stop frequency****Command**

```
[ :SOURce[1] | 2 ] :CORRection:FLATness:STEP:STOP <freq>
```

**Query**

```
[ :SOURce[1] | 2 ] :CORRection:FLATness:STEP:STOP?
```

**Response**

```
<freq> Unit: Hz
```

**Parameter**

<freq>	Refer to Table 5.5.2-2 Frequency Setting Range.
Setting range	Frequency range of the power sensor
Resolution	0.01 Hz
Default	1 GHz
Suffix code	HZ, KHZ, MHZ, GHZ, KZ, MZ, GZ Handled as HZ when omitted.

**Example of Use**

To set the stop frequency to 5 GHz.

```
CORR:FLAT:STEP:STOP 5GHZ
```

```
CORR:FLAT:STEP:STOP?
```

```
> 5000000000.00
```

Level Offset

**Level** or **Top>Level, >** **Configure Correction>Use Power Sensor>Settings>Level Offset**

Enables/disables the offset level adding for the power sensor reading.

Press **F3 Level Offset** in the Settings function menu to set the level offset On/Off.

- Off Does not add the offset level (Default).
- On Adds the offset level.

When this function is used, the displayed power sensor value is offset with the value specified to Level Offset Value. It is used when the path loss or gain from SG to DUT is corrected.

Power sensor reading after offset = power sensor reading + offset level




Figure 5.5.2-1 Overview of Offset Level

Remote command

Set the level offset to On/Off

Command

`[ :SOURCE[1] | 2 ] :CORRection:PMETer:GAIN2:STATE <boolean>`

Query

`[ :SOURCE[1] | 2 ] :CORRection:PMETer:GAIN2:STATE?`

Response

`<boolean>` 0 or 1

Parameter

`<boolean>` On/Off of the level offset  
OFF | 0 Off (Default)  
ON | 1 On



**Example of Use**

To set the level offset to ON.  
 CORR:PMET:GAIN2:STAT ON  
 CORR:PMET:GAIN2:STAT?  
 > 1

## Level Offset Value

 or **Top>Level, >**  **Configure Correction>Use Power Sensor>Settings>Level Offset Value**

Sets the offset level value to be added to the power sensor reading.

Press **F4 Level Offset Value** in the Settings function menu to display the **Level Offset Value** dialog box in the active function frame. Enter the numbers and press the unit key of the Unit function menu to set the offset level value.

Setting range	-100 dB to 100 dB
Resolution	0.01 dB
Default	0 dB

**Remote command****Set the offset level****Command**

```
[ :SOURce[1] | 2 ] :CORRection:PMETer:GAIN2[ :INPut ][ :MAGNitud  
e ] <rem_ampl>
```

**Query**

```
[ :SOURce[1] | 2 ] :CORRection:PMETer:GAIN2[ :INPut ][ :MAGNitud  
e ] ?
```

**Response**

```
<rem_ampl>
```

**Parameter**

<rem_ampl>	Offset level
Setting range	-100 dB to 100 dB
Resolution	0.01 dB
Default	0 dB

**Example of Use**

To set the offset level to 20 dB.  
 CORR:PMET:GAIN2 20  
 CORR:PMET:GAIN2?  
 > 20.00

## Correction Points

 or **Top>Level, >**  **>Configure Correction>Use Power Sensor>Settings>Correction Points**

Sets the measurement point number when the correction table is created with the power sensor.

The measurement point interval is by the following:

$(\text{Start frequency} - \text{stop frequency}) / (\text{correction point} - 1)$

Press **F5 Correction Points** in the Settings function menu to display the **Correction Points** dialog box in the active function frame. Enter the numbers and press **F1 Enter** to set the correction points.

Setting range	2 to 4096
Resolution	1
Default	2

### Remote command

#### Set the measurement point number

##### Command

```
[ :SOURCE[1] | 2 ] :CORRection:FLATness:STEP:POINTs  
<ext_integer>
```

##### Query

```
[ :SOURCE[1] | 2 ] :CORRection:FLATness:STEP:POINTs
```

##### Response

```
<ext_integer>
```

##### Parameter



<ext_integer>	Measurement point number
Setting range	2 to 4096
Resolution	1
Default	2

##### Example of Use

To set the measurement point number to 1000 points.

```
CORR:FLAT:STEP:POIN 1000  
CORR:FLAT:STEP:POIN?  
> 1000
```

## Averaging

 or **Top>Level**,  **Configure Correction>Use Power Sensor>Settings>Averaging**

Enables/disables the averaging for the measurement value with the power sensor.

Pressing **F6 Averaging** in the Setting function menu sets the averaging.

Off Does not execute the averaging(Default).

On Executes the averaging.

## Remote command

## Set the averaging to On/Off

## Command

```
[ :SOURCE[1] | 2 ] :CORRection:PMETer:AVERage[ :STATe ]
<boolean>
```

## Query

```
[ :SOURCE[1] | 2 ] :CORRection:PMETer:AVERage[ :STATe ]?
```

## Response

```
<boolean> 0 or 1
```

## Parameter

```
<boolean> Averaging On/Off
OFF | 0 Off (Default)
ON | 1 On
```

## Example of Use



To set the averaging for SG2 power sensor measurement to On.

```
SOUR2:CORR:PMET:AVER ON
```

```
SOUR2:CORR:PMET:AVER?
```

```
> 1
```

## Averaging Count

 or **Top**>**Level**, >>**Configure Correction**>**Use Power Sensor**>**Settings**>**Averaging Count**

Sets the averaging count for the measurement values with the power sensor.

Press **F7 Averaging Count** in the Settings function menu to display the **Averaging count** dialog box in the active function frame. Enter the numbers and press **F1 Enter** to set the averaging count.

Setting range	1 to 2048
Resolution	1
Default	10

### Remote command

#### Set the averaging count

##### Command

```
[ :SOURce[1] | 2 ] :CORRection:PMETer:AVERAge:COUNT  
<ext_integer>
```

##### Query

```
[ :SOURce[1] | 2 ] :CORRection:PMETer:AVERAge:COUNT?
```

##### Response

```
<ext_integer>
```

##### Parameter

<ext_integer>	Measurement point number
Setting range	1 to 2048
Resolution	1
Default	10

#### Example of Use

To set the averaging count for SG2 power sensor measurement to 1024.

```
SOUR2:CORR:PMET:AVER:COUN 1024
```

```
SOUR2:CORR:PMET:AVER:COUN?
```

```
> 1024
```

### 5.5.3 Zero adjustment: Zero Sensor

 or Top>Level, >>Configure Correction>Use Power Sensor>Zero Sensor

Executes the zero adjustment for the power sensor.

Press **F4 Zero Sensor** in the Use Power Sensor function menu to execute the zero adjustment for the power sensor.

“Zeroing the Sensor” is displayed and the output of the MG3710A/MG3740A is Off during the adjustment. Also keys other than the power key are disabled.

#### CAUTION

The power sensor may be damaged depending on the output level of the MG3710A/MG3740A. Beware not to apply excessive input when the terminal is connected.

#### Remote command

#### Execute the zero adjustment

##### Command

```
[ :SOURce[1] | 2 ] :CORRection:PMETer:ZERoset
```

##### Example of Use

To execute the zero adjustment for the power sensor.

```
CORR:PMET:ZER
```

#### Setting method

#### Example: To execute the zero adjustment for the power sensor

1. Connect the USB terminal of the power sensor to the USB terminal of the MG3710A/MG3740A.  
Connect the RF Input terminal of the power sensor to the terminal to be measured. At this time, the power sensor may be damaged depending on the output level of the MG3710A/MG3740A. Beware not to apply excessive input when the terminal is connected.
2. Enter the information of the connected power sensor with ComPort number and Model to the MG3710A/MG3740A.
3. Set the MG3710A/MG3740A RF Output to Off.  
Press **F4 Zero Sensor** to execute the zero adjustment for the power sensor.

### 5.5.4 Creating correction table: Create Correction File

 or Top>Level, >  > **Configure Correction>Use Power Sensor>Create Correction File**

This connects the PowerSensor and creates the Correction Table. The Correction Table cannot be created if it is not executed when a USB power sensor is connected.

Save and recall to use the created Correction Table according to sections below:

- 5.4.7 “Saving user correction table: Save”
- 5.4.6 “Recalling user correction table: Open”

This function cannot be executed during Sweep/List.

Press **F6 Create Correction File** in the USB Power Sensor function menu to create the correction table.

The progress bar is displayed and the stop confirmation is displayed on the function menu during execution. When the stop confirmation is displayed, keys other than the function keys, power key, and cancel key are disabled. When the cancel key or power key is pressed, selection of Yes with the stop confirmation is assumed.

#### Remote command

#### Create the correction table

##### Command

Execution command

```
[ :SOURce[ 1 ] | 2 ] :CORRection:PMETer:CREate
```

Processing stop command

```
[ :SOURce[ 1 ] | 2 ] :CORRection:PMETer:CREate:ABORT
```

##### Query

Confirms the execution status.

```
[ :SOURce[ 1 ] | 2 ] :CORRection:PMETer:STATus?
```

##### Response

<status>

##### Parameter

<status>	CreateCorrectionTable execution status
0	Not executed
1	Being executed

##### Details

This function cannot be set during Sweep/List.

**Example of Use**

To create the correction table, confirms the execution status, and stops the execution.


```
CORR:PMET:CRE
CORR:PMET:STAT?
> 1
CORR:PMET:CRE:ABOR
```

**Setting method****Example: To create the correction table.**

1. Connect the USB terminal of the power sensor to the USB terminal of the MG3710A/MG3740A.  
Also connect the RF Input terminal of the power sensor to the end of the path to be corrected.

 **CAUTION**

The power sensor may be damaged depending on the output level of the MG3710A/MG3740A. Beware not to apply excessive input when the terminal is connected.



**Figure 5.5.4-1 Connection**

2. Press **F1 Connection Settings** in the USB Power Sensor function menu, and enter the information of the connected power sensor to ComPort number and Model with **F1 COM Port** and **F2 Model**.
3. Press **F2 Settings** in the USB Power Sensor function menu to open the Settings function menu, and enter the information of the frequency range and measurement point number of the measurement target to **F1 Start Freq**, **F2 Stop Freq**, and **F5 Correction Points**.
4. Set the path loss/gain between the MG3710A/MG3740A and the power sensor to **F4 Level Offset Value** in the Settings function menu, and set **F3 Level Offset** to On. Set the output level of the MG3710A/MG3740A to the level of the test target.

5. Press **F6 Create Correction File** in the USB Power Sensor function menu to output the CW signal from the MG3710A/MG3740A and sweep frequency between Start Frequency and Stop Frequency. The signal is received by the power sensor, and the difference from the MG3710A/MG3740A output level is created as the correction table.
6. Save the created Correction Table according to 5.4.7 “Saving user correction table: Save”.



## Chapter 6 Sweep/List

---

This chapter describes the operations and screen display of the Sweep/List function.

Note on remote command:

When the language mode is SCPI, the target SG can be selected with the beginning node of commands for controlling individual functions. Refer to Appendix E.7.6 “Selecting SG1/2” for details.

6.1	Sweep/List Function .....	6-2
6.1.1	Display description .....	6-2
6.2	Setting Item .....	6-5
6.2.1	Setting operation item: Sweep .....	6-6
6.2.2	Sweep Type .....	6-9
6.2.3	Sweep Repeat .....	6-10
6.2.4	Start/Stop Sweep .....	6-10
6.2.5	Sweep Direction .....	6-11
6.2.6	Manual mode .....	6-12
6.2.7	Sweep Out .....	6-14
6.2.8	Trigger Out Polarity .....	6-16
6.3	Sweep Function .....	6-18
6.3.1	Configure Step Sweep .....	6-18
6.4	List Function: Configure Step Sweep .....	6-29
6.4.1	List Table setting .....	6-30
6.4.2	Inserting/deleting row for List Table .....	6-37
6.4.3	Selecting dwell time: Dwell Type .....	6-40
6.4.4	Recalling List Table: Open .....	6-41
6.4.5	Saving List Table: Save .....	6-43
6.5	Point Trigger .....	6-46

## 6.1 Sweep/List Function

 or **Top>Sweep/List**

MG3710A/MG3740A has the Sweep function for frequencies and levels to be changed within the specified range and the List function for frequencies and levels to be changed according to the List created with setting values in advance.

The Sweep function divides the specified range with the sweep point number set with Step Points and executes the sweep operation in a step-like form.

The List function assumes one row of the List Table as one sweep point and changes settings according to the List.

**Note:**

The Sweep function cannot be executed for SG1 and SG2 simultaneously.

The analog modulation (AM/FM/φM) cannot be used during Sweep/List.

Pressing **Sweep/List** of the main function key or **F3 Sweep/List** in the top function menu displays the Sweep/List function menu and **Sweep/List Info** dialog box.

This chapter assumes that you press **Sweep/List** of the main function key or **F3 Sweep/List** in the top function menu, unless otherwise specified.

### 6.1.1 Display description

The display items of the Sweep/List Info dialog box differs between the Sweep function and List function.

The progress status is displayed with the progress bar at the bottom of this screen.



Figure 6.1.1-1 Sweep/List Info Dialog Box (Sweep Type : “Sweep”)




Figure 6.1.1-2 Sweep/List Info Dialog Box (Sweep Type : “List”)

Table 6.1.1-1 Sweep/List Info Display Items

type	Display	Description
Sweep /List	Sweep	Indicates items, frequency (Freq), and level (Lvl) to execute the Sweep/List function.
	Sweep Type	Distinguishes the Sweep function (Sweep) and List function (List).
Sweep	Frequency Start	Display start frequency of the Sweep function
	Frequency Stop	Display stop frequency of the Sweep function
	Level Start	Display start level of the Sweep function
	Level Stop	Display stop level of the Sweep function
	Step Points	Sweep point number on the Sweep function
List	Step Points	Number of sweep points for List function
	Dwell Types	Distinguishes the reference Sweep/List of DwellTime on the List function.
Sweep /List	Manual Mode	Distinguishes Automatic (Off) and Manual (On) for the operation to move to the next sweep point.
	Sweep Direction	Distinguishes the Up/Down of the execution order of the Sweep/List function.
	Sweep Repeat	Distinguishes the Continuous (Cont)/Once (Single) of the Sweep/List function.
	Point Trigger	Distinguishes the point trigger On/Off and Start/Point trigger.
	Point Trigger Source	Distinguishes the External (Ext)/Key (Key)/Remote command (Bus)/Timer (Timer) of point trigger source
	Current Point	Indicates the sweep point/ the number of sweep points being executed .
	Step Dwell	Indicates the output dwell time on Sweep/List function. Displayed when Dwell Type is Sweep.

The following are remote commands for items displayed in the Sweep/List Info dialog box.

### Recalling sweep point being executed: Current Point

This command recalls the sweep point being executed.

**Remote command**

**Query the current sweep point  
Query**

[ :SOURce ] :SWEep :CPOint ?

[ :SOURce ] :LIST :CPOint ?

**Response**

<point>

**Parameter**

<point> Sweep point being executed

**Programming Example**

To recall the sweep point being executed.

SWE :CPO?

> 100

### Recalling sweep point number: Current Point

The sweep point number is recalled.

**Remote command**

**Recall the sweep point number  
Query**

[ :SOURce ] :LIST :POINts ?

**Response**

<point>

**Parameter**

<point> Sweep point number

**Programming Example**

To recall the sweep point number.

LIST :POIN?

> 100

## 6.2 Setting Item

The Sweep/List function menu is described below.

Sweep/List function menu: Sweep/List

**Table 6.2.1-1 Sweep/List Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Sweep Off	Opens the Sweep Mode function menu and sets the execution of Sweep/List function. Refer to 6.2.1 "Setting operation item: Sweep".
	F2	Sweep Type Sweep List	Selects the Sweep function or List function. Refer to 6.2.2 "Sweep Type".
	F3	Sweep Repeat Cont Single	Sets the operation count for Sweep/List function to Single/Continuous. Refer to 6.2.3 "Sweep Repeat".
	F4	Start Sweep/Stop Sweep	Starts and stops the Sweep/List function. Refer to 6.2.4 "Start/Stop Sweep".
	F5	Sweep Direction Up Down	Sets the direction of execution order for Sweep/List function. Refer to 6.2.5 "Sweep Direction".
	F6	Configure Step Sweep	Displays the Sweep function menu and executes the Sweep function-related settings. Refer to 6.3 "Sweep Function".
	F7	Configure List Sweep	Displays the List Table function menu and executes the List function-related settings. List Table is displayed in the function display area. Refer to 6.4 "List Function: Configure Step Sweep".
	F8	Point Trigger	Displays the Point Trigger function menu and sets the trigger. Refer to 6.5 "Point Trigger".
2	F1	Manual Mode Off On	Sets Automatic (Off) and Manual (On) for the operation to move to the next point on Sweep function and List function. Refer to 6.2.6 "Manual mode".
	F2	Manual Point 1	Sets the sweep point manually on Sweep function and List function. Refer to 6.2.6 "Manual mode".
	F4	Sweep Out Sweep Status	Displays the Sweep Out function menu and sets the signal output from the SweepOut terminal. Refer to 6.2.7 "Sweep Out".
	F5	Trigger Out Polarity Positive Negative	Sets the polarity of Point Trigger Out signal. Refer to 6.2.8 "Trigger Out Polarity".

### 6.2.1 Setting operation item: Sweep



or **Top>Sweep/List, >Sweep**

Selects the items (frequency and level) to be executed with the setting parameters of the Sweep/List function.

Press **F1 Sweep** to display the Sweep Mode function menu.

The parameters to execute the Sweep/List function are set from the frequency and level.

The setting status of the Sweep Mode function menu is displayed under the **F1 Sweep** in the **Sweep/List** function menu.

Example:

Freq+Lvl                      To execute the Sweep function or List function for Freq (frequency) and Lvl (level)

**Table 6.2.1-1 Sweep Mode Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Off	Stops all execution of the Sweep function and List function for <b>F2 Freq</b> and <b>F3 Level</b> .
	F2	Freq <u>Off</u> On	Sets Stop (Off) or Execution (On) of the Sweep/List function for the frequency.
	F3	Level <u>Off</u> On	Sets Stop (Off) or Execution (On) of the Sweep/List function for the level.

#### Setting all Sweep/List function to Off: Off



or **Top>Sweep/List, >Sweep>Off**

Sets all of the Sweep/List function to Off.

Press **F1 Off** to set the Sweep/List function for the frequency and level to Off.

#### Remote command

#### Set all of the Sweep/List function to Off

#### Command

[ :SOURce ] :LIST:OFF

#### Programming Example

To set all of the Sweep/List function to Off.

LIST:OFF

## Sweep/List function for frequency: Freq

 or **Top>Sweep/List, >Sweep>Frequency**

The Sweep/List function for frequency is set.

Press **F2 Freq** to set the Sweep/List function for frequency to On/Off.

On	Executes
Off	Stops (Default)

**Remote command**

**Enables/disables the Sweep/List function for frequency**  
**Command**

```
[ :SOURce[ 1 ] | 2 ] :FREQuency:MODE CW | FIXed | LIST
```

**Query**

```
[ :SOURce[ 1 ] | 2 ] :FREQuency:MODE?
```

**Response**

<mode> CW, FIX or LIST  
For Freq=Off, CW

**Parameter**

<mode>	Sweep function
CW	Does not execute the frequency sweep
FIXed	Does not execute the frequency sweep (Default)
LIST	Executes the sweep function.

**Programming Example**

To execute the sweep function for frequency.

```
FREQ:MODE LIST
FREQ:MODE?
> LIST
```

### Sweep/List function for level: Level

 or **Top>Sweep/List, >Sweep>Level**

Sets the Sweep/List function for output level.

Press **F3 Level** to set the Sweep/List function for output level to On/Off.

On	Executes
Off	Stops (Default)

#### Remote command

**Enables/disables the Sweep/List function for level**

##### Command

[ :SOURce[ 1 ] | 2 ] :POWer:MODE FIXed | LIST

##### Query

[ :SOURce[ 1 ] | 2 ] :POWer:MODE?

##### Response

<mode>                      FIX or LIST

##### Parameter

<mode>	Sweep function
FIXed	Fixed level (Default)
LIST	Executes the sweep function.

##### Programming Example

To execute the sweep function for level.

```
POW:MODE LIST
POW:MODE?
> LIST
```



## 6.2.2 Sweep Type



or **Top>Sweep/List, >Sweep Type**

Selects the Sweep function or List function.

Press **F2 Sweep Type** to select.

Sweep	Step Sweep function (Default)
List	List Sweep function

### Remote command

#### Select the Sweep function or List function

##### Command

```
[ :SOURce ] :LIST:TYPE LIST|STEP
```

##### Query

```
[ :SOURce ] :LIST:TYPE?
```

##### Response

```
<type> LIST or STEP
```

##### Parameter

<type>	Type of Sweep
STEP	Step Sweep function (Default)
LIST	List Sweep function

#### Programming Example

To select the List function from the Sweep function and List function.

```
LIST:TYPE LIST
```

```
LIST:TYPE?
```

```
> LIST
```

### 6.2.3 Sweep Repeat



or **Top>Sweep/List, >Sweep Repeat**

Selects the operation count for the Sweep/List function from Continuous/Single.

Press **F3 Sweep Repeat** to select.

Cont Continuous (Default)

Single Once (Single)

#### Remote command

**Select the operation count for the Sweep/List function from Continuous/Single**

#### Command

`:INITiate:CONTinuous[:ALL] <boolean>`

#### Query

`:INITiate:CONTinuous[:ALL]?`

#### Response

`<boolean>` 0 or 1

#### Parameter

`<boolean>` Repetition count

OFF | 0 Once (Single)

ON | 1 Continuous (Default)

#### Programming Example

To set the sweep count to Continuous.

```
INIT:CONT ON
```

```
INIT:CONT?
```

```
> 1
```

### 6.2.4 Start/Stop Sweep



or **Top>Sweep/List, >Start/Stop Sweep**

Sets the Sweep/List function to Start/Stop every time the button is pressed.

Press **F4 Start/Stop Sweep** to execute.

#### Note:

This function is unavailable when the setting explained in 6.2.1 “Setting operation item: Sweep” is set to Off.

<b>Remote command</b>	<b>Execute the sweep operation</b>
	<b>Command</b>
	<code>:INITiate[:IMMediate][:ALL]</code>
	<code>[:SOURce]:TSWEEP</code>
	<b>Programming Example</b>
	To execute the sweep operation.
	INIT
	TSW

### 6.2.5 Sweep Direction



or **Top>Sweep/List, >Sweep Direction**

Sets the execution order for Sweep/List function.

Press **F5 Sweep Direction** to set.

Up	From the start to the stop for Sweep function, and from the first to the end for List function (Default)
Down	In reverse order of Up

<b>Remote command</b>	<b>Set the execution order for Sweep/List function</b>
	<b>Command</b>
	<code>[:SOURce]:LIST:DIRection UP DOWN</code>
	<b>Query</b>
	<code>[:SOURce]:LIST:DIRection?</code>
	<b>Response</b>
<code>&lt;direction&gt;</code>	UP or DOWN
	<b>Parameter</b>
<code>&lt;direction&gt;</code>	Execution order
UP	From the start to the stop for Sweep function, and from the first to the end for List function (Default)
DOWN	In reverse order of Up
	<b>Programming Example</b>
	To set the execution order to Up.
	LIST:DIR UP
	LIST:DIR?
	> UP

## 6.2.6 Manual mode

Sets the method to move to the next point on Sweep function and List function.

### Manual Mode

 or **Top>Sweep/List, >**  **Manual Mode**

Enables/disables the Manual Mode on Sweep function and List function.

Press **F1 Manual Mode** in the second page of the Sweep/List function menu to switch

- |     |  |
|-----|--|
| Off | Sets the automatic movement to the next point (Default).             |
| On  | Sets the manual movement to the point set with <b>Manual Point</b> . |

### Remote command

#### Enables/disables the Manual Mode

##### Command

[ :SOURce ] :LIST:MODE AUTO|MANual

##### Query

[ :SOURce ] :LIST:MODE?

##### Response

<mode> AUTO or MAN

##### Parameter

<mode>	Operation mode
AUTO	Auto (Default)
MANual	Manual

#### Programming Example

To set the point movement to Manual.

```
LIST:MODE MAN
```

```
LIST:MODE?
```

```
> MAN
```

## Manual Point

 or **Top>Sweep/List, >**  **Manual Point**

Sets the sweep point manually on Sweep function and List function.

Press **F2 Manual Point** in the second page of the Sweep/List function menu to display the **Manual Point** dialog box in the active function frame. Set the Manual Point.

Range	On the Sweep function: 1 to the Step Point of SG1/2 On the List function: 1 to the Step Point of SG1/2
Default	1



**Figure 6.2.6-1 Manual Point Dialog Box**

### Remote command

#### Set the sweep point

##### Command

```
[ :SOURCE ] :LIST:MANual <ext_integer>
```

##### Query

```
[ :SOURCE ] :LIST:MANual?
```

##### Response

```
<ext_integer>
```

##### Parameter

<ext_integer>	Sweep point number
Range	Refer to the above description.
Default	Refer to the above description.

#### Programming Example

To set the sweep points to 100.

```
LIST:MAN 100
```

```
LIST:MAN?
```

```
> 100
```

### 6.2.7 Sweep Out

 or **Top>Sweep/List, >**  **Sweep Out**

Sets the signal (information) output from the SweepOut terminal.

To use this function, the general purpose input/output option is required. This function is unavailable when Sweep/List Type is set to Sweep for SG2.

Press **F4 Sweep Out** in the second page of the Sweep/List function menu to display the Sweep Out function menu for selection.

- 10 V Sweep Signal      Outputs the sweep position with 0 to 10 V.
- Sweep Status            Outputs the identifying signal for sweeping and non-sweeping (Default).




Figure 6.2.7-1 10 V Sweep Signal




Figure 6.2.7-2 Sweep Status

**Remote command****Select the SweepOut terminal output format****Command**

```
:ROUTe[:CONNectors]:OUTPut:SOUT SWEep|SETTled
```

**Query**

```
:ROUTe[:CONNectors]:OUTPut:SOUT?
```

**Response**

```
<mode> SWE or SETT
```

**Parameter**

<mode>	Output signal
SWEep	10 V Sweep Signal
SETTled	Sweep Status (Default)

**Details**

To use this function, the general purpose input/output option 017/117 is required.



This function is unavailable when Sweep/List Type is set to Sweep for SG2.

**Programming Example**

To set the output signal to Sweep Status.

```
ROUT:OUTP:SOUT SETT  
ROUT:OUTP:SOUT?  
> SETT
```

## 6.2.8 Trigger Out Polarity

 or **Top>Sweep/List, >**  **Trigger Out Polarity**


Sets the polarity of Point Trigger Out signal.

**Note:**

For the output connector setting, refer to 7.4.2 “Route Output Connectors”.

Press **F5 Trigger Out Polarity** in the second page of the Sweep/List function menu to set the polarity of Point Trigger Out signal.

Positive	Positive polarity (Default)
Negative	Negative polarity



**Figure 6.2.8-1 Polarity**

**Remote command**

**Set the polarity of Point Trigger Out signal**

**Command**

`:TRIGger:OUTPut:POLarity POSitive|NEGative`

**Query**

`:TRIGger:OUTPut:POLarity?`

**Response**

`<polarity>` POS or NEG

**Parameter**

<code>&lt;polarity&gt;</code>	Signal polarity
POSitive	Positive polarity (Default)
NEGative	Negative polarity



**Programming Example**

To set the signal polarity to negative.

```
TRIG:OUTP:POL NEG
```

```
TRIG:OUTP:POL?
```

```
> NEG
```

## 6.3 Sweep Function

### 6.3.1 Configure Step Sweep



or **Top>Sweep/List, >Configure Step Sweep**

Execute the settings to execute the Sweep function.

Press **F6 Configure Step Sweep** in the Sweep/List function menu to display the Sweep function menu.

**Table 6.3.1-1 Sweep Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Freq Start 1.00000000000 GHz	Sets the start frequency of the Sweep function.
	F2	Freq Stop 1.00000000000 GHz	Sets the stop frequency of the Sweep function.
	F3	Level Start -144.00 dBm	Sets the start level of the Sweep function.
	F4	Level Stop -144.00 dBm	Sets the stop level of the Sweep function.
	F5	Points 101	Sets the point number on the Sweep function.
	F6	Dwell Time 2.000 ms	Sets the dwell time at each point on the Sweep function execution.
	F8	Step Shape <u>SawTooth</u> Triangle	Selects the normal sweep or triangle sweep on the Sweep function.

## Sweep start frequency: Freq Start

 or **Top>Sweep/List, >Configure Step Sweep>Freq Start**

Sets the start frequency of the Sweep function.

Press **F1 Freq Start** to display the **Freq Start** dialog box in the active function frame. Set the start frequency.

Range	Same as the frequency setting range of MG3710A/MG3740A
Resolution	0.01 Hz
Default	1 GHz



Figure 6.3.1-1 Freq Start Dialog Box

## Remote command

## Set the start frequency of the Sweep function

## Command

```
[ :SOURce[1] | 2 ] :FREQuency:STARt <freq>
```

## Query

```
[ :SOURce[1] | 2 ] :FREQuency:STARt?
```

## Response

```
<freq> Unit: Hz
```

## Parameter

<freq>	Start frequency
Range	Depends on the frequency setting range of MG3710A/MG3740A.
Resolution	0.01 Hz
Default	1 GHz
Suffix code	HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ When omitted Hz

## Programming Example


To set the start frequency to 800 MHz.

```
FREQ:STAR 800MHZ
```

```
FREQ:STAR?
```

```
> 800000000.00
```

Sweep stop frequency: Freq Stop

 or **Top>Sweep/List, >Configure Step Sweep>Freq Stop** Sets the stop frequency of the Sweep function.

Press **F2 Freq Stop** to display the **Freq Stop** dialog box in the active function frame. Set the stop frequency.

Range	Same as the frequency setting range of MG3710A/MG3740A.
Resolution	0.01 Hz
Default	1 GHz



Figure 6.3.1-2 Freq Stop Dialog Box

Remote command

**Set the sweep stop frequency of the Sweep function**

**Command**

[ :SOURce[1] | 2 ] :FREQuency:STOP <freq>

**Query**

[ :SOURce[1] | 2 ] :FREQuency:STOP?

**Response**

<freq>

**Parameter**

<freq>	Stop frequency
Range	Depends on the frequency setting range of MG3710A/MG3740A.
Resolution	0.01 Hz
Default	1 GHz
Suffix code	HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ When omitted Hz

**Programming Example**

To set the frequency to 1,800 MHz.  
 FREQ:STOP 1800MHZ  
 FREQ:STOP?  
 > 1800000000.00

**Related command**

This command sets the sweep center frequency of the Sweep function. Using this command with the command to set the span frequency sets the start and stop frequencies as a result. This is a function only with remote commands.

**Remote command****Set the sweep center frequency of the Sweep function****Command**

```
[ :SOURCE[1] | 2 ] :FREQUENCY:CENTer <freq>
```

**Query**

```
[ :SOURCE[1] | 2 ] :FREQUENCY:CENTer? [ MAXimum | MINimum ]
```

**Response**

<freq>	On the use of MAXimum Maximum settable frequency of MG3710A/MG3740A
	On the use of MINimum Minimum settable frequency of MG3710A/MG3740A (9 kHz)
	On unused Center frequency

**Parameter**

<freq>	Frequency
Range	Depends on the frequency setting range of MG3710A/MG3740A.
Resolution	0.01 Hz
Default	1 GHz
Suffix code	HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ When omitted     Hz

**Programming Example**

To set the center frequency to 800 MHz.

```
FREQ:CENT 800MHZ
```

```
FREQ:CENT?
```

```
> 800000000.00
```

**Related command**

This command sets the sweep span frequency of the Sweep function. Using this command with the command to set the center frequency sets the start and stop frequencies as a result. This is a function only with remote commands.

**Remote command**

**Set the sweep span frequency of the Sweep function**

**Command**

[ :SOURce[1] | 2 ] :FREQuency:SPAN <freq>

**Query**

[ :SOURce[1] | 2 ] :FREQuency:SPAN? [ MAXimum | MINimum ]

**Response**

<freq>

On the use of MAXimum

Maximum settable frequency span of  
MG3710A/MG3740A

Maximum settable frequency of  
MG3710A/MG3740A – 9 kHz

On the use of MINimum

Minimum settable frequency of  
MG3710A/MG3740A (0 Hz)

On unused

Span frequency

**Parameter**

<freq>

Frequency

Range

Depends on the frequency setting range of  
MG3710A/MG3740A.

Resolution

0.01 Hz

Default

1 GHz

Suffix code

HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ

When omitted Hz

**Programming Example**

To set the span frequency to 800 MHz.

```
FREQ:SPAN 800MHZ
```

```
FREQ:SPAN?
```

```
> 800000000.00
```

## Sweep start level: Level Start

 or **Top>Sweep/List, >Configure Step Sweep>Level Start**

Sets the start output level of the Sweep function.

Press **F3 Level Start** to display the **Level Start** dialog box in the active function frame. Set the start output level.

Range	Same as the output level setting range of MG3710A/MG3740A.
Resolution	0.01 dB
Default	Same as the output level initial value of MG3710A/MG3740A.




Figure 6.3.1-3 Level Start Dialog Box

## Remote command

## Set the start output level of the Sweep function

## Command

```
[ :SOURce[1] | 2 ] :POWer:STARt <ampl>
```

## Query

```
[ :SOURce[1] | 2 ] :POWer:STARt?
```

## Response

```
<ampl> Unit: dBm
```

## Parameter

<ampl>	Start output level
Range	Same as the output level setting range of MG3710A/MG3740A
Resolution	0.01 dB
Default	Same as the output level initial value of MG3710A/MG3740A

## Programming Example

To set the sweep start output level to -30.00 dBm.

```
POW:STAR -30.00
```

```
POW:STAR?
```

```
> -30.00
```

Sweep stop level: Level Stop

 or **Top>Sweep/List, >Configure Step Sweep>Level Stop**  
 Sets the stop output level of the Sweep function.

Press **F4 Level Stop** to display the **Level Stop** dialog box in the active function frame. Set the stop output level.

Range	Same as the output level setting range of MG3710A/MG3740A
Resolution	0.01 dB
Default	Same as the output level initial value of MG3710A/MG3740A



Figure 6.3.1-4 Level Stop Dialog Box

Remote command

**Set the stop output level of the Sweep function**

**Command**

`[ :SOURce[1] | 2 ] :POWer:STOP <ampl>`

**Query**

`[ :SOURce[1] | 2 ] :POWer:STOP?`

**Response**

`<ampl>` Unit: dBm

**Parameter**

<code>&lt;ampl&gt;</code>	Stop output level
Range	Same as the output level setting range of MG3710A/MG3740A
Resolution	0.01 dB
Default	Same as the output level initial value of MG3710A/MG3740A

**Programming Example**

To set the sweep stop output level to -50.00 dBm.

`POW:STOP -50.00`

`POW:STOP?`

`> -50.00`



## Sweep points: Points



or **Top>Sweep/List, >Configure Step Sweep>Points**

Sets the point number on the Sweep function.

Press **F5 Points** to display the **Points** dialog box in the active function frame. Set the point number.

Range	Minimum value	2	
	Maximum value	1000	Normal sweep
		500	Triangle sweep
Resolution		1	
Default		101	



Figure 6.3.1-5 Points Dialog Box

## Remote command

**Set the point number on the Sweep function**

**Command**

```
[ :SOURCE[1] | 2 ] :SWEep:POINts <value>
```

**Query**

```
[ :SOURCE[1] | 2 ] :SWEep:POINts?
```

**Response**

```
<value>
```

**Parameter**

<value>	Point number		
Range	Minimum value	2	
	Maximum value	1000	Normal sweep
		500	Triangle sweep
Resolution		1	
Default		101	

**Programming Example**

To set the point number to 300.

```
SWE:POIN 300
```

```
SWE:POIN?
```

```
> 300
```

Dwell Time

 or **Top>Sweep/List, >Configure Step Sweep>Dwell Time**

Sets the dwell time at each point on the Sweep function execution.

Press **F6 Dwell Time** to display the **Dwell Time** dialog box in the active function frame. Set the dwell time.

Range	100 $\mu$ s to 16 s
Resolution	1 $\mu$ s
Default	2 ms



Figure 6.3.1-6 Dwell Time Dialog Box

Remote command

**Set the dwell time at each point on the Sweep function execution**

**Command**

`[ :SOURCE[1] | 2 ] :SWEep:DWELl <time>`

**Query**

`[ :SOURCE[1] | 2 ] :SWEep:DWELl?`

**Response**

`<time>` Unit: s

**Parameter**

<code>&lt;time&gt;</code>	Dwell time
Range	100 $\mu$ s to 16 s
Resolution	1 $\mu$ s
Default	2 ms
Suffix code	S,MS,US,NS,PS
	When omitted S

**Programming Example**

To set the dwell time to 200  $\mu$ s.

`SWEep:DWEL 200US`

`SWEep:DWEL?`

`> 0.000200`

## Step Shape



or **Top>Sweep/List, >Configure Step Sweep>Step Shape**

Selects the sweep shape from normal sweep or triangle sweep on the Sweep function.

Press **F8 Step Shape** to switch the normal sweep/triangle sweep.

Saw Tooth

Normal sweep (Default)

Triangle

Triangle sweep




Figure 6.3.1-7 Saw Tooth (Normal) Sweep




Figure 6.3.1-8 Triangle Sweep

**Remote command**

**Select the sweep shape on the Sweep function**

**Command**

[ :SOURCE[1] | 2 ] :SWEep:SHAPE <shape>

**Query**

[ :SOURCE[1] | 2 ] :SWEep:SHAPE?

**Response**

<shape>

**Parameter**

<shape>	Sweep shape
SAWtooth	Normal sweep (Default)
TRIangle	Triangle sweep

**Programming Example**

To set the sweep shape to the triangle sweep.

```
SWE:SHAP TRI
```

```
SWE:SHAP?
```

```
> TRI
```

## 6.4 List Function: Configure Step Sweep

 or **Top>Sweep/List, >Configure List Sweep**

Configures the settings to execute the List function.

Press **F7 Configure List Sweep** in the Sweep/List function menu to display the ListTable function menu and List Table.

**Table 6.4-1 List Table Function Menu**

Page	Key No.	Menu Display	Function
1	F1		The function displayed on <b>F1</b> depends on the cursor position on List Table.
		Edit Item	Displayed when the cursor is on Frequency, Level or Dwell on List Table. The input dialog box for the selected item is displayed in the active function frame. Enter the appropriate number. Refer to 6.4.1 "List Table setting".
		SG <u>SG1</u> SG2	Displayed when the cursor is on SG of the List Table. Select SG to be applied. Refer to 6.4.1 "List Table setting".
	F2	Insert Row	Inserts a row to the list. The row is added above the row where the cursor is positioned. Refer to 6.4.2 "Inserting/deleting row for List Table".
	F3	Delete Row	Deletes the row where the cursor is positioned in the list. Refer to 6.4.2 "Inserting/deleting row for List Table".
	F4	Clear	Deletes all of the list and initializes it. Refer to 6.4.2 "Inserting/deleting row for List Table".
	F6	Dwell Type <u>Sweep</u> List	Selects the application origin for DwellTime on the List function. Refer to 6.4.3 "Selecting dwell time: Dwell Type".
	F7	Open	Displays the Recall List Table function menu and recalls the List Table data. Refer to 6.4.4 "Recalling List Table: Open".
	F8	Save	Displays the Save List Table function menu and saves the List Table. Refer to 6.4.5 "Saving List Table: Save".

### 6.4.1 List Table setting

**Sweep/List** or **Top>Sweep/List, >Configure List Sweep**

**F1** key in the function menu depends on the item selected with the cursor on List Table.

Move the cursor with the rotary knob or step key to set items.




Figure 6.4.1-1 List Table

SG setting: SG

**Sweep/List** or **Top>Sweep/List, >Configure List Sweep>SG**

When the cursor is on “**SG**”, **F1** key is “**SG**”. Press **F1 SG** to select SG to apply List Table.

- SG1 Targets SG1. (Default)
- SG2 Targets SG2.

Remote command

**Set SG1 and SG2 specifying the list number**

**Command**

`[ :SOURce ] :LIST:SOURce:SPECify <integer> , 1 | 2`

**Query**

`[ :SOURce ] :LIST:SOURce:SPECify? <integer>`

**Response**

<SG> 1 or 2

**Parameter**

<integer>	List number
Range	1 to 500
Resolution	1
Default	1
<SG>	SG number
1	SG1 (Default)
2	SG2

**Programming Example**

To set SG2 to the list number 20.

```
LIST:SOUR:SPEC 20,2
```

```
LIST:SOUR:SPEC? 20
```

```
> 2
```

**Setting frequency: Edit Item**

 or **Top>Sweep/List, >Configure List Sweep>Edit Item**

When the cursor is on “Frequency”, F1 key is “Edit Item”. Press **F1 Edit Item** to display the **Frequency** dialog box in the active function frame. Set the frequency.

Range	Same as the frequency setting range of MG3710A/MG3740A
Resolution	0.01 Hz
Default	1 GHz




Figure 6.4.1-2 Frequency Dialog Box

**Remote command**

**Set the frequency specifying the list number**

**Command**

```
[ :SOURce ] :LIST:FREQuency:SPECify <integer> , <freq>
```

**Query**

```
[ :SOURce ] :LIST:FREQuency:SPECify? <integer>
```

**Response**

<freq>                      Unit: Hz

**Parameter**

<integer>                    List number

Range                        1 to 500

Resolution                   1

Default                      1

<freq>                        Frequency

Range                        Depends on the frequency setting range of  
MG3710A/MG3740A.

Resolution                   0.01 Hz

Default                      1 GHz

Suffix code                   HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ  
When omitted              Hz

**Programming Example**

To set 800 MHz to the list number 1.

```
LIST:FREQ:SPEC 1,800MHZ
```

```
LIST:FREQ:SPEC? 1
```

```
> 800000000
```



## Setting Level: Edit Item

 or **Top>Sweep/List, >Configure List Sweep>Edit Item**

When the cursor is on “**Level**”, F1 key is “Edit Item”. Press **F1 Edit Item** to display the **Level** dialog box in the active function frame. Set the level.

Range Same as the output level setting range of MG3710A/MG3740A

Resolution 0.01 dB

Default Same as the output level initial value of MG3710A/MG3740A




Figure 6.4.1-3 Level Dialog Box

## Remote command

## Set the level specifying the list number

## Command

```
[ :SOURce ] :LIST:POWer:SPECify <integer> , <ampl>
```

## Query

```
[ :SOURce ] :LIST:POWer:SPECify? <integer>
```

## Response

```
<ampl> Unit: dBm
```

## Parameter

```
<integer> List number
```

Range 1 to 500

Resolution 1

Default 1

```
<ampl> Output level
```

Range Output level setting range of MG3710A/MG3740A

Resolution 0.01 dB

Default Minimum output level of MG3710A/MG3740A

Suffix code DBM, DM, DBUV, DBUVE  
DBM when omitted

**Programming Example**

To set -30.00 dBm to the list number 1.

```
LIST:POW:SPEC 1,-30.00
LIST:POW:SPEC? 1
> -30.00
```

Setting dwell time: Edit Item

 or **Top>Sweep/List, >Configure List Sweep>Edit Item**

When the cursor is on “Dwell”, F1 key is “Edit Item”. Press **F1 Edit Item** to display the **Dwell** dialog box in the active function frame. Set the Dwell Time.

Range                                    100 µs to 16 s  
 Resolution                                1 µs (990 ns)  
 Default                                    2 ms



Figure 6.4.1-4 Dwell Dialog Box

**Remote command**

**Set the dwell time specifying the list number**

**Command**

```
[ :SOURCE ]:LIST:DWELL:SPECify <integer>,<time>
```

**Query**

```
[ :SOURCE ]:LIST:DWELL:SPECify? <integer>
```

**Response**

```
<time>                                    Unit: s
```

**Parameter**

<integer>	List number
Range	1 to 500
Resolution	1
Default	1
<time>	Dwell time
Range	100 $\mu$ s to 16 s
Resolution	1 $\mu$ s (990 ns)
Default	2 ms
Suffix code	S, MS, US, NS, PS
	S when omitted

**Programming Example**

To set 200  $\mu$ s to the list number 1.

```
LIST:DWEL:SPEC 1,200US
```

```
LIST:DWEL:SPEC? 1
```

```
> 0.000200
```

**Operation description****Operation of Dwell Time**


Dwell Time operation differs between SG with one list and SG with two lists.

1. For SG with one list

The signal of each element has the dwell time specified with Dwell Time.

**Table 6.4.1-1 Setting Example of Dwell Time**

No.	Type of SG	Frequency	Dwell Time
1	SG1	F1	1 ms
2	SG1	F2	2 ms
3	SG1	F3	3 ms
4	SG1	F4	4 ms
5	SG1	F5	5 ms



**Figure 6.4.1-5 Dwell Time Operation (1SG)**

2. For SG with two lists

It is same as the SG with one list that the signal output of the next Element is started after Dwell Time; however, the other SG which is not the target SG for the next Element keeps unchanged status (the signal output is not stopped).

Table 6.4.1-2 Setting Example of Dwell Time

No.	Type of SG	Frequency	Dwell Time
1	SG1	F1	1ms
2	SG2	F2	2ms
3	SG1	F3	3ms
4	SG1	F4	4ms
5	SG2	F5	5ms





Figure 6.4.1-6 Dwell Time Operation (2SG)


## 6.4.2 Inserting/deleting row for List Table

Insertion/deletion of input row for List Table is executed.

Inserting row to List Table: Insert Row

 or **Top>Sweep/List, >Configure List Sweep>Insert Row** Press **F2 Insert Row** to add a row beneath the row where the cursor is positioned and existed rows are replaced down by one row. The added row is a copy of the specified row.

List Table can have up to 500 rows.



List Table						
	SG	Frequency	Level			Dwell
1	SG1	1.0000000000 GHz	-30.00 dBm			1 ms
▶ 2	SG1	1.1000000000 GHz	-27.00 dBm			2 ms
3	SG1	1.2000000000 GHz	-24.00 dBm			3 ms
4	SG1	1.3000000000 GHz	-21.00 dBm			4 ms

List Table						
	SG	Frequency	Level			Dwell
1	SG1	1.0000000000 GHz	-30.00 dBm			1 ms
▶ 2	SG1	1.1000000000 GHz	-27.00 dBm			2 ms
3	SG1	1.1000000000 GHz	-27.00 dBm			2 ms
4	SG1	1.2000000000 GHz	-24.00 dBm			3 ms
5	SG1	1.3000000000 GHz	-21.00 dBm			4 ms

Figure 6.4.2-1 Insert Row

### Remote command

**Add a new row above the specified row**

**(The added row will be a copy of the specified row)**

#### Command

```
[ :SOURCE ] :LIST :TYPE :LIST :INSert [ <integer> ]
```

#### Parameter

<integer> Position for the row to be inserted

Range 1 to the sweep point number  
The last row when omitted

Resolution 1

Default 1

#### Programming Example

To add a new row above the 10<sup>th</sup> row.

```
LIST :TYPE :LIST :INS 10
```

Deleting row from List Table: Delete Row

 or **Top>Sweep/List, >Configure List Sweep>Delete Row**

Press **F3 Delete Row** to delete the row where the cursor is positioned and existed rows are replaced up by one row.




Figure 6.4.2-2 Delete Row

Remote command

Delete the specified row

(When there is only one row, the row is changed to the initial value)

Command

[ :SOURCE ] :LIST:TYPE:LIST:DELeTe [ <integer> ]

Parameter


<integer>	Position of the row to be deleted
Range	1 to the sweep point number The last row when omitted
Resolution	1
Default	1

Programming Example

To delete the 10<sup>th</sup> row.

LIST:TYPE:LIST:DEL 10

Clearing List Table: Clear

 or **Top>Sweep/List, >Configure List Sweep>Clear**

Press **F4 Clear** to delete all rows of List Table.

The diagram illustrates the effect of the 'Clear' command on the List Table. It shows two screenshots of the 'List Table' interface. The top screenshot shows a table with four rows of data. The bottom screenshot shows the same table after the 'Clear' command, with only one row remaining. A large black arrow points from the top table to the bottom table, indicating the transition.

List Table						
	SG	Frequency	Level			Dwell
1	SG1	1.0000000000 GHz	-30.00 dBm			1 ms
▶	2	SG1	1.1000000000 GHz	-27.00 dBm		2 ms
	3	SG1	1.2000000000 GHz	-24.00 dBm		3 ms
	4	SG1	1.3000000000 GHz	-21.00 dBm		4 ms

List Table						
	SG	Frequency	Level			Dwell
▶	1	SG1	1.0000000000 GHz	-144.00 dBm		2 ms

Figure 6.4.2-3 Clear

**Remote command**

**Delete all rows of List Table**

**Command**


[ :SOURCE ] :LIST:TYPE:LIST:INITialize:PRESet

**Programming Example**

To delete all rows of List Table.

LIST:TYPE:LIST:INIT:PRES

### 6.4.3 Selecting dwell time: Dwell Type

 or **Top>Sweep/List, >Configure List Sweep>Dwell Type**  
Selects the Dwell Time used on the List function.

Press **F6 Dwell Type** to switch List/Sweep.

List	Applies the Dwell Time in List. (Default)
Sweep	Applies the Dwell Time set with the Sweep function menu.

#### Remote command

**Select the dwell time applied on the List function**

#### Command

[ :SOURCE ] :LIST:DWELL:TYPE LIST|STEP

#### Query

[ :SOURCE ] :LIST:DWELL:TYPE?

#### Response

<type> LIST or STEP

#### Parameter

<type>	Dwell time to be applied
LIST	Dwell Time in List (Default)
STEP	Dwell Time set with the Sweep function menu

#### Programming Example

To apply the Dwell Time in List.

```
LIST:DWEL:TYPE LIST
```

```
LIST:DWEL:TYPE?
```

```
> LIST
```



### 6.4.4 Recalling List Table: Open

 or **Top>Sweep/List, >Configure List Sweep>Open**  
 Recalls the saved List Table file.

**Remote command**

**Recall the saved List Table file**

**Command**

:MMEMory:LOAD:LIST <string>[,<device>]

**Parameter**

<string> File name without an extension  
 Character string within 100 characters enclosed by double quotes ( " ") or single quotes ( ' ') (excluding extension)  
 <device> Drive number  
 Options A to Z, currently selected drive when omitted

**Programming Example**

To recall the List file with the file name of “ABC” from the D drive.  
 MMEM:LOAD:LIST "ABC", D

**Setting method**

**Example: To recall the List Table file.**

1. Press **F7 Open** in the List Table function menu to display the List Table Recall dialog box in the active function frame, File List dialog box in the function display frame, and List Table Recall function menu in the function menu frame.

**Table 6.4.4-1 List Table Recall Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Opens the Device function menu for selection of Device where List Table to be recalled is saved.
	F7	Open	Recalls the List Table file in Device selected with <b>F1 Drive</b> .
	F8	Cancel	Returns to the previous menu.

2. Press **F1 Drive** to select Device containing the List Table file to be recalled.  
 Options All connected Drives  
 Default C
3. The File List dialog box of the device selected in Step 2 is displayed, and the csv files are displayed.



**Figure 6.4.4-1 List Table Recall Screen**

4. Select the List Table file to be recalled.
5. Press **F7 Open** to recall the selected List Table file.

**Note:**

File names are listed in alphanumeric order.

If no List Table file exists, "File not found" is displayed.

## 6.4.5 Saving List Table: Save



or **Top>Sweep/List, >Configure List Sweep>Save**

Saves the List Table with set parameters in the internal hard disk.

### Remote command

#### Save the List Table with set parameters

##### Command

```
:MMEMory:STORe:LIST [<string>[,<device>]]
```

##### Parameter

<string>

File name without an extension

Character string within 100 characters enclosed by double quotes (" ") or single quotes (' ') (excluding extension)

The following characters cannot be used:

```
\ / : * ? " " \ ' < > |
```

Automatically named as "List[Date]\_[Additional number].csv" when omitted.

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

<device>

Drive number

Options

A to Z, currently selected drive when omitted

##### Details

A space or dot "." at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

A destination path to save the file is the following directory in the specified drive.

```
Anritsu\MG3710A\User Data>ListTable\
```

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

##### Programming Example

To save the LIST file with the file name of "ABC" to the D drive.

```
MMEM:STOR:LIST "ABC",D
```

Setting method


**Example: To save the currently displayed List Table with the file name of “ABC”.**

1. Press **F8 Save** in the List Table function menu to display the List Table Save dialog box in the active function frame, File List dialog box in the function display frame, and List Table Save function menu in the function menu frame.

**Table 6.4.5-1 List Table Save Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Displays the Device function menu and sets the destination Drive.
	F7	Change Focus	Moves the cursor between dialog box and file list.
	F7	Save	Saves the file to the Device selected with <b>F1 Drive</b> .
	F8	Cancel	Returns to the previous menu.

2. Press **F1 Drive** to select the destination Device.  
Options All connected Drives  
Default C
3. The File List dialog box of the device selected in Step 2 is displayed, and the csv files are displayed.



**Figure 6.4.5-1 List Table Save Screen**

4. Enter the file name to the text box in the active function frame. By default, the “ListDate\_Additional number” is displayed in the text box.

5. Enter “ABC” in the text box and press **F7 Save**. The List Table file with the entered file name is saved, and the List Table Save dialog box closes. Press **F8 Cancel** to return to the previous screen without saving the List Table file.

**Note:**

When you input a file name, an extension is automatically added. You cannot specify an extension.

The maximum 100 characters are allowed for a file name.

Destination path:

Anritsu\MG3710A\User Data>ListTable\

Default destination name:

List[date]\_[additional number].csv

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

Characters available for file names are displayed on the character palette.

The following characters cannot be used:

\ / : \* ? " ' < > |

A space or dot “.” at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

## 6.5 Point Trigger



or **Top>Sweep/List, >Point Trigger**

Sets the point trigger to move to the next point on Sweep/List function.

**Note:**


The Point Trigger uses the trigger signal input as Pattern Trigger1. For the input connector setting, refer to Section 7.4.1 “Route Input Connectors”.

Press **F8 Point Trigger** in the Sweep/List function menu to display the Point Trigger function menu.

**Table 6.5-1 Point Trigger Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Point Trigger <u>Off</u> On	Enables/disables the trigger on Sweep/List function.
	F2	Mode <u>Start</u> Point	Selects the trigger mode on Sweep/List function.
	F3	Source Ext	Displays the Point Trigger Source function menu and sets the trigger source on Sweep/List function.
	F4	Delay 0.00000000 s	Sets the delay time from Point Trigger input to hardware settings on Sweep/List function.
	F5	Edge <u>Rise</u> Fall	Sets the polarity to be triggered for External PointTriggerSource.
	F6	Timer Period 1.000 ms	Sets the timer trigger period.
	F8	Trigger Key	Executes Point Trigger if the key is pressed when Source is Trigger Key.

## Point Trigger

 or **Top>Sweep/List, >Point Trigger>Point Trigger**

Enables/disables the trigger on Sweep/List function.

Press **F1 Point Trigger** to switch the trigger On/Off.

Off Does not use the trigger (Default).

On Uses the trigger.

When Manual Mode is On, Manual has priority and Trigger is ignored.

### Remote command

#### Enables/disables the trigger

##### Command

[ :SOURCE ] :LIST:TRIGger [ :STATE ] <boolean>

##### Query

[ :SOURCE ] :LIST:TRIGger [ :STATE ] ?

##### Response

<boolean> 0 or 1

##### Parameter

<boolean> Trigger setting

OFF | 0 Does not use the trigger (Default).

ON | 1 Uses the trigger.

##### Details

When Manual Mode is On, Manual has priority and Trigger is disabled.

##### Programming Example

To set the trigger to On.

```
LIST:TRIG ON
```

```
LIST:TRIG?
```

```
> 1
```

Trigger mode: Mode



or **Top>Sweep/List, >Point Trigger>Mode**

The trigger mode on Sweep/List function is selected.  
Press **F2 Mode** to switch Start/Point trigger.

Start	Start trigger (Default)
Point	Point trigger

Remote command

**Set the trigger mode**

**Command**

[ :SOURce ] :LIST:TRIGger:MODE START | POINTs

**Query**

[ :SOURce ] :LIST:TRIGger:MODE?

**Response**

<mode> STAR or POIN

**Parameter**

<mode>	Trigger setting
START	Start trigger (Default)
POINTs	Point trigger

**Programming Example**

To set the trigger mode to Start trigger.

```
LIST:TRIG:MODE STAR
LIST:TRIG:MODE?
> STAR
```

Operation description

**Start trigger and Point trigger**




Figure 6.5-1 Start Trigger






Figure 6.5-2 Point Trigger

Trigger source: Source

 or **Top>Sweep/List, >Point Trigger>Source**

Sets the trigger source on Sweep/List function.

Press **F3 Source** to display the Point Trigger function menu and select the trigger source.

Ext	External input (PatternTrigger1) (Default)
Key	Trigger key <b>F8 Trigger Key</b>
Bus	Remote command
Timer	Trigger with the internal timer

Remote command

**Set the trigger source**

**Command**

[ :SOURCE ] :LIST:TRIGger:SOURCE BUS|EXTernal|KEY|TIMER

**Query**

[ :SOURCE ] :LIST:TRIGger:SOURCE?

**Response**

<source> BUS, EXT, KEY or TIM

**Parameter**

<source>	Trigger source
BUS	Remote command
EXTernal	External input (PatternTrigger1) (Default)
KEY	Trigger key <b>F8 Trigger Key</b>
TIMER	Trigger with the internal timer

**Programming Example**

To set the trigger source to the internal timer.

```
LIST:TRIG:SOUR TIM
LIST:TRIG:SOUR?
> TIM
```

Trigger delay: Delay

 or **Top>Sweep/List, >Point Trigger>Delay**

Sets the delay time from Point Trigger input to hardware settings on Sweep/List function.

Press **F4 Delay** to display the **Delay** dialog box in the active function frame. Set the delay time.

Range	0 s to 2.5 s
Resolution	10 ns
Default	0 s

**Remote command**

**Set the delay time from the Point Trigger input**

**Command**

```
[ :SOURce ] :LIST:TRIGger:DELAy <time>
```

**Query**

```
[ :SOURce ] :LIST:TRIGger:DELAy?
```

**Response**

```
<time> Unit: s
```

**Parameter**

<time>	Delay time
Range	0 s to 2.5 s
Resolution	10 ns
Default	0 s
Suffix code	S, MS, US, NS, PS S when omitted

**Programming Example**

To set the delay time from the Point Trigger input to 200 μs.

```
LIST:TRIG:DEL 200US
LIST:TRIG:DEL?
> 0.00020000
```

## Trigger edge: Edge



or **Top>Sweep/List, >Point Trigger>Edge**

Sets the polarity to be triggered for External PointTriggerSource.  
Press **F5 Edge** to switch Rise/Fall.

Rise	Rise (Default)
Fall	Fall

**Remote command****Set the trigger polarity****Command**

```
:TRIGger[:SEquence]:SLOPe POSitive|NEGative
```

**Query**

```
:TRIGger[:SEquence]:SLOPe?
```

**Response**

```
<edge> POS or NEG
```

**Parameter**

<edge>	Trigger polarity
POSitive	Rise (Default)
NEGative	Fall

**Programming Example**


To set the trigger polarity to fall.

```
TRIG:SLOP NEG
```

```
TRIG:SLOP?
```

```
> NEG
```

## Timer Period

 or **Top>Sweep/List, >Point Trigger>Timer Period**

Sets the timer trigger period.

Press **F6 Timer Period** to display the **Timer Period** dialog box in the active function frame. Set the period.

Range	500 $\mu$ s to 4000 s
Resolution	1 $\mu$ s
Default	1 ms

### Remote command

#### Set the timer trigger period

##### Command

`:TRIGger[:SEquence]:TIMER <time>`

##### Query

`:TRIGger[:SEquence]:TIMER?`

##### Response

`<time>`

##### Parameter

<code>&lt;time&gt;</code>	Timer trigger period
Range	500 $\mu$ s to 4000 s
Resolution	1 $\mu$ s
Default	1 ms
Suffix code	S, MS, US, NS, PS S when omitted

#### Programming Example


To set the timer trigger period to 10 ms.

```
TRIG:TIM 10MS
```

```
TRIG:TIM?
```

```
> 0.010000
```

## Trigger Key

 or **Top>Sweep/List, >Point Trigger>Trigger Key**

Generates the trigger manually.

When the trigger source is set to Trigger Key, press **F8 Trigger Key** to allow manual generation of the trigger.

# Chapter 7 Modulation

---

This chapter describes the operations and input/output signal settings related to the modulation function of MG3710A/MG3740A.

Note on remote command:

When the language mode is SCPI, the target SG can be selected with the beginning node of commands for controlling individual functions. Refer to Appendix E.7.6 “Selecting SG1/2” for details.

7.1	Setting Digital Modulation Analysis.....	7-2
7.1.1	Display description .....	7-4
7.2	Analog Modulation: Analog/Pulse.....	7-12
7.2.1	AM modulation: AM .....	7-14
7.2.2	FM/φM.....	7-30
7.2.3	Pulse.....	7-54
7.2.4	Optimize Function for the Analog Modulation: Optimize .....	7-69
7.3	Baseband Mode.....	7-71
7.3.1	ARB .....	7-74
7.3.2	Pattern generation mode: Combination Mode .....	7-80
7.3.3	ARB Setup.....	7-94
7.3.4	Loading waveform pattern: Load.....	7-106
7.3.5	Selecting output waveform pattern: Select... ..	7-119
7.3.6	Copying external waveform pattern: Copy ... ..	7-129
7.3.7	RF Gate .....	7-136
7.3.8	Start/Frame Trigger .....	7-145
7.3.9	Setting Frame trigger operation:Event .....	7-155
7.3.10	Frame Count.....	7-158
7.3.11	Baseband Clock .....	7-161
7.3.12	Marker Setup .....	7-167
7.3.13	Sequence Mode .....	7-175
7.3.14	Pattern Trigger.....	7-181
7.3.15	Sync Multi SG.....	7-189
7.4	Route Connectors.....	7-203
7.4.1	Route Input Connectors .....	7-204
7.4.2	Route Output Connectors.....	7-214
7.5	AWGN.....	7-228
7.6	I/Q Modulation.....	7-236
7.6.1	I/Q Calibration.....	7-244
7.6.2	Analog I/Q Input Adjustments.....	7-248
7.6.3	Analog I/Q Output Adjustments.....	7-251
7.6.4	Internal Baseband Adjustments .....	7-259

## 7.1 Setting Digital Modulation Analysis

**Mode** or **Top>Mode**

Press **Mode** of the main function key or **F4 Mode** on the top function menu to activate the digital modulation setting mode and the ARB/Waveform function menu is displayed.

In MG3740A, **Mode** can be set only when option-020/120 is installed.

This section assumes that you press **Mode** and the digital modulation setting mode has been activated, unless otherwise specified.




Figure 7.1-1 Outline of MG3710A/MG3740A modulation circuit

Settings of ARB of the digital modulation setting mode and AWGN, Analog/Pulse, I/Q, Modulation, and SG Output on the Top function menu switch the flow of modulated signals and decide the type of signals output from the RF and I/Q output.

The digital modulation states of RF and I/Q output corresponding to each setting are described on the next page.

**Table 7.1-1 Digital modulation Setup State and Signal Output**

Settings			Output Signal		
I/Q Src	I/Q Out	Modulation	I/Q Out	RF Output	
Internal, Analog I/Q In	RF	Off	No output	CW	
Analog I/Q In		On		External vector modulation	
Internal				Internal vector modulation	
Internal, Analog I/Q In	Analog I/Q Out	Off	No output	CW	
Analog I/Q In		On		Internal I/Q signal	External vector modulation*
Internal					CW*

\* If I/Q Out is set to **Analog I/Q Out** and Modulation is **On**, the RF output level is not guaranteed.

### 7.1.1 Display description

This section describes the Hardware Block Chart. For the ARB Info display description, refer to 7.3.1 “ARB”.

Press the Top menu to display the Hardware Block Chart and each of SG1 and SG2 has the independent display screen.

Press each displayed block to display the function menu and dialog box necessary for setting.




Figure 7.1.1-1 Hardware Block Chart

**Note:**

The figure above is for explanation; it is different from the actual display.



Table 7.1.1-1 Hardware Block Chart Display Details















No	Display Example	Display	Description
1		ARB	ARB block
		On/Off	Indicates On/Off of ARB (function to generate modulated signals with arbitrary waveform patterns).
		Out:	Indicates On/Off of the arbitrary waveform pattern output.
2		AWGN	AWGN block
		On/Off	Indicates On/Off of AWGN addition.
3		Analog Mod	Analog Modulation block
		AM/FM/ $\phi$ M	Indicates the analog modulation (AM/FM/ $\phi$ M) during modulation.
4		I/Q	I/Q block
		Src: Internal/ Analog I/Q In	Indicates the I/Q signal source.
		Out: RF/ Analog I/Q Out	Indicates the output destination for baseband signals.
5		Local Oscillator	Local Oscillator block
		Src: Int/Ext/Sync	Indicates the Local signal source.
		Out: ---/On/Off	Indicates On/Off of the Local signal external output.
6		Pulse Mod	Pulse Modulation block
		On/Off	Indicates On/Off of Pulse modulation.
7		---	Indicates that inputs from two function blocks of the left side and bottom side are combined and output to the function block of the right side.
8		---	Indicates that the input Local signal from the bottom side is modulated with the input signal from the left side and output to the function block of the right side.
9		---	Indicates the RF Output is On.
10		Analog I/Q Out	Indicates the Analog I/Q signal is set to the external output.

Table 7.1.1-1 Hardware Block Chart Display Details (Continued)

No .	Display Example	Display	Description
11		Analog I/Q In	Indicates the Analog I/Q signal is set to the external input.
12		LO In (For SG1)	Indicates the SG1 Local signal source is set to Ext (input from the rear LO Input connector).
		SG1 (For SG2)	Indicates the SG2 Local signal source is set to Sync and the signal is input from SG1.
13		SG2 (For SG1)	Indicates the SG1 Local signal external output setting is On and the signal is output to SG2. If SG2 is not installed, "LO Out" (output from the rear LO Output connector) is displayed.
		LO Out (For SG2)	Indicates the Local signal external output setting (output from the rear LO Output connector) is On.
14		---	Click to switch Hardware Block Chart and ARB Info display. The switching button appears only in the MG3740A with option-020/120 installed. Refer to 7.3.1 "ARB".

**Remote command****Query the pattern playback status****Query**

```
[ :SOURce[1] | 2 ] :RADio:ARB:REGister[:STATus]?
```

**Response**

```
<status>
```

**Parameter**

```
<status>
```

Playback status

Value

= bit0 + bit1 + bit2 + bit3 + bit4 + bit5 + bit6 + bit7

bit2 :  $2^2 = 4$ 

Playing

bit0, 1, 3 to 15

Not used

Range

0 to 255

Default

0 (Paused)

**Details**

“Paused” is returned while waiting for trigger.

**Programming Example**

To query the playback status of SG1 output pattern.

```
RAD:ARB:REG?
```

```
> 4
```

Resident display frame ARB

Information of the waveform pattern selected with ARB function is displayed in the resident display frame in the lower function display frame. In MG3740A, resident display frame ARB is available only when option-020/120 is installed.




Figure 7.1.1-2 Resident Display Frame ARB

Table 7.1.1-2 Resident Display Frame ARB

No	Function	Display Example	Description
1	ARB status	On	Indicates On/Off of the ARB function. On : ARB On Off : ARB Off
2	Output waveform status	A+B	Indicates the status of output waveform. CW : CW A : Outputs the waveform pattern of Memory A. B : Outputs the waveform pattern of Memory B. A+B : Outputs the waveform patterns of Memory A and Memory B. A+AWGN : Outputs the waveform pattern of Memory A and AWGN. B+AWGN : Outputs the waveform pattern of Memory B and AWGN. Multiplex : Outputs the Multiplex waveform. Long : Outputs the Long waveform. Seq.(A) : Outputs the Sequence waveform (Only Memory A is used). Seq.(A+B) : Outputs the Sequence waveform (Add Pattern is added). Seq.(A+AWGN) : Outputs the Sequence waveform (AWGN is added).

**Table 7.1.1-2 Resident Display Frame ARB (Cont'd)**

No	Function	Display Example	Description
3	Rate Mismatch display	Rate Mismatch	Displays the Rate Mismatch information. This is displayed when the rate matching is unavailable due to internal operation clock limitation of the MG3710A/MG3740A. Refer to Figure 7.3.2-6 "Rate Matching Function".
4	FIR Error display	FIR Error	Displays the FIR Error information. This is displayed for the condition of no correct signal output when the waveform is to be output which uses the internal FIR filter of the MG3710A/MG3740A.

**Note:**

For Add Pattern, refer to 4.8.2 "Combination File Edit screen" in *MG3700A/3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)*.

## Rate Mismatch

The Rate Mismatch message is displayed only when “Mismatch” of Rate Matching has occurred in the ARB field of the resident display frame.

### Remote command

#### Query the status of Rate Matching

##### Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:RMATching:ERRor?
```

##### Response

```
<status>
```

##### Parameter

```
<status>
```

NORM

Status of Rate Matching

Normal

A mismatch of sampling rates does not occur.

MISS

Mismatch

A mismatch of sampling rates occurs. The sampling rate of Pattern B was changed to that of Pattern A.

#### Programming Example

To query the Rate Matching status of SG1.

```
RAD:ARB:RMAT:ERR?
```

```
> NORM
```

## FIR Error

The FIR Error message is displayed for the condition of no correct signal output when the waveform is to be output which uses the internal FIR filter of the MG3710A/MG3740A.

With the Internal FIR function, the signal to which the FIR filter is applied can be output within the MG3710A/MG3740A under the following conditions.

- Combination file

Waveform of Data Width of 1, 2, or 4 with the use of Internal FIR at Memory A side

Waveform of Data Width of 16 with the use of Internal FIR at Memory B side

- Pattern file

Waveform of Data Width of 1, 2, or 4 with the use of Internal FIR at Memory A side

No output at Memory B side

If the waveform with the use of Internal FIR is output under the conditions other than the above, FIR Error is displayed and no correct signal is output.

## 7.2 Analog Modulation: Analog/Pulse

### Top>➔>Analog/Pulse

Executes the analog modulation (AM/FM/φM) for modulated signals created by CW signal or ARB. In addition, when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed, the analog modulation can be executed with the external input signal.

For usage with low output frequency, the impact of second harmonic wave cut filter may degrade characteristics of high-frequency wave side.

Pulse modulation is executed with arbitrary frequency and timing settings. Modulation by external input signals is also supported. The RF Gate function which runs in tandem with the waveform pattern and the pulse modulation can be applied simultaneously, and the pulse modulation is executed because of OR.

#### Notes:

- If the output modulated wave exceeds the modulation bandwidth of the MG3710A/MG3740A, a missing signal/alias may occur. When AM modulation, FM modulation, or φM modulation is executed, be careful that the bandwidth used does not to exceed the modulation bandwidth.
- The analog modulation (AM/FM/φM) cannot be used during Sweep/List.
- The FM modulation and φM modulation cannot be executed simultaneously. Other combinations can be executed simultaneously.
- When additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed, using the analog modulation input may cause analog modulation input overflow.

Press **F3 Analog/Pulse** on page 2 of the top function key to open the **Analog Modulation Info** dialog box and the Analog Pulse function menu.

Analog Modulation Info						
Modulation	State	Depth/Deviation	Source	Rate	Delay	Width
AM	Off	0.1 %		400.0 Hz		
FM	On	1.0000 kHz		400.0 Hz		
φM	Off	0.000 Hz		400.0 Hz		
Pulse	On		Freerun	400.0 Hz	0.00000000 ...	2.00 μsec
Pulse 2	On		Freerun	400.0 Hz	0.00000000 ...	2.00 μsec

Figure 7.2-1 Analog Modulation Info



Table 7.2-1 Analog Pulse Function Menu

Page	Key No.	Menu Display	Function
1	F1	AM	Displays the AM function menu to set the settings related to AM (amplitude) modulation. Refer to 7.2.1 "AM Modulation: AM".
	F2	FM/φM	Displays the FM/φM function menu to set the settings related to FM (frequency) modulation/φM (phase) modulation. Refer to 7.2.2 "FM/φM".
	F3	Pulse	Displays the Pulse function menu to set the settings related to Pulse modulation. Refer to 7.2.3 "Pulse".
	F8	Optimize <u>Spurious</u> Distortion	Selects Spurious Mode or Distortion Mode to optimize analog modulation. Refer to 7.2.4 "Optimize Function for the Analog Modulation: Optimize".

### 7.2.1 AM modulation: AM

 or Top>>Analog/Pulse>AM

Sets the settings related to AM (amplitude) modulation.

Press **AM** on the main function menu or **F1 AM** on the Analog Pulse function menu to open the AM function menu.

**Note:**

Settings related to the AM modulation are disabled when Sweep/List is being executed.

Out Of Range status may be displayed while the AM modulation is applied. This indicates the status where the output level has been adjusted automatically not to exceed the output upper level of the MG3710A/MG3740A.

In this case, the operations below allows avoiding the Out Of Range.

- Disable the AM modulation.
- Lower the AM modulation depth.
- Lower the Level.

**Table 7.2.1-1 AM Function Menu**

Page	Key No.	Menu Display	Function
1	F1	AM1 Setup	Sets the AM1.
	F2	AM2 Setup	Sets the AM2. This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **AM1 Setup (AM2 Setup)** on the AM function menu to open the AM1 setup (AM2 setup) function menu.



Example: To execute the AM modulation.

1. Set the AM modulation to On with **F1 AM**.
2. Select the AM modulation application type with **F2 AM Depth Type**.
3. Set the AM modulation depth with **F3 AM Depth (Lin)** or **F4 AM Depth (Log)**.
4. Set the modulation frequency with **F5 AM Rate**.
5. Press **RF Output On/Off** to light the LED to set the RF output to On.
6. Press **Mod On/Off** to light the LED to start the AM modulation.

Table 7.2.1-2 AM Function Menu

Page	Key No.	Menu Display	Function
1	F1	AM <u>Off</u> On	Enables/disables the AM (amplitude) modulation.
	F2	AM Depth Type <u>Lin</u> Exp	Selects the AM modulation application type.
	F3	AM Depth (Lin) 0.1 %	Sets the AM modulation depth with the linear value.
	F4	AM Depth (Log) 3.00 dB	Sets the AM modulation depth with the Log value.
	F5	AM Rate 400.0 Hz	Sets the AM modulation frequency.
	F6	Setup AM Source	Sets the AM modulation signal. This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.
	F7	Phase Adjust 0.0 deg	Adjusts the phase of internal AM modulation signal. This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

AM Modulation On/Off: AM

 or **Top**  **>Analog/Pulse>AM>AM1 Setup (AM2 Setup), AM**  
 Enables/disables AM (amplitude) modulation.

Press **F1 AM** on the AM1 Setup (AM2 Setup) Function Menu to turn on/off.

Off Disables AM Modulation (Default).  
 On Enables AM Modulation.

**Remote command**

**To enable/disable AM Modulation Command**

`[ :SOURce [1] | 2 ] :AM [1] | 2 :STATe <boolean>`

**Query**

`[ :SOURce [1] | 2 ] :AM [1] | 2 :STATe?`

**Response**

`<boolean>` 0 or 1

**Parameter**


`<boolean>` AM Modulation On/Off  
 OFF | 0 Disables AM Modulation (Default).  
 ON | 1 Enables AM Modulation.

**Programming Example**

To set the AM Modulation to On.

```
AM:STAT ON
AM:STAT?
> 1
```

AM Depth Type: AM Depth Type

 or **Top**  **>Analog/Pulse>AM>AM1 Setup (AM2 Setup), AM Depth Type**

Selects the AM modulation application type.

**Note:**

AM Depth Type is a shared parameter for the AM1 and the AM2. The same value is set.

Press **F2 AM Depth Type** on the AM1 Setup (AM2 Setup) function menu for selection.

Lin Linear format (Default)  
 Exp Exponential format

**Remote command**

**Select the AM modulation application type**

**Command**

[ :SOURce[1] | 2 ] :AM:TYPE LINear|EXPonential

**Query**

[ :SOURce[1] | 2 ] :AM:TYPE?

**Response**

<type> LIN or EXP

**Parameter**

<type>	Type
LINear	Linear format (Default)
EXPonential	Exponential format

**Programming Example**

To set the AM modulation application type to the linear format.

AM:TYPE LIN

AM:TYPE?

> LIN

**AM Depth (Lin)**

 or Top >  > Analog/Pulse > AM > AM1 Setup (AM2 Setup),

**AM Depth (Lin)**

Sets the AM modulation depth with the linear value.

Press **F3 AM Depth (Lin)** on the AM1 Setup (AM2 Setup) function menu to set with the **AM Depth (Lin)** dialog box. This can be selected when **Lin** is selected at **AM Depth Type**.

Range	0% to 100%
Resolution	0.1%
Default	0.1%

When the AM modulation is executed for the CW signal with the amplitude A, the signal below is created.




Figure 7.2.1-1 AM Modulation (Lin)

**Remote command**

**Set the AM modulation depth with the linear value**

**Command**

`[ :SOURce [1] | 2 ] :AM [1] | 2 [ :DEPTh ] [ :LINear ] <percent>`

**Query**

`[ :SOURce [1] | 2 ] :AM [1] | 2 [ :DEPTh ] [ :LINear ] ?`

**Response**

`<percent>`                      Unit: %

**Parameter**

<code>&lt;percent&gt;</code>	Linear value for AM modulation depth
Range	0% to 100%
Resolution	0.1%
Default	0.1%
Unit	%
Suffix code	PCT (%), When omitted: PCT

**Details**

This can be set when a linear waveform is set at AM Depth Type.

**Programming Example**

To set the AM modulation depth to 5% with the linear value.

```
AM 5
AM?
> 5.0
```

## AM Depth (Log)

**AM** or **Top** → **Analog/Pulse** > **AM** > **AM1 Setup (AM2 Setup)**,  
**AM Depth (Log)**

Sets the AM modulation depth with the Log value.

This cannot be set when the external modulation signal is selected (Ext is selected in the AM source).

Press **F4 AM Depth (Log)** on the AM1 Setup (AM2 Setup) function menu to set with the **AM Depth (Log)** dialog box. This can be selected when **Exp** is selected at **AM Depth Type**.

Range	0 dB to 10 dB
Resolution	0.01 dB
Default	3 dB

When the AM modulation is executed for the CW signal with the amplitude A, the signal below is created.




Figure 7.2.1-2 AM Modulation (Log)

## Remote command

## Set the AM modulation depth with the Log value

## Command

```
[ :SOURce[1] | 2 ] :AM[1] | 2 [ :DEPTh ] :EXPonential <rel_ampl>
```

## Query

```
[ :SOURce[1] | 2 ] :AM[1] | 2 [ :DEPTh ] :EXPonential?
```

## Response

```
<rel_ampl> Unit: DB
```

## Parameter

<rel_ampl>	Log value for AM modulation depth
Setting	0 to 10 dB
Resolution	0.01 dB
Default	3 dB
Suffix code	DB, When omitted: DB

**Details**



This can be set when an exponential function waveform is set at AM Depth Type.

**Programming Example**

To set the AM modulation depth to 5 dB with the Log value.

```
AM:EXP 5
AM:EXP?
> 5.00
```

**AM Rate**

 or **Top** >  > **Analog/Pulse** > **AM** > **AM1 Setup (AM2 Setup), AM Rate**

Sets the AM modulation frequency.

Press **F5 AM Rate** on the AM1 Setup (AM2 Setup) function menu to set with the **AM Rate** dialog box.

This cannot be set when the external modulation signal is selected (**Ext** is selected in the AM source).

Range	0.1 Hz to 50 MHz
Resolution	0.1 Hz
Default	400 Hz

**Remote command**

**Set the AM modulation frequency**

**Command**

```
[ :SOURce [1] | 2 ] :AM [1] | 2 :INTernal:FREQuency <freq>
```

**Query**

```
[ :SOURce [1] | 2 ] :AM [1] | 2 :INTernal:FREQuency?
```

**Response**

```
<freq> Unit: HZ
```

**Parameter**

<freq>	AM modulation frequency
Range	0.1 Hz to 50 MHz
Resolution	0.1 Hz
Default	400 Hz
Suffix code	HZ, KHZ, MHZ, GHZ, KZ, MZ, GZ When omitted: HZ



**Programming Example**

To set the AM modulation frequency to 500 Hz.

AM:INT:FREQ 500

AM:INT:FREQ?

> 500.0

Setup AM Source

 or Top>  > Analog/Pulse>AM>AM1 Setup (AM2 Setup),  
**Setup AM Source**

Sets the AM modulation signals.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.


Press **F6 Setup AM Source** on the AM1 Setup (AM2 Setup) function menu to open the Setup AM Source function menu.

**Table 7.2.1-3 Setup AM Source Function Menu**



Page	Key No.	Menu Display	Function
1	F1	AM Source <u>Int</u> Ext	Switches the internal modulation signal/external modulation signal.
	F2	Waveform Sine	Selects the waveform of the internal modulation signal. This can be select when <b>Int</b> is selected in the AM source.
	F6	Coupling <u>DC</u> AC	Sets the DC coupling or AC coupling for the external modulation signal.
	F7	Impedance 600 Ω	Sets the termination for the external modulation signal.
	F8	Ext DC Cal	Adjusts the DC offset for the external modulation signal.

**Note:**

Because the external modulation signal has terminating resistance, some voltage may be generated even if the coupling is set to AC.



### Switching AM Source: AM Source

 or **Top**  **>Analog/Pulse>AM>AM1 Setup (AM2 Setup)> Setup AM Source, AM Source**

Switches the AM modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F1 AM Source** on the Setup AM Source function menu for selection.

Int	Internal modulation signal (Default)
Ext	External modulation signal

#### Remote command

#### Switch the AM modulation signal

##### Command

[ :SOURce [1] | 2 ] :AM [1] | 2 :SOURce INT | INT1 | INT2 | EXT

##### Query

[ :SOURce [1] | 2 ] :AM [1] | 2 :SOURce?

##### Response

<type> INT or EXT

##### Parameter

<type>	Type
INT	Internal modulation signal (Default)
INT1	Internal modulation signal (Processed as INT)
INT2	Internal modulation signal (Processed as INT)
EXT	External modulation signal

#### Programming Example

To switch the AM modulation signal to the external modulation signal.

```
AM:SOUR EXT
```

```
AM:SOUR?
```

```
> EXT
```

### AM Waveform: Waveform

 or **Top** >  > **Analog/Pulse** > **AM** > **AM1 Setup (AM2 Setup)** > **Setup AM Source, Waveform**

Selects the waveform of the internal modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F2 Waveform** on the Setup AM Source function menu for selection.

This can be set when **Int** is selected in the AM source.

Options	Sine (Sine wave) Triangle (Triangular waveform) Square (Square wave) Positive Ramp (Ramp wave (positive)) Negative Ramp (Ramp wave (negative))
Default	Sine

Figure 7.2.1-3 shows the types of selectable waveforms.




Figure 7.2.1-3 Type of Analog Waveform

**Remote command**

**Select the waveform of the internal AM modulation signal**

**Command**

```
[ :SOURce[1] | 2 ] :AM[1] | 2 :INTernal:FUNCTion[1] | 2 :SHAPE  
SINE | TRIangle | SQUare | RAMP
```

**Query**

```
[ :SOURce[1] | 2 ] :AM[1] | 2 :INTernal:FUNCTion[1] | 2 :SHAPE?
```

**Response**

```
<type> SINE, TRI, SQU, RAMP
```

**Parameter**

<type>	waveform
SINE	Sine (Default)
TRIangle	Triangle
SQUare	Square
RAMP	Ramp

**Programming Example**

To set the waveform of the internal AM modulation signal to the Triangle.

```
AM:INT:FUNC:SHAP TRI
AM:INT:FUNC:SHAP?
> TRI
```

**Remote command****Select the shape of the ramp wave****Command**

```
[ :SOURce[1] | 2 ] :AM[1] | 2 :INTernal:FUNCtion:SHAPE:RAMP
POSitive|NEGative
```

**Query**

```
[ :SOURce[1] | 2 ] :AM[1] | 2 :INTernal:FUNCtion:SHAPE:RAMP?
```

**Response**

```
<type> POS,NEG
```

**Parameter**

<type>	waveform
POSitive	Positive Ramp (Default)
NEGative	Negative Ramp

**Programming Example**

To set the shape of the ramp wave to the negative ramp.

```
AM:INT:FUNC:SHAP RAMP
AM:INT:FUNC:SHAP:RAMP NEG
AM:INT:FUNC:SHAP:RAMP?
> NEG
```

## Coupling: Coupling

 or **Top**  **>Analog/Pulse>AM>AM1 Setup (AM2 Setup)> Setup AM Source, Coupling**

Sets the DC coupling or AC coupling for the external modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F6 Coupling** on the Setup AM Source function menu for selection.

DC	DC coupling (Default)
AC	AC coupling

### Remote command

#### Set the DC coupling or AC coupling for the external modulation signal Command

```
[ :SOURce [1] | 2 ] :EXTMod:COUPling DC|AC
```

#### Query

```
[ :SOURce [1] | 2 ] :EXTMod:COUPling?
```

#### Response

```
<type> DC, AC
```

#### Parameter

<type>	Coupling
DC	DC coupling (Default)
AC	AC coupling

#### Programming Example



To set the DC coupling for the external modulation signal.

```
EXTM:COUP DC
```

```
EXTM:COUP?
```

```
> DC
```

## Impedance: Impedance

 or **Top**  **>Analog/Pulse>AM>AM1 Setup (AM2 Setup)> Setup AM Source, Impedance**

Sets the termination for the external modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F7 Impedance** on the Setup AM Source function menu for selection.

50 $\Omega$	50 $\Omega$ termination
600 $\Omega$	600 $\Omega$ termination (Default)
Hi-Z	High impedance (100 k $\Omega$ /70 pF)

## Remote command

**Set the termination for the external modulation signal Command**

```
[ :SOURce [1] | 2 ] :EXTMod:IMPedance 50 | 600 | HIZ
```

**Query**

```
[ :SOURce [1] | 2 ] :EXTMod:IMPedance?
```

**Response**

```
<type> 50, 600, HIZ
```

**Parameter**

<type>	Termination
50	50 $\Omega$ termination
600	600 $\Omega$ termination (Default)
HIZ	High impedance (100 k $\Omega$ /70 pF)

**Programming Example**

To set the 50  $\Omega$  termination for the external modulation signal.

```
EXTM:IMP 50
```

```
EXTM:IMP?
```

```
> 50
```

## Ext DC Cal: Ext DC Cal

 or **Top**  **>Analog/Pulse>AM>AM1 Setup (AM2 Setup)> Setup AM Source, Ext DC Cal**

Adjusts the DC offset for external modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

This can be used when in the modulation output status (setting either AM, FM,  $\phi$ M, or Pulse modulations to On, and Mod to On).

When one of the following conditions is met, press **F8 Ext DC Cal** on the Setup AM Source function menu to adjust the DC offset.

- AM = On and AM Source = Ext in AM1 Setup
- AM = On and AM Source = Ext in AM2 Setup
- FM = On and FM Source = Ext in FM1 Setup
- FM = On and FM Source = Ext in FM2 Setup
- $\phi$ M = On and  $\phi$ M Source = Ext in  $\phi$ M1 Setup
- $\phi$ M = On and  $\phi$ M Source = Ext in  $\phi$ M2 Setup

### Remote command

**Adjust the DC offset for external modulation signal**  
**Command**

`:CALibration:EXTernal[1]|2:DC`

### Parameter

None

### Details

As for node `:EXTernal[1]|2`, select the external modulation signal for SG1 or the external modulation signal for SG2. Set as follows:

External modulation signal for SG1: `:EXTernal1` or `EXTernal`

External modulation signal for SG2: `:EXTernal2`

### Programming Example

To Adjust the DC offset for external modulation signal.

`CAL:EXT:DC`



## AM Phase Adjust: Phase Adjust

 or **Top**  **>Analog/Pulse>AM>AM1 Setup (AM2 Setup), Phase Adjust**

Adjusts a phase of internal AM modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F7 Phase Adjust** on the AM1 Setup (AM2 Setup) function menu to set with the **Phase Adjust** dialog box.

Range	-180 deg to +180 deg
Resolution	0.1 deg
Default	0 deg

**Remote command****Adjust the phase of internal AM modulation signal****Command**

```
[ :SOURce [1] | 2 ] :AM [1] | 2 :INTernal :FUNction [1] | 2 :POFFset
<phase>
```

**Query**

```
[ :SOURce [1] | 2 ] :AM [1] | 2 :INTernal :FUNction [1] | 2 :POFFset?
```

**Response**

```
<phase> Unit: deg
```

**Parameter**

<phase>	Phase of internal AM modulation signal
Range	-180 deg to +180 deg
Resolution	0.1 deg
Default	0 deg
Suffix code	DEG, When omitted: DEG

**Programming Example**

To set the phase of internal AM modulation signal to 10 deg.

```
AM:INT:FUNC:POFF 10
AM:INT:FUNC:POFF?
> 10.0
```

## 7.2.2 FM/φM

 or **Top**  **>Analog/Pulse>FM/φM**

Sets the settings related to FM (frequency) modulation or φM (phase) modulation.

Press **FM/φM** on the main function menu or **F2 FM/φM** on the Analog Mod function menu to open the FM/φM function menu.

**Notes:**

- The FM modulation and φM modulation cannot be set to on simultaneously.
- Settings related to FM modulation and φM modulation are disabled when Sweep/List is being executed.

**Table 7.2.2-1 FM/φM Function Menu**

Page	Key No.	Menu Display	Function
1	F1	FM/φM1 Setup	Sets the FM/φM1.
	F2	FM/φM2 Setup	Sets the FM/φM2. This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **FM/φM1 Setup (FM/φM2 Setup)** on the AM function menu to open the FM/φM1 (FM/φM2) function menu.

Example: To execute the FM modulation.

<Procedure>

1. Set the FM modulation to On with **F1 FM**.
2. Set the FM frequency deviation with **F2 FM Deviation**.
3. Set the FM modulation frequency with **F3 AM Rate**.
4. Press **RF Output On/Off** to light the LED to set the RF output to On.
5. Press **Mod On/Off** to light the LED to start the FM modulation.

Example: To execute the φM modulation.

<Procedure>

1. Selects Page 2 of M/φM1 (FM/φM2) Setup Function Menu.
2. Set the φM modulation to On with **F1 φM**.
3. Set the φM deviation angle with **F2 φM Deviation**.
4. Set the φM modulation frequency with **F3 φM Rate**.
5. Press **RF Output On/Off** to light the LED to set the RF output to On.
6. Press **Mod On/Off** to light the LED to start the φM modulation.

Table 7.2.2-1 FM/ $\phi$ M1 Setup / FM/ $\phi$ M2 Setup Function Menu

Page	Key No.	Menu Display	Function
1	F1	FM <u>Off</u> On	Enables/disables the FM (Frequency Modulation).
	F2	FM Deviation 1.0000 kHz	Sets the FM frequency deviation.
	F3	FM Rate 400.0 Hz	Sets the FM modulation frequency.
	F4	Setup FM Source	Sets the FM modulation signal. This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.
	F5	Phase Adjust 0.0 deg	Adjusts the phase of internal FM modulation signal. This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.
2	F1	$\phi$ M <u>Off</u> On	Sets the $\phi$ M (phase modulation) On/Off.
	F2	$\phi$ M Deviation 1.0000 kHz	Sets the $\phi$ M deviation angle.
	F3	$\phi$ M Rate 400.0 Hz	Sets the $\phi$ M modulation frequency.
	F4	Setup $\phi$ M Source	Sets the $\phi$ M modulation signal. This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.
	F5	Phase Adjust 0.0 deg	Adjusts the phase of internal FM modulation signal. This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.



## FM Deviation

 or **Top**  **>Analog/Pulse>FM/φM>FM/φM1 Setup (FM/φM2 Setup), FM Deviation**

The FM frequency deviation is set.

Press **F2 FM Deviation** on the FM/φM1 Setup (FM/φM2 Setup) function menu to set with the **FM Deviation** dialog box.

**Range**                      When FM Waveform is Sine:  
                                     0 Hz to  $(40 \text{ MHz} - \text{FMDeviation2nd}^{*1})^{*2}$ ,  
                                     or 0 Hz to  $(50 \text{ MHz} - \text{FM Rate})^{*3}$   
                                     the maximum is whichever smaller.  
                                     When FM Waveform is other than Sine:  
                                     0 Hz to 4 MHz,  
                                     or 0 Hz to  $(5 \text{ MHz} - \text{FM Rate})^{*4}$   
                                     or 0 Hz to  $(40 \text{ MHz} - \text{FMDeviation2nd}^{*1})^{*2}$   
                                     the maximum is the smallest of the three.

**Resolution**                      0.1 Hz

**Default**                              1 kHz (FM/φM1)  
     0 Hz (FM/φM2)

\*1: FM Deviation2nd is the frequency deviation of FM/φM2 available when MG3710A/MG3740A-080/180 is installed.


In FM Deviation2nd, the maximum value is calculated by applying FM Deviation.

\*2:  $\text{FM Deviation} + \text{FMDeviation2nd} \leq 40 \text{ MHz}$

\*3:  $\text{FM Rate} + \text{FM Deviation} \leq 50 \text{ MHz}$

\*4:  $\text{FM Rate} + \text{FM Deviation} \leq 5 \text{ MHz}$

When the FM modulation is executed for the CW signal with  $f_c$  [Hz], the signal below is created.



**Figure 7.2.2-1 FM Modulation**

**Remote command**

**Set the FM frequency deviation**

**Command**

`[ :SOURce[1] | 2 ] :FM[1] | 2 [ :DEViation ] <freq>`

**Query**

`[ :SOURce[1] | 2 ] :FM[1] | 2 [ :DEViation ] ?`

**Response**

`<freq>`                      Unit: HZ

**Parameter**

`<freq>`

FM frequency deviation

Range

When FM Waveform is Sine:

0 Hz to  $(40 \text{ MHz} - \text{FMDeviation2nd}^{*1})^{*2}$ ,  
or 0 Hz to  $(50 \text{ MHz} - \text{FM Rate})^{*3}$

the maximum is whichever smaller.

When FM Waveform is other than Sine:

0 Hz to 4 MHz,

or 0 Hz to  $(5 \text{ MHz} - \text{FM Rate})^{*4}$

or 0 Hz to  $(40 \text{ MHz} - \text{FMDeviation2nd}^{*1})^{*2}$

the maximum is the smallest of the three.

Resolution                      0.1 Hz

Default                            1 kHz

Suffix code                      HZ, KHZ, MHZ, GHZ, KZ, MZ, GZ

When omitted: HZ

**Programming Example**

To set the FM frequency deviation to 500 Hz.

`FM 500`

`FM?`

`> 500.0`

## FM modulation frequency: FM Rate

 or **Top** >  > **Analog/Pulse** > **FM/φM** > **FM/φM1 Setup (FM/φM2 Setup), FM Rate**

Sets the FM modulation frequency.

Press **F3 FM Rate** on the FM/φM1 Setup (FM/φM2 Setup) function menu to set with the **FM Rate** dialog box.

Range	When FM Waveform is Sine: 0.1 Hz to 40 MHz, or (50 MHz–FM Deviation), whichever smaller*1 When FM Waveform is other than Sine: 0.1 Hz to 4 MHz, or (5 MHz–FM Deviation), whichever smaller*2
Resolution	0.1 Hz
Default	400 Hz

\*1: FM Rate + FM Deviation ≤ 50 MHz

\*2: FM Rate + FM Deviation ≤ 5 MHz

## Remote command

## Set the FM modulation frequency

## Command

`[ :SOURce [1] | 2 ] :FM [1] | 2 :INTernal:FREQuency <freq>`

## Query

`[ :SOURce [1] | 2 ] :FM [1] | 2 :INTernal:FREQuency?`

## Response

<freq> Unit: HZ

## Parameter


<freq>	FM modulation frequency
Range	When FM Waveform is Sine: 0.1 Hz to 40 MHz, or (50 MHz–FM Deviation), whichever smaller*1 When FM Waveform is other than Sine: 0.1 Hz to 4 MHz, or (5 MHz–FM Deviation), whichever smaller*2
Resolution	0.1 Hz
Default	400 Hz
Suffix code	HZ, KHZ, MHZ, GHZ, KZ, MZ, GZ When omitted: HZ

**Programming Example**

To set the FM modulation frequency to 500 Hz.

```
FM:INT:FREQ 500
FM:INT:FREQ?
> 500.0
```

Setup FM Source

 or **Top** >  > **Analog/Pulse** > **FM/φM** > **FM/φM1 Setup (FM/φM2 Setup), Setup FM Source**

Sets the FM modulation signals.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.


Press **F4 Setup FM Source** on the FM/φM1 Setup (FM/φM2 Setup) function menu to open the Setup FM Source function menu.

**Table 7.2.2-2 Setup FM Source Function Menu**

Page	Key No.	Menu Display	Function
1	F1	FM Source <u>Int</u> Ext	Switches the internal modulation signal/external modulation signal.
	F2	Waveform Sine	Selects the waveform of the internal modulation signal. This can be selected when <b>Int</b> is selected in the FM source.
	F6	Coupling <u>DC</u> AC	Sets the DC coupling or AC coupling for the external modulation signal.
	F7	Impedance 600 Ω	Sets the termination for the external modulation signal.
	F8	Ext DC Cal	Adjusts the DC offset for the external modulation signal.



**Note:**

Because the external modulation signal has terminating resistance, some voltage may be generated even if the coupling is set to AC.





## Switching FM Source: FM Source

 or **Top**  **>Analog/Pulse>FM/φM>FM/φM1 Setup (FM/φM2 Setup)>Setup FM Source, FM Source**

Switches the FM modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F1 FM Source** on the Setup FM Source function menu for selection.

Int	Internal modulation signal (Default)
Ext	External modulation signal

**Remote command****Switch the FM modulation signal****Command**

```
[ :SOURce [1] | 2 ] :FM[1] | 2 :SOURce INT | INT1 | INT2 | EXT
```

**Query**

```
[ :SOURce [1] | 2 ] :FM[1] | 2 :SOURce?
```

**Response**

```
<type> INT or EXT
```

**Parameter**

<type>	Type
INT	Internal modulation signal (Default)
INT1	Internal modulation signal (Processed as INT)
INT2	Internal modulation signal (Processed as INT)
EXT	External modulation signal

**Programming Example**



To switch the FM modulation signal to the external modulation signal.

```
FM:SOUR EXT
```

```
FM:SOUR?
```

```
> EXT
```

## FM Waveform: Waveform

 or **Top**  **>Analog/Pulse>FM/φM>FM/φM1 Setup (FM/φM2 Setup)>Setup FM Source, Waveform**

Selects the waveform of the internal modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F2 Waveform** on the Setup FM Source function menu for selection. This can be set when **Int** is selected in the FM source.

Options	Sine (Sine wave)
	Triangle (Triangular waveform)
	Square (Square wave)
	Positive Ramp (Ramp wave (positive))
	Negative Ramp (Ramp wave (negative))

Default Sine

See Figure 7.2.1-3 for the types of selectable waveforms.

### Remote command

#### Select the waveform of the internal FM modulation signal

##### Command

```
[ :SOURce [1] | 2 ] :FM [1] | 2 :INTernal :FUNctIon [1] | 2 :SHAPE
SINE | TRIangle | SQUare | RAMP
```

##### Query

```
[ :SOURce [1] | 2 ] :FM [1] | 2 :INTernal :FUNctIon [1] | 2 :SHAPE?
```

##### Response

```
<type> SINE, TRI, SQU, RAMP
```

##### Parameter

<type>	waveform
SINE	Sine (Default)
TRIangle	Triangle
SQUare	Square
RAMP	Ramp

##### Programming Example

To set the waveform of the internal FM modulation signal to the Triangle.

```
FM:INT:FUNC:SHAP TRI
FM:INT:FUNC:SHAP?
> TRI
```

**Remote command****Select the shape of the ramp wave****Command**

```
[ :SOURce[1] | 2 ] :FM[1] | 2 :INTernal:FUNCTion[1] | 2 :SHAPE:RAMP
POSitive|NEGative
```

**Query**

```
[ :SOURce[1] | 2 ] :FM[1] | 2 :INTernal:FUNCTion[1] | 2 :SHAPE:RAMP
?
```

**Response**

```
<type> POS, NEG
```

**Parameter**

```
<type> waveform
  POSitive Positive Ramp (Default)
  NEGative Negative Ramp
```

**Programming Example**

To set the shape of the ramp wave to the negative ramp.

```
FM:INT:FUNC:SHAP RAMP
FM:INT:FUNC:SHAP:RAMP NEG
FM:INT:FUNC:SHAP:RAMP?
> NEG
```

**Coupling: Coupling**

 or **Top**  **>Analog/Pulse>FM/φM>FM/φM1 Setup (FM/φM2 Setup)>Setup FM Source, Coupling**

Sets the DC coupling or AC coupling for the external modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F6 Coupling** on the Setup FM Source function menu for selection.

```
DC DC coupling (Default)
AC AC coupling
```

**Remote command****Set the DC coupling or AC coupling for the external modulation****Command**

```
[ :SOURce[1] | 2 ] :EXTMod:COUPling DC|AC
```

**Query**

```
[ :SOURce[1] | 2 ] :EXTMod:COUPling?
```

**Response**

```
<type> DC, AC
```

**Parameter**



<type>	Coupling
DC	DC coupling (Default)
AC	AC coupling

**Programming Example**

To set the DC coupling for the external modulation.

```
EXTM:COUP DC
EXTM:COUP?
> DC
```

Impedance: Impedance

 or **Top**  **>Analog/Pulse>FM/φM>FM/φM1 Setup (FM/φM2 Setup)>Setup FM Source, Impedance**

Sets the termination for the external modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F7 Impedance** on the Setup FM Source function menu for selection.

50 Ω	50 Ω termination
600 Ω	600 Ω termination (Default)
Hi-Z	High impedance (100 kΩ/70 pF)

**Remote command**

**Set the termination for the external modulation signal**

**Command**

```
[ :SOURce [1] | 2 ] :EXTMod:IMPedance 50 | 600 | HIZ
```

**Query**

```
[ :SOURce [1] | 2 ] :EXTMod:IMPedance?
```

**Response**

```
<type> 50, 600, HIZ
```

**Parameter**



<type>	Termination
50	50 Ω termination
600	600 Ω termination (Default)
HIZ	High impedance (100 kΩ/70 pF)

**Programming Example**

To set the 50 Ω termination for the external modulation signal.

```
EXTM:IMP 50
EXTM:IMP?
> 50
```

## Ext DC Cal: Ext DC Cal

 or **Top**  **>Analog/Pulse>FM/φM>FM/φM1 Setup (FM/φM2 Setup)>Setup FM Source, Ext DC Cal**

Adjusts the DC offset for external modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

This can be used when in the modulation output status (setting either AM, FM, φM, or Pulse modulations to On, and Mod to On).

When one of the following conditions is met, press **F8 Ext DC Cal** on the Setup FM Source function menu to adjust the DC offset.

- AM = On and AM Source = Ext in AM1 Setup
- AM = On and AM Source = Ext in AM2 Setup
- FM = On and FM Source = Ext in FM1 Setup
- FM = On and FM Source = Ext in FM2 Setup
- φM = On and φM Source = Ext in φM1 Setup
- φM = On and φM Source = Ext in φM2 Setup

**Remote command****Adjust the DC offset for external modulation signal****Command**

```
:CALibration:EXTernal[1]|2:DC
```

**Parameter**

None

**Details**

As for node :EXTernal[1]|2, select the external modulation signal for SG1 or the external modulation signal for SG2 .Set as follows:

External modulation signal for SG1: :EXTernal1 or EXTernal

External modulation signal for SG2: :EXTernal2

**Programming Example**

To Adjust the DC offset for external modulation signal.

```
CAL:EXT:DC
```

## FM Phase Adjust: Phase Adjust

 or **Top**  **>Analog/Pulse>FM/φM>FM/φM1 Setup (FM/φM2 Setup), Phase Adjust**

Adjusts a phase of internal FM modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F5 Phase Adjust** on the FM/φM1 Setup (FM/φM2 Setup) function menu to set with the **Phase Adjust** dialog box.

Range	-180 deg to +180 deg
Resolution	0.1 deg
Default	0 deg

### Remote command

**Adjust the phase of internal FM modulation signal**

#### Command

```
[ :SOURce [1] | 2 ] :FM[1] | 2 :INTernal :FUNction[1] | 2 :POFFset
<phase>
```

#### Query

```
[ :SOURce [1] | 2 ] :FM[1] | 2 :INTernal :FUNction[1] | 2 :POFFset?
```

#### Response

```
<phase> Unit: deg
```

#### Parameter

<phase>	Phase of internal FM modulation signal
Range	-180 deg to +180 deg
Resolution	0.1 deg
Default	0 deg
Suffix code	DEG, When omitted: DEG

#### Programming Example

To set the phase of internal FM modulation signal to 10 deg.

```
FM:INT:FUNC:POFF 10
FM:INT:FUNC:POFF?
> 10.0
```

$\phi$ M modulation On/Off:  $\phi$ M

 or Top >  > Analog/Pulse > FM/ $\phi$ M > FM/ $\phi$ M1 Setup  
(FM/ $\phi$ M2 Setup) > ,  $\phi$ M

Enables/disables the  $\phi$ M (phase) modulation.

Press **F1  $\phi$ M** in the second page of the FM/ $\phi$ M1 Setup (FM/ $\phi$ M2 Setup) function menu to set On/Off.

Off Disables  $\phi$ M Modulation (Default).

On Enables  $\phi$ M Modulation.

The  $\phi$ M modulation cannot be set to On at the same time with the FM modulation.

#### Remote command

#### Enable/disable the $\phi$ M modulation

##### Command

```
[ :SOURce [1] | 2 ] :PM [1] | 2 :STATe <boolean>
```

##### Query

```
[ :SOURce [1] | 2 ] :PM [1] | 2 :STATe?
```

##### Response

```
<boolean> 0 or 1
```

##### Parameter

```
<boolean>  $\phi$ M Modulation On/Off  
OFF | 0 Disables  $\phi$ M Modulation (Default).  
ON | 1 Enables  $\phi$ M Modulation.
```

#### Programming Example

To set the  $\phi$ M modulation to On.

```
PM:STAT ON
```

```
PM:STAT?
```

```
> 1
```

$\phi$ M Deviation

**FM/PM** or **Top**  $\rightarrow$  **Analog/Pulse**  $\rightarrow$  **FM/ $\phi$ M**  $\rightarrow$  **FM/ $\phi$ M1 Setup (FM/ $\phi$ M2 Setup)**  $\rightarrow$   **$\phi$ M Deviation**

Sets the  $\phi$ M deviation angle.

Press **F2  $\phi$ M Deviation** in the second page of the FM/ $\phi$ M1 Setup (FM/ $\phi$ M2 Setup) function menu to set with the  **$\phi$ M Deviation** dialog box.

Range	When $\phi$ M Waveform is Sine: 0 rad to 160 rad, or (40 MHz $\div$ $\phi$ M Rate) rad, whichever smaller*1 When $\phi$ M Waveform is other than Sine: 0 rad to 160 rad, or (4 MHz $\div$ $\phi$ M Rate) rad, whichever smaller*2
Resolution	0.001 rad
Default	0 rad

- \*1:  $\phi$ M Rate  $\times$   $\phi$ M Deviation  $\leq$  40 MHz
- \*2:  $\phi$ M Rate  $\times$   $\phi$ M Deviation  $\leq$  4 MHz

When the  $\phi$ M modulation is executed for the CW signal, the signal below is created.




Figure 7.2.2-2  $\phi$ M Modulation

Remote command

Set the  $\phi$ M deviation angle

Command

`[ :SOURce[1] | 2 ] :PM[1] | 2 [ :DEViation ] <ext_numeric>`

Query

`[ :SOURce[1] | 2 ] :PM[1] | 2 [ :DEViation ] ?`

Response

`<ext_numeric>` Unit: rad



**Parameter**


<ext_numeric>	$\phi$ M deviation angle
Range	When $\phi$ M Waveform is Sine: 0 rad to 160 rad, or (40 MHz $\div$ $\phi$ M Rate) rad, whichever smaller* <sup>1</sup> When $\phi$ M Waveform is other than Sine: 0 rad to 160 rad, or (4 MHz $\div$ $\phi$ M Rate) rad, whichever smaller* <sup>2</sup>
Resolution	0.001 rad
Default	0 rad
Suffix code	None

**Programming Example**

To set the  $\phi$ M frequency deviation to 50 rad.

```
PM 50
PM?
> 50.000
```

$\phi$ M modulation frequency:  $\phi$ M Rate

 or Top>  > Analog/Pulse> FM/ $\phi$ M> FM/ $\phi$ M1 Setup  
(FM/ $\phi$ M2 Setup)> ,  $\phi$ M Rate

Sets the  $\phi$ M modulation frequency.

Press **F3  $\phi$ M Rate** in the second page of the FM/ $\phi$ M1 Setup (FM/ $\phi$ M2 Setup) function menu to set with the  **$\phi$ M Rate** dialog box.

Range	When $\phi$ M Waveform is Sine: 0.1 Hz to 40 MHz, or (40 MHz $\div$ $\phi$ M Deviation) MHz, whichever smaller* <sup>1</sup> When $\phi$ M Waveform is other than Sine: 0.1 Hz to 4 MHz, or (4 MHz $\div$ $\phi$ M Deviation) MHz, whichever smaller* <sup>2</sup>
Resolution	0.1 Hz
Default	400 Hz

\*1:  $\phi$ M Rate  $\times$   $\phi$ M Deviation  $\leq$  40 MHz

\*2:  $\phi$ M Rate  $\times$   $\phi$ M Deviation  $\leq$  4 MHz

**Remote command**

**Set the  $\phi$ M modulation frequency**

**Command**

`[ :SOURce[1] | 2 ] :PM[1] | 2 :INTernal:FREQuency <freq>`

**Query**

`[ :SOURce[1] | 2 ] :PM[1] | 2 :INTernal:FREQuency?`

**Response**

`<freq>`                      Unit: HZ

**Parameter**

`<freq>`                       $\phi$ M modulation frequency

Range                      When  $\phi$ M Waveform is Sine:  
                                    0.1 Hz to 40 MHz,  
                                    or (40 MHz  $\div$   $\phi$ M Deviation) MHz,  
                                    whichever smaller

                                    When  $\phi$ M Waveform is other than Sine:  
                                    0.1 Hz to 4 MHz,  
                                    or (4 MHz  $\div$   $\phi$ M Deviation) MHz,  
                                    whichever smaller

Resolution                  0.1 Hz

Default                      400 Hz

Suffix code                  HZ, KHZ, MHZ, GHZ, KZ, MZ, GZ  
                                    When omitted: HZ

**Programming Example**

To set the  $\phi$ M modulation frequency to 500 Hz.

`PM:INT:FREQ 500`

`PM:INT:FREQ?`

`> 500.0`

Setup  $\phi$ M Source

**AM** or **Top** > **→** > **Analog/Pulse** > **FM/ $\phi$ M** > **FM/ $\phi$ M1 Setup**  
**(FM/ $\phi$ M2 Setup)** > **→**, **Setup  $\phi$ M Source**

Sets the  $\phi$ M modulation signals.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.


Press **F4 Setup  $\phi$ M Source** in the second page of the FM/ $\phi$ M1 Setup (FM/ $\phi$ M2 Setup) function menu to open the Setup  $\phi$ M Source function menu.

**Table 7.2.2-3 Setup  $\phi$ M Source Function Menu**

Page	Key No.	Menu Display	Function
1	F1	$\phi$ M Source <u>Int</u> Ext	Switch the internal modulation signal/external modulation signal.
	F2	Waveform Sine	Selects the waveform of the internal modulation signal. This can be selected when <b>Int</b> is selected in the $\phi$ M source.
	F6	Coupling <u>DC</u> AC	Sets the DC coupling or AC coupling for the external modulation signal.
	F7	Impedance 600 $\Omega$	Sets the termination for the external modulation signal.
	F8	Ext DC Cal	Adjusts the DC offset for the external modulation signal.

**Note:**

Because the external modulation signal has terminating resistance, some voltage may be generated even if the coupling is set to AC.



### Switching $\phi$ M Source: $\phi$ M Source

 or **Top**  **>Analog/Pulse>FM/ $\phi$ M>FM/ $\phi$ M1 Setup (FM/ $\phi$ M2 Setup)>**  **>Setup  $\phi$ M Source,  $\phi$ M Source**

Switches the  $\phi$ M modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F1  $\phi$ M Source** on the Setup  $\phi$ M Source function menu for selection.

Int	Internal modulation signal (Default)
Ext	External modulation signal

#### Remote command

#### Switch the $\phi$ M modulation signal

##### Command

[ :SOURce [1] | 2 ] :PM[1] | 2 :SOURce INT | INT1 | INT2 | EXT

##### Query

[ :SOURce [1] | 2 ] :PM[1] | 2 :SOURce?

##### Response

<type> INT or EXT

##### Parameter

<type>	Type
INT	Internal modulation signal (Default)
INT1	Internal modulation signal (Processed as INT)
INT2	Internal modulation signal (Processed as INT)
EXT	External modulation signal

#### Programming Example

To switch the  $\phi$ M modulation signal to the external modulation signal.

```
PM:SOUR EXT
```

```
PM:SOUR?
```

```
> EXT
```

$\phi$ M Waveform: Waveform

 or **Top**  **Analog/Pulse**  **FM/ $\phi$ M**  **FM/ $\phi$ M1 Setup (FM/ $\phi$ M2 Setup)**  **Setup  $\phi$ M Source, Waveform**

Selects the waveform of the  $\phi$ M internal modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F2 Waveform** on the Setup  $\phi$ M Source function menu for selection. This can be set when **Int** is selected in the  $\phi$ M source.

Options	Sine (Sine wave)
	Triangle (Triangular waveform)
	Square (Square wave)
	Positive Ramp (Ramp wave (positive))
	Negative Ramp (Ramp wave (negative))

Default Sine

See Figure 7.2.1-3 for the types of selectable waveforms.

**Remote command****Select the waveform of the internal  $\phi$ M modulation signal****Command**

```
[ :SOURce[1] | 2 ] :PM[1] | 2 :INTernal:FUNCTion[1] | 2 :SHAPE
SINE | TRIangle | SQUare | RAMP
```

**Query**

```
[ :SOURce[1] | 2 ] :PM[1] | 2 :INTernal:FUNCTion[1] | 2 :SHAPE?
```

**Response**

```
<type> SINE, TRI, SQU, RAMP
```

**Parameter**

<type>	waveform
SINE	Sine (Default)
TRIangle	Triangle
SQUare	Square
RAMP	Ramp

**Programming Example**

To set the waveform of the internal  $\phi$ M modulation signal to the Triangle.

```
PM:INT:FUNC:SHAP TRI
PM:INT:FUNC:SHAP?
> TRI
```

**Remote command**

**Select the shape of the ramp wave**

**Command**

[ :SOURce[1] | 2 ] :PM[1] | 2 :INTernal:FUNCTion[1] | 2 :SHAPE:RAMP  
 POSitive|NEGative

**Query**

[ :SOURce[1] | 2 ] :PM[1] | 2 :INTernal:FUNCTion[1] | 2 :SHAPE:RAMP  
 ?

**Response**

<type> POS, NEG

**Parameter**

<type>	waveform
POSitive	Positive Ramp (Default)
NEGative	Negative Ramp

**Programming Example**

To set the shape of the ramp wave to the negative ramp.

```
PM:INT:FUNC:SHAP RAMP
PM:INT:FUNC:SHAP:RAMP NEG
PM:INT:FUNC:SHAP:RAMP?
> NEG
```

Coupling: Coupling

 or **Top**  **Analog/Pulse**  **FM/φM**  **FM/φM1 Setup**  
**(FM/φM2 Setup)**  **Setup φM Source, Coupling**

Sets the DC coupling or AC coupling for the external modulation signal. This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F6 Coupling** on the Setup φM Source function menu for selection.

DC	DC coupling (Default)
AC	AC coupling

**Remote command**

**Set the DC coupling or AC coupling for the external modulation**

**Command**

[ :SOURce[1] | 2 ] :EXTMod:COUPLing DC|AC

**Query**

[ :SOURce[1] | 2 ] :EXTMod:COUPLing?

**Response**

<type> DC, AC

**Parameter**

<type>	Coupling
DC	DC coupling (Default)
AC	AC coupling

**Programming Example**

To set the DC coupling for the external modulation.

```
EXTM:COUP DC
```

```
EXTM:COUP?
```

```
> DC
```

## Impedance: Impedance

 or **Top**  **Analog/Pulse**  **FM/φM**  **FM/φM1 Setup**  
**(FM/φM2 Setup)**  **Setup φM Source, Impedance**

Sets the termination for the external modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F7 Impedance** on the Setup φM Source function menu for selection.

50 Ω	50 Ω termination
600 Ω	600 Ω termination (Default)
Hi-Z	High impedance (100 kΩ/70 pF)

**Remote command****Set the termination for the external modulation signal****Command**

```
[ :SOURce [1] | 2 ] :EXTMod:IMPedance 50|600|HIZ
```

**Query**

```
[ :SOURce [1] | 2 ] :EXTMod:IMPedance?
```

**Response**

```
<type> 50,600,HIZ
```

**Parameter**

<type>	Termination
50	50 Ω termination
600	600 Ω termination (Default)
HIZ	High impedance (100 kΩ/70 pF)

**Programming Example**

To set the 50 Ω termination for the external modulation signal.

```
EXTM:IMP 50
```

```
EXTM:IMP?
```

```
> 50
```

## Ext DC Cal: Ext DC Cal

 or **Top** >  > **Analog/Pulse** > **FM/φM** > **FM/φM1 Setup**  
**(FM/φM2 Setup)** >  > **Setup φM Source, Ext DC Cal**

Adjusts the DC offset for external modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

This can be used when in the modulation output status (setting either AM, FM, φM, or Pulse modulations to On, and Mod to On).

When one of the following conditions is met, press **F8 Ext DC Cal** on the Setup φM Source function menu to adjust the DC offset.

- AM = On and AM Source = Ext in AM1 Setup
- AM = On and AM Source = Ext in AM2 Setup
- FM = On and FM Source = Ext in FM1 Setup
- FM = On and FM Source = Ext in FM2 Setup
- φM = On and φM Source = Ext in φM1 Setup
- φM = On and φM Source = Ext in φM2 Setup

### Remote command

#### Adjust the DC offset for external modulation signal

##### Command

`:CALibration:EXTernal[1]|2:DC`

##### Parameter

None

##### Details

As for node `:EXTernal[1]|2`, select the external modulation signal for SG1 or the external modulation signal for SG2. Set as follows:

External modulation signal for SG1: `:EXTernal1` or `EXTernal`

External modulation signal for SG2: `:EXTernal2`


##### Programming Example

To Adjust the DC offset for external modulation signal.

`CAL:EXT:DC`



$\phi$ M Phase Adjust: Phase Adjust

 or **Top**  **>Analog/Pulse>FM/ $\phi$ M>FM/ $\phi$ M1 Setup (FM/ $\phi$ M2 Setup)>**  **, Phase Adjust**

Adjusts a phase of internal  $\phi$ M modulation signal.

This is available only when additional analog modulation input option (MG3710A/MG3740A-050/080/150/180) is installed.

Press **F5 Phase Adjust** in the second page of the FM/ $\phi$ M1 Setup (FM/ $\phi$ M2 Setup) function menu to set with the **Phase Adjust** dialog box.

Range	-180 deg to +180 deg
Resolution	0.1 deg
Default	0 deg

**Remote command****Adjust the phase of internal  $\phi$ M modulation signal****Command**

```
[ :SOURce [1] | 2 ] :PM [1] | 2 :INTernal :FUNction [1] | 2 :POFFset
<phase>
```

**Query**

```
[ :SOURce [1] | 2 ] :PM [1] | 2 :INTernal :FUNction [1] | 2 :POFFset?
```

**Response**

```
<phase> Unit: deg
```

**Parameter**

<phase>	Phase of internal $\phi$ M modulation signal
Range	-180 deg to +180 deg
Resolution	0.1 deg
Default	0 deg
Suffix code	DEG, When omitted: DEG

**Programming Example**

To set the phase of internal  $\phi$ M modulation signal to 10 deg.

```
PM:INT:FUNC:POFF 10
PM:INT:FUNC:POFF?
> 10.0
```

### 7.2.3 Pulse

**Pulse** or **Top** → **Analog/Pulse** → **Pulse**

Sets the settings related to Pulse modulation.

Press **Pulse** of the main function key or **F3 Pulse** on the Analog Mod function menu to display the Pulse function menu.

Settings related to Pulse modulation are disabled when Sweep/List is being executed.

The pulse modulation can be executed as follows:

Pulse modulation with the internal signal


Set it with **Pulse Source** in the Pulse function menu.

Pulse modulation with RF Gate

For the pulse modulation method with the pulse modulation control bit (RF Gate) added to the waveform pattern, refer to 4.5.5 “Input file format” in the *MG3700A/MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)*, and for the RF Gate setting method, refer to 7.3.7 “RF Gate” in this document.

Pulse modulation with the external signal

When the external signal is used, select **Ext Pulse** with the **Pulse Source** function menu in the Pulse function menu to input the modulated signal from the AUX connector on the rear panel. Refer to Table 3.1.2-1 “AUX Connectors”.



**Figure 7.2.3-1 External Pulse Modulated Signal Input (Pulse Mod) Connector**

Use the following terminals of the AUX connector to execute the Pulse modulation with the external signal.

- Pulse Mod terminal The Pulse modulation signal (TTL level and DC-coupling) is input.

Example: To execute the Pulse modulation.

1. Set the Pulse modulation to On with **F1 Pulse**.
2. Select the Pulse modulation signal source with **F2 Pulse Source**.
3. Set the settings of **F3 Pulse Rate** to **F8 Pulse 2 Width** according to the Pulse modulation signal source.
4. Set the output polarity of Pulse Sync signal and Pulse Video signal with **F1 Ext. Out Polarity** in Page 2.
5. Set the polarity of the signal input from the Pulse Mod connector with **F2 Ext. In Polarity** in Page 2.
6. Press **RF Output On/Off** to light the LED to set the RF output to On.
7. Press **Mod On/Off** to light the LED to start the Pulse modulation.

**Table 7.2.3-1 Pulse Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Pulse <u>Off</u> On	Enables/disables the Pulse modulation.
	F2	Pulse Source Freerun	Selects the Pulse modulation signal source.
	F3	Pulse Rate 400.0 Hz	Sets the Pulse modulation frequency.
	F4	Pulse Period 4.00 $\mu$ s	Sets the Pulse modulation period.
	F5	Pulse Delay 0.00000000 s	Sets the Pulse modulation delay time after the trigger event.
	F6	Pulse Width 2.00 $\mu$ s	Sets the Pulse modulation width.
	F7	Pulse 2 Delay 0.00000000 s	Sets the delay time of the second Pulse after the first Pulse.
	F8	Pulse 2 Width 2.00 $\mu$ s	Sets the second Pulse width.
2	F1	Ext Out Polarity <u>Positive</u> Negative	Selects the polarity of the Pulse Sync signal and Pulse Video signal.
	F2	Ext In Polarity <u>Positive</u> Negative	Selects the polarity of the signal input from the Pulse Mod terminal.

## Pulse

 or **Top**  **>Analog/Pulse>Pulse,Pulse**

Enables/disables the Pulse modulation.

Press **F1 Pulse** on the Pulse function menu to set On/Off.

Off                                      Disables Pulse modulation (Default).  
On                                         Enables Pulse modulation.

### Remote command

#### Enable/disable the Pulse modulation

##### Command

`[ :SOURce [1] | 2 ] :PULM:STATe <boolean>`

##### Query

`[ :SOURce [1] | 2 ] :PULM:STATe?`

##### Response

`<boolean>`                              0 or 1

##### Parameter

`<boolean>`                              Pulse Modulation On/Off  
OFF|0                                    Disables Pulse modulation (Default).  
ON|1                                     Enables Pulse modulation.

#### Programming Example

To set the Pulse modulation to On.

```
PULM:STAT ON
PULM:STAT?
> 1
```

Pulse Source

**Pulse** or **Top** → **Analog/Pulse>Pulse, Pulse Source**

Selects the Pulse modulation signal source.

Press **F2 Pulse Source** on the Pulse function menu to open the Pulse Source function menu for selection.

**Table 7.2.3-2 Pulse Source Function Menu**




Page	Key No.	Menu Display	Function
1	F1	Square	<p>Internal freerun pulse string with 50% of duty cycle. The period is set with Pulse Rate.</p>  <p>The diagram shows a square wave pulse. A horizontal arrow above the pulse indicates the period, labeled <math>1/PulseRate</math>. The pulse width is approximately half the period. The horizontal axis is labeled 'Time'.</p>
	F2	Freerun	<p>Internal freerun pulse string (Default). The period and pulse width are set with Pulse Period and Pulse Width.</p>  <p>The diagram shows a square wave pulse. A horizontal arrow above the pulse indicates the full period, labeled 'PulsePeriod'. A shorter horizontal arrow above the pulse indicates the pulse width, labeled 'PulseWidth'. The horizontal axis is labeled 'Time'.</p>
	F3	Triggered	<p>Generates the pulse in synchronization with the trigger event. The delay time after the trigger event and pulse width are set with Pulse Delay and Pulse Width.</p>  <p>The diagram shows a 'Trigger' signal (a square wave) and a resulting pulse. The pulse starts after a 'PulseDelay' from the rising edge of the trigger. The pulse width is labeled 'PulseWidth'. Below the trigger signal, shaded rectangular areas indicate that trigger inputs occurring between the trigger event and the pulse completion are ignored. The horizontal axis is labeled 'Time'.</p>

Table 7.2.3-2 Pulse Source Function Menu (Cont'd)





Page	Key No.	Menu Display	Function
	F4	Adjustable Doublet	<p>Generates two pulses in synchronization with the trigger event.</p> <p>The delay time after the trigger event and pulse width are set with Pulse Delay and Pulse 2 Delay, and Pulse Width and Pulse 2 Width. The second pulse delay is based on the first pulse rise.</p>  <p>Trigger inputs executed between the trigger input and the pulse completion are ignored.</p>
	F5	Trigger Doublet	<p>Generates two pulses in synchronization with the trigger event.</p> <p>The delay time after the trigger event and pulse width are set with Pulse Delay and Pulse Width. The first pulse synchronizes with the external trigger signal. The second pulse delay is based on the first pulse rise.</p>  <p>Trigger inputs executed between the trigger input and the pulse completion are ignored.</p>

Table 7.2.3-2 Pulse Source Function Menu (Cont'd)

Page	Key No.	Menu Display	Function
	F6	Gated	<p>Generates the internal pulse string. However, pulses are valid only when the trigger is being input. The period and pulse width are set with Pulse Period and Pulse Width.</p> 
	F7	Ext Pulse	<p>Generates the pulse signal in synchronization with the external trigger signal.</p> 

**Note:**

For specifications of pulse signal, refer to Appendix A, subsection “<Analog modulation/Pulse modulation>”.

**Remote command**

**Select the Pulse modulation signal source from Freerun or Ext Pulse Command**

`[ :SOURCE[1] | 2 ] :PULM:SOURce INTernal|EXTernal`

**Query**

`[ :SOURCE[1] | 2 ] :PULM:SOURce?`

**Response**

`<type>` INT or EXT

**Parameter**

<code>&lt;type&gt;</code>	Signal source
INTernal	Freerun (Default)
EXTernal	Ext Pulse

**Programming Example**

To set the Pulse modulation signal source to Freerun.

`PULM:SOUR INT`

`PULM:SOUR?`

`> INT`

**Remote command**

**Select the Pulse modulation signal source from seven types Command**

`[ :SOURCE[1] | 2 ] :PULM:SOURce:INTernal  
SQUare|FRUN|TRIGgered|ADouBlet|DOUBlet|GATed|EXTPulse`

**Query**

`[ :SOURCE[1] | 2 ] :PULM:SOURce:INTernal?`

**Response**

`<type>` SQU, FRUN, TRIG, ADO, DOUB, GAT or EXTP

**Parameter**

<code>&lt;type&gt;</code>	Signal source
SQUare	Square
FRUN	Freerun (Default)
TRIGgered	Triggered
ADouBlet	Adjustable Doublet
DOUBlet	Trigger Doublet
GATed	Gated
EXTPulse	Ext Pulse



**Programming Example**

To set the Pulse modulation signal source to Freerun.

```
PULM:SOUR:INT FRUN
PULM:SOUR:INT?
> FRUN
```

**Pulse Rate**

 or **Top**  **Analog/Pulse** **Pulse, Pulse Rate**

Sets the Pulse modulation frequency.

Press **F3 Pulse Rate** on the Pulse function menu to set with the **Pulse Rate** dialog box. This can be set when **Square** is selected at **Pulse Source**.

Range	0.1 Hz to 10 MHz
Resolution	0.1 Hz
Default	400 Hz

**Remote command****Set the Pulse modulation frequency****Command**

```
[ :SOURce [1] | 2 ] :PULM:INTernal:FREQuency <freq>
```

**Query**

```
[ :SOURce [1] | 2 ] :PULM:INTernal:FREQuency?
```

**Response**

```
<freq> Unit: HZ
```

**Parameter**

<freq>	Frequency
Range	0.1 Hz to 10 MHz
Resolution	0.1 Hz
Default	400 Hz
Suffix code	HZ, KHZ, MHZ, GHZ, KZ, MZ, GZ When omitted: HZ

**Details**

This can be set when **Square** is selected at Pulse modulation signal source.

**Programming Example**

To set the Pulse modulation frequency to 500 Hz.

```
PULM:INT:FREQ 500
PULM:INT:FREQ?
> 500.0
```

## Pulse Period

 or **Top**  **>Analog/Pulse>Pulse,Pulse Period**

Sets the Pulse modulation period.

Press **F4 Pulse Period** on the Pulse function menu to set with the **Pulse Period** dialog box. This can be set when **Freerun,Gated** is selected at Pulse Source.

Range	10 ns to 20 s
Resolution	10 ns
Default	4 $\mu$ s

### Remote command

#### Set the Pulse modulation period

##### Command

```
[ :SOURCE[1] | 2 ] :PULM:INTernal:PERiod <time>
```

##### Query

```
[ :SOURCE[1] | 2 ] :PULM:INTernal:PERiod?
```

##### Response

```
<time> Unit: S
```

##### Parameter

<time>	Period
Range	10 ns to 20 s
Resolution	10 ns
Default	4 $\mu$ s
Suffix code	S, MS, US, NS, PS, When omitted: S

##### Details

This can be set when **Freerun, Gated** is selected at Pulse modulation signal source.

##### Programming Example

To set the Pulse modulation period to 15  $\mu$ s.

```
PULM:INT:PER 15US
```

```
PULM:INT:PER?
```

```
> 0.00001500
```

## Pulse Delay

 or **Top**  **>Analog/Pulse>Pulse, Pulse Delay**

Sets the Pulse modulation delay time after the trigger event.

Press **F5 Pulse Delay** on the Pulse function menu to set with the **Pulse Delay** dialog box. This can be set when **Triggered, Adjustable Doublet, Trigger Doublet** is selected at Pulse Source.

Range	0 s to 20 s – Pulse Width
Resolution	10 ns
Default	0 s

## Remote command

**Set the Pulse modulation delay time****Command**

```
[ :SOURce [1] | 2 ] :PULM:INTernal:DELay [1] | 2 <time>
```

**Query**

```
[ :SOURce [1] | 2 ] :PULM:INTernal:DELay [1] | 2 ?
```

**Response**

```
<time> Unit: S
```

**Parameter**

<time>	Delay time
Range	0 s to 20 s – Pulse Width
Resolution	10 ns
Default	0 s
Suffix code	S, MS, US, NS, PS, When omitted: S

**Details**

This can be set when **Triggered, Adjustable Doublet, Trigger Doublet** is selected at Pulse modulation signal source.

As for node :DELay [1] | 2, select Pulse 1 Delay or Pulse 2 Delay. Set as follows:

Pulse Delay: :DELay1 or :DELay

Pulse 2 Delay: :DELay2.

**Programming Example**

To set the delay time after the first Pulse modulation trigger event to 15  $\mu$ s.

```
PULM:INT:DEL 15US
```

```
PULM:INT:DEL?
```

```
> 0.00001500
```

## Pulse Width

 or **Top**  **>Analog/Pulse>Pulse, Pulse Width**

Sets the Pulse modulation width.

Press **F6 Pulse Width** on the Pulse function menu to set with the **Pulse Width** dialog box. This can be set when **Freerun, Triggered, Adjustable Doublet, Trigger Doublet, Gated** is selected at Pulse Source.

Setting range

Lower limit 10 ns

Upper limit Pulse Period\*<sup>1</sup>

20 s – Pulse Delay\*<sup>2</sup>

\*1: When Pulse Source is set to Freerun or Gated

\*2: When Pulse Source is Triggered, Adjustable Doublet, or Trigger Doublet

Resolution 10 ns

Default 2 μs

### Remote command

#### Set the Pulse modulation width

##### Command

`[ :SOURce [1] | 2 ] :PULM:INTernal:PWIDth [1] | 2 <time>`

##### Query

`[ :SOURce [1] | 2 ] :PULM:INTernal:PWIDth [1] | 2 ?`

##### Response

`<time>` Unit: S

##### Parameter

`<time>` Pulse modulation width

Setting range

Lower limit 10 ns

Upper limit Pulse Period

(When Pulse Source is set to Freerun or Gated)

20 s – Pulse Delay

(When Pulse Source is Triggered, Adjustable Doublet, or Trigger Doublet)

Resolution 10 ns

Default 2 μs

Suffix code S, MS, US, NS, PS, When omitted: S

**Details**

This can be set when **Freerun, Triggered, Adjustable Doublet, Trigger Doublet, Gated** is selected at Pulse modulation signal source.

As for node :PWIDth[1]|2, select Pulse Width or Pulse 2 Width. Set as follows:

Pulse Width: :PWIDth1 or :PWIDth

Pulse 2 Width: :PWIDth2

**Programming Example**

To set the first Pulse modulation width to 5  $\mu$ s.

```
PULM:INT:PWID 5US
PULM:INT:PWID?
> 0.00000500
```

**Pulse 2 Delay**

 or **Top**  **Analog/Pulse>Pulse, Pulse 2 Delay**

Sets the delay time of the second Pulse after the first Pulse.

Press **F7 Pulse 2 Delay** on the Pulse function menu to set with the **Pulse 2 Delay** dialog box. This can be set when **Adjustable Doublet** is selected at **Pulse Source**.

Range	0 s to 20 s – Pulse 2 Width – Pulse Delay
Resolution	10 ns
Default	0 s

**Remote command****Set the delay time of the second Pulse after the first Pulse Command**

```
[ :SOURce[1]|2 ] :PULM:INTernal:DELAy[1]|2 <time>
```

**Query**

```
[ :SOURce[1]|2 ] :PULM:INTernal:DELAy[1]|2?
```

**Response**

```
<time> Unit: S
```

**Parameter**

<time>	The delay time from the first Pulse to the second Pulse
Range	0 s to 20 s – Pulse 2 Width – Pulse Delay
Resolution	10 ns
Default	0 s
Suffix code	S, MS, US, NS, PS, When omitted: S

**Details**

This can be set when **Adjustable Doublet** is selected at Pulse modulation signal source.

As for node :DElAy[1] | 2, select Pulse Delay or Pulse 2 Delay. Set as follows:

Pulse Delay:: :DElAy1 or :DElAy.

Pulse 2 Delay:: :DElAy2.

**Programming Example**

To set the delay time from the first Pulse to the second Pulse to 5  $\mu$ s.

```
PULM:INT:DEL2 5US
PULM:INT:DEL2?
> 0.00000500
```

**Pulse 2 Width**

 or **Top**  **Analog/Pulse > Pulse, Pulse 2 Width**

Sets the second Pulse width.

Press **F8 Pulse 2 Width** on the Pulse function menu to set with the **Pulse 2 Width** dialog box. This can be set when **Adjustable Doublet** is selected at Pulse Source.

Range	10 ns to 20 s – Pulse Delay – Pulse 2 Delay
Resolution	10 ns
Default	2 $\mu$ s

**Remote command**

**Set the second Pulse width**

**Command**

```
[ :SOURce[1] | 2 ] :PULM:INTernal:PWIDth[1] | 2 <time>
```

**Query**

```
[ :SOURce[1] | 2 ] :PULM:INTernal:PWIDth[1] | 2?
```

**Response**

<time> Unit: S

**Parameter**

<time>	The second Pulse width
Range	10 ns to 20 s – Pulse Delay – Pulse 2 Delay
Resolution	10 ns
Default	2 $\mu$ s
Suffix code	S, MS, US, NS, PS, When omitted: S

**Details**

This can be set when **Adjustable Doublet** is selected at Pulse modulation signal source.

As for node :PWIDth[1]|2, select Pulse Width or Pulse 2 Width. Set as follows:

Pulse Width: :PWIDth1 or :PWIDth

Pulse 2 Width: :PWIDth2

**Programming Example**

To set the second Pulse width to 5  $\mu$ s.

```
PULM:INT:PWID2 5US
```

```
PULM:INT:PWID2?
```

```
> 0.00000500
```

## Pulse Sync/Pulse Video output signal polarity: Ext. Out Polarity

 or **Top**  **Analog/Pulse** ,  **Ext. Out Polarity**

Selects the output polarity of the Pulse Sync signal and Pulse Video signal.

Press **F1 Ext. Out Polarity** on page 2 of the Pulse function menu for selection.

Positive	Positive polarity (Default)
Negative	Negative polarity

**Remote command**

**Select the output polarity of the Pulse Sync signal and Pulse Video signal**

**Command**

```
[ :SOURce[1]|2 ] :PULM:INTernal[1]:VIDeo:POLarity  
NORMal|INVerted
```

**Query**

```
[ :SOURce[1]|2 ] :PULM:INTernal[1]:VIDeo:POLarity?
```

**Response**

```
<mode> NORM or INV
```

**Parameter**

<mode>	Output polarity of the Pulse Sync signal and Pulse Video signal
NORMal	Positive polarity (Default)
INVerted	Negative polarity

**Programming Example**

To set the output polarity of the Pulse Sync signal and Pulse Video signal to the negative polarity.

```
PULM:INT:VID:POL INV
PULM:INT:VID:POL?
> INV
```

**Pulse Mod input signal polarity: Ext. In Polarity**

 or **Top**  **Analog/Pulse**  **Ext. In Polarity**

Selects the polarity of the signal input from the Pulse Mod terminal.

Press **F2 Ext. In Polarity** on page 2 of the Pulse function menu for selection.

Positive	Positive polarity (Default)
Negative	Negative polarity

**Remote command**

**Select the polarity of the signal input from the Pulse Mod terminal**  
**Command**

```
[ :SOURce [1] | 2 ] :PULM:EXTernal:POLarity NORMal | INVerted
```

**Query**

```
[ :SOURce [1] | 2 ] :PULM:EXTernal:POLarity?
```

**Response**

```
<mode> NORM or INV
```

**Parameter**

<mode>	Input polarity of the Pulse Sync signal and Pulse Video signal
NORMal	Positive polarity (Default)
INVerted	Negative polarity

**Programming Example**

To set the polarity of the signal input from the Pulse Mod terminal to the negative polarity.

```
PULM:EXT:POL INV
PULM:EXT:POL?
> INV
```



## 7.2.4 Optimize Function for the Analog Modulation: Optimize

 or  >  (Back key) > **Optimize**,  
or **Top** >  > **Analog/Pulse** > **Optimize**

Selects Spurious Mode or Distortion Mode to optimize analog modulation.

Because the MG3710A/MG3740A performs analog modulation by quadrature modulator, carrier leak causes distortions. To avoid the distortions, analog modulation is performed with frequency offset in the baseband (Distortion Mode). However, when analog modulation is performed with frequency offset, carrier leak and image are generated in the frequency different from the original harmonic spurious. To avoid the problem, the mode is switchable to Spurious Mode which allows analog modulation without frequency offset.

### Notes:

- Distortion Mode's level accuracy is degraded because the frequency offset is applied.
- When the output frequency becomes under 7 MHz, Distortion Mode is automatically switched to Spurious Mode. To use Distortion Mode in 7 MHz or higher, execute re-setting.

Press **F8 Optimize** on the Analog Pulse function menu for selection.

Spurious	Disables the frequency offset. (Default for MG3710A)
Distortion	Enables the frequency offset. (Default for MG3740A)

### Remote command

### Select the frequency offset of the analog modulation

#### Command

```
[ :SOURce [1] | 2 ] :AOPTimize:MODE SPURious | DISTortion
```

#### Query

```
[ :SOURce [1] | 2 ] :AOPTimize:MODE?
```

#### Response

```
<type> SPUR or DIST
```

#### Parameter

<type>	Type
SPURious	Disables the frequency offset. (Default for MG3710A)
DISTortion	Enables the frequency offset. (Default for MG3740A)

**Programming Example**

To enable the frequency offset of the analog modulation.

```
AOPT:MODE DIST
```

```
AOPT:MODE?
```

```
> DIST
```

## 7.3 Baseband Mode

 or **Top>Mode**

MG3710A/MG3740A allows reproducing the waveform pattern to execute the vector modulation with the pattern.

**Note:**

MG3740A allows to execute the vector modulation only when option-020/120 is installed.

The waveform patterns are stored as the pattern file in the internal HDD of MG3710A/MG3740A. Furthermore, a folder to classify the patterns according to the types is called a “package”.

When reproducing the waveform pattern, it is necessary first to load the package pattern stored in the internal hard disk into the waveform memory. MG3710A/MG3740A has two waveform memories of I and Q which have two channels configuration, and the package pattern is loaded into either one or both of them.

Next, the pattern to be output is selected among the patterns loaded into the waveform memory. One for each Memory A and B can be selected. Either one of patterns of Memory A and B or the combination of patterns of Memory A and B is output.

**Note:**

The operation to combine the patterns of Memory A and B to output requires the Combination of Baseband Signal option (option-048/148, option078/178). If not installed, Memory B cannot be used.

In addition, a file called the combination file exists in the package. The combination of patterns to be output is specified and the output level ratio and others are set for this combination file. When the combination file is selected, the pattern is output as specified in the file; therefore the selection for each memory as above is not required.

The state where the pattern is output as the specification in the file after the combination file is selected or the pattern file is selected only for Memory A (B) is called the Defined mode. On the other hand, the state where the pattern is selected for each of Memory A and B, and the output level ratio and others are set on the digital modulation setting screen is called the Edit mode.

In this document, the pattern file and combination file are called the waveform file collectively, and in MG3710A/MG3740A, the pattern file and combination file are used unconsciously.




Figure 7.3-1 Relation of Pattern File and Combination File




Figure 7.3-2 Outline of Waveform Pattern Output

The following are methods to add a new package pattern to the internal hard disk:

- Uses an USB memory or others.  
For the method using a USB memory, refer to 7.3.6 “Copying external waveform pattern: Copy”.
- Transfers from an external personal computer using IQproducer™ (supplied application software).
- Creates the waveform pattern with IQproducer™ (supplied application software) installed in the MG3710A/MG3740A.

For the method to transfer with IQproducer™, refer to the *MG3700A/MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)*.


### 7.3.1 ARB

**Mode** or **Top>Mode**


Generates modulated signals with arbitrary waveform patterns.

In MG3740A, the ARB function can be used only when option-020/120 is installed.

Press **Mode** of the main function key or **F4 Mode** on the top function menu to display the **ARB Info** dialog box and ARB/Waveform function menu.






Before waveform file is selected





After waveform file is selected

Figure 7.3.1-1 ARB Info

Table 7.3.1-1 ARB Info Display Contents

No.	Display Example	Display	Description
1	Combination	---	Other than the below
		Combination	Indicates to combine the waveform patterns of Memory A and Memory B to output. A+B
		Sequence	Indicates that it is in the sequence mode. Seq.(A), Seq.(A+AWGN)
		Sequence +	Indicates that it is in the sequence mode with Add Pattern. Seq.(A+B)
		Multiplex	Indicates Multiplex waveform output. (Multiplex)
2		---	Indicates Memory A.
		Not Selected	Indicates that no waveform is selected.
		Package	Waveform package name for the waveform output from Memory A
		Pattern	Waveform file name for the waveform output from Memory A
3		---	Indicates Memory B.
		Not Selected	Indicates that no waveform is selected.
		Package	Waveform package name for the waveform output from Memory B
		Pattern	Waveform file name for the waveform output from Memory B
		On	Indicates that the AWGN signal is on.
4	Level -207.00 dBm	---	Indicates the output level of the signal from Memory A.
5	Level Ratio -63.00 dBm	Level Ratio	Indicates the output level ratio of the signals from Memory A and Memory B.
		C/N Ratio	Indicates the output level ratio of the signal from Memory A or Memory B and AWGN signal.
6	Level -144.00 dBm	---	Indicates the output level of the signal from Memory B.
7	Freq Offset	A	Frequency image for the signal output from Memory A
		B	Frequency image for the signal output from Memory B
		CNT	Center Frequency displayed frequency
		Frequency	Offset frequency from Center Frequency
		N	AWGN signal
8	Start Offset 10/3 chip 868 ns	Start Offset	Indicates the offset time for the play start timing of Memory A and B. Memory A is the reference, and offset is applied to the B side.
		10/3 chip	Display with System Unit of Memory B
		868 ns	Display of the time above

**Table 7.3.1-1 ARB Info Display Contents (Cont'd)**


No.	Display Example	Display	Description
9		---	Indicates that the signal output from Memory A and the signal output from the waveform memory B are being combined.
10		---	Click to switch Hardware Block Chart and ARB Info display.

**Table 7.3.1-2 ARB/Waveform Function Menu**

Page	Key No.	Menu Display	Function
1	F1	ARB Off <u>On</u>	Enables/disables the function to generate modulated signals with arbitrary waveform patterns.
	F2	Combination Mode Edit <u>Defined</u>	Sets the function mode to generate the pattern with Baseband.  Refer to 7.3.2 "Pattern generation mode".
	F3	ARB Setup	Displays the ARB Setup function menu.  Refer to 7.3.3 "ARB Setup".
	F4	Load	Displays the Waveform Load function menu to load the waveform pattern from HDD to the waveform memory.  Refer to 7.3.4 "Loading waveform pattern: Load".
	F5	Select	Displays the Waveform Select function menu to select the waveform pattern to be output.  Refer to 7.3.5 "Selecting output waveform pattern: Select".
	F6	Copy	Displays the Waveform Copy function menu to copy the waveform pattern from the external device to HDD.  Refer to 7.3.6 "Copying external waveform pattern: Copy".
	F8	Restart	Restarts the waveform pattern being played. Both Pattern A and B are targeted.
2	F1	RF Gate	Displays the RF Gate function menu.  Refer to 7.3.7 "RF Gate".
	F2	Start/Frame Trigger	Displays the Start/Frame Trigger function menu.  Refer to 7.3.8 "Start/Frame Trigger".
	F3	Baseband Clock	Displays the Baseband Clock function menu.  Refer to 7.3.11 "Baseband Clock".
	F4	Marker Setup	Displays the Marker Setup function menu.  Refer to 7.3.12 "Marker Setup".
	F6	RMS Value Tuning 0.00 dB	Tunes the RMS value input to D/A of the IQ waveform data.
	F7	Sequence Mode	Displays the Sequence Mode function menu.  Refer to 7.3.13 "Sequence Mode".
	F8	Sync Multi SG	Displays the Sync Multi SG function menu.  Refer to 7.3.15 "Sync Multi SG".



## ARB On/Off: ARB

 or **Top>Mode, >ARB**

Enables/disables the function to generate modulated signals with arbitrary waveform patterns.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 ARB** of the ARB function menu for setting.

Off	Does not generate modulated signals with arbitrary waveform patterns.
On	Generates modulated signals with arbitrary waveform patterns. (Default)

## Remote command

**Enable/disable the function to generate modulated signals with arbitrary waveform patterns**

**Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB[:STATe] <boolean>
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB[:STATe] ?
```

**Response**

```
<boolean> 0 or 1
```

**Parameter**

<boolean>	Generation of modulated signals with arbitrary waveform patterns On/Off
OFF   0	Does not generate modulated signals with arbitrary waveform patterns.
ON   1	Generates modulated signals with arbitrary waveform patterns (Default).

**Programming Example**

To set the generation of modulated signals with arbitrary waveform patterns to On.

```
RAD:ARB ON
```

```
RAD:ARB?
```

```
> 1
```

## Restart

 or **Top>Mode, >Restart**

Restarts the waveform pattern being played.  
Both Pattern A and B are targeted.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F8 Restart** on the ARB function menu for execution.

### Remote command

#### Restart the waveform pattern

##### Command


```
[ :SOURce [1] | 2 ] :RADio:ARB:WAVEform:REStart
```

##### Programming Example

To playback the waveform pattern from the beginning.

```
RAD:ARB:WAV:REST
```

## RMS Value Tuning

 or **Top>Mode, >>RMS Value Tuning**

Tunes the IQ waveform data amplitude (RMS value) input to the D/A convertor of the internal arbitrary waveform generator.

This function is used for optimization of the output signal distortion or others.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F6 RMS Value Tuning** on page 2 of the ARB/Waveform function menu for setting.

Range	-8.00 dB to 8.00 dB
Resolution	0.01 dB
Default	0.00 dB

### Remote command

#### Tune the IQ Waveform data input amplitude

##### Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:RMStuning <rel_ampl>
```

##### Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:RMStuning?
```

##### Response

```
<rel_ampl> Unit: DB
```

**Parameter**

<rel_ampl>	IQ waveform data input amplitude
Range	-8.00 dB to 8.00 dB
Resolution	0.01 dB
Default	0.00 dB
Suffix code	DB, When omitted: DB

**Programming Example**

To tune the IQ Waveform data input amplitude to 1 dB.

```
RAD:ARB:RMST 1.00
RAD:ARB:RMST?
> 1.00
```

**Operational explanation** To avoid the DAC over-range:

Lower the RMS value with **RMS Value Tuning**. However, be careful about the dynamic range decrease.


To increase the dynamic range:

Raise the RMS value with **RMS Value Tuning**. However, be careful about the DAC over-range.

**Note:**

Even if the RMS value is changed with **RMS Value Tuning**, the output level is maintained; however, in some cases Unleveled is indicated. In this case, setting **RMS Value Tuning** to 0 dB allows avoiding Unleveled with this function.

### 7.3.2 Pattern generation mode: Combination Mode

 or **Top>Mode, >Combination Mode**

Sets the function mode to generate the pattern with Baseband.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Combination Mode** on the ARB/Waveform function menu for setting.

Edit	Mode to generate modulated signals with the combination of arbitrary waveform patterns.
Defined	Mode to generate modulated signals with the combination specified to the waveform file (Default).

#### Remote command

**Select the function mode to generate the pattern with Baseband Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:PCOMbination EDIT|DEFined
```

#### Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:PCOMbination?
```

#### Response

```
<mode> EDIT or DEF
```

#### Parameter

<mode>	The function mode to generate the pattern with Baseband.
EDIT	Mode to generate modulated signals with the combination of arbitrary waveform patterns.
DEFined	Mode to generate modulated signals with the combination specified to the waveform file (Default).

#### Programming Example

To set the function mode to generate the pattern with Baseband to the mode to generate modulated signals with the combination of arbitrary waveform patterns.

```
RAD:ARB:PCOM EDIT
RAD:ARB:PCOM?
> EDIT
```

To execute modulation with Defined mode





Figure 7.3.2-1 ARB Info (Combination)

With the Defined mode, the digital modulation setting screen display depends on the contents of the selected waveform file. However, the pattern is output according to the settings of the waveform file; therefore, basically the settings for output level ratio are not required. This mode is useful for simple evaluations such as the adjacent channel selectivity and sensitivity measurement in AWGN addition state.

In MG3740A, this can be used only when option-020/120 is installed.

The procedure is explained below.

Example: To select the waveform file and output the pattern in the Defined mode.

1. Press **F4 Load** to select the waveform file and load into the memory. Refer to 7.3.4 “Loading waveform pattern: Load”.
2. Press **F2 Combination Mode** to set to “Defined”.
3. Press **F5 Select** to select the waveform file loaded into the memory. Refer to 7.3.5 “Selecting output waveform pattern: Select”.
4. Light the lamp (green) of  key to start the vector modulation.
5. When the output level, offset reference signal, frequency offset, and others of the pattern in each memory are changed, change the settings in the same way as 7.3.3 “ARB Setup”.

To execute continuous operations in Defined mode.

 or **Top>Mode>Combination Mode**



Figure 7.3.2-2 ARB Info (Sequence+)


Selecting the combination file with the definition of continuous operations in the Defined mode activates the sequence mode. The sequence mode allows the continuous operations where the waveform pattern and output level are switched automatically according to the definition of the combination file. Manual operations is also possible, instead of using the continuous operations.

For details of the combination file for the sequence mode with the definition of the continuous operations, refer to the *MG3700A/MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)*.

In MG3740A, this can be used only when option-020/120 is installed.

The procedure is explained below.

Example: To execute the continuous operations in the sequence mode.

1. Select the combination file (for the sequence mode) to load into the memory. Refer to 7.3.4 “Loading waveform pattern: Load”.
2. Press **F2 Combination Mode** to set to Defined.
3. Press **F5 Select** to select the waveform file loaded into the memory. Refer to 7.3.5 “Selecting output waveform pattern: Select”.
4. Light the lamp (green) of  key to start the vector modulation and the continuous operations simultaneously. Press **F2 Sequence Restart** on the Sequence Mode function menu to restart the continuous operations from the beginning.

5. Press **F7 Sequence Mode** on page 2 of the ARB/Waveform function menu to display the **Sequence Progress** dialog box where the continuous operations state can be confirmed. The highlighted element indicates the pattern which is currently being output. The operations are repeated only for the number of times of Repeat where the one time is the data length of the waveform pattern of each element.

Setting **F3 Play Mode** to “Manual” on the Sequence Mode function menu switches the continuous operations to Manual. Then the operation is unlimitedly repeated for the highlighted element. Press **F1 Next Pattern** to move the operation to the next element.

Index	Package Name	Pattern Name	Repeat	Frequency Offset	Level
1	GPS	DATA1c	1	0 Hz	0.00 dB
2	GPS	DATA0	3	0 Hz	0.00 dB
3	GPS	DATA1	1	0 Hz	0.00 dB
4	GPS	DATA0	1	0 Hz	0.00 dB
5	GPS	DATA1	2	0 Hz	0.00 dB
6	GPS	DATA0	14	0 Hz	0.00 dB
7	GPS	DATA1	2	0 Hz	0.00 dB
8	GPS	DATA1	1	0 Hz	0.00 dB
9	GPS	DATA0	2	0 Hz	0.00 dB
10	GPS	DATA1	1	0 Hz	0.00 dB
11	GPS	DATA0	2	0 Hz	0.00 dB

Total : 23

ARB	Power Meter	BER
On	A : Off	Stop
Seq.(A)	B : Off	0.000E+000 0 %
		0 / 0

Figure 7.3.2-3 Sequence Progress

When Frequency or Level is changed during the sequence mode operation, Play Mode is changed to “Manual” and the sequence operation is stopped. To restart the sequence operation, set Play Mode to “Auto”.

Sampling Rate A/B (Refer to 7.3.3 “ARB Setup”) setting cannot be changed during the sequence operation. In addition, ATTT Hold (Refer to 5.3.4 “ATTT Hold”) is always Off during the operation.

The displayed output level differs between On and Off of the vector modulation. The output level for each element and the maximum output level for all elements are displayed for On of the vector modulation and for Off of the vector modulation respectively.

Setting **F1 Pattern Trigger** on the Pattern Trigger function menu (Refer to 7.3.14 “Pattern Trigger”) to “On” and inputting the external trigger to Pattern Trigger on the back of MG3710A (Refer to 7.4.1 “Route Input Connectors”) moves the operation to the next element.

Setting **F5 Switching Point** on the Pattern Trigger function menu to “Pattern” switches the base unit for the switching time for the next element with **F1 Next Pattern** or external triggers to the data length of the waveform pattern of each element. On the other hand, setting to

“Frame” switches the base unit to the frame length of the waveform of each element.






Figure 7.3.2-4 Switching Time



To output the pattern loaded into Memory A for modulation in Edit mode

 or **Top>Mode>Combination Mode**




**Figure 7.3.2-5 ARB Info**

The pattern file is selected (the combination file cannot be selected) for modulation in the Edit mode. The pattern is selected for each memory for output. Here the pattern is output from Memory A.

In MG3740A, this can be used only when option-020/120 is installed.

The procedure is explained below.

1. Press **F4 Load** to select the waveform file and load into the memory. Refer to 7.3.4 “Loading waveform pattern: Load”.
2. Press **F2 Combination Mode** on the ARB/Waveform function menu for setting to Edit.
3. Press **F5 Select** to select the waveform file loaded into the memory. Refer to 7.3.5 “Selecting output waveform pattern: Select”.
4. Press **F3 ARB Setup** to display the ARB Setup function menu and set **F1 Output A** to On.
5. Press  to light the lamp (green) of the key to start the vector modulation.

To combine outputs from Memory A and B for modulation in Edit mode

 or **Top>Mode>ARB Setup**

The output level, sampling rate, frequency offset, start offset, and spectrum reverse of Memory A and B can be set on the screen for combination of two patterns in the Edit mode. Using this function requires the Combination of Baseband Signal option.

In MG3740A, this can be used only when option-020/120 is installed.

Here, operations for the case where the two signals with same frequency are added for the desired wave and delay wave and for the case where the offset is added between the frequencies of two signals such as the adjacent channel selectivity are explained.

#### Output level

Specify the output level of the pattern. It can be specified for each of Memory A and B. **Level A/B**

In addition, the setting with the output level ratio of Memory A and B is available. **A/B Ratio**

The target for the level change on output level ratio change is changed with the setting of **A/B Signal Setting**. The displayed RF output level may be lower than the minimum output level of the MG3710A/MG3740A depending on the setting of the output level ratio; however, actually there is no output with the level lower than the minimum output level of the MG3710A/MG3740A.

#### Sampling rate

The sampling rates of the waveform signals of patterns of Memory A and B are set.

#### Sampling Rate A/B

#### Frequency offset

**Freq Offset** when **Central Signal** is “A”

The center frequency of Memory B is displaced based on the pattern of Memory A (0 Hz).

**Freq Offset** when **Central Signal** is “B”

The center frequency of Memory A is displaced based on the pattern of Memory B (0 Hz).

**Freq Offset A/B** when **Central Signal** is “Baseband DC”

The center frequencies of patterns of Memory A and B are displaced based on the Baseband center frequency.

Settings are executed with this function when there is an offset between frequencies of two signals such as the adjacent channel selectivity.

**Start offset**


Different play start timing is set for the patterns of Memory A and B. Memory A is the reference, and offset is applied to the B side. This function is enabled when the same pattern is output from Memory A and B and the correlation of both is to be decreased. **Start Offset**

**Spectrum reverse**

I/Q of patterns of Memory A and B are swapped and the spectrum is reversed.

**Spectrum A/B****Combination of signals with different sampling rates (Rate matching function)**

When a signal with a different sampling rate has been set to Memory A and Memory B, a combined signal which maintains each sampling rate is output. It is useful for purposes with the use of combined signals with different rates such as Multi Standard signals.



**Figure 7.3.2-6 Rate Matching Function**


Some combinations of waveform sampling rates may disable rate matching due to internal operation clock limitation of the MG3710A/MG374A. In this case, Rate Mismatch warning is displayed.




Figure 7.3.2-7 Rate Mismatch Display

**Note:**

When the Rate Mismatch is displayed, the sampling rate of Memory B side is changed to the frequency which is the same as the sampling rate of Memory A side. Therefore, the pattern of Memory B side operates with the sampling clock which differs from the pattern's clock, and is output in a bandwidth which differs from the normal status.



Memory B: GSM signal (Normal)



Memory B: GSM signal (RateMismatch)

Figure 7.3.2-8 Memory B Waveform of Rate Mismatch

When Rate Mismatch is displayed, the digital addition function (Rate Matching Function) does not work properly. Prepare a signal generator and add the signals externally.

To add two waves with same frequency in Edit mode

Mode or Top>Mode




Figure 7.3.2-9 Two Waves Added Output

When the center frequencies of two patterns are to be set to the same value, set the frequency offset to 0 Hz. This function is useful when the transmission signal pattern of Memory A and the delay wave of Memory B are output for measurement of the performance of receiver.

In MG3740A, this can be used only when option-020/120 is installed.





Figure 7.3.2-10 Example of Desired Wave and Delay Wave with Same Frequency


The procedure is explained below.

Example: To combine pattern files loaded into Memory A and B with the same frequency.

1. Press **F4 Load** to select the waveform file and load into the memory. Refer to 7.3.4 “Loading waveform pattern: Load”.
2. Press **F2 Combination Mode** on the ARB function menu to set to Edit.
3. Press **F5 Select** to select the waveform file loaded into the memory. Refer to 7.3.5 “Selecting output waveform pattern: Select”.
4. Press **F3 ARB Setup** to display the ARB Setup function menu and set **F1 Output A** and **F3 Output B** to On.
5. Set output levels with **F2 Level A** and **F4 Level B**.  
When the unit is changed, the unit of RF output level A and B are changed in tandem.
6. Set the time offset of Pattern B based on Pattern A side with **F5 Start Offset** in Page 2.
7. Press  to light the lamp (green) of the key to start the vector modulation.

To give offsets to frequencies of two waves in Edit mode

or **Top>Mode>ARB Setup**




**Figure 7.3.2-11 Frequency Offset Output**

When the center frequencies of two patterns are to be displaced, set the frequency offset to the arbitrary value. This function is useful when the transmission signal pattern of Memory A and the interference signal from the adjacent channel of Memory B are output for measurement of the performance of the receiver.

In MG3740A, this can be used only when option-020/120 is installed.

Use example




**Figure 7.3.2-12 Example of Frequency Offset**

The use example above is for Memory B as offset reference. It is also available that the offset reference is Memory A.

The procedure is explained below.

Example: To combine pattern files loaded into Memory A and B with the different frequency.

1. Press **F4 Load** to select the waveform file and load into the memory. Refer to 7.3.4 “Loading waveform pattern: Load”.
2. Press **F2 Combination Mode** on the ARB function menu to set to Edit.
3. Press **F5 Select** to select the waveform file loaded into the memory. Refer to 7.3.5 “Selecting output waveform pattern: Select”.
4. Press **F3 ARB Setup** to display the ARB Setup function menu and set **F1 Output A** and **F3 Output B** to On.
5. Set output levels with **F2 Level A** and **F4 Level B**.  
When the unit is changed, the unit of RF output level A and B are changed in tandem.
6. Next, set the frequency offset between A and B.  
Press **F4 Center Signal** on page 2 of ARB Setup function menu to set the pattern as the frequency reference to “B”.
7. Press **F1 Freq Offset** on page 2 of ARB Setup function menu to display the **Freq Offset A** dialog box to set the offset frequency.
8. Press  to light the lamp (green) of the key to start the vector modulation.



---

## Various settings for pattern output

 or **Top>Mode**

In MG3740A, this can be used only when option-020/120 is installed.

To re-output the pattern from the beginning.

Without the external trigger signal input, when the end of the waveform pattern is output, the pattern is automatically output from the beginning repeatedly. Press **F8 Restart** on the ARB function menu to allow re-output of the waveform pattern from the beginning with the arbitrary timing. However, pressing **F2 Sequence Restart** on the Sequence Mode function menu restarts the continuous operations from the first element in the sequence mode.

Switching I/Q signal source

To output the internal vector modulation signal with the waveform pattern, I/Q signal source must be set for the internal signal. Press **F2 I/Q** on page 2 of the top function menu to display the I/Q function menu, and press **F1 I/Q Source** to select “Internal”.

When the modulated signal is the burst wave.

When the waveform pattern used is the burst wave, press **F4 RF Gate** on the ARB function menu, and press **F1 RF Gate** on the RF Gate function menu to set the RG Gate function to “On”.

To output the pattern loaded into Memory B for modulation

Previously in this document, the procedure to output the pattern loaded into Memory A for modulation has been explained. In addition, the pattern loaded into Memory B can be output for modulation. In the procedure for this case, not **F1 Output A** but **F3 Output B** is set to “On”. In addition, when patterns are loaded into both of Memory A and B, set both of **F1 Output A** and **F3 Output B** to “On” to output from patterns included in the both memories.

### 7.3.3 ARB Setup

 or **Top>Mode, >ARB Setup**

Press **F3 ARB Setup** on the ARB function menu to open the ARB Setup function menu.

In MG3740A, this can be used only when option-020/120 is installed.

**Table 7.3.3-1 ARB Setup Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Output A Off <u>On</u>	Enables/disables the Pattern A output.
	F2	Level A -144.00 dBm	Sets the Pattern A output level.
	F3	Output B <u>Off</u> On	Enables/disables the Pattern B output.
	F4	Level B -140.00 dBm	Sets the Pattern B output level.
	F5	A/B Signal Setting A B <u>A&amp;B</u>	Selects the target for level change on A/B Ratio change. (The option which is not selected is fixed.)
	F6	A/B Ratio 0.00 dB	Sets the level ratio of Pattern A and Pattern B.
	F7	Sampling Rate A 20.000000 Hz	Sets the Pattern A sampling rate.
	F8	Sampling Rate B 20.000000 Hz	Sets the Pattern B sampling rate.
2	F1	Freq Offset 0 Hz	Sets the frequency offset between Pattern A and B. When CenterSignal is A or B, the frequency offset is set with this parameter.
	F2	Freq Offset A 0 Hz	Sets the frequency offset of Pattern A based on Baseband center frequency.
	F3	Freq Offset B 0.00 Hz	Sets the frequency offset of Pattern B based on Baseband center frequency.
	F4	Center Signal Baseband DC	Selects the pattern to be the reference on frequency display.
	F5	Start Offset 0	Sets the time offset of Pattern B based on Pattern A side.
	F6	Spectrum A <u>Normal</u> Reverse	Swaps I/Q of Pattern A and reverses the spectrum.
	F7	Spectrum B <u>Normal</u> Reverse	Swaps I/Q of Pattern B and reverses the spectrum.

## Output A/Output B

 or **Top>Mode,>ARB Setup>Output A or Output B**

Enables/disables the Pattern A/B output.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 Output A/F3 Output B** on the ARB Setup function menu for setting.

Off	Does not output Pattern A/B.	
On	Outputs Pattern A/B.	
Default	Output A	On
	Output B	Off

## Remote command

## Enable/disable the Pattern A/B output

## Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:OUTPut <boolean>
```

## Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:OUTPut?
```

## Response

```
<boolean> 0 or 1
```

## Parameter

<boolean>	Frequency relative display On/Off	
OFF 0	Does not output Pattern A/B.	
ON 1	Outputs Pattern A/B.	
Default	Output A	On
	Output B	Off

## Programming Example

To set Pattern B output to On.

```
RAD:ARB:WMB:OUTP ON
RAD:ARB:WMB:OUTP?
> 1
```

## Level A/Level B

 or **Top>Mode,>ARB Setup>Level A or Level B**

Sets the Pattern A/B output level.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Level A/F4 Level B** on the ARB Setup function menu for setting.

Resolution                      0.01 dB

Default                          Minimum value of Output Level

### Remote command

#### Set Pattern A/B output level

##### Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:Power <ampl>
```

##### Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:POWer?
```

##### Response

<ampl>                              Unit: dBm

##### Parameter

<ampl>                              Pattern A/B output level

Resolution                      0.01 dB

Suffix code                      DBM, DM, DBUV, DBUVE, When omitted: DBM

#### Programming Example

To set Pattern A output level to -30.00 dBm.

```
RAD:ARB:WMA:POW -30.00
```

```
RAD:ARB:WMA:POW?
```

```
> -30.00
```

## A/B Signal Setting

**Mode** or **Top>Mode,>ARB Setup>A/B Signal Setting**

Selects the target for level change on A/B Ratio change (The option which is not selected is fixed).

In MG3740A, this can be used only when option-020/120 is installed.

Press **F5 A/B Signal Setting** on the ARB Setup function menu for setting.

A	Fixes Level B and changes Level A.
B	Fixes Level A and changes Level B.
A&B	Fixes OutputLevel and changes Level A and Level B. (Default)

## Remote command

**Select the target for level change on A/B Ratio change****Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:POWer:RATio:TARGeT A|B|AB
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:POWer:RATio:TARGeT?
```

**Response**

```
<mode>
```

**Parameter**

<mode>	Target for level change on A/B Ratio change
A	Fixes Level B and changes Level A.
B	Fixes Level A and changes Level B.
AB	Fixes OutputLevel and changes Level A and Level B. (Default)

**Programming Example**


To select Level B for the target for level change on A/B Ratio change.

```
RAD:ARB:POW:RAT:TARG B
```

```
RAD:ARB:POW:RAT:TARG?
```

```
> B
```

## A/B Ratio

 or **Top>Mode, >ARB Setup>A/B Ratio**

Sets the level ratio of Pattern A and Pattern B.  
A/B is indicated with dB.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F6 A/B Ratio** on the ARB Setup function menu for setting.

Range	– 80 dB to 80 dB
Resolution	0.01 dB
Default	0 dB

### Remote command

#### Set the level ratio of Pattern A and Pattern B

##### Command

```
[ :SOURce[1] | 2 ] :RADio:ARB:POWer:RATio <rel_ampl>
```

##### Query

```
[ :SOURce[1] | 2 ] :RADio:ARB:POWer:RATio?
```

##### Response

```
<rel_ampl> Unit: DB
```

##### Parameter

```
<rel_ampl> Level ratio of Pattern A and Pattern B
```

Range – 80 dB to 80 dB

Resolution 0.01 dB

Default 0 dB

Suffix code DB, When omitted: DB

#### Programming Example


To set the level ratio of Pattern A and Pattern B to –30.00 dB.

```
RAD:ARB:POW:RAT -30.00
```

```
RAD:ARB:POW:RAT?
```

```
> -30.00
```

## Sampling Rate A/Sampling Rate B

 or **Top>Mode, >ARB Setup>Sampling Rate A** or **Sampling Rate B**  
Sets the waveform signal sampling rate.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F7 Sampling Rate A/F8 Sampling Rate B** on the ARB Setup function menu for setting with the displayed dialog box.

Range	0.02 to 200 MHz (MG3710A) 0.02 to 8 MHz (MG3740A)
Resolution	0.001 Hz
Default	20 kHz

### Remote command

#### Query the baseband signal sampling rate

##### Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:SCLock:RATE <freq>
```

##### Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:SCLock:RATE?
```

##### Response

```
<freq> Unit: Hz
```

##### Parameter

<freq>	Sampling rate
Range	0.02 to 200 MHz (MG3710A) 0.02 to 8 MHz (MG3740A)
Resolution	0.001 Hz
Default	20 kHz
Suffix code	HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ When omitted: HZ

### Programming Example

To set SG1 waveform Memory A sampling rate.

```
RAD:ARB:WMA:SCL:RATE 80MHZ
```

```
RAD:ARB:WMA:SCL:RATE?
```

```
> 80000000.000
```

## Freq Offset

 or **Top>Mode,>ARB Setup>****>Freq Offset**

Sets the frequency offset between Pattern A and B with this parameter, when CenterSignal is A or B.

The parameter is available only when the waveform is selected in Memory A and B and Output A and B are On at the same time. This is disabled when CenterSignal is Baseband DC.

In MG3740A, this can be used only when option-020/120 is installed.

Range	-200 MHz /2 to 200 MHz /2 (MG3710A) -8 MHz to 8 MHz (MG3740A)
Resolution	1 Hz
Default	0 Hz

### Note:

If the output modulated wave exceeds the modulation bandwidth of the MG3710A/MG3740A, a missing signal/alias may occur. When the frequency offset is used, be careful that the bandwidth used does not to exceed the modulation bandwidth.

## Remote command

### Set the frequency offset of Pattern A/Pattern B

#### Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:FREQuency:OFFSet <freq>
```

#### Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:FREQuency:OFFSet?
```

#### Response

```
<freq> Unit: HZ
```


#### Parameter

<freq>	Frequency
Range	- 200 MHz /2 to 200 MHz /2 (MG3710A) -8 MHz to 8 MHz (MG3740A)
Resolution	1 Hz
Default	0 Hz
Suffix code	HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ When omitted: HZ



**Details**

When CenterSignal is A, the value is offset of B for A. When CenterSignal is B, the value is offset of A for B.



**Figure 7.3.3-1 Example of Frequency Offset Setting**

**Programming Example**

To set the SG1 frequency offset to 800 Hz.

```
RAD:ARB:FREQ:OFFS 800
```

```
RAD:ARB:FREQ:OFFS?
```

```
> 800
```

## Freq Offset A/Freq Offset B

 or **Top>Mode, >ARB Setup>**  **>Freq Offset A or Freq Offset B**

Sets the frequency offset of Pattern A/Pattern B based on Baseband center frequency

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 Freq Offset A/F2 Freq Offset B** on page 2 of the ARB Setup function menu for setting.

Range	–200 MHz/2 to 200 MHz /2 (MG3710A) –8 MHz /2 to 8 MHz /2 (MG3740A)
Resolution	1 Hz
Default	0 Hz

**Note:**

If the output modulated wave exceeds the modulation bandwidth of the MG3710A/MG3740A, a missing signal/alias may occur. When the frequency offset is used, be careful that the bandwidth used does not to exceed the modulation bandwidth.

### Remote command

#### Set the frequency offset of Pattern A/Pattern B

**Command**

`[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:FREQuency:OFFSet <freq>`

**Query**

`[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:FREQuency:OFFSet?`

**Response**

`<freq>` Unit: HZ

**Parameter**

<code>&lt;freq&gt;</code>	Frequency
Range	–200 MHz/2 to 200 MHz /2 (MG3710A) –8 MHz /2 to 8 MHz /2 (MG3740A)
Resolution	1 Hz
Default	0 Hz
Suffix code	HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ When omitted: HZ

**Programing Example**

To set the SG1 Pattern A frequency offset to 800 Hz.

```
RADio:ARB:WMA:FREQ:OFFS 800
RADio:ARB:WMA:FREQ:OFFS?
> 800
```

## Center Signal

 or **Top>Mode,>ARB Setup>****>Center Signal**

Selects the pattern to be the reference on frequency display.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F3 Center Signal** on page 2 of ARB Setup function menu to open the Center Signal function menu for selection.

A	Pattern A is the reference.
B	Pattern B is the reference.
Baseband DC	DC position of Baseband is the reference (Default).

### Note:

When the control language is set to MG3700A, B (Pattern B is the reference.) is a default. The default is effective after preset. For control languages, refer to “Selecting control language” in Section 9.4.1 “Interface Settings”.

## Remote command

### Select the pattern to be referenced on frequency display

#### Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:CSIGnal A|B|BDC
```

#### Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:CSIGnal?
```

#### Response

```
<mode>
```

#### Parameter

<mode>	Pattern for frequency display
A	Pattern A is the reference.
B	Pattern B is the reference.
BDC	DC position of Baseband is the reference (Default).

### Programming Example

To set the pattern to be the reference on frequency display to Pattern A.

```
RAD:ARB:CSIG A
```

```
RAD:ARB:CSIG?
```

```
> A
```

## Start Offset

 or **Top>Mode, >ARB Setup>**  **>Start Offset**

Sets the time offset of Pattern B based on Pattern A side.

The parameter is available only when the waveform is selected in Memory A and B and Output A and B are On at the same time.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F4 Start Offset** on page 2 of ARB Setup function menu for setting.

Range	0 to the number of sampling data items of Pattern B – 1 or 9 999 999, whichever smaller
Resolution	1
Default	0
Unit	The number of samples with Sampling Rate B rate

## Remote command

### Set the time offset

#### Command

```
[ :SOURce[1] | 2 ] :RADio:ARB:TIME:SOFFset <ext_integer>
```

#### Query

```
[ :SOURce[1] | 2 ] :RADio:ARB:TIME:SOFFset?
```

#### Response

```
<ext_integer>
```

#### Parameter

<ext_integer>	Time offset value of Pattern B based on Pattern A side
Setting range	0 to the number of sampling data items of Pattern B – 1 or 9 999 999, whichever smaller
Resolution	1
Default	0
Unit	The number of samples with Sampling Rate B rate
Suffix code	None

### Programming Example

To set the time offset of Pattern B based on Pattern A side to 800.

```
RAD:ARB:TIME:SOFF 800
```

```
RAD:ARB:TIME:SOFF?
```

```
> 800
```

## Spectrum A/Spectrum B

**Mode** or **Top>Mode, >ARB Setup>→>Spectrum A or Spectrum B**

I/Q swap for Pattern A is executed and the spectrum is reversed.

Spectrum A reverses the spectrum of the waveform memory A, and Spectrum B reverses the spectrum of the waveform memory B. Similar to this, **F2 RF Spectrum** of the Frequency function menu on page 2 inverts the spectrum of the waveform memory A and B, respectively. Reversing RF Spectrum and Spectrum A or B simultaneously returns the status to Normal.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F5 Spectrum A/F6 Spectrum B** on page 2 of ARB Setup function menu for setting.

Normal	Does not reverse (Default).
Reverse	Reverses.

## Remote command

## Set the spectrum reverse

## Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:SPECTrum NORMal|INVert
```

## Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:SPECTrum?
```

## Response

```
<mode> NORM or INV
```

## Parameter

<mode>	Spectrum reverse On/Off
NORMal	Does not reverse (Default).
INVert	Inverts.

## Programming Example

To set the spectrum reverse for Pattern A.

```
RAD:ARB:WMA:SPEC INV
RAD:ARB:WMA:SPEC?
> INV
```

### 7.3.4 Loading waveform pattern: Load

or **Top>Mode>Load**

Loads the waveform pattern from HDD into the waveform memory.

In MG3740A, this can be used only when option-020/120 is installed.

**Notes:**

- To load the waveform pattern to the memory, the license file corresponding to each pattern must be installed. Refer to 9.4.4 “Install” for installation of the license file.
- Do not plug in and out the USB memory stick while loading a waveform pattern.

Press **Load** of the main function key or **F4 Load** on the ARB/Waveform function menu to open the **Waveform List to Load** dialog box and Waveform Load function menu.




Figure 7.3.4-1 Waveform List to Load

Table 7.3.4-1 Waveform List to Load

No.	Display Example	Description	
1	Drive C:	Drive number	
2	Pattern in Packages : Test	Name of package displaying pattern	
3	Package Name	Package file name	
4	Pattern Name	Pattern file name	
5	Type	File type	
6	Status*	Status	File type
		Comment 1/2/3	Displays the Comment Lines 1/2/3
		Version	Version number
		Size	File size
		Sampling Rate	Sampling frequency
		RMS Value	RMS value
7	3.992 378 056 GByte Free	Remaining free Memory A or Memory B	
8	54 patterns	Number of patterns included in the selected package	

\*: Displayed items switch according to Waveform Load function menu and Subitem Status.

**Remote command**

**Query the waveform pattern file version on the hard disk  
Query**

To query the version of the single pattern file (wvi/wvd). The version of the combination file (wvc) cannot be confirmed with this command.

```
:MMEMory:WAVeform:VERSion? <string1>,<string2>[,<device>]
```

```
:MMEMory:WAVeform:SINGle:VERSion?  
<string1>,<string2>[,<device>]
```

**Response**

```
<version>
```

**Parameter**

<device>	Source drive number A to Z, currently selected drive when omitted
<string1>	Package name Character string within 31 characters enclosed by double quotes ( " ") or single quotes ( ' ' )
<string2>	Pattern name (excluding extensions) Character string within 100 characters enclosed by double quotes ( " ") or single quotes ( ' ' )
<version>	Version number: 00.00 to FF.FF in hexadecimal When patterns do not exist, *** is returned.

**Details**

This is a function only with remote commands.

**Programming Example**

To query the "TEST" pattern version number of the package "WCDMA" in C drive.

```
MMEM:WAV:VERS? "WCDMA", "TEST"  
> 1.00
```



**Remote command      Query the hard disk free space information****Query**

:MMEMory:FREE[:ALL]? [&lt;device&gt;]

**Response**

&lt;integer1&gt;,&lt;integer2&gt;      Unit: byte

**Parameter**

<device>      Source drive number A to Z, drive C when omitted

<integer1>      Number of bytes in whole HDD

<integer2>      Number of bytes of the remaining space  
-999.0 is returned when no devices exist.

**Programming Example**

To query the hard disk free space in C drive.

MMEM:FREE?

&gt; 1234567890,123456789

**Table 7.3.4-2 Waveform Load Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Selects the device which includes the waveform pattern to be queried.
	F2	Focus Package <u>P</u> attern	Moves the cursor between Package/Pattern frames.
	F3	Update Info	Updates the waveform pattern information in HDD.
	F4	Subitem Status	Switches the Subitem displayed items in <b>Waveform List to Load</b> dialog box.
	F5	Show Details	Displays details of the selected waveform pattern information in HDD.
	F6	Load Pattern	Loads the selected pattern in <b>Waveform List to Load</b> dialog box.
	F7	Load All Patterns	Loads all of the patterns in selected package in <b>Waveform List to Load</b> dialog box.
	F8	To Memory <u>A</u> B	Selects the waveform memory for the pattern to be loaded into.
2	F5	Delete pattern from selected drive	Deletes the selected waveform pattern.

Example: To load the waveform pattern into the waveform memory of MG3710A/MG3740A.

The explanation is provided below with the assumption that the Load Waveform function menu is displayed.

1. Press **F1 Drive** to select the device which includes the waveform pattern to be loaded.
2. Press **F8 To Memory** to select the waveform memory for the waveform pattern to be loaded.
3. The list of packages is displayed in the **Waveform List to Load** dialog box. Select Package with **F2 Focus**, and move the cursor on the package which includes the waveform pattern to be loaded with the direction key or rotary knob.
4. The list of waveform files of the selected package is displayed. Select Pattern with **F2 Focus**, and move the cursor on the waveform file to be loaded with the direction key or rotary knob.
5. Press **F6 Load Pattern** to load the waveform file specified in Step 4 into the waveform memory.

**Notes:**

- Displays of **F6** and **F7** are displayed when Pattern is selected with **F2 Focus**.
  - Press **F7 Load All Patterns** to load all of the waveform files of Package selected in Step 3 regardless of the setting in Step 4.
  - If an unreadable (grayed out) Pattern file is selected, **F6** becomes unavailable.
6. When loading of waveform patterns is finished, the residual memory display is changed corresponding to the total space of loaded waveform patterns.  
4096 waveform files and 4096 packages can be loaded into the waveform memory. 4096 waveform files can be stored in one package.

## Drive

 or **Top>Mode>Load, >Drive**

Selects the device which includes the waveform pattern to be loaded.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 Drive** on the Waveform Load function menu to display the Device function menu for selection.

Options	All connected Drives
Default	C

## Moving cursor: Focus

 or **Top>Mode>Load, >Focus**

Moves the cursor between Package/Pattern frames in the **Waveform List to Load** dialog box.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Focus** on the Waveform Load function menu for selection.

Package	Moves the cursor to Package List.
Pattern	Moves the cursor to Pattern List.

## Update Info

 or **Top>Mode>Load, >Update Info**

Updates the waveform pattern information in HDD.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F3 Update Info** on the Waveform Load function menu for selection.

### Remote command

#### Update the waveform pattern information in the HDD to enable loading Command

To update all the waveform pattern information.

```
:MMEMory:UPDate:WAVEform:ALL
```

To update the single pattern file (wvi/wvd).

(If there is a wvc/wvi with the same name, both files are upload.)

```
:MMEMory:UPDate:WAVEform <string1>,<string2>[,<device>]
```

**Parameter**

<string1>	Package name Character string within 31 characters enclosed by double quotes ( " ") or single quotes ( ' ' )
<string2>	Pattern name (excluding extensions) Character string within 100 characters enclosed by double quotes ( " ") or single quotes ( ' ' )
<device>	Source drive number A to Z, drive C when omitted

**Programming Example**

To update all the waveform pattern information.

```
MMEM:UPD:WAV:ALL
```

To update the single pattern file "TEST" in the package "WCDMA" in drive D.

```
MMEM:UPD:WAV "WCDMA", "TEST", D
```

Switching subitem: Subitem

 or **Top>Mode>Load,>Subitem**


Selects the display items of Subitem in **Waveform List to Load** dialog box from the Subitem function menu.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F4 Subitem** on the Waveform Load function menu for selection.

F1 Status	Pattern type
F2 Comment Line1	Comment Line 1
F3 Comment Line2	Comment Line 2
F4 Comment Line3	Comment Line 3
F5 Version	Version number
F6 Size	File size
F7 Sampling Rate	Sampling frequency
F8 RMS Value	RMS value

## Show Details

 or **Top>Mode>Load, >Show Details**

Displays the details of the selected waveform pattern information in HDD.

In MG3740A, this can be used only when option-020/120 is installed.

Select Pattern in the **Waveform List to Load** dialog box and press **F5 Show Details** on the Waveform Load function menu to display the **Details of Waveform Data** dialog box.



**Figure 7.3.4-2 Details of Waveform Data**

Package	Package file name
Pattern	Pattern file name
[Comment]	
Line1 =	Comment
Line2 =	Comment
Line3 =	Comment
Line4 =	Comment
Line5 =	Comment
Line6 =	Comment
Line7 =	Comment

## Load Pattern

 or **Top>Mode>Load, >Load Pattern**

Loads the selected waveform pattern in HDD.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F6 Load Pattern** on the Waveform Load function menu for loading. This is displayed when Pattern is selected with **F2 Focus**.

If an unreadable (grayed out) Pattern file is selected, **F6** becomes unavailable.

**Remote command**

**Start loading the waveform pattern from the hard disk to the waveform memory**

**Command**

:MMEMory[1]|2:LOAD:WAVEform:WMA|WMB|LONG|COMBination  
<string1>,<string2>[,<device>]

**Query**

:MMEMory[1]|2:LOAD:WAVEform:WMA|WMB|LONG|COMBination?  
<string1>,<string2>[,<device>]

**Response**

<status>

**Parameter**

<string1>	Package name Character string within 31 characters enclosed by double quotes ( " ") or single quotes ( ' ' )
<string2>	Pattern name (excluding extensions) Character string within 100 characters enclosed by double quotes ( " ") or single quotes ( ' ' )
<device>	Source drive number A to Z, currently selected drive when omitted
WMA	Wave Memory A
WMB	Wave Memory B
LONG	Long Pattern
COMBination	Combination Pattern
<status>	Status
0	Already loaded
1	Can be loaded
2	License required
3	No corresponding file
4	Insufficient waveform memory free space
5	Internal error
6	Version mismatch
7	Pattern file/combination file analysis error
8	Illegal pattern file/combination file (.wvi)
9	Exceeded number of loadable waveform pattern files/combination files
10	Exceeded number of loadable packages

**Details**

If a waveform pattern is loaded when the same waveform pattern has already been loaded, the existing waveform pattern is overwritten.

**Programming Example**

To start loading "RMC15k" pattern file in package "WCDMA" in drive E into the SG2 waveform memory A.

```
MMEM2:LOAD:WAV:WMA "WCDMA","RMC15k",E
*OPC?                // Loaded when 1 is returned
MMEM2:LOAD:WAV:WMA? "WCDMA","RMC15k",E
> 0                  // Already loaded
```

**Remote command****Confirm the loading status****Query**

```
:MMEMory[1]|2:LOAD:WAVeform:STATus?
```

**Response**

```
1                Being loaded.
0                Not being loaded.
```

**Programming Example**

To confirm SG2 loading status.

```
MMEM2:LOAD:WAV:STAT?
> 1
```

**Remote command****Cancel the active loading operation****Command**

```
:MMEMory[1]|2:LOAD:WAVeform:ABORt
```

**Programming Example**

To cancel SG2 loading.

```
MMEM2:LOAD:WAV:ABOR
```

When the pattern file (long pattern data file) which is larger than the space of Memory A is loaded, both Memory A and B are used for loading. However, the long pattern data file can be loaded only in the Defined mode.

When selecting Long Pattern, the following Confirmation function menu is displayed. Since Long Pattern is an extremely large file, all the previously opened contents in Memory A and Memory B are erased. The selected pattern file is loaded into Memory A from the beginning, and the part which does not fit into Memory A is loaded into Memory B.


**Table 7.3.4-3 Confirmation Function Menu**

Page	Key No.	Menu Display	Function
1	F7	Confirm overwriting All Loaded Pattern	Deletes contents of Memory A and Memory B and loads Long Pattern
	F8	Cancel	Returns to the menu before this menu is opened.

**Select** is executed by pressing **F7 Confirm overwriting All Loaded Pattern**.

Up to 4096 pattern files can be loaded into each Memory A and B. On the other hand, the number of combination files which can be loaded into the memory is 4096 at a maximum. Also, up to 4096 packages can be loaded into Memory A and B in total.

Up to 4096 waveform files can be stored in one package. If the same package exists in Memory A and B, the number of waveform files loaded into both memories are totaled. In that case, if the same pattern file is loaded into both Memory A and B, each pattern file in A and B are counted.



### Load All Patterns

 or **Top>Mode>Load>, Load All Pattern**

Loads all of the patterns in the selected package in **Waveform List to Load** dialog box.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F7 Load All Patterns** on the Waveform Load function menu for loading. This is displayed when Pattern is selected with **F2 Focus**.



## Loading destination: To Memory

 or **Top>Mode>Load, >To Memory**

Selects the waveform memory for the pattern to be loaded into.



In MG3740A, this can be used only when option-020/120 is installed.

This function specifies the loading destination waveform memory when the pattern file is loaded without being LongPattern. This function is disabled for the combination file and LongPattern because their loading destination waveform memory has been already determined.

Press **F8 To Memory** on the Waveform Load function menu for selection. This is not displayed when the waveform memory B option is not installed.

A Waveform memory A (Default)  
B Waveform memory B

## Delete

 or **Top>Mode>Load, >> Delete pattern from selected drive**

Deletes the selected waveform pattern.

In MG3740A, this can be used only when option-020/120 is installed.

Select the waveform pattern to be deleted in the **Waveform List to Load** dialog box and press **F5 Delete pattern from selected drive** on page 2 of Waveform Load function menu to display the Confirmation function menu and to highlight only the waveform pattern to be deleted.

Press **F7 Confirm Deletion** on the Confirmation function menu to execute the deletion.

**Table 7.3.4-4 Confirmation Function Menu**

Page	Key No.	Menu Display	Function
1	F7	Confirm Deletion	Deletes the waveform pattern.
	F8	Cancel	Returns the menu before this menu is opened.

**Remote command**

**Delete the selected waveform pattern in HDD**

**Command**

To delete the combination file (wvc) or single pattern (wvi/wvd).  
If there is a wvc/wvi with the same name, the combination file has priority.

```
:MMEMory:DELeTe:WAVeform[:NAME]  
<string1>,<string2>,[<device>]
```

To delete the single pattern file (wvi/wvd).

The combination file (wvc) cannot be deleted with this command.

```
:MMEMory:DELeTe:WAVeform:SINGLe[:NAME]  
<string1>,<string2>,[<device>]
```

**Parameter**

<string1>	Package name Character string within 31 characters enclosed by double quotes ( " ") or single quotes ( ' ' )
<string2>	Pattern name (excluding extensions) Character string within 100 characters enclosed by double quotes ( " ") or single quotes ( ' ' )
<device>	Source drive number A to Z, drive C when omitted

**Details**

This command does not delete waveform patterns in the waveform memory.

**Programming Example**

To delete the combination file "TESTALL" in the package "WCDMA" in drive D.

```
MMEM:DEL:WAV "WCDMA","TESTALL",D
```

To delete the single pattern file "TEST" in the package "WCDMA" in drive D.

```
MMEM:DEL:WAV:SING "WCDMA","TESTALL",D
```

### 7.3.5 Selecting output waveform pattern: Select

or **Top>Mode>Select**

Selects the waveform pattern to be output.

In MG3740A, this can be used only when option-020/120 is installed.

Press **Select** of the main function key or **F5 Select** on the ARB/Waveform function menu to display the **Waveform List to Play** dialog box and Waveform Select function menu.




Figure 7.3.5-1 Waveform List to Play

Table 7.3.5-1 Waveform List to Play

No.	Display Example	Description	
1	in Memory A	Indicates the displayed memory when Combination Mode is Edit.	
2	Pattern in Packages : Test	Name of package displaying pattern	
3	Package Name	Package file name	
4	Pattern Name	Pattern file name	
5	Type	Indicates the memory type or comb (combination file) when Combination Mode is Edit. Indicates the file type when Combination Mode is Defined.	
6	Status*	Status	File type
		Comment 1/2/3	Displays the Comment Lines 1/2/3
		Version	Version number
		Size	File size
		Sampling Rate	Sampling frequency
		RMS Value	RMS value
7	4 patterns	Number of patterns included in the selected package	

\*: Displayed items switch according to Waveform Select function menu and Subitem Status.

Table 7.3.5-2 Waveform Select Function Menu

Page	Key No.	Menu Display	Function
1	F2	Focus Package <u>Pattern</u>	Moves the cursor between Package/Pattern frames.
	F4	Subitem Status	Switches the Subitem displayed items in <b>Waveform List to Play</b> dialog box.
	F6	Select	Selects the waveform file to be output.
	F8	On Memory A B	Switches the Memory of the waveform pattern information to be displayed in <b>Waveform List to Play</b> dialog box.
2	F1	Delete	Deletes the selected package and pattern in the waveform memory.
	F2	Clear Memory	Deletes all patterns in the waveform memory.

Example: To select the waveform file to be output from the waveform memory.

The explanation is provided below with the assumption that the Waveform Select function menu is displayed.

1. The list of waveform patterns is displayed in the **Waveform List to Play** dialog box. Select Package with **F2 Focus**, and move the cursor on the package which includes the waveform file to be output with the direction key or rotary knob.
2. The list of waveform files is displayed. Select Pattern with **F2 Focus**, move the cursor on the waveform file to be output with the direction key or rotary knob, and press **F6 Select** to select the waveform file to be output.

The waveform pattern can be output with addition of AWGN. For the AWGN function, refer to 7.5 “AWGN”.

When “Preset” is done, the waveform file selection is released. However, the waveform pattern loaded into the waveform memory remains.

Example: To delete the waveform file from the waveform memory.

The explanation is provided below with the assumption that the Waveform Select function menu is displayed.

1. The list of waveform patterns is displayed in the **Waveform List to Play** dialog box. Select Package with **F2 Focus**, and move the cursor on the package which includes the waveform file to be deleted with the direction key or rotary knob.
2. The list of waveform files is displayed. Select Pattern with **F2 Focus**, move the cursor on the waveform file to be deleted with the direction key or rotary knob, and press **F1 Delete** in the page 2 of Waveform Select function menu to delete the waveform file.

**Note:**

Press **F2 Clear Memory** to delete all waveform files in the waveform memory A and B.

Even when the waveform file is deleted from the waveform memory, if the deleted waveform file remains in HDD, it can be loaded again.

**Remote command**

**Query the waveform pattern name loaded into the waveform memory A/B**

**Query**

```
:MEMory[1] | 2:WAVEform:WMA|WMB|LONG|COMBination:NAME?
<ext_integer>
```

**Response**

```
<string1>,<string2>
```

**Parameter**

<code>&lt;ext_integer&gt;</code>	Random numbers allocated to waveform patterns.
Range	0 to (Number of waveform patterns in the waveform memory – 1)
Resolution	1
<code>&lt;string1&gt;</code>	Package name Character string within 31 characters enclosed by double quotes ( " ") or single quotes ( ' ' )
<code>&lt;string2&gt;</code>	Pattern name (excluding extensions) Character string within 100 characters enclosed by double quotes ( " ") or single quotes ( ' ' )

**Programming Example**

To query the second waveform pattern name loaded in SG1 waveform memory A.

```
MEM:WAV:WMA:NAME? 2
> "WCDMA", "TEST"
```

**Remote command****Query the number of waveform patterns loaded in the waveform memory****Query**

```
:MEMory[1] | 2:WAVeform:WMA|WMB|LONG|COMBination:COUNT?
```

**Response**

```
<integer>
```

**Parameter**

<integer>                      Number of waveform patterns loaded into waveform memory

Range                            0 to 4096

Resolution                      1

**Programming Example**

To query the number of waveform pattern files loaded into SG1 waveform memory A.

```
MEM:WAV:WMA:COUN?
> 2
```

**Remote command****Query the waveform memory free space****Query**

For the waveform memory A

```
:MEMory[1] | 2:WAVeform:WMA:FREE?
```

For the waveform memory B

```
:MEMory[1] | 2:WAVeform:WMB:FREE?
```

**Response**

```
<integer1>,<integer2>,<integer3>
```

**Parameter**

<integer1>                      Free space (in byte)

<integer2>                      Continuous free space (in byte)

<integer3>                      Total waveform memory size (in byte)

### Programming Example

To query the SG1 waveform memory A free space.

```
MEM:WAV:WMA:FREE?
```

```
> 1234567890,12345678,123456789
```

### Moving cursor: Focus

 or **Top>Mode>Select, >Focus**

Moves the cursor between Package/Pattern frames in the **Waveform List to Play** dialog box.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Focus** on the Waveform Select function menu for selection.

Package	Moves the cursor to Package List.
Pattern	Moves the cursor to Pattern List.

### Switching subitem: Subitem

 or **Top>Mode>Select, >Subitem**

Selects the display items of Subitem in **Waveform List to Play** dialog box from the Subitem function menu.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F4 Subitem** on the Waveform Select function menu for selection.

F1 Status	Pattern type
F2 Comment Line1	Comment Line 1
F3 Comment Line2	Comment Line 2
F4 Comment Line3	Comment Line 3
F5 Version	Version number
F6 Size	File size
F7 Sampling Rate	Sampling frequency
F8 RMS Value	RMS value

### Selecting waveform pattern: Select

 or **Top>Mode>Select, >Select**

Selects the waveform pattern to be played from the waveform patterns loaded into the waveform memory.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F6 Select** on the Waveform Select function menu to select the waveform pattern to be played.



**Remote command**

**Select the waveform file to be played from the waveform patterns in the waveform memory**

**Command**

```
[ :SOURce[1] | 2 ] :RADio:ARB:WMA | WMB | LONG | COMBination:WAVEform <string1>,<string2>
```

**Query**

```
[ :SOURce[1] | 2 ] :RADio:ARB:WMA | WMB | LONG | COMBination:WAVEform?
```

**Response**

```
<string1> "NONE" is returned when nothing is selected.
<string2> "NONE" is returned when nothing is selected.
```

**Parameter**


```
<string1> Package name
Character string within 31 characters enclosed
by double quotes ( " ") or single quotes ( ' ')
<string2> Pattern name (excluding extensions)
Character string within 100 characters enclosed
by double quotes ( " ") or single quotes ( ' ')
WMA Wave Memory A
PatternCombination is automatically set to Edit.
WMB Wave Memory B
PatternCombination is automatically set to Edit.
LONG Long Pattern
PatternCombination is automatically set to
Defined.
COMBination Combination Pattern
PatternCombination is automatically set to
Defined.
```

**Programming Example**

To playback the combination file "RMC15k" in the package "WCDMA" on SG2.

```
SOUR2:RAD:ARB:COMB:WAV "W-CDMA", "RMC15k"
SOUR2:RAD:ARB:COMB:WAV?
> "WCDMA", "RMC15k"
SOUR2:RAD:ARB:LONG:WAV?
> "NONE", "NONE"
```

Selecting waveform pattern: On Memory

 or **Top>Mode>Select, >On Memory**

Switches the Memory of the waveform pattern information to be displayed in **Waveform List to Play** dialog box.



In MG3740A, this can be used only when option-020/120 is installed.

Press **F8 On Memory** on the Waveform Select function menu to switch Memory A and B.

**Note:**

This is displayed when Combination Mode is set to Edit.

Delete

 or **Top>Mode>Select, >>Delete**

Deletes the specified waveform pattern in the waveform memory.

In MG3740A, this can be used only when option-020/120 is installed.

Select the waveform pattern to be deleted in the **Waveform List to Play** dialog box and press **F1 Delete** on page 2 of Waveform Select function menu to display the Confirmation function menu and to highlight only the waveform pattern to be deleted.

Press **F7 Confirm Delete** on the Confirmation function menu to execute the deletion.

**Table 7.3.5-3 Confirmation Function Menu**

Page	Key No.	Menu Display	Function
1	F7	Confirm Deletion	Deletes the waveform pattern.
	F8	Cancel	Returns the menu before this menu is opened.

**Remote command**

**Delete the specified package and waveform file in the waveform memory**

**Command**

```
:MEMory[1] | 2:DElete:WAVEform:WMA|WMB|LONG|COMBination:[ :
NAME] <string1>,<string2>
```

**Parameter**

<string1>	Package name Character string within 31 characters enclosed by double quotes ( " ") or single quotes ( ' ' )
<string2>	Pattern name (excluding extensions) Character string within 100 characters enclosed by double quotes ( " ") or single quotes ( ' ' )

**Details**

This command does not delete waveform patterns on the hard disk.

**Programming Example**

To delete the pattern "TEST" in the package "WCDMA" in SG2 waveform memory A.

```
MEM2:DEL:WAV:WMA "WCDMA", "TEST"
```

**Clear Memory**

 or **Top>Mode>Select, >**  **Clear Memory**

Deletes all patterns in the waveform memory. All patterns in both the waveform memory A and B are deleted.

In MG3740A, this can be used only when option-020/120 is installed.

Select the waveform pattern to be deleted in the **Waveform List to Play** dialog box and press **F2 Clear Memory** on page 2 of Waveform Select function menu to display the Confirmation function menu and to highlight only the waveform patterns to be deleted.

Press **F7 Confirm Delete** on the Confirmation function menu to execute the deletion.

**Table 7.3.5-4 Confirmation Function Menu**

Page	Key No.	Menu Display	Function
1	F7	Confirm Deletion	Deletes the waveform patterns.
	F8	Cancel	Returns the menu before this menu is opened.

**Remote command**

**Delete all waveform patterns in the waveform memory**

**Command**

:MEMory[1] | 2:DELeTe:WAVEform:ALL

**Details**

This command does not delete waveform patterns on the hard disk.

**Programming Example**

To delete all waveform patterns in SG2 waveform memory.

MEM2:DEL:WAV:ALL

### 7.3.6 Copying external waveform pattern: Copy

**Mode** or **Top>Mode,>Copy**

Copies the waveform pattern of the external device such as USB memory to the internal HDD of MG3710A/MG3740A.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F6 Copy** on the ARB/Waveform function menu to open the **Copy Pattern to HDD** dialog box and Copy Pattern function menu.




Figure 7.3.6-1 Waveform List to Copy

Table 7.3.6-1 Waveform List to Copy

No.	Display Example	Description
1	Drive C:	Drive number
2	Package Name	Package file name
3	Pattern Name	Pattern file name
4	Type	File type
5	Path	Location where pattern file saved
6	54 patterns	Number of patterns included in the selected package

**Table 7.3.6-2 Waveform Copy Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C	Selects the copy source device for the waveform pattern.
	F2	Focus <u>Package</u> Pattern	Moves the cursor between Package/Pattern frames.
	F6	Copy Pattern/Package	Copies the selected waveform pattern to HDD.
	F7	Copy All Patterns/Packages	Copies all waveform files/packages to HDD.
	F8	To Drive C:	Sets the copy destination drive for the waveform file.

Example: To copy the waveform pattern of the external device such as USB memory to the specified drive.

The explanation is provided below with the assumption that the Waveform Copy function menu is displayed.

1. Press **F1 Drive** to select the device which includes the waveform pattern to be copied.
2. The list of waveform patterns is displayed in the **Waveform List to Copy** dialog box. Select Package with **F2 Focus**, and move the cursor on the waveform pattern to be copied with the direction key or rotary knob.
3. The list of waveform files of the selected package is displayed. Select Pattern with **F2 Focus**, and move the cursor on the waveform file to be copied with the direction key or rotary knob.
4. Press **F6 Copy Pattern** to copy the waveform file specified in Step 3 into the copy destination device.

**Notes:**

Even when only the combination file is copied to the internal hard disk, if the pattern file specified with the combination file does not exist in the internal hard disk, the combination file cannot be loaded into the memory.

When copying waveform file, copy the waveform file to the root directory of the target device, or make a sub-directory that bears the name of the package. See the example below.

Example: Preparing waveform file (“test.wvi” or “test.wvd” – package name being “ABC”) to be copied into the F drive.

Copy the file into the following directory you are going to create, so that it will be:

F:\test.wvi, F:\test.wvd or

F:\ABC\test.wvi, F:\ABC\test.wvd

Do not turn off the power while the waveform file is being copied.

### Copy source drive: Drive

 or **Top>Mode,>Copy>Drive**

Selects the copy source drive for the waveform pattern.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 Drive** on the Waveform Copy function menu to display the Drive function menu for selection.

Options	All connected Drives
Default	C

### Moving cursor: Focus

 or **Top>Mode,>Copy>Focus**

Moves the cursor between Package/Pattern frames in the **Waveform List to Copy** dialog box.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Focus** on the Waveform Copy function menu for selection.

Package	Moves the cursor to Package List.
Pattern	Moves the cursor to Pattern List.

### Switching subitem: Subitem

 or **Top>Mode,>Copy>Subitem**

Selects the display items of Subitem in **Waveform List to Copy** dialog box from the Subitem function menu.


In MG3740A, this can be used only when option-020/120 is installed.

Press **F4 Subitem** on the Waveform Copy function menu for selection.

F1 Status	Pattern type
F2 Comment Line1	Comment Line 1
F3 Comment Line2	Comment Line 2
F4 Comment Line3	Comment Line 3
F5 Version	Version number
F6 Size	File size
F7 Sampling Rate	Sampling frequency
F8 RMS Value	RMS value



## Copy Pattern/Copy Package

 or **Top>Mode, >Copy>Copy Pattern/Copy Package**

Copies the selected waveform pattern of the specified drive to HDD.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F6 Copy Pattern/Copy Package** on the Waveform Copy function menu for copy.

When Pattern is selected with **F2 Focus**, Copy Pattern is executed, and when Package is selected, Copy Package is executed.

### Remote command

**Copies the selected waveform pattern of the specified drive to HDD.**

#### Command

To copy all waveform patterns in the specified folder.

```
:MMEMory:COPI:WAVEform:ALL
```

```
<device1>[,<string>|ROOT[,<device2>]]
```

To copy the combination file (wvc) or single pattern (wvi/wvd).

If there is a wvc/wvi with the same name, the combination file has priority.

```
:MMEMory:COPI:WAVEform
```

```
<device1>,<string>|ROOT,<string1>[,<device2>]
```

To copy the single pattern file (wvi/wvd).

The combination file (wvc) cannot be copied with this command.

```
:MMEMory:COPI:WAVEform:SINGLE
```

```
<device1>,<string>|ROOT,<string1>[,<device2>]
```

#### Parameter

<device1>	Copy source drive A to Z, drive C when omitted
<device2>	Copy destination drive A to Z, drive C when omitted
<string>	Package name When omitted: all packages Character string within 31 characters enclosed by double quotes (" ") or single quotes (' ')
ROOT	Root folder All packages when omitted.
<string1>	Pattern name (excluding extensions) Character string within 100 characters enclosed by double quotes (" ") or single quotes (' ')

### Programming Example

To copy all waveform patterns included in the package “WCDMA” in E drive to D drive.

```
M MEM: COPY: WAV: ALL E, "WCDMA", D
```

To copy the waveform file “TEST” included in the root folder in E drive to D drive.

```
M MEM: COPY: WAV E, ROOT, "TEST", D
```

To copy the single pattern file “TEST” included in the package “WCDMA” in E drive to C drive.

```
M MEM: COPY: WAV: SING E, "WCDMA", "TEST"
```

### Copy All Patterns/Copy All Packages

 or **Top>Mode,>Copy>Copy All Patterns/Copy All Packages**

Copies all waveform files/packages to HDD.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F7 Copy All Patterns/Copy All Packages** on the Waveform Copy function menu for copy. The progress bar and Progress function menu are displayed during execution.

When “Pattern” is selected with **F2 Focus**, Copy All Patterns is executed, and when “Package” is selected, Copy All Packages is executed.

**Example:** To copy the waveform files to HDD.

The explanation is provided below with the assumption that the Waveform Copy function menu is displayed.

1. Press **F1 Drive** to select the device which includes the waveform pattern to be copied.
2. The list of waveform patterns is displayed in the **Waveform List to Copy** dialog box. Select Package with **F2 Focus**, and move the cursor on the package which includes the waveform patterns to be copied with the direction key or rotary knob.
3. The list of waveform files of the selected package is displayed. Select Pattern with **F2 Focus**, and move the cursor on the waveform file to be copied with the direction key or rotary knob.
4. Press **F7 Copy All Patterns** on the Waveform Copy function menu to copy the waveform patterns.

**Note:**

Press **F7 Delete All** on the Waveform Copy function menu to delete all waveform patterns according to the setting with **F2 Focus** regardless of settings in Step 2 and 3.

5. The progress bar window is displayed during copying of pattern files.
6. When copying waveform patterns is finished, the progress bar window is closed.

**Notes:**

- When the deleted pattern file has been specified with the combination file, the combination file cannot be loaded into the memory any more.
- Do not turn off the power while the waveform pattern is being deleted.
- When the package is deleted, all waveform files included in the package are deleted.
- Note that the waveform pattern deleted from the internal hard disk cannot be recovered.

**Setting copy destination drive: To Drive**

 or **Top>Mode, >Copy>To Drive**

Sets the copy destination drive for the waveform file.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F8 To Drive** on the Waveform Copy function menu for setting.

### 7.3.7 RF Gate

 or Top>Mode, >

Controls the RF output On/Off for the modulated wave to execute the pulse modulation. This function is used for the pulse modulation for the RF output when the burst signal such as TDMA is used. The RF On/Off control can be executed with the pulse modulation control bit (when Edit Mode = Off) added to the waveform pattern or user-specified interval/width (when Edit Mode = On/Sync).


In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 RF Gate** on page 2 of ARB/Waveform function menu to open the RF Gate function menu.

**Table 7.3.7-1 RF Gate Function Menu**

Page	Key No.	Menu Display	Function
1	F1	RF Gate Off <u>On</u>	Enables/disables the RF Gate function.
	F2	Edit Mode <u>Off</u> On Sync	Sets the RF Gate edit function.
	F3	Type <u>Single</u> Double	Sets the number of RF Gate lines to be edited.
	F4	Offset 1 0.00	Sets Offset from the top output of Pattern to RF Gate1.
	F5	Width 1 1.00	Sets the RF Gate1 width.
	F6	Offset 2 0.00	Sets Offset for the RF Gate2 timing after Pattern top output.
	F7	Width 2 1.00	Sets the RF Gate2 width.
	F8	Cycle 1.00	Sets the cycle for RF Gate1 and RF Gate2. The cycle for RF Gate1 and RF Gate2 is common.

## RF Gate

 or **Top>Mode,>**  **RF Gate>RF Gate**

Enables/disables the RF Gate function.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 RF Gate** on the RF Gate function menu to set On/Off.

Off	RF Gate is not used. Constant output.
On	RF output On/Off control is executed with RF Gate (Default).

## Remote command

## Enable/disable the RF Gate function

## Command

```
[ :SOURce[1] | 2 ] :RADio:ARB:RFGate <boolean>
```

## Query

```
[ :SOURce[1] | 2 ] :RADio:ARB:RFGate?
```

## Response

```
<boolean> 0 or 1
```

## Parameter

<boolean>	RF Gate function On/Off
OFF   0	RF Gate is not used. Constant output.
ON   1	RF output On/Off control is executed with RF Gate (Default).

## Programming Example

To set the RF Gate function to On.

```
RAD:ARB:RFG ON
```

```
RAD:ARB:RFG?
```

```
> 1
```

## Editing RF Gate: Edit Mode

 or **Top>Mode,>**  **RF Gate>Edit Mode**

Enables/disables the RF Gate edit function.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Edit Mode** on the RF Gate function menu to set On/Off.

Off	RF Gate bit in Pattern is used. When both Pattern A and B have been selected, the RF Gate bit in Pattern A is used (Default).
On	RF Gate is edited. RF Gate frequency is set by the user. RF Gate bit in Pattern is disabled.

Sync RF Gate is edited. RF Gate cycle synchronizes with the Pattern cycle. RF Gate bit in Pattern is disabled.

The MG3710A/MG3740A allows handling up to 16 bits of waveform data bit length. In this case, the RF Gate signal cannot be embedded in the waveform data; therefore, this function is used for editing.

If the RF Gate bit is not added to the waveform pattern, even setting the Edit Mode to Off does not allow the RF output On/Off control. The RF Gate bit can be added when the waveform pattern bit width is 14 or 15 bits.

For the method to add the bit to the waveform pattern, refer to the *MG3700A/MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)*.

**Remote command**

**Enable/disable the RF Gate function**

**Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:PULSe:EDIT [ :STATe]
ON|OFF|PATSync
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:PULSe:EDIT [ :STATe] ?
```

**Response**

```
<mode> ON,OFF or PATS
```

**Parameter**

<mode>	RF Gate edit function On/Off
OFF	RF Gate bit in Pattern is used. When both Pattern A and B have been selected, the RF Gate bit in Pattern A is used (Default).
ON	RF Gate is edited. RF Gate frequency is set by the user. RF Gate bit in Pattern is disabled.
PATSync	RF Gate is edited. RF Gate cycle synchronizes with the Pattern cycle. RF Gate bit in Pattern is disabled.

**Programming Example**

To set the RF Gate edit function to On (the cycle is set by the user).

```
RAD:ARB:PULS:EDIT ON
RAD:ARB:PULS:EDIT?
> ON
```

## RF Gate line: Type

**Mode** or **Top>Mode, >→>RF Gate>Type**

Selects the number of RF Gate lines to be edited.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F3 Type** on the RF Gate function menu for selection.

Single	The output signal is gated with one RF Gate (Default). Set RF Gate 1 with <b>F4</b> , <b>F5</b> , and <b>F8</b> .
Double	The output signal is gated with combined (OR) two RF Gate lines. Set two RF Gate 1/2 with <b>F4</b> to <b>F8</b> .

## Remote command

**Set the number of RF Gate lines to be edited****Command**

```
[ :SOURCE[1] | 2 ] :RADio:ARB:PULSe:TYPE SINGLE | DOUBle
```

**Query**

```
[ :SOURCE[1] | 2 ] :RADio:ARB:PULSe:TYPE?
```

**Response**

```
<mode> SING or DOUB
```

**Parameter**

<mode>	RF Gate edit function On/Off
SINGle	The output signal is gated with one RF Gate (Default).
DOUBle	The output signal is gated with combined (OR) two RF Gate lines.

**Programming Example**

To set the number of RF Gate lines to be edited to two lines.

```
RAD:ARB:PULS:TYPE DOUB
```

```
RAD:ARB:PULS:TYPE?
```

```
> DOUB
```

RF Gate offset 1/2: Offset 1/ Offset 2

**Mode** or **Top>Mode,>** **→** **RF Gate>Offset 1/Offset 2**

Sets the offset from the top output of Pattern to RF Gate1/2.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F4 Offset 1/F6 Offset 2** on the RF Gate function menu for setting.

Range	Lower limit	0
	Upper limit	$(2^{24} - 1) \div \text{OverSampling A/B}$
Resolution		0.01
Default		0
Unit		SystemUnit A/B
OverSampling A/B		Over sampling magnification ratio of the waveform data A/B

**Note:**

The following are applied:

For Pattern A output: OverSampling A and SystemUnit A.

For Pattern B output: OverSampling B and SystemUnit B.

For Pattern A/B simultaneous output: OverSampling A and SystemUnit A.




Figure 7.3.7-1 RF Gate Offset, Width, and Cycle

**Remote command**

**Set the offset from the top output of Pattern to RF Gate1/2**

**Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:PULSe [1] | 2 :EDIT:OFFSet
<ext_numeric>
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:PULSe [1] | 2 :EDIT:OFFSet?
```

**Response**

```
<ext_numeric>
```



**Parameter**

<ext_numeric>	Offset value from the top output of Pattern to RF Gate1/2	
Range	Lower limit	0
	Upper limit	$(2^{24} - 1) \div \text{OverSampling}$ A/B
Resolution	0.01	
Default	0	
Unit	SystemUnit A/B	
Suffix code	None	

**Details**

As for node :PULSe[1] | 2, select RF Gate 1 or RF Gate 2. Set as follows:

RF Gate 1: :PULSe1 or :PULSe

RF Gate 2: :PULSe2

**Programming Example**

To set the RF Gate2 offset to 1.

```
RAD:ARB:PULS2:EDIT:OFFS 1
```

```
RAD:ARB:PULS2:EDIT:OFFS?
```

```
> 1.00
```

## RF Gate width 1/2: Width 1/ Width 2

 or **Top>Mode,>**  **>RF Gate>Width 1/Width 2**

Sets the RF Gate1/2 width.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F5 Width 1/F7 Width 2** on the RF Gate function menu for setting.

## Setting range

Minimum value	$1 \div \text{OverSampling}$ A/B
Maximum value	When RF Gate Edit Mode1/2 is set to “On”, $(2^{24} - 1) \div \text{OverSampling}$ A/B (Rounded to two decimal places) or RF Gate Cycle, whichever smaller When RF Gate Edit Mode1/2 is set to “Sync”, $(2^{24} - 1) \div \text{OverSampling}$ A/B (Rounded to two decimal places) or $\text{DataPointA/B} \div \text{OverSampling}$ A/B, whichever smaller
Resolution	0.01 [SystemUnit A/B]
Default	1
Unit	SystemUnit A/B
OverSampling A/B	Over sampling magnification ratio of the waveform data A/B

SystemUnit A/B	Data unit for each system (Symbol, Bit, Chip, and others)
DataPointA/B	Waveform pattern cycle

**Note:**

The following are applied:  
 When Pattern A is output,  
 OverSampling A, SystemUnit A.  
  
 When Pattern B is output,  
 OverSampling B, SystemUnit B.  
  
 When both A/B is output,  
 OverSampling A, SystemUnit A.

**Remote command**

**Set the RF Gate1/2 width**

**Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:PULSe [1] | 2 :EDIT:WIDTh
<ext_numeric>
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:PULSe [1] | 2 :EDIT:WIDTh?
```

**Response**

```
<ext_numeric>
```

**Parameter**

```
<ext_numeric>          RF Gate1/2 width
Setting range, resolution, and default
                        Refer to the above explanation.
Unit                    SystemUnit A/B
Suffix code             None
```

**Details**

As for node :PULSe [1] | 2, select RF Gate 1 or RF Gate 2. Set as follows:



```
RF Gate 1: :PULSe1 or :PULSe
```

```
RF Gate 2: :PULSe2
```

**Programming Example**

```
To set the RF Gate1 width to 1.
RAD:ARB:PULS:EDIT:WIDTh 1
RAD:ARB:PULS:EDIT:WIDTh?
> 1.00
```

## RF Gate cycle: Cycle

 or **Top>Mode,>**  **RF Gate>Cycle**

Sets the cycle for RF Gate1 and RF Gate2. The cycle for RF Gate1 and RF Gate2 is common.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F8 Cycle** on the RF Gate function menu for setting.

## Range

Lower limit	$1 \div \text{OverSampling A/B}$
Upper limit	$(2^{24} - 1) \div \text{OverSampling A/B}$ (Rounded to two decimal places)
Resolution	0.01
Default	1
Unit	SystemUnit A/B
OverSampling A/B	Over sampling magnification ratio of the waveform data A/B
SystemUnit A/B	Data unit for each system (Symbol, Bit, Chip, and others)

**Note:**

The following are applied:  
When Pattern A is output,  
OverSampling A, SystemUnit A.

When Pattern B is output,  
OverSampling B, SystemUnit B.

When both A/B is output,  
OverSampling A, SystemUnit A.

**Remote command****Set the cycle for RF Gate1 and RF Gate2****Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:PULSe:EDIT:CYCLe <ext_numeric>
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:PULSe:EDIT:CYCLe?
```

**Response**

```
<ext_numeric>
```

**Parameter**

<ext_numeric>	Cycle for RF Gate1 and RF Gate2
Range	$1 \div \text{OverSampling A/B}$ to $(2^{24} - 1) \div \text{OverSampling A/B}$
Resolution	0.01
Default	1
Unit	SystemUnit A/B
Suffix code	None

**Programming Example**

To set the cycle for RF Gate1 and RF Gate2 to 1.

```
RAD:ARB:PULS:EDIT:CYCL 1
```

```
RAD:ARB:PULS:EDIT:CYCL?
```

```
> 1.00
```

### 7.3.8 Start/Frame Trigger

 or **Top>Mode,>**  **>Start/Frame Trigger**

Sets the settings related to Start/Frame Trigger.

This is used to interlock the waveform pattern play operation with the external trigger input.

Press **F2 Start/Frame Trigger** on the ARB/Waveform function menu to open the Start/Frame Trigger function menu.

**Table 7.3.8-1 Start/Frame Trigger Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Start/Frame Trigger <u>Off</u> On	Enables/disables the trigger to be used for Baseband signal output start. In MG3740A, this can be selected only when option-020/120 is installed.
	F2	Mode <u>Start</u> Frame	Selects the mode for the trigger to be used for Baseband signal output start. In MG3740A, this can be selected only when option-020/120 is installed.
	F3	Source Ext	Selects Start/Frame Trigger Source. In MG3740A, this can be selected only when option-020/120 is installed.
	F4	Delay 0.00	Sets the delay time from the Trigger input to RF signal output. In MG3740A, this can be selected only when option-020/120 is installed.
	F5	Edge <u>Rise</u> Fall	Sets the detection edge of Start/Frame trigger input. In MG3740A, this can be selected only when option-020/120 is installed.
	F6	Event Buffered Trig	Sets the trigger operation when Frame trigger is used. In MG3740A, this can be selected only when option-020/120 is installed. Refer to 7.3.9 “Setting Frame trigger operation: Event”.
	F7	Frame Count 1 Frame	Sets the number of frames to output when Frame trigger operation is executed. In MG3740A, this can be selected only when option-020/120 is installed. Refer to 7.3.10 “Frame Count”
	F8	Trigger Key	Generates Start/Frame Trigger manually. This is executable only from this menu. When SFTriggerSource is Trigger Key, executing this function applies the trigger.

## Start/Frame Trigger

 or **Top>Mode, >**  **>Start/Frame Trigger>Start/Frame Trigger**

Enables/disables the trigger to be used for Baseband signal output start.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 Start/Frame Trigger** on the Start/Frame Trigger function menu for setting.

Off	Does not use the trigger (Default).
On	Uses the trigger.

To output the signal in synchronization with the external trigger signal. MG3710A/MG3740A allows output waveform patterns in synchronization with the trigger signal input from the external. The external trigger signal can be selected from the two types of Start Trigger to specify the waveform pattern output start position and Frame Trigger to specify the output timing for each burst when the burst signal is selected.

Also in the sequence mode, using Pattern Trigger allows specifying the element switching timing.

### Start Trigger operation

In Start Trigger operation, after the waveform pattern is selected, output is started according to the rising timing of the first external trigger signal and continued. The second and later input external trigger signals are invalid. The relation between the external trigger signal and waveform pattern output can be set with Delay. When Delay is set to “0”, the waveform pattern is output 1 Frame (\*) cycle behind which is determined with the waveform pattern after the external trigger signal rising.

\*: 1 Frame cycle means values below.

- (1) When the waveform pattern is generated with the use of Convert function of IQproducer™

The number of samples of 1 Frame is set with the settings of Burst Setting Frame Length ( $L_f$ ) and Gap Length ( $L_g$ ). 1 Frame cycle is  $L_f + L_g$  which means the number of samples between 1 Frames.

Example: When the over sampling data of four times of W-CDMA is converted:

$$\text{Frame Length} = 3.84 \times 10^6 \text{ [sample/s]} \times 0.01 \text{ [s]} \times 4 \text{ [Over sampling ratio]} = 153600$$

For details, refer to 4.5.3 “Editing Convert data” in the *MG3700A/MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)*.

- (2) When the waveform pattern is generated with the application to generate the signal which is the option of IQproducer™

The frame length supporting each communications system is set automatically. In this case, the values of  $L_f$  and  $L_g$  change depending on whether the system used is for continuous waves or burst waves as follows:

- For continuous waves

$L_f$  = The number of samples for 1 Frame of the system is set.


$L_g$  = 0 is set.

- For burst waves

$L_f$  = The number of samples for 1 Slot or 1 Frame of the system is set.

$L_g$  = “The number of samples for 1 Frame” – “The number of samples for 1 Slot” or 0 is set.

The details for the above depend on systems; however,  $L_f + L_g$  is the number of samples for 1 Frame determined with systems in each case.



\* When Delay is set to 0, the waveform pattern is output Frame cycle and processing delay generated from trigger waveform pattern generation with internal delay (additional delay) behind.

\* Frame cycle depends on systems. Refer to the operation manual for the selected waveform pattern.

**Figure 7.3.8-1 Start Trigger Timing**

Frame Trigger operation

In Frame Trigger operation, one frame of waveform pattern is output according to the rising timing of the external trigger signal. When the frame output is finished, it'll be in trigger wait state again. The relation between the external trigger signal and waveform pattern output is same as StartTrigger. The operation when Delay is set to "0" and the external trigger signal is input with Frame cycle is shown below.




Figure 7.3.8-2 Frame Trigger Timing

When the external trigger signal input cycle is shorter than Frame cycle by N [sample] count or more, the external trigger signal is masked to be an invalid trigger and the burst wave corresponding to the trigger signal cannot be obtained.

$$N \text{ [sample]} = (L_f + L_g) - (L_f + 1)$$

- \* For  $L_f$  and  $L_g$ , refer to Start Trigger in the previous section.
- \* When Delay is set to + side, Frame cycle is longer by the number of Samples set with Delay.
- \* The maximum value of N ( $N_{max}$ ) can be calculated with the equation below according to the Interpolation Ratio (IPLR) determined with Sampling Clock ( $f_s$ ).
- \* In the equation above, when N exceeds  $N_{max}$ , N is assumed to be  $N_{max}$ .

$$N_{max} = 28 / IPLR$$

IPLR:  $2^n$  value that satisfies  $160 \text{ MHz} \geq IPLR \times f_s > 80 \text{ MHz}$   
 (n is an integer of 3 or higher)

However, for  $f_s > 20 \text{ MHz}$ , IPLR is assumed to be 1.

Here, for example, when  $L_f = 140$  symbol,  $L_g = 280$  symbol, and Sampling Clock = 50 MHz, the right side of N equation above exceeds  $N_{max}$ ; therefore,  $N=28$  is assumed, and the trigger input with the cycle which is shorter than Frame cycle ( $L_f + L_g$ ) by 28 samples or more is invalid.






Figure 7.3.8-3 Frame Trigger Cycle

**Remote command**

**Enable/disable the trigger to be used for Baseband signal output start Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger[:STATe] <boolean>
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger[:STATe] ?
```

**Response**

```
<boolean> 0 or 1
```

**Parameter**

```
<boolean> Trigger On/Off
ON | 1 On
OFF | 0 Off
```

**Programming Example**

To set trigger to On.

```
RAD:ARB:TRIG ON
RAD:ARB:TRIG?
> 1
```

### Trigger mode: Mode

**Mode** or **Top>Mode,>→>Start/Frame Trigger>Mode**

Selects the operation mode for the trigger to be used for Baseband signal output start.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Mode** on the Start/Frame Trigger function menu for selection.

Start	Start Trigger (Default)
Frame	Frame Trigger

### Remote command

**Set the operation mode for the trigger to be used for Baseband signal output start**

#### Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:MODE START | FRAMe
```

#### Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:MODE?
```

#### Response

```
<mode> STAR or FRAM
```

#### Parameter

<mode>	External trigger operation mode
STARt	Start trigger
FRAMe	Frame trigger

#### Programming Example

To set the operation mode for the external trigger to Start trigger.

```
RAD:ARB:TRIG:MODE STAR
```

```
RAD:ARB:TRIG:MODE?
```

```
> STAR
```

## Trigger source: Source

 or **Top>Mode,>**  **>Start/Frame Trigger>Source**

Selects Start/Frame Trigger Source.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F3 Source** on the Start/Frame Trigger function menu to open the S/F Trigger function menu for selection of the trigger source.

Ext (External)	Signal of the terminal allocated to SG1 StartFrameTrig (Default)
Trigger Key	Press <b>F8 Trigger Key</b> .
Bus	Receives remote command * TRG.
Sync to SG1	The start of SG1 and SG2 signals are synchronized with the use of the same trigger source as SG1. If SG1 is freerun, they cannot be synchronized (Valid only with SG2).

## Remote command

## Select Start/Frame Trigger Source

## Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:SOURce KEY|EXT|BUS|SYNC
```

## Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:SOURce?
```

## Response

```
<source>
```

## Parameter

<source>	Trigger signal source
KEY	Press <b>F8 Trigger Key</b> .
EXT	Signal of the terminal allocated to SG1 StartFrameTrig (Default)
BUS	Receives remote command * TRG.
SYNC	The start of SG1 and SG2 signals are synchronized with the use of the same trigger source as SG1. If SG1 is freerun, they cannot be synchronized (Valid only with SG2).

## Programming Example

To set the trigger signal source to Trigger Key.

```
RAD:ARB:TRIG:SOUR KEY
RAD:ARB:TRIG:SOUR?
> KEY
```

## Delay

 or **Top>Mode,>**  **>Start/Frame Trigger>Delay**

Sets the delay time from the Trigger input to RF signal output.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F4 Delay** on the Start/Frame Trigger function menu for setting.

Range	Varies depending on the selected waveform pattern.
Resolution	0.01 [SystemUnit]
Default	0
SamplingClock	Baseband signal output sampling clock Sampling Clock
SamplingRate	Sampling rate Sampling RateA/B
OverSampling	Over sampling magnification ratio of the waveform data
SystemUnit	Data unit for each system (Symbol, Bit, Chip, and others)

### Remote command

**Set the delay time from the Trigger input to RF signal output**

#### Command

[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:DELAy <ext\_numeric>

#### Query

[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:DELAy?

#### Response

<ext\_numeric>

#### Query

[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:DELAy:TIME?

#### Response

<time>                      Unit: s

**Parameter**

<ext_numeric>	Start trigger delay time
Range	Varies depending on the selected waveform pattern.
Resolution	0.01
Default	0
Unit	SystemUnit
Suffix code	None
<time>	Start trigger delay time
Unit	s
Resolution	1 ps

**Programming Example**

To set the start trigger delay time to 30 SystemUnit.

```
RAD:ARB:TRIG:DEL 30
RAD:ARB:TRIG:DEL?
> 30.00
RAD:ARB:TRIG:DEL:TIME?
> 3E-06
```

**Detection edge: Edge**

 or **Top>Mode,>**  **>Start/Frame Trigger>Edge**

Sets the detection edge of Start/Frame trigger input.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F5 Edge** on the Start/Frame Trigger function menu for selection.

**Options**

Rise	The trigger is applied at the signal rising edge (Default).
Fall	The trigger is applied at the signal falling edge.

**Remote command****Set the detection edge of Start/Frame trigger input****Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:SLOPe POSitive|NEGative
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:SLOPe?
```

**Response**

```
<edge> POS or NEG
```

**Parameter**

<edge>	Trigger input detection edge
POSitive	Rise, signal rising edge (Default)
NEGative	Fall, signal falling edge

**Programming Example**

To set the external trigger polarity to Fall.

```
RAD:ARB:TRIG:SLOP NEG
```

```
RAD:ARB:TRIG:SLOP?
```

```
> NEG
```

Trigger Key

 or **Top>Mode,>**  **>Start/Frame Trigger>Trigger Key**

Generates Start/Frame Trigger manually. This is executable only from this menu. It is enabled only when Trigger Key is set with **F3 Source**.

Press **F8 Trigger Key** on the Start/Frame Trigger function menu to apply the trigger.

### 7.3.9 Setting Frame trigger operation: Event

**Mode** or **Top>Mode,>** **→>Start/Frame Trigger>Event**

Frame trigger has four types of operations. The trigger operation when it is used is set.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F6 Event** on the Start/Frame Trigger function menu to open the S/F Trigger Event function menu for selection.

#### Options

No Retrigger	The trigger received during pattern output is ignored (Default).
Buffered Trig	The trigger received during pattern output is waited until the current pattern output is completed, and after completion the next frame is output.
Restart on Trig	The pattern is immediately restarted with the trigger received during pattern output.

#### Remote command

#### Set the trigger operation when Frame trigger is used

##### Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:RETRigger
BUFFered|NORe trig|REStart
```

##### Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:TRIGger:RETRigger?
```

##### Response

```
<mode> BUFF,NOR or REST
```

##### Parameter

<mode>	Trigger operation when Frame trigger is used
NORe trig	Triggers received during pattern output are ignored (Default).
BUFFered	The trigger received during pattern output is waited until the current pattern output is completed, and after completion the next frame is output.
REStart	The pattern is immediately restarted with the trigger received during pattern output.

**Programming Example**

To set the trigger operation when Frame trigger is used to No Retrigger.

```
RAD:ARB:TRIG:RETR NOR
```


```
RAD:ARB:TRIG:RETR?
```

```
> NOR
```


**Operation description** The trigger operations are described below.

**No Retrigger**

When Frame Trigger is received in the section where the pattern signal output is not finished and the second pattern start position is in the section where the first pattern signal output is not finished, the second pattern output is not executed, and the trigger is discarded.



**Figure 7.3.9-1 Frame Trigger No Retrigger**



**Figure 7.3.9-2 Frame Trigger No Retrigger**



## Buffered Trigger

When Frame Trigger is received in the section where the pattern signal output is not finished, the second pattern start position is placed to meet the first pattern finish position for output to avoid pattern output overlap.




Figure 7.3.9-3 Frame Trigger Buffered Trigger

## Restart on Trigger

When Frame Trigger is received in the section where the pattern signal output is not finished and patterns are to be overlapped, the first pattern output is stopped, and the second pattern is overwritten.




Figure 7.3.9-4 Frame Trigger Restart on Trigger

### Note:

Trigger inputs on output wait in each mode above are queued, and output is judged sequentially. The queue size is 16384 ( $=2^{14}$ ). If the trigger is input beyond the size, the trigger is discarded.  $2^{14}$  is the size which allows all triggers of 10 ms cycle when Delay is the maximum.

### 7.3.10 Frame Count

 or **Top>Mode, >**  **>Start/Frame Trigger>Frame Count**

Sets the number of frames to output when Frame trigger is input during Frame trigger operation.

This is enabled when the trigger mode is set to Frame.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F7 Frame Count** on the Start/Frame Trigger function menu for setting.

#### Remote command

**Set the number of frames to output when Frame trigger is input Command**

`[ :SOURCE[1] | 2 ] :RADio:ARB:TRIGger:FRAMe:COUNT <integer>`

#### Query

`[ :SOURCE[1] | 2 ] :RADio:ARB:TRIGger:FRAMe:COUNT?`

#### Response

`<integer>`

#### Parameter

<code>&lt;integer&gt;</code>	Output Frame Number
Range	1 to 32767
Resolution	1
Default	1
Unit	Frame
Suffix code	None

#### Programming Example

To set 1000 to the number of frames to output when Frame trigger is input.

```
RAD:ARB:TRIG:FRAM:COUN 1000
```

```
RAD:ARB:TRIG:FRAM:COUN?
```


```
> 1000
```

Refer to the following pages for the Frame Count operation.

### When Event is No Retrigger

When Frame Trigger is received in the section where the pattern signal output for the number of frames, which is set to Frame Count, is not finished and the second pattern start position is in the section where the first pattern signal output is not finished, the second pattern output is not executed, and the trigger is discarded. The frame numbering of the second pattern is continued from the first pattern.

The following figure shows an example of when the Frame Count is set to 4.




**Figure 7.3.10-1 Frame Trigger No Retrigger**

### When Event is Buffered Trigger

When Frame Trigger is received in the section where the pattern signal output for the number of frames, which is set to Frame Count, is not finished, the second pattern start position is placed to meet the first pattern finish position for preventing pattern outputs from overlapping each other. The frame numbering of the second pattern is continued from the first pattern.

The following figure shows an example of when the Frame Count is set to 3.



**Figure 7.3.10-2 Frame Trigger Buffered Trigger**

### When Event is Restart on Trigger

When Frame Trigger is received in the section where the pattern signal output for the number of frames, which is set to Frame Count, is not finished, the first pattern output is stopped, and the second pattern is overwritten. The frame numbering of the second pattern begins at the sum of “Frame number at which the output starts” and “Frame Count setting”.

The following figure shows an example of when the Frame Count is set to 3.




Figure 7.3.10-3 Frame Trigger Restart on Trigger

### To add two waves

When combining two signals, each of pattern signals A and B is outputted at its frame length by the number of frames set to Frame Count. At this time, the Trigger Disable period (When Event is No Retrigger) or the Trigger Retention period (When Event is Buffered on Trigger) is established according to the pattern with longer frame length. If one pattern signal with shorter frame length has been output within shorter time, this function holds the final sample level and adds it to the other pattern signal in order to output a combined wave.

The following figure shows an example of when the Frame Count is set to 3.






Figure 7.3.10-4 Frame Trigger to add two waves

### 7.3.11 Baseband Clock

 or **Top>Mode, >**  **Baseband Clock**

Sets the settings related to Baseband Clock.

This cannot be used in MG3740A.

The Baseband Clock function menu is used when the external reference clock is input to be used for Baseband. The arbitrary Sampling Clock can be generated because the input clock is divided with the divider within the hardware.

This function is used when the 1.2288 MHz multiplication clock is to be the reference signal like the CDMA2000 base station or when the synchronized signals are to be output with the use of the same clock source like MINO.

Press **F3 Baseband Clock** on page 2 of ARB/Waveform function menu to open the Baseband Clock function menu.

**Table 7.3.11-1 Baseband Clock Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Source Int	Selects the Baseband Reference Clock signal source.
	F2	Division 1/2	Sets the division ratio for the external input Clock for generation of Baseband Reference Clock.
	F3	Out <u>Off</u> On	Sets the Baseband clock reference to Off (not to be output) or On (to be output).

Clock source: Source

 or **Top>Mode, >**  **Baseband Clock>Source**

Selects the Baseband Reference Clock signal source.

This cannot be used in MG3740A.

Press **F1 Source** on the Baseband Clock function menu to open the Baseband Clock Source function menu for selection of the signal source.

This is an independent parameter for each SG. It can be set in the modulation output status (when waveform selection is Mod = On).

For SG1	
Int	The internal signal source is the reference (Default).
Ext	The clock input from the rear panel BB REF Clock Input is the reference. Used for inputting DUT clock or others.
Ext(BB Ref Sync)	The clock input from the rear panel BB REF Clock Input is the reference. Used for synchronization for multiple MG3710As. BB REF Clock Output of MG3710A must be input as the reference.
For SG2	
Int	The internal signal source is the reference (Default).
Sync with 1st SG	Baseband clock used by SG1 is the reference.

**Remote command**

**Select the Baseband Reference Clock signal source**

**Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:CLOCK:REFerence [ :SOURce ]
INTernal | EXTernal | EXTSync | SYNC
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:CLOCK:REFerence [ :SOURce ] ?
```

**Response**

```
<source> INT, EXT, EXTS or SYNC
```

**Parameter**

```
<source> Baseband signal reference clock
INTernal Int (Default)
EXTernal Ext
EXTSync Ext (BB Ref Sync)
SYNC Sync with 1st SG
```

**Programming Example**

To set the baseband signal reference clock to Ext.

```
RAD:ARB:CLOC:REF EXT
RAD:ARB:CLOC:REF?
> EXT
```

Clock division ratio: Division

**Mode** or **Top>Mode,>** **→>Baseband Clock>Division**

Sets the division ratio for the external input Clock for generation of Baseband Reference Clock.

This cannot be used in MG3740A.

Press **F2 Division** on the Baseband Clock function menu to open the Baseband Clock Division function menu for selection of the division ratio.

Range Refer to the table below.

**Table 7.3.11-2 Baseband Reference Clock Division**

Sampling Rate [MHz]	Baseband Reference Clock Division setting range									
	16	8	4	2	1	1/2	1/4	1/8	1/16	
<b>0.02</b> ≤f≤ <b>0.048828125</b>	√	√	√	√	√					
<b>0.048828125</b> <f≤ <b>0.09765625</b>	√	√	√	√	√	√				
<b>0.09765625</b> <f≤ <b>0.1953125</b>	√	√	√	√	√	√	√			
<b>0.1953125</b> <f≤ <b>0.390625</b>	√	√	√	√	√	√	√	√		
<b>0.390625</b> <f≤ <b>3.125</b>	√	√	√	√	√	√	√	√	√	√
<b>3.125</b> <f≤ <b>6.25</b>		√	√	√	√	√	√	√	√	√
<b>6.25</b> <f≤ <b>12.5</b>			√	√	√	√	√	√	√	√
<b>12.5</b> <f≤ <b>25</b>				√	√	√	√	√	√	√
<b>25</b> <f≤ <b>50</b>					√	√	√	√	√	√
<b>50</b> <f≤ <b>100</b>						√	√	√	√	√
<b>100</b> <f≤ <b>200</b>							√	√	√	√

Default 1 or within the heavy lines in the table above

**Remote command**

**Set the division ratio for the external input Clock**

**Command**

```
[ :SOURce[1] ] :RADio:ARB:CLOCK:REFerence:DIVision  
SIXTeenth|EIGHth|QUARter|HALF|X1|X2|X4|X8|X16
```

**Query**

```
[ :SOURce[1] ] :RADio:ARB:CLOCK:REFerence:DIVision?
```

**Response**

```
<clock> SIXT,EIGH,QUAR,HALF,X1,X2,X4,X8 or X16
```

**Parameter**

<clock>	Baseband signal reference clock
SIXTeenth	Sampling Clock $\times$ 1/16
EIGHth	Sampling Clock $\times$ 1/8
QUARter	Sampling Clock $\times$ 1/4
HALF	Sampling Clock $\times$ 1/2
X1	Sampling Clock $\times$ 1
X2	Sampling Clock $\times$ 2
X4	Sampling Clock $\times$ 4
X8	Sampling Clock $\times$ 8
X16	Sampling Clock $\times$ 16

The setting range is described in Table 7.3.11-2 “Baseband Reference Clock Division”.

**Programming Example**

To set the baseband signal reference clock frequency to sampling clock  $\times$  2.

```
RAD:ARB:CLOC:REF:DIV X2  
RAD:ARB:CLOC:REF:DIV?  
> X2
```



## Clock output: Out

 or **Top>Mode, >**  **Baseband Clock>Out**

Enables/disables the Baseband clock reference output.

This cannot be used in MG3740A.

Press **F3 Out** on the Baseband Clock function menu for setting.

This is a shared parameter for each SG. It can be set when either SG1 is in the modulation output status when SG1 is installed or when SG2 is in the modulation output status when SG2 is installed (when waveform selection is Mod=On).

Setting range

Off	Outputs the Baseband clock reference (Default).
On	Does not output the Baseband clock reference.

## Remote command

## Output the Baseband clock reference

## Command

```
[ :SOURce ] :RADio:ARB:CLOCK:REFerence:OUTPut <boolean>
```

## Query

```
[ :SOURce ] :RADio:ARB:CLOCK:REFerence:OUTPut?
```

## Response

```
<boolean>          0 or 1
```

## Parameter

<boolean>	Frequency relative display On/Off
OFF 0	Outputs the Baseband clock reference(Default).
ON 1	Does not output the Baseband clock reference.

## Programming Example

To output the Baseband clock reference.

```
RAD:ARB:CLOC:REF:OUTP ON
```

```
RAD:ARB:CLOC:REF:OUTP?
```

```
> 1
```

## Sampling Clock

Queries the Baseband signal output sampling clock.  
This is a function only with a remote command.

### Remote command

#### Query the baseband signal sampling clock

##### Query

```
[ :SOURce] :RADio:ARB:SCLock:RATE?
```

##### Response

```
<freq>                               Unit: Hz
```

##### Parameter

```
<freq>                               Sampling clock  
Range                                 140 MHz to 200 MHz  
Resolution                             0.001 Hz
```

##### Programming Example

To query the sampling clock.

```
RAD:ARB:SCL:RATE?
```

```
>140000000.000
```

### 7.3.12 Marker Setup

**Mode** or **Top>Mode, >→>Marker Setup**

Sets the settings related to Marker.

In MG3740A, this can be used only when option-020/120 is installed.

The Marker function is used as the trigger out function when the waveform pattern specified positions (the top of Frame, top of burst, or others) are to be used as triggers.

Press **F4 Marker Setup** on the ARB/Waveform function menu to open the **Marker Setup** dialog box and Marker Setup function menu.

Marker Setup						
Name	Label	Polarity	Edit Mode	Offset	Width	Cycle
Marker 1 A	Duty 1/2	Positive	On	0 sample	2 sample	2 sample
Marker 2 A	Duty 1/4	Positive	On	0 sample	2 sample	2 sample
Marker 3 A	Duty 1/8	Positive	On	0 sample	2 sample	2 sample
Marker 1 B		Positive	Off	0	1	1
Marker 2 B		Positive	Off	0	1	1
Marker 3 B		Positive	Off	0	1	1

**Figure 7.3.12-1 Marker Setup**

Marker 1 to 3 indicate Marker number, and A and B indicate the waveform Pattern A and B.

**Table 7.3.12-1 Marker Setup Function Menu**


Page	Key No.	Menu Display	Function
1	F1	Marker 1 A	Displays Marker 1 A Setup function menu.
	F2	Marker 2 A	Displays Marker 2 A Setup function menu.
	F3	Marker 3 A	Displays Marker 3 A Setup function menu.
	F4	Marker 1 B	Displays Marker 1 B Setup function menu.
	F5	Marker 2 B	Displays Marker 2 B Setup function menu.
	F6	Marker 3 B	Displays Marker 3 B Setup function menu.

Press **F1 Marker 1 A to F6 Marker 3 B** on the Marker Setup function menu to open each corresponding Marker Setup function menu.


Set the selected waveform Pattern Marker output (output from the rear panel AUX connector). Marker 1 A Setup function menu is described in the table below.

**Table 7.3.12-2 Marker 1 A Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Edit Mode <u>Off</u> On Sync	Enables/disables the Marker 1 edit function. When set to On/Sync, Marker bit in Pattern is disabled.
	F2	Offset 0.00	Sets Offset from the top output of Pattern to Marker 1 output timing.
	F3	Width 1.00	Sets the output width of Marker 1.
	F4	Cycle 1.00	Sets the output cycle of Marker 1.
	F8	Polarity <u>Positive</u> Negative	Sets the output polarity of Marker 1.



**Figure 7.3.12-2 Offset, Width, Cycle**



**Figure 7.3.12-3 Polarity**

## Edit Mode

 or **Top>Mode, >**  **>Marker Setup>Marker 1/2/3 A(B)>Edit Mode**

Enables/disables the Marker 1 edit function. When set to On/Sync, Marker bit in Waveform Pattern is disabled.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 Edit Mode** on the Marker 1/2/3 A(B) function menu for setting.

On	Edits the Marker position. Also Marker cycle is set by the user.
Off	Uses Marker bit in pattern. (Default).
Sync	Edits the Marker position. Marker cycle synchronizes with the Pattern cycle.

**Notes:**

- For the method to edit Marker bit in the pattern, refer to *MG3700A/MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)*.
- OFF can be specified for Marker 1, 2, and 3 only if a waveform pattern that consists of 14-bit resolution IQ data is selected. If a 15-bit or 16-bit resolution waveform pattern is selected, the following restrictions apply:

15-bit resolution: Markers 2 and 3 cannot be set to OFF|0.

16-bit resolution: Markers 1 to 3 cannot be set to OFF|0.

**Remote command****Enable/disable the Marker 1/2/3 edit function****Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:MARKer1|2|3:EDIT[:STATe]
] <boolean>|PATSync
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:MARKer1|2|3:EDIT[:STATe]
]?
```

**Response**

```
<mode> 0,1 or PATS
```

**Parameter**

<mode>	User setting mode
ON   1	Outputs the user setting marker.
OFF   0	Outputs the marker previously recorded in the waveform pattern.
PATSync	Outputs the marker at the start of the waveform pattern.

**Details**

OFF | 0 can be specified for Marker 1, 2, and 3 only if a waveform pattern that consists of 14-bit resolution IQ data is selected. If a 15-bit or 16-bit resolution waveform pattern is selected, the following restrictions apply:

15-bit resolution: Markers 2 and 3 cannot be set to OFF | 0.

16-bit resolution: Markers 1 to 3 cannot be set to OFF | 0.

**Programming Example**

To set Marker 2 in Pattern A to user setting.

```
RAD:ARB:WMA:MARK2:EDIT ON
RAD:ARB:WMA:MARK2:EDIT?
> 1
```

Offset

 or **Top** > **Mode**, >  > **Marker Setup** > **Marker 1/2/3 A(B)** > **Offset**

Sets Offset from the top output of Waveform Pattern to Marker output timing.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Offset** on the Marker 1/2/3 A(B) function menu for setting.

Setting range

Lower limit	0
Upper limit	$(2^{24} - 1) \div \text{OverSampling A/B}$ (Rounded to two decimal places)
Resolution	0.01 [System Unit A/B]
Default	0
OverSampling A/B	Over sampling magnification ratio of the waveform data A/B
System Unit A/B	Data unit for each system (Symbol, Bit, Chip, and others)

**Remote command****Set Offset from the top output of Waveform Pattern to Marker 1/2/3 output timing****Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:MARKer1|2|3:EDIT:OFFSet
<ext_numeric>
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:MARKer1|2|3:EDIT:OFFSet
?
```

**Response**

```
<ext_numeric>
```

**Parameter**

<ext_numeric>	Starting offset value
	Setting range, resolution, and default
	Refer to the above explanation.
Unit	SystemUnit A/B
Suffix code	None

**Programming Example**

To set the starting offset of Marker 2 of Waveform Pattern A to 100.

```
RAD:ARB:WMA:MARK2:EDIT:OFFS 100
```

```
RAD:ARB:WMA:MARK2:EDIT:OFFS?
```

```
> 100.00
```

**Output width: Width**

 or **Top>Mode**,  **Marker Setup>Marker 1/2/3 A(B)>Width**

Sets the output width of Marker.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F3 Width** on the Marker 1/2/3 A(B) function menu for setting.

**Setting range**

Lower limit	$1 \div \text{OverSampling A/B}$ (Rounded to two decimal places)
-------------	---

Upper limit	When Marker1/2/3 Edit ModeA/B is set to “On”: $(2^{24} - 1) \div \text{OverSampling A/B}$ (Rounded to two decimal places) or Marker1/2/3 CycleA/B, whichever smaller When Marker1/2/3 Edit ModeA/B is set to “Sync”: $(2^{24} - 1) \div \text{OverSampling A/B}$ (Rounded to two decimal places) or DataPointA/B $\div$ OverSampling A/B, whichever smaller
Resolution	0.01 [System Unit A/B]
Default	1
OverSampling A/B	Over sampling magnification ratio of the waveform data A/B
System Unit A/B	Data unit for each system (Symbol, Bit, Chip, and others)
DataPointA/B	Waveform pattern cycle

**Remote command**

**Set the Marker 1/2/3 output pulse width**

**Command**

```
[ :SOURce[1] | 2 ] :RADio:ARB:WMA|WMB:MARKer1 | 2 | 3 :EDIT:WIDTh
<ext_numeric>
```

**Query**

```
[ :SOURce[1] | 2 ] :RADio:ARB:WMA|WMB:MARKer1 | 2 | 3 :EDIT:WIDTh?
```

**Response**

```
<ext_numeric>
```

**Parameter**

```
<ext_numeric>      Pulse width
Setting range, resolution, and default
                    Refer to the above explanation.
Unit                SystemUnit A/B
Suffix code         None
```

**Programming Example**

```
To set the pulse width of Marker 2 of Waveform Pattern A to 50.
RAD:ARB:WMA:MARK2:EDIT:WIDT 50
RAD:ARB:WMA:MARK2:EDIT:WIDT?
> 50.00
```



## Cycle

 or **Top>Mode**, **>**  **>Marker Setup>Marker 1/2/3 A/B>Cycle**

Sets the output cycle of Marker.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F4 Cycle** on the Marker 1/2/3 A(B) function menu for setting.

## Setting range

Lower limit	$1 \div \text{OverSampling A/B}$ (Rounded to two decimal places)
Upper limit	$(2^{24} - 1) \div \text{OverSampling A/B}$ (Rounded to two decimal places)
Resolution	0.01 [System Unit A/B]
Default	1
OverSampling A/B	Over sampling magnification ratio of the waveform data A/B
System Unit A/B	Data unit for each system (Symbol, Bit, Chip, and others)

## Remote command

## Set the Marker 1/2/3 output cycle

## Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:MARKer1|2|3:EDIT:CYCLE
<ext_numeric>
```

## Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:WMA|WMB:MARKer1|2|3:EDIT:CYCLE?
```

## Response

```
<ext_numeric>
```

## Parameter

```
<ext_numeric>      Output pulse cycle
Setting range, resolution, and default
                    Refer to the above explanation.
Unit                SystemUnit A/B
Suffix code         None
```

## Programming Example

To set the output pulse cycle of Marker 2 of Waveform Pattern A to 200.

```
RAD:ARB:WMA:MARK2:EDIT:CYCL 200
```

```
RAD:ARB:WMA:MARK2:EDIT:CYCL?
```

```
> 200.00
```

## Polarity

 or **Top>Mode**, >  > **Marker Setup>Marker 1/2/3 A/B>Polarity**

Sets the output polarity of Marker.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F8 Polarity** on the Marker 1/2/3 A(B) function menu for setting.

Positive	Positive polarity (Default)
Negative	Negative polarity

### Remote command

#### Set the Marker 1/2/3 output polarity

##### Command

```
[ :SOURce[1] | 2 ] :RADio:ARB:WMA|WMB:MARKer|2|3:POLarity  
POSitive|NEGative
```

##### Query

```
[ :SOURce[1] | 2 ] :RADio:ARB:WMA|WMB:MARKer|2|3:POLarity?
```

##### Response

```
<polarity>          POS or NEG
```

##### Parameter

<polarity>	Polarity
POSitive	Positive (Positive polarity)
NEGative	Negative (Negative polarity)

#### Programming Example

To set the polarity of Marker 2 of Waveform Pattern A to Negative.

```
RAD:ARB:WMA:MARK2:POL NEG
```

```
RAD:ARB:WMA:MARK2:POL?
```

```
> NEG
```

### 7.3.13 Sequence Mode

or **Top>Mode, >**  **Sequence Mode**

Sequence Mode is to play the waveform patterns in the specified sequence.

In MG3740A, this can be used only when option-020/120 is installed.

For the creation method for combination files for Sequence Mode, refer to *MG3700A/MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)*.

Press **F7 Sequence Mode** on page 2 of ARB/Waveform function menu to open the **Sequence Progress** dialog box and Sequence Mode function menu.

Index	Package Name	Pattern Name	Repeat	Frequency Offset	Level
1	Test	BBDC	1	0 Hz	0.00 dB
2	TestWvc2	BBDCp1	1	0 Hz	0.00 dB
3	Test	BBDC	1	0 Hz	0.00 dB

Total : 3

ARB  
On  
Seq (A+B)

Power Meter  
A : Off  
B : Off

BER  
Stop 0.000E+000 0 %  
0 / 0

**Figure 7.3.13-1 Sequence Progress Dialog Box**

Index	Element (each element of Sequence Mode) number
Package Name	Package name
Pattern Name	Pattern file name
Repeat	Repetition count of the element
Frequency Offset	Frequency offset of the element based on Baseband center frequency
Level	Level ratio of each element When Add Pattern is not set, the element of the highest output level becomes the reference. When Add Pattern is set, the output level of Add Pattern becomes the reference.
Total	Displays the number of elements in Sequence Mode.

**Note:**

For Add Pattern, refer to 4.8.2 “Combination File Edit screen” in *MG3700A/MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)*.

**Table 7.3.13-1 Sequence Mode Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Next Pattern	Proceeds with the elements of the sequence mode to the next element.
	F2	Sequence Restart	Restarts the elements from the top in the sequence mode.
	F3	Play Mode <u>A</u> uto Manual	Selects the play mode for elements of the sequence mode.
	F4	Repeat Mode <u>C</u> ontinuous Single	Selects the operation after the last element is executed in the sequence mode.
	F5	PatternTrigger	Displays the Pattern Trigger function menu. Refer to 7.3.14 “PatternTrigger”.

Next Pattern

 or **Top>Mode, >**  **Sequence Mode>Next Pattern**

The elements of the sequence mode is proceeded with to the next element.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 Next Pattern** on the Sequence Mode function menu for execution.

**Remote command**

**Proceed with the elements of the sequence mode to the next element Command**



`[ :SOURCE [ 1 ] | 2 ] :RADio:ARB:SEQuence:NEXT`

**Programming Example**

To proceed with the elements of the sequence mode to the next element.

`RAD:ARB:SEQ:NEXT`

## Sequence Restart

 or **Top>Mode,>>Sequence Mode>Sequence Restart**

Restarts the elements from the top in the sequence mode.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Sequence Restart** on the Sequence Mode function menu for execution.

### Remote command

#### Restart the elements from the top in the sequence mode

##### Command

```
:INITiate[1] | 2:ARB:SEquence[:IMMEDIATE]
```

##### Related command

Use the following command to obtain the play status and to wait for completion.

```
[:SOURce[1] | 2]:RADio:ARB:SEquence:REGister[:STATus]?
```

##### Programming Example

To restart SG1 output elements from the top in the sequence mode.

```
INIT:ARB:SEQ
```

### Remote command

#### Query the playback status of the sequence mode

##### Query

```
[:SOURce[1] | 2]:RADio:ARB:SEquence:REGister[:STATus]?
```

##### Response

```
<status>
```

##### Parameter

<status>	Playback status
bit2 : 2 <sup>2</sup> = 4	(0: Paused, 1: Playback)
bit0, 1, 3 to 15	Not used

##### Details

“Playing” is returned during trigger waiting.

##### Related command

Use the following command for the pattern play status.

```
[:SOURce[1] | 2]:RADio:ARB:REGister[:STATus]?
```



##### Programming Example

To query the SG1 output play status in the sequence mode.

```
RAD:ARB:SEQ:REG?
```

```
> 4
```

## Play Mode

 or **Top>Mode,>**  **>Sequence Mode>Play Mode**

Selects the play mode for elements of the sequence mode.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F3 Play mode** on the Sequence Mode function menu for selection.

Auto Proceeds with elements automatically.

Manual Proceeds with elements manually.

### Remote command

**Select the play mode for elements of the sequence mode**

#### Command

`[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:MODE AUTO|MANual`

#### Query

`[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:MODE?`

#### Response

`<mode>` AUTO|MANual

#### Parameter

`<mode>` Play mode for elements

AUTO Proceeds with elements automatically.

MANual Proceeds with elements manually.

#### Programming Example

To set the play mode for elements of the sequence mode to automatic.

```
RAD:ARB:SEQ:MODE AUTO
```

```
RAD:ARB:SEQ:MODE?
```

```
> AUTO
```

## Repeat Mode

**Mode** or **Top>Mode,>→>Sequence Mode>Repeat Mode**

Selects the operation after the last element is executed in the sequence mode.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F4 Repeat mode** on the Sequence Mode function menu for selection.

Continuous	After the last element is executed, the execution of signal output is continued returning to the first element.
Single	After the last element is executed, execution is stopped.

### Remote command

**Select the operation after the last element is executed in the sequence mode**

#### Command

INITiate[1] | 2:ARB:SEquence:CONTinuous[:ALL] <boolean>

#### Query

INITiate[1] | 2:ARB:SEquence:CONTinuous[:ALL] ?

#### Response

<boolean>                    0 or 1

#### Parameter

<boolean>	Operation after the last element is executed
ON   1	Continuous
OFF   0	Single

#### Programming Example

To set the sequence mode to Single.

```
INIT:ARB:SEQ:CONT OFF
```

```
INIT:ARB:SEQ:CONT?
```

```
> 0
```

**Remote command**

**Set the RepeatCount of each index for Sequence Mode**

**Command**

```
[ :SOURce[1] | 2 ] :RADio:ARB:SEQuence:ELEMent:RCOunt  
<integer>, <ext_integer>
```

**Query**

```
[ :SOURce[1] | 2 ] :RADio:ARB:SEQuence:ELEMent:RCOunt?  
<integer>
```

**Response**

```
<ext_integer>
```

**Parameter**

<integer>	Index
Range	1 to 200
Default	1
Suffix code	None
<ext_integer>	RepeatCount
Range	0 to 65535
Resolution	1
Default	0
Suffix code	None

**Programming Example**

To set the RepeatCount at Index = 1 to 100.

```
RAD:ARB:SEQ:ELEM:RCO 1,100
```

```
RAD:ARB:SEQ:ELEM:RCO? 1
```

```
> 100
```



### 7.3.14 Pattern Trigger

**Mode** or **Top>Mode,>→>Sequence Mode>PatternTrigger**

Uses the pattern trigger to proceed with patterns to the next pattern in the sequence mode.

In MG3740A, this can be used only when option-020/120 is installed.

**Note:**

In the sequence mode, the pattern trigger and pattern status are used as the trigger to be used to proceed with patterns to the next pattern. Switching of the pattern trigger and pattern status depends on the internal setting of the waveform pattern. The pattern status operation is described in the last half of this section.

Press **F5 Pattern Trigger** on the Sequence Mode function menu to open the **Pattern Trigger Info** dialog box and Pattern Trigger function menu.



Pattern Trigger Info				
Pattern Trigger	On			
Pattern Trigger Mode	3 Triggers			
Switching Point	Pattern			
Name	State	Source	Edge	
Pattern Trigger 1	Off	Ext	Rise	
Pattern Trigger 2	Off	Ext	Rise	
Pattern Trigger 3	Off	Ext	Rise	

Figure 7.3.14-1 Pattern Trigger Info Dialog Box

Table 7.3.14-1 Pattern Trigger Function Menu

Page	Key No.	Menu Display	Function
1	F1	Pattern Trigger <u>Off</u> On	Sets whether the trigger is to be used or not to be used for Sequence Mode pattern switching.
	F2	Pattern Trigger 1	Displays the Pattern Trigger 1 function menu.
	F3	Pattern Trigger 2	Displays the Pattern Trigger 2 function menu.
	F4	Pattern Trigger 3	Displays the Pattern Trigger 3 function menu.
	F5	Switching Point <u>Pattern</u> Frame	Selects the switching timing to move to the next element on pattern trigger input.
	F8	Trigger Key	Generates Pattern Trigger manually. This is executable only from this menu. When Pattern Trigger Source is Trigger Key, executing this function applies the trigger.

## Pattern Trigger

 or **Top>Mode, >>Sequence Mode>PatternTrigger**  
**>PatternTrigger**

Sets whether the trigger is to be used or not to be used for Sequence Mode pattern switching.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 Pattern Trigger** on the Pattern Trigger function menu for setting.

On	Uses the trigger.
Off	Does not use the trigger (Default).

### Remote command

**Set whether the trigger is to be used or not to be used for Sequence Mode pattern switching**

#### Command

`[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:TRIGger [ :STATe ]`  
<boolean>

#### Query

`[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:TRIGger [ :STATe ] ?`

#### Response

<boolean>                    0 or 1

#### Parameter



<boolean>	Trigger On/Off
OFF   0	Uses the trigger.
ON   1	Does not use the trigger (Default).

#### Programming Example

To use the trigger for Sequence Mode pattern switching.

```
RAD:ARB:SEQ:TRIG ON
RAD:ARB:SEQ:TRIG?
> 1
```

## Pattern Trigger 1/2/3

 or **Top>Mode, >>Sequence Mode>PatternTrigger**  
**>PatternTrigger 1/2/3**

Sets the pattern trigger 1/2/3.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Pattern Trigger 1 to F4 Pattern Trigger 3** on the Pattern Trigger function menu to display the Pattern Trigger 1 to Pattern Trigger 3 function menus. Pattern Trigger 1 function menu is described in the table below.

**Table 7.3.14-2 Pattern Trigger 1 Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Pattern Trigger 1 <u>Off</u> On	Enables/disables the pattern trigger 1.
	F2	Source <u>Ext</u> Bus Key	Sets the trigger source of the pattern trigger 1.
	F3	Edge <u>Rise</u> Fall	Sets the edge of the pattern trigger 1.

## Pattern Trigger 1/2/3 On/Off: Pattern Trigger 1/2/3

 or **Top>Mode, >>Sequence Mode>PatternTrigger**  
**>PatternTrigger 1/2/3>PatternTrigger 1/2/3**

Enables/disables the pattern trigger 1/2/3.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F1 Pattern Trigger 1/2/3** on the Pattern Trigger 1/2/3 function menu for setting.

On Enables the pattern trigger 1/2/3.

Off Disables the pattern trigger 1/2/3 (Default).

**Remote command****Enable/disable the pattern trigger 1/2/3****Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:TRIGger1 | 2 | 3 :STATE
<boolean>
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:TRIGger1 | 2 | 3 :STATE?
```

**Response**

```
<boolean> 0 or 1
```



**Parameter**

<boolean>	Trigger On/Off
OFF   0	Disables the pattern trigger 1/2/3 (Default).
ON   1	Enables the pattern trigger 1/2/3.

**Programming Example**

To enable the pattern trigger 1.  
 RAD:ARB:SEQ:TRIG1:STAT ON  
 RAD:ARB:SEQ:TRIG1:STAT?  
 > 1

Trigger source: Source

 or **Top>Mode, >**  **Sequence Mode>PatternTrigger**  
**>PatternTrigger 1/2/3>Source**

Sets the pattern trigger 1/2/3 trigger source.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F2 Source** on the Pattern Trigger 1/2/3 function menu for setting.

Ext	Terminal set to PatternTrig1/2/3 with RouteInputConnectors (Default)
Bus	Remote command
Key	Trigger Key

**Remote command**

**Set the pattern trigger 1/2/3 trigger source**

**Command**

[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:TRIGger1 | 2 | 3 :SOURce KEY | EXT | BUS

**Query**

[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:TRIGger1 | 2 | 3 :SOURce?

**Response**

<mode> EXT, BUS or KEY

**Parameter**

<mode>	Trigger source
EXT	Terminal set to PatternTrig1/2/3 with RouteInputConnectors (Default)
BUS	Remote command
KEY	Trigger Key

**Programming Example**

To set the pattern trigger 1 trigger source to Trigger Key.

```
RAD:ARB:SEQ:TRIG1:SOUR KEY
```

```
RAD:ARB:SEQ:TRIG1:SOUR?
```

```
> KEY
```

**Pattern Status**

The pattern status is a type of trigger to be used to proceed with patterns to the next pattern in the sequence mode.

In MG3740A, this can be used only when option-020/120 is installed.

While the pattern trigger 1/2/3 become three triggers independently, the pattern status create eight trigger statuses with three signal statuses.

To use the pattern status, the use of the pattern status must be set to the waveform pattern in advance.

The relation of Status and Status terminal is shown in the figure below.

**Table 7.3.14-3 Relation of Status 0 to 7 and Status Terminal**

Status	Pattern Status 1	Pattern Status 2	Pattern Status 3
0	High	High	High
1	Low	High	High
2	High	Low	High
3	Low	Low	High
4	High	High	Low
5	Low	High	Low
6	High	Low	Low
7	Low	Low	Low

## Edge

**Mode** or **Top>Mode**, **>→>Sequence Mode>PatternTrigger**  
**>PatternTrigger 1/2/3>Edge**

Sets the pattern trigger 1/2/3 edge.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F3 Edge** on the Pattern Trigger 1/2/3 function menu for setting.

Rise Applies the trigger at the signal rising. (Default)

Fall Applies the trigger at the signal falling.

### Remote command

#### Set the pattern trigger 1/2/3 edge

##### Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:TRIGger1 | 2 | 3 :SLOPe  
POSitive | NEGative
```

##### Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:TRIGger1 | 2 | 3 :SLOPe?
```

##### Response

```
<mode> POS or NEG
```

##### Parameter

```
<mode> Pattern trigger edge
```

```
POSitive Rise, the trigger is applied at the signal rising.  
(Default)
```

```
NEGative Fall, the trigger is applied at the signal falling.
```

#### Programming Example

To apply the trigger to the pattern trigger 1 edge at the signal rising.

```
RAD:ARB:SEQ:TRIG1:SLOP POS
```

```
RAD:ARB:SEQ:TRIG1:SLOP?
```

```
> POS
```

## Switching Point

**Mode** or **Top>Mode, >** **→** **Sequence Mode>PatternTrigger >Switching Point**

Selects the switching timing to move to the next element on pattern trigger input.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F5 Switching Point** on the Sequence Mode function menu for selection.

Pattern	Switched to the next element with the data length of the waveform pattern of each element as the base unit (Default).
Frame	Switched to the next element with the frame length of the waveform pattern of each element as the base unit.




Figure 7.3.14-2 Switching Timing

## Remote command

Select the switching timing to move to the next element on pattern trigger input

## Command

```
[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:TRIGger:SPOint
PATTen | FRAMe
```

## Query

```
[ :SOURce [1] | 2 ] :RADio:ARB:SEQuence:TRIGger:SPOint?
```

## Response

```
<mode> PATT or FRAM
```

**Parameter**

<mode>	Switching timing to move to the next element
PATtern	Switched to the next element with the data length of the waveform pattern of each element as the base unit (Default).
FRAMe	Switched to the next element with the frame length of the waveform pattern of each element as the base unit.

**Programming Example**

To set the switching timing base unit to move to the next element on pattern trigger input to the frame length.

```
RAD:ARB:SEQ:TRIG:SPO FRAM
RAD:ARB:SEQ:TRIG:SPO?
> FRAM
```

Trigger Key

 or **Top>Mode, >**  **Sequence Mode>PatternTrigger >Trigger Key**

Generates Pattern Trigger manually. This is executable only from this menu. It is enabled only when Trigger Key is set with **F2 Source** on the Pattern Trigger 1/2/3 function menu.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F8 Trigger Key** on the Pattern Trigger function menu to apply the trigger.



### 7.3.15 Sync Multi SG

**Mode** or **Top>Mode,>→>Sync Multi SG**

Sync Multi SG function is used to output signals with synchronized timings or phases among multiple SGs.

In MG3740A, the Sync Multi SG function cannot be used.

The MG3710A can have the synchronization system with up to four units. Sharing each Local signal, baseband clock, and trigger signal allows output of phase coherent signals with the same signal output timings. If four units of 2nd RF option-installed MG3710A are used, 8x8 MIMO system configuration will be available.

This function allows easy setting necessary for the synchronization system configuration with multiple MG3710As. (The Local signal input/output and baseband lock input/output require the Universal Input/Output option.)

**Note:**

When several MG3710A units are connected, sometimes the output level of the MG3710A LO Output is outside the LO Input level range, depending on the set frequency. In this case, use an external LO signal source to input a LO signal with the appropriate level to the MG3710A LO Input connector.

Common Setting

Number of Slaves: 3

LO Sync: On




Figure 7.3.15-1 Sync Multi SG Configuration

SG1/2 synchronization procedure

The method to synchronize the phases and timings of signals output from SG1/2 with the use of the Multi SG Sync function is explained.

1. Phase synchronization

1.1 Output waveform patterns which become 0 Hz (= DC) on Baseband from both SG1 and SG2.

Waveform pattern	BBDC (Waveform pattern where I-phase is 1-fixed and Q-phase is 0-fixed)
Frequency	Same setting value (frequency to be used after synchronization)
Level	Same setting value (level to be used after synchronization)
Mod	On
RF	On
ATT Hold	On

Changing frequency/level changes the internal path length; therefore, phase/timing synchronization must be executed again. (When ATT Hold = On, changing the level does not change the path length.)

- 1.2 Execute the synchronization setting for SG1 and SG2.

Sync Type	SG1&2
LO Sync	On

When the option-017/117 is installed, SG1/2 Local signal and Baseband Reference Clock are connected within the unit. The synchronization can be executed without change.

- 1.3 Execute I/Q DC Cal for both SG1 and SG2, and minimize carrier leakage.

- 1.4 When synchronizing several MG3710A units, connect them as shown.


When synchronizing several MG3710A units, connect them as shown in items 1 to 4 of Figure 7.3.15-1 Sync Multi SG Composition and set Sync Type, Number of Slaves, Slave Position, and LO Sync at each SG.

**Note:**

When several MG3710A units are connected, sometimes the output level of the MG3710A LO Output is outside the LO Input level range, depending on the set frequency. In this case, use an external LO signal source to input a LO signal with the appropriate level to the MG3710A LO Input connector.

- 1.5 Input the mixed wave of SG1 and SG2 to the spectrum analyzer.

Input the mixed wave of SG1/2 to the spectrum analyzer as shown in the figure below.



**Figure 7.3.15-2 Phase Synchronization/Timing Synchronization Adjustment**

1.6 Adjust the I/Q Phase of SG1 (coarse adjustment).

Estimate the phase difference between SG1/2 using the behavior where CW signals with the phase difference of 180 degrees negate each other. Adjust the SG1 I/Q Phase to the values where the mixed wave output level becomes the minimum.

1.7 Adjust the level of SG1.

Adjust the level of SG1 to reduce the level difference between SG1/2 close to zero because the level difference between SG1/2 remains as the residual level. Adjust the level of SG1 to the value where the mixed wave output level becomes the minimum.

1.8 Adjust the I/Q Phase of SG1 (fine adjustment).

Adjust the SG1 I/Q Phase to the values where the mixed wave output level becomes the minimum again.

2. Timing synchronization

Adjust the timing synchronization continuously after the phase synchronization is completed.

2.1 Output waveform patterns to be used from both SG1/2.

Waveform pattern	Same setting (arbitrary waveform pattern)
ATT Hold	On

2.2 Adjust the I/Q Delay of SG1 (coarse adjustment).

Estimate the timing difference between SG1/2 using the behavior where CW signals with the phase difference of 180 degrees negate each other. Adjust the SG1 I/Q Delay to the values where the mixed wave output level becomes the minimum.

2.3 Adjust the level of SG1.

Adjust the level of SG1 to reduce the level difference between SG1/2 close to zero because the level difference between SG1/2 remains as the residual level. Adjust the level of SG1 to the value where the mixed wave output level becomes the minimum.

2.4 Adjust the I/Q Delay of SG1 (fine adjustment).

Adjust the I/Q Delay of SG1.

2.5 Add +180 degrees to the I/Q Phase of SG1.

Add +180 degrees to the I/Q Phase value of SG1 in Step 1.8 and set the I/Q Phase again. They are changed from reversed status to in-phase status.

## Display description

Press **F8 Sync Multi SG** on the ARB/Waveform function menu page 2 to display the Sync Multi SG.













Figure 7.3.15-3 Sync Multi SG

**Notes:**

- The figure above is for explanation; it is different from the actual display.
- SG2-related blocks are displayed when SG2 (Option 062/162, 064/164 or 066/166) is installed.

Table 7.3.15-1 Sync Multi SG Display Contents

No.	Display Example	Display	Description
1		Master, Slave#1 to Slave#3	Displays the order of connecting MG3710A units when using several MG3710A units. This is displayed when Sync Type is Master or Slave. The number of Slaves displayed depends on the “Number of Slaves” setting.
2		LO Input	Indicates the Local signal source is set to Ext (input from the rear LO Input connector).
3		SG1	---
		I/Q Phase	Displays the I/Q Phase setting for SG1.
		I/Q Delay	Displays the I/Q Delay setting for SG1.
4		SG2	---
		I/Q Phase	Displays the I/Q Phase setting for SG2.
		I/Q Delay	Displays the I/Q Delay setting for SG2.
5		LO Source (SG1)	Indicates the status of the Local signal source for SG1. The status of the Local signal source for SG1 can be switched between Int and Ext by clicking this block.
6		LO Source (SG2)	Indicates the status of the Local signal source for SG2. The status of the Local signal source for SG2 can be switched between Int and Sync by clicking this block.
7		1st RF Output	Indicates that the RF Output of SG1 is On.
8		2nd RF Output	Indicates that the RF Output of SG2 is On.
9		LO Output	Indicates the Local signal external output setting (output from the rear LO Output connector) is On.

Press **F8 Sync Multi SG** on page 2 of ARB/Waveform function menu to open the Sync Multi SG function menu. Also the Sync Multi SG control is also displayed.

**Table 7.3.15-2 Sync Multi SG Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Sync Type Off	Sets the synchronization mode.
	F2	Number of Slaves 1	Sets the number of connected Slaves. This is enabled when SyncType is Master or Slave.
	F3	Slave Position 1	Sets the position of MG3710A when SyncType is Slave. This is enabled when SyncType is or Slave. It is used for setting judgment such as the case Lo Out is set to Off for connection termination.
	F4	LO Sync Off On	Enables/disables the Local synchronization. This is used to synchronize signal phases from SGs.
	F5	Sync	Starts synchronization for multiple SGs. This is enabled when SyncType is Master or Slave.
	F6	Waveform Restart	Simultaneously restarts each waveform pattern selected by SG1 and SG2 when SG2 (Option 062/162, 064/164 or 066/166) is installed.
	F7	I/Q Phase 0.00 deg	Adjusts the Baseband signal phase. This is used to adjust multiple SGs signal phases with MIMO or beam forming.
	F8	I/Q Delay 0.000000000000 s	Adjusts the Baseband signal output timings. This is used when multiple SGs are to be synchronized and timings for signals to reach to DUT are to be adjusted.

## Sync Type

 or **Top>Mode,>**  **>Sync Multi SG>Sync Type**

Sets the synchronization mode.

Press **F1 Sync Type** on the Sync Multi SG function menu to open the Sync Type function menu for selection of the synchronization mode.

Off	Does not execute synchronization (Default).
Master	Synchronizes multiple SGs. MG3710A is positioned as Master. When SG2 is installed, SG1 and SG2 are synchronized.
Slave	Synchronizes multiple SGs. MG3710A is positioned as Slave. When SG2 is installed, SG1 and SG2 are synchronized.
SG1 & SG2	Synchronizes SG1 and SG2 of MG3710A.

**Remote command**

**Set the synchronization mode**

**Command**

`[ :SOURCE ] :RADio:ARB:MBSync OFF|SG12|MASTer|SLAVe`

**Query**

`[ :SOURCE ] :RADio:ARB:MBSync?`

**Response**

`<mode> OFF,SG12,MAST or SLAV`

**Parameter**

<code>&lt;mode&gt;</code>	Synchronization mode
OFF	Does not execute synchronization (Default).
MAST	Synchronizes multiple SGs. MG3710A is positioned as Master. When SG2 is installed, SG1 and SG2 are synchronized.
SLAV	Synchronizes multiple SGs. MG3710A is positioned as Slave. When SG2 is installed, SG1 and SG2 are synchronized.
SG12	Synchronizes SG1 and SG2 of MG3710A.

**Programming Example**

To set to the mode to synchronizes SG1 and SG2 of MG3710A.

`RAD:ARB:MBSY SG12`

`RAD:ARB:MBSY?`

`> SG12`

**Number of Slaves**

 or **Top>Mode,>>Sync Multi SG>Number of Slaves**

Sets the number of connected Slaves. This is enabled when SyncType is Master or Slave.

Press **F2 Number of Slaves** on the Sync Multi SG function menu for setting.

Range	1 to 3
Resolution	1
Default	1



**Remote command****Set the number of connected Slaves****Command**

```
[ :SOURCE ] :RADio:ARB:MBSync:NSLaves <ext_integer>
```

**Query**

```
[ :SOURCE ] :RADio:ARB:MBSync:NSLaves?
```

**Response**

```
<ext_integer>
```

**Parameter**

<ext_integer>	The number of connected Slaves
Range	1 to 3
Resolution	1
Default	1
Suffix code	None

**Programming Example**

To set the number of connected Slaves to 2.

```
RAD:ARB:MBSY:NSL 2
```

```
RAD:ARB:MBSY:NSL?
```

```
> 2
```

**Slave Position**

 or **Top>Mode**,  **>Sync Multi SG>Slave Position**

Sets the position of MG3710A when SyncType is Slave. This is enabled when SyncType is or Slave. It is used for setting judgment such as the case Lo Out is set to Off for connection termination.

Press **F3 Slave Position** on the Sync Multi SG function menu for setting.

Range	1 to 3
Resolution	1
Default	1

**Remote command**

**Set the position of MG3710A when SyncType is Slave**

**Command**

`[ :SOURCE ] :RADio:ARB:MBSync:SREference <ext_integer>`

**Query**

`[ :SOURCE ] :RADio:ARB:MBSync:SREference?`

**Response**

`<ext_integer>`

**Parameter**

<code>&lt;ext_integer&gt;</code>	Position of MG3710A
Range	1 to 3
Resolution	1
Default	1
Suffix code	None

**Programming Example**

To set the position of MG3710A when SyncType is Slave to 2.

`RAD:ARB:MBSY:SREF 2`

`RAD:ARB:MBSY:SREF?`

`> 2`

**Local synchronization: LO Sync**

 or **Top>Mode**, **>**  **>Sync Multi SG>LO Sync**

Enables/disables the Local synchronization. This is used to synchronize signal phases from SGs.

Press **F4 LO Sync** on the Sync Multi SG function menu for setting.

**Off** Does not execute Local synchronization (Default).

**On** Executes Local synchronization.

**Remote command****Enable/disable the Local synchronization****Command**

```
[ :SOURce ] :RADio:ARB:MBSYnc:LOSYnc <boolean>
```

**Query**

```
[ :SOURce ] :RADio:ARB:MBSYnc:LOSYnc?
```

**Response**

```
<boolean> 0 or 1
```

**Parameter**

<boolean>	Local synchronization On/Off
OFF 0	Does not execute Local synchronization (Default).
ON 1	Executes Local synchronization.

**Programming Example**

To set the Local synchronization to On.

```
RAD:ARB:MBSY:LOSY ON
```

```
RAD:ARB:MBSY:LOSY?
```

```
> 1
```

**Sync**

 or **Top>Mode**, >  **>Sync Multi SG>Sync**

Synchronization for multiple SGs is started. This is enabled when SyncType is Master or Slave.

To start the signal output with the same trigger signal, execute Sync starting from SGs of latter part, and when all SGs are in trigger waiting status, input the trigger to Master SG.

Press **F5 Sync** on the Sync Multi SG function menu for setting.

**Remote command****Start synchronization for multiple SGs****Command**


```
[ :SOURce ] :RADio:ARB:MBSYnc:SSLaves
```

**Programming Example**

To start synchronization for multiple SGs.

```
RAD:ARB:MBSY:SSL
```

## Waveform Restart

 or **Top>Mode, >**  **>Sync Multi SG>Waveform Restart**

Simultaneously restarts each waveform pattern selected by SG1 and SG2 when SG2 (Option 062/162, 064/164 or 066/166) is installed. SG1 and SG2 enter the Waiting-for-Trigger state when the trigger is to be used for Baseband signal output start.

Press **F6 Waveform Restart** on the Sync Multi SG function menu for setting.

### Remote command

**Restarts each waveform pattern selected by SG1 and SG2**  
**Command**

```
[ :SOURce ] :RADio:ARB:MBSync:REStart
```

### Programming Example

To restart each waveform pattern selected by SG1 and SG2.

```
RAD:ARB:MBSY:REST
```

## I/Q Phase

 or **Top>Mode, >**  **>Sync Multi SG>I/Q Phase**

Adjusts the Baseband signal IQ phase.

This is used to adjust multiple SGs signal phases with MIMO or beam forming. The setting is same as **F5 I/Q Phase** in Table 7.6.4-1 “Internal Baseband Adjust Function Menu”.

Press **F7 I/Q Phase** on the Sync Multi SG function menu for adjustment.

Range	–360 deg to 360 deg
Resolution	0.01 deg
Default	0 deg

## Remote command

**Adjust the Baseband signal IQ phase****Command**

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:PHASe <phase>
```

**Query**

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:PHASe?
```

**Response**

```
<phase> Unit: deg
```

**Parameter**

<phase>	Baseband signal phase
Range	–360 deg to 360 deg
Resolution	0.01 deg
Default	0 deg
Suffix code	DEG, When omitted: DEG

**Programming Example**

To set the Baseband signal IQ phase to 5 deg.

```
DM:IQAD:PHAS 5
```

```
DM:IQAD:PHAS?
```

```
> 5.00
```

## I/Q Delay

 or **Top>Mode,>**  **>Sync Multi SG>I/Q Delay**

Adjusts the Baseband signal output timings.

This is used when multiple SGs are to be synchronized and timings for signals to reach to DUT are to be adjusted. The setting is same as **F7 I/Q Delay** in Table 7.6.4-1 “Internal Baseband Adjust Function Menu”.

Press **F8 I/Q Delay** on the Sync Multi SG function menu for adjustment.

Range	-400 ns to 400 ns
Resolution	1 ps
Default	0 s

### Remote command

#### Adjust the Baseband signal IQ output timing

##### Command

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:DELay <time>
```

##### Query

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:DELay?
```

##### Response

```
<time> Unit: S
```

##### Parameter

<time>	Baseband signal output timings
Range	-400 ns to 400 ns
Resolution	1 ps
Default	0 s
Suffix code	S, MS, US, NS, PS, When omitted: S

#### Programming Example

To set the time difference between I phase and Q phase to 300 ns.

```
DM:IQAD:DEL 300NS
DM:IQAD:DEL?
> 0.000000300000
```

## 7.4 Route Connectors

Top>

Sets signals of the input and output connectors. This setting is common for the entire MG3710A/MG3740A.

Press **F4 Route Connectors** on page 2 of the top function menu to open the Route Connectors function menu.

**Table 7.4-1 Route Connectors Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Route Input Connectors	Displays the Input Connectors function menu to set the input signals. Refer to 7.4.1 "Route Input Connectors".
	F2	Route Output Connectors	Displays the Output Connectors function menu to set the output signals. Refer to 7.4.2 "Route Output Connectors".

### 7.4.1 Route Input Connectors

Top>

Sets signals input to input connectors displayed on the menu.

Press **F1 Route Input Connectors** on the Route Connectors function menu to display the Input Connectors function menu.

**Table 7.4.1-1 Input Connectors Function Menu**

Page	Key No.	Menu Display	Function
1	F1	S/F Trigger	Selects the signal input to the Start/Frame Trigger Input connector.
	F2	Pattern Trigger 1	Selects the signal input to the Pattern Trigger 1 Input connector.
	F3	Pattern Trigger 2	Selects the signal input to the Pattern Trigger 2 terminal of AUX connector. This is available in MG3740A only when option-020/120 is installed.
	F4	Pattern Trigger 3	Selects the signal input to the Pattern Trigger 3 terminal of AUX connector. This is available in MG3740A only when option-020/120 is installed.
	F5	Pattern Status 1	Selects the signal input to the Pattern Status 1 terminal of AUX connector. This is available in MG3740A only when option-020/120 is installed.
	F6	Pulse Mod	Selects the signal input to the Pulse Mod terminal of AUX connector.
	F7	Pattern Trigger Type Shared Ind	Sets the usage of PatternTrigger 1, 2, 3, and PatternStatus1. This is available in MG3740A only when option-020/120 is installed.



## Setting each input connector

Top>

Press **F1 to F6** on the Input Connectors function menu to display the Input Connectors function menu.

You can set signals in the table below regardless of names of input connectors.

**Table 7.4.1-2 Input Connector Function Menu (MG3710A, MG3740A installed option-020/120)**

Page	Key No.	Menu Display	Function
1	F1	SG1 S/F Trigger	Handles the input signal as S/F Trigger for SG1. Refer to 7.3.8 "Start/Frame Trigger".
	F2	SG2 S/F Trigger	Handles the input signal as S/F Trigger for SG2. This is displayed when option-062/064/066/ 162/164/166 is installed. Refer to 7.3.8 "Start/Frame Trigger".
	F3	Pattern Trigger 1	Handles the input signal as Pattern Trigger 1/Point Trigger. Refer to 7.3.14 "Pattern Trigger". Refer to 6.5 "Point Trigger".
	F4	Pattern Trigger 2	Handles the input signal as Pattern Trigger 2/Pattern Status 2. Refer to 7.3.14 "PatternTrigger".
	F5	Pattern Trigger 3	Handles the input signal as Pattern Trigger 3/Pattern Status 3. Refer to 7.3.14 "PatternTrigger".
	F6	Pattern Status 1	Handles the input signal as Pattern Status 1. Refer to 7.3.14 "PatternTrigger".
	F7	SG1 Pulse Mod	Handles the input signal as SG1 Pulse Mod. Menu Display is <b>Pulse Mod</b> when option-062/064/066/ 162/164/166 is not installed. Refer to 7.2.3 "Pulse".
	F8	SG2 Pulse Mod	Handles the input signal as SG2 Pulse Mod. This is displayed when option-062/064/066/ 162/164/166 is installed. Refer to 7.2.3 "Pulse".
2	F1	Off	Does not use the input signal.

**Table 7.4.1-3 Input Connector Function Menu (MG3740A not installed option-020/120)**

Page	Key No.	Menu Display	Function
1	F1	Off	Does not use the input signal.
	F3	Pattern Trigger 1	Handles the input signal as Pattern Trigger 1/Point Trigger. Refer to 7.3.14 "Pattern Trigger". Refer to 6.5 "Point Trigger".
	F7	SG1 Pulse Mod	Handles the input signal as SG1 Pulse Mod. Menu Display is [Pulse Mod] when option-062/064/066/162/164/166 is installed. Refer to 7.2.3 "Pulse".
	F8	SG2 Pulse Mod	Handles the input signal as SG2 Pulse Mod. This is displayed when option-062/064/066/162/164/166 is installed. Refer to 7.2.3 "Pulse".

S/F Trigger

**Top>**  **Route Connectors>Route Input Connectors>S/F Trigger**

Selects the signal input to the S/F Trigger connector.

Press **F1 S/F Trigger** in Table 7.4.1-1 "Input Connectors Function Menu" to select the signal.

Options Listed in Table 7.4.1-2 "Input Connector Function Menu".

Default SG1 S/F Trigger (MG3710A, MG3740A-020/120)  
OFF (MG3740A, when MG3740A-020/120 is not installed)

**Remote command**

**Select the signal input to the S/F Trigger connector**

**Command**

```
:ROUte[:CONNectors]:INPut:TRIGger:SFRame
SFT|SG2SFT|PT1|PT2|PT3|PS1|PM|SG2PM|OFF
```

**Query**

```
:ROUte[:CONNectors]:INPut:TRIGger:SFRame?
```

**Response**

```
<signal>
```

**Parameter**

&lt;signal&gt;

Signal input to the S/F Trigger connector

Options

Refer to the table below.

**Table 7.4.1-4 Input Connector**

Parameter	Signal to be input	Remarks
SFT	SG1 S/F Trigger	Default (MG3710A, MG3740A-020/120) In MG3740A, this cannot be selected when option-020/120 is not installed.
SG2SFT	SG2 S/F Trigger	In MG3740A, this cannot be selected when option-020/120 is not installed.
PT1	Pattern Trigger 1 /Point Trigger	
PT2	Pattern Trigger 2 /Pattern Status 2	In MG3740A, this cannot be selected when option-020/120 is not installed.
PT3	Pattern Trigger 3 /Pattern Status 3	In MG3740A, this cannot be selected when option-020/120 is not installed.
PS1	Pattern Status 1	In MG3740A, this cannot be selected when option-020/120 is not installed.
PM	SG1 Pulse Mod	
SG2PM	SG2 Pulse Mod	
OFF	Off	Default (MG3740A when option-020/120 not installed)

**Programming Example**

To set the signal input to the S/F Trigger connector to SG1 S/F Trigger.

```
ROUT:INP:TRIG:SFR SFT
```

```
ROUT:INP:TRIG:SFR?
```

```
> SFT
```

**Pattern Trigger 1**

**Top** >  **Route Connectors** > **Route Input Connectors** > **Pattern Trigger 1**

Selects the signal input to the Pattern Trigger 1 connector.

Press **F2 Pattern Trigger 1** in Table 7.4.1-1 “Input Connectors Function Menu” to select the signal.

Options Listed in Table 7.4.1-2 “Input Connector Function Menu”.

Default Pattern Trigger 1

(MG3710A, MG3740A-020/120)

OFF

(MG3740A, when option-020/120 not installed)

**Remote command**

**Select the signal input to the Pattern Trigger 1 connector**

**Command**

```
:ROUte[:CONNectors]:INPut:TRIGger:PATtern1
SFT|SG2SFT|PT1|PT2|PT3|PS1|PM|SG2PM|OFF
```

**Query**

```
:ROUte[:CONNectors]:INPut:TRIGger:PATtern1?
```

**Response**

```
<signal>
```

**Parameter**

<signal>

Signal input to the Pattern Trigger 1 connector

Options

Listed in Table 7.4.1-3 “Input Connector”.

Default

PT1 (MG3710A, MG3740A-020/120)

OFF

(MG3740A, when option-020/120 not installed)

**Programming Example**

To set the signal input to the Pattern Trigger 1 connector to SG1 S/F Trigger.

```
ROUT:INP:TRIG:PATT1 SFT
ROUT:INP:TRIG:PATT1?
> SFT
```

Pattern Trigger 2

**Top>  >Route Connectors>Route Input Connectors>Pattern Trigger 2**

Selects the signal input to the Pattern Trigger 2 connector.

In MG3740A, this can be selected only when option-020/120 is installed.

Press **F3 Pattern Trigger 2** in Table 7.4.1-1 “Input Connectors Function Menu” to select the signal.

Options

Listed in Table 7.4.1-2 “Input Connector Function Menu”.

Default

Pattern Trigger 2

**Remote command****Select the signal input to the Pattern Trigger 2 connector****Command**

```
:ROUte[:CONNectors]:INPut:TRIGger:PATtern2
SFT|SG2SFT|PT1|PT2|PT3|PS1|PM|SG2PM|OFF
```

**Query**

```
:ROUte[:CONNectors]:INPut:TRIGger:PATtern2?
```

**Response**

```
<signal>
```

**Parameter**

```
<signal>
```

Signal input to the Pattern Trigger 2 connector

Options

Listed in Table 7.4.1-3 “Input Connector”.

Default

PT2

**Programming Example**

To set the signal input to the Pattern Trigger 2 connector to SG1 S/F Trigger.

```
ROUT:INP:TRIG:PATT2 SFT
```

```
ROUT:INP:TRIG:PATT2?
```

```
> SFT
```

## Pattern Trigger 3

**Top>Route Connector>Route Input Connectors>Pattern Trigger 3**

Selects the signal input to the Pattern Trigger 3 connector.

In MG3740A, this can be selected only when option-020/120 is installed.

Press **F4 Pattern Trigger 3** in Table 7.4.1-1 “Input Connectors Function Menu” to select the signal.

Options

Listed in Table 7.4.1-2 “Input Connector Function Menu”.

Default

Pattern Trigger 3

**Remote command****Select the signal input to the Pattern Trigger 3 connector****Command**

```
:ROUte[:CONNectors]:INPut:TRIGger:PATtern3
SFT|SG2SFT|PT1|PT2|PT3|PS1|PM|SG2PM|OFF
```

**Query**

```
:ROUte[:CONNectors]:INPut:TRIGger:PATtern3?
```

**Response**

<signal>

**Parameter**

<signal>

Signal input to the Pattern Trigger 3 connector

Options

Listed in Table 7.4.1-3 “Input Connector”.

Default

PT3

**Programming Example**

To set the signal input to the Pattern Trigger 3 connector to SG1 S/F Trigger.

```
ROUT:INP:TRIG:PATT3 SFT
```

```
ROUT:INP:TRIG:PATT3?
```

```
> SFT
```

Pattern Status 1

**Top** >  **Route Connectors** > **Route Input Connectors** > **Pattern Status 1**

Selects the signal input to the Pattern Status 1 connector.

In MG3740A, this can be selected only when option-020/120 is installed.

Press **F5 Pattern Status 1** in Table 7.4.1-1 “Input Connectors Function Menu” to select the signal.

Options

Listed in Table 7.4.1-2 “Input Connector Function Menu”.

Default

Pattern Status 1

**Remote command**

**Select the signal input to the Pattern Status 1 connector**

**Command**

```
:ROUTe[:CONNectors]:INPut:STATus:PATtern1
```

```
SFT|SG2SFT|PT1|PT2|PT3|PS1|PM|SG2PM|OFF
```

**Query**

```
:ROUTe[:CONNectors]:INPut:STATus:PATtern1?
```

**Response**

<signal>

**Parameter**

<signal>

Signal input to the Pattern Status 1 connector

Options

Listed in Table 7.4.1-3 “Input Connector”.

Default

PS1

**Programming Example**

To set the signal input to the Pattern Status 1 connector to SG1 S/F Trigger.

```
ROUT:INP:STAT:PATT1 SFT
ROUT:INP:STAT:PATT1?
> SFT
```

**Pulse Mod**  **Route Connectors > Route Input Connectors > Pulse Mod**

Selects the signal input to the Pulse Mod connector.

Press **F6 Pulse Mod** in Table 7.4.1-1 “Input Connectors Function Menu” to select the signal.

Options	Listed in Table 7.4.1-2 “Input Connector Function Menu”.
Default	SG1 Pulse Mod (When option-062/064/066/162/164/166 is installed.) Pulse Mod (When option-062/064/066/162/164/166 is not installed.)

**Remote command**
**Select the signal input to the Pulse Mod connector**  
**Command**

```
:ROUTe[:CONNectors]:INPut:PLUM
SFT|SG2SFT|PT1|PT2|PT3|PS1|PM|SG2PM|OFF
```

**Query**

```
:ROUTe[:CONNectors]:INPut:PLUM?
```

**Response**

```
<signal>
```

**Parameter**

```
<signal>
```

Signal input to the Pulse Mod connector

Options

Listed in Table 7.4.1-3 “Input Connector”.

Default

PM

**Programming Example**

To set the signal input to the Pulse Mod connector to SG1 S/F Trigger.

```
ROUT:INP:PLUM SFT
ROUT:INP:PLUM?
> SFT
```

**Pattern Trigger Type**
**Top**  **Route Connectors > Route Input Connectors > Pattern Trigger Type**

Selects the usage of PatternTrig1, 2, 3, and PatternStatus1.

In MG3740A, this can be selected only when option-020/120 is installed.

Press **F7 Pattern Trigger Type** on the Input Connectors function menu to select the usage.

- Shared                      PatternTrig1,2,3 and PatternStatus1 are handled as the same signal in SG1/2. This is used when the sequence mode is controlled with all control signals of PatterTrig1,2,3 and PatternStatus1, or when the sequence mode of SG1 and SG2 are synchronized for operation (Default).
- Ind (Independent)      PatternTrig1,2 are handled as PatternTrig1,2 for SG1, and PatternTrig3 and PatternStatus1 are handled as PatternTrig1,2 for SG2. This is used when the sequence mode is operated in SG1/2 independently.




Figure 7.4.1-1 Shared Image




Figure 7.4.1-2 Independent Image

Remote command

Select the usage of PatternTrig1, 2, 3, and PatternStatus1  
Command

:ROUTE[:CONNECTors]:INPut:TRIGger:PATtern:TYPE



SHARe|DIVide

**Query**

:ROUte[:CONNeCtors]:INPut:TRIGger:PATTern:TYPE?

**Response**

<mode> SHAR or DIV

**Parameter**

<mode>	Usage of PatternTrig 1, 2, 3, and PatternStatus1
SHARe	Shared (Default)
DIVide	Independent

**Programming Example**

To set the usage of PatternTrig 1, 2, 3 and PatternStatus1 to Independent.

```
ROUT:INP:TRIG:PATT:TYPE DIV
ROUT:INP:TRIG:PATT:TYPE?
> DIV
```

## 7.4.2 Route Output Connectors

Top>>Route Connectors>Route Output Connectors

Sets signals output from output connectors displayed on the menu.

Press **F2 Route Output Connectors** on the Route Connectors function menu to display the Output Connectors function menu.

**Table 7.4.2-1 Output Connectors Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Marker 1	Sets the signal output from the Marker 1 Output connector.
	F2	Marker 2	Sets the signal output from the Marker 2 terminal of AUX connector. This is available in MG3740A only when option-020/120 is installed.
	F3	Marker 3	Sets the signal output from the Marker 3 terminal of AUX connector. This is available in MG3740A only when option-020/120 is installed.
	F4	Pulse Video	Sets the signal output from the Pulse Video terminal of AUX connector.
	F5	Pulse Sync	Sets the signal output from the Pulse Sync terminal of AUX connector.
	F6	Sync Trig Out	Sets the signal output from the Sync Trig Out terminal of AUX connector. This is available in MG3740A only when option-020/120 is installed.

### Setting each output connector

Top>>Route Connectors>Route Output Connectors>F1 to F6

Press **F1 to F6** on the Output Connectors function menu to display the Marker Connectors function menu.

You can set signals in the table below regardless of names of output connectors.

Table 7.4.2-2 Marker Connector Function Menu (MG3710A, MG3740A installed option-020/120)

Page	Key No.	Menu Display	Function
1	F1	SG1 Marker 1 A	Outputs SG1 Waveform Memory A side Marker 1 signal. Refer to 7.3.12 "Marker Setup".
	F2	SG1 Marker 2 A	Outputs SG1 Waveform Memory A side Marker 2 signal. Refer to 7.3.12 "Marker Setup".
	F3	SG1 Marker 3 A	Outputs SG1 Waveform Memory A side Marker 3 signal. Refer to 7.3.12 "Marker Setup".
	F4	SG1 Marker 1 B	Outputs SG1 Waveform Memory B side Marker 1 signal. This is not displayed when the option 048/148 is not installed. Refer to 7.3.12 "Marker Setup".
	F5	SG1 Marker 2 B	Outputs SG1 Waveform Memory B side Marker 2 signal. This is not displayed when the option 048/148 is not installed. Refer to 7.3.12 "Marker Setup".
	F6	SG1 Marker 3 B	Outputs SG1 Waveform Memory B side Marker 3 signal. This is not displayed when the option 048/148 is not installed. Refer to 7.3.12 "Marker Setup".
	F7	SG1 Pulse Sync	Outputs the signal synchronized with SG1 Pulse cycle. This is used when the measurement synchronized with the pulse modulation of the MG3710A/MG3740A is to be executed. Refer to Figure 7.4.2-3 "SG1/2 Pulse Sync" and 7.2.3 "Pulse"
	F8	SG1 Pulse Video	Outputs the signal synchronized with SG1 Pulse On interval. This is used when the measurement synchronized with the pulse modulation of the MG3710A/MG3740A is to be executed. Refer to Figure 7.4.2-4 "SG1/2 Pulse Video" and 7.2.3 "Pulse".

**Table 7.4.2-2 Marker Connector Function Menu  
(MG3710A, MG3740A installed option-020/120, Cont'd)**

Page	Key No.	Menu Display	Function
2	F1	SG1 Settled	Outputs the settling signal of SG1. This is used when the measurement synchronized with the signal transmission after frequency switching or others of the MG3710A/MG3740A is to be executed. Refer to Figure 7.4.2-5 "SG1/2 Source Settled".
	F2	Sync Trigger Out	Outputs the trigger signal for synchronization for multiple SGs. This is used for output waveforms of multiple signal generators to be synchronized with Start/Frame Trigger input to the MG3710A/MG37140A. Refer to Figure 7.4.2-1 "Sync Trigger Out".
	F3	Pattern Trigger 1 Out	Outputs Pattern Trigger 1 signal. This is used for output waveforms of multiple signal generators to be synchronized with Pattern Trigger 1 input to the MG3710A/MG3740A. Refer to 7.3.14 "Pattern Trigger".
	F4	Pattern Trigger 2 / Pattern Status 2	Outputs Pattern Trigger 2/Pattern Status 2 signal. This is used for output waveforms of multiple signal generators to be synchronized with Pattern Trigger 2/Pattern Status 2 input to the MG3710A/MG3740A. Refer to 7.3.14 "Pattern Trigger".
	F5	Pattern Trigger 3 / Pattern Status 3	Outputs Pattern Trigger 3/Pattern Status 3 signal. This is used for output waveforms of multiple signal generators to be synchronized with Pattern Trigger 3/Pattern Status 3 input to the MG3710A/MG3740A. Refer to 7.3.14 "Pattern Trigger".
	F6	Pattern Status 1	Outputs Pattern Status 1 signal. This is used for output waveforms of multiple signal generators to be synchronized with Pattern Status 1 input to the MG3710A/MG3740A. Refer to 7.3.14 "PatternTrigger Pattern Status".
	F7	Point Trigger	Outputs Point Trigger signal. This is used for measurement synchronized with Sweep/List function. Refer to Figure 7.4.2-2 "Point Trigger Out" and 6.5 "Point Trigger".
	F8	SG2 Marker 1 A	Outputs SG2 Waveform Memory A side Marker 1 signal. This is not displayed when the option 062/162, 064/164 or 066/166 is not installed. Refer to 7.3.12 "Marker Setup".

**Table 7.4.2-2 Marker Connector Function Menu  
(MG3710A, MG3740A installed option-020/120, Cont'd)**

Page	Key No.	Menu Display	Function
3	F1	SG2 Marker 2 A	Outputs SG2 Waveform Memory A side Marker 2 signal. This is not displayed when the option 062/162, 064/164 or 066/166 is not installed. Refer to 7.3.12 "Marker Setup".
	F2	SG2 Marker 3 A	Outputs SG2 Waveform Memory A side Marker 3 signal. This is not displayed when the option 062/162, 064/164 or 066/166 is not installed. Refer to 7.3.12 "Marker Setup".
	F3	SG2 Marker 1 B	Outputs SG2 Waveform Memory B side Marker 1 signal. This is not displayed when the option 078/178 is not installed. Refer to 7.3.12 "Marker Setup".
	F4	SG2 Marker 2 B	Outputs SG2 Waveform Memory B side Marker 2 signal. This is not displayed when the option 078/178 is not installed. Refer to 7.3.12 "Marker Setup".
	F5	SG2 Marker 3 B	Outputs SG2 Waveform Memory B side Marker 3 signal. This is not displayed when the option 078/178 is not installed. Refer to 7.3.12 "Marker Setup".
	F6	SG2 Pulse Sync	Outputs the signal synchronized with SG2 Pulse cycle. This is used when the measurement synchronized with the pulse modulation of the MG3710A/MG3740A is to be executed. This is not displayed when the option 062/162, 064/164 or 066/166 is not installed. Refer to Figure 7.4.2-3 "SG1/2 Pulse Sync" and 7.2.3 "Pulse".
	F7	SG2 Pulse Video	Outputs the signal synchronized with SG2 Pulse On interval. This is used when the measurement synchronized with the pulse modulation of the MG3710A/MG3740A is to be executed. This is not displayed when the option 062/162, 064/164 or 066/166 is not installed. Refer to Figure 7.4.2-4 "SG1/2 Pulse Video" and 7.2.3 "Pulse".
	F8	SG2 Settled	Outputs the settling signal of SG2. This is used when the measurement synchronized with the signal transmission after frequency switching or others of the MG3710A/MG3740A is to be executed. This is not displayed when the option 062/162, 064/164 or 066/166 is not installed. Refer to Figure 7.4.2-5 "SG1/2 Source Settled".

**Table 7.4.2-3 Marker Connector Function Menu (MG3740A not installed option-020/120)**

Page	Key No.	Menu Display	Function
1	F1	SG1 Pulse Sync	Outputs the signal synchronized with SG1 Pulse cycle. This is used when the measurement synchronized with the pulse modulation of the MG3740A is to be executed. Refer to Figure 7.4.2-3 "SG1/2 Pulse Sync" and 7.2.3 "Pulse"
	F2	SG1 Pulse Video	Outputs the signal synchronized with SG1 Pulse On interval. This is used when the measurement synchronized with the pulse modulation of the MG3740A is to be executed. Refer to Figure 7.4.2-4 "SG1/2 Pulse Video" and 7.2.3 "Pulse".
	F3	SG1 Settled	Outputs the settling signal of SG1. This is used when the measurement synchronized with the signal transmission after frequency switching or others of the MG3740A is to be executed. Refer to Figure 7.4.2-5 "SG1/2 Source Settled".
	F4	Point Trigger	Outputs Point Trigger signal. This is used for measurement synchronized with Sweep/List function. Refer to Figure 7.4.2-2 "Point Trigger Out" and 6.5 "Point Trigger".
	F5	SG2 Pulse Sync	Outputs the signal synchronized with SG2 Pulse cycle. This is used when the measurement synchronized with the pulse modulation of the MG3740A is to be executed. This is not displayed when the option 062/162, 064/164 or 066/166 is not installed. Refer to Figure 7.4.2-3 "SG1/2 Pulse Sync" and 7.2.3 "Pulse".
	F6	SG2 Pulse Video	Outputs the signal synchronized with SG2 Pulse On interval. This is used when the measurement synchronized with the pulse modulation of the MG3740A is to be executed. This is not displayed when the option 062/162, 064/164 or 066/166 is not installed. Refer to Figure 7.4.2-4 "SG1/2 Pulse Video" and 7.2.3 "Pulse".
	F7	SG2 Settled	Outputs the settling signal of SG2. This is used when the measurement synchronized with the signal transmission after frequency switching or others of the MG3740A is to be executed. This is not displayed when the option 062/162, 064/164 or 066/166 is not installed. Refer to Figure 7.4.2-5 "SG1/2 Source Settled".

**SG1/2 Marker 1A to 3A:** Output level is TTL.

Outputs the waveform pattern-defined marker signal or user-defined marker signal.

**SG1/2 Marker 1B to 3B:** Output level is TTL.

Outputs the waveform pattern-defined marker signal or user-defined marker signal.

**Sync Trigger Out:** Output level is TTL.

Sends the trigger signal input as S/F Trigger to DFF circuit and outputs the signal at the timing of synchronization with Baseband Reference Clock Out falling.




Figure 7.4.2-1 Sync Trigger Out

**Pattern Trigger 1 Out, Pattern Trigger 2 / Pattern Status 2 Out, Pattern Trigger 3 / Pattern Status 3 Out:** Output level is TTL.

This is same as Sync Trigger Source Out.

**Point Trigger Out:** Output level is TTL.

Outputs the signal at the timing of switching of Sweep/List function sweep point.




Figure 7.4.2-2 Point Trigger Out

**SG1/2 Pulse Sync:** Output level is TTL.

Outputs the signal synchronized with the start position of the pulse modulation cycle.




Figure 7.4.2-3 SG1/2 Pulse Sync

**SG1/2 Pulse Video:** Output level is TTL.

Outputs the signal synchronized with the modulated signal of the pulse modulation.




Figure 7.4.2-4 SG1/2 Pulse Video

**SG1/2 Settled:** Output level is TTL

Outputs the signal synchronized with the settling of SG1/2. “Settling” indicates the status where the signal transmission is being prepared with switching of the frequency or waveform data.

Example:

- During Cal
- When signals are not being output due to digital delay






Figure 7.4.2-5 SG1/2 Source Settled

## Marker 1 connector: Marker 1

**Top** > > **Route Connectors** > **Route Output Connectors** > **Marker 1**

Selects the signal output from the Marker 1 connector.

Press **F1 Marker 1** on the Output Connectors function menu to select the signal.

Options	Listed in Table 7.4.2-2 “Marker Connector Function Menu”.
Default	SG1 Marker 1 A (MG3710A, MG3740A-020/120) Point Trigger Out (MG3740A, when MG3740A-020/120 is not installed)

## Remote command

**Select the signal output from the Marker 1 connector****Command**

```
:ROUTe[:CONNectors]:OUTPut:MARKer1
M1A|M1B|M2A|M2B|M3A|M3B|SG2M1A|SG2M1B|SG2M2A|SG2M2B|SG2M
3A|SG2M3B|SYNC|PT1|PT2|PT3|PS1|POINT|PSY|SG2PSY|PVID|SG2
PVID|SET|SG2SET
```

**Query**

```
:ROUTe[:CONNectors]:OUTPut:MARKer1?
```

**Response**

```
<mode>
```

**Parameter**

```
<mode>
```

Signal to be output

Options

Refer to the table below.

Table 7.4.2-4 Marker Connector

Parameter	Signal to be output	Remarks
M1A	SG1 Marker 1 A	Default (MG3710A, MG3740A-020/120) In MG3740A, this cannot be selected when option-020/120 is not installed.
M2A	SG1 Marker 2 A	In MG3740A, this cannot be selected when option-020/120 is not installed.
M3A	SG1 Marker 3 A	In MG3740A, this cannot be selected when option-020/120 is not installed.
M1B	SG1 Marker 1 B	In MG3740A, this cannot be selected when option-020/120 is not installed.
M2B	SG1 Marker 2 B	In MG3740A, this cannot be selected when option-020/120 is not installed.
M3B	SG1 Marker 3 B	In MG3740A, this cannot be selected when option-020/120 is not installed.
PSY	SG1 Pulse Sync	
PVID	SG1 Pulse Video	
SET	SG1 Settled	
SYNC	Sync Trigger Out	In MG3740A, this cannot be selected when option-020/120 is not installed.
PT1	Pattern Trigger 1 Out	In MG3740A, this cannot be selected when option-020/120 is not installed.
PT2	Pattern Trigger 2 / Pattern Status 2	In MG3740A, this cannot be selected when option-020/120 is not installed.
PT3	Pattern Trigger 3 / Pattern Status 3	In MG3740A, this cannot be selected when option-020/120 is not installed.
PS1	Pattern Status 1	In MG3740A, this cannot be selected when option-020/120 is not installed.
POINT	Point Trigger	Default (MG3740A when option-020/120 is not installed)
SG2M1A	SG2 Marker 1 A	In MG3740A, this cannot be selected when option-020/120 is not installed.
SG2M2A	SG2 Marker 2 A	In MG3740A, this cannot be selected when option-020/120 is not installed.
SG2M3A	SG2 Marker 3 A	In MG3740A, this cannot be selected when option-020/120 is not installed.
SG2M1B	SG2 Marker 1 B	In MG3740A, this cannot be selected when option-020/120 is not installed.
SG2M2B	SG2 Marker 2 B	In MG3740A, this cannot be selected when option-020/120 is not installed.
SG2M3B	SG2 Marker 3 B	In MG3740A, this cannot be selected when option-020/120 is not installed.
SG2PSY	SG2 Pulse Sync	
SG2PVID	SG2 Pulse Video	
SG2SET	SG2 Settled	

**Programming Example**

To set the signal output from the Marker 1 connector to SG1 Marker 1 A.

```
ROUT:OUTP:MARK1 M1A
ROUT:OUTP:MARK1?
> M1A
```

**Marker 2 connector: Marker 2**

**Top** >  **Route Connectors** > **Route Output Connectors** > **Marker 2**

Selects the signal output from the Marker 2 connector.

In MG3740A, this can be selected only when option-020/120 is installed.

Press **F2 Marker 2** on the Output Connectors function menu to select the signal.

Options	Listed in Table 7.4.2-2 “Marker Connector Function Menu”.
Default	SG1 Marker 2 A

**Remote command****Select the signal output from the Marker 2 connector****Command**

```
:ROUTe[:CONNectors]:OUTPut:MARKer2
M1A|M1B|M2A|M2B|M3A|M3B|SG2M1A|SG2M1B|SG2M2A|SG2M2B|SG2M
3A|SG2M3B|SYNC|PT1|PT2|PT3|PS1|POINT|PSY|SG2PSY|PVID|SG2
PVID|SET|SG2SET
```

**Query**

```
:ROUTe[:CONNectors]:OUTPut:MARKer2?
```

**Response**

```
<mode>
```

**Parameter**

<mode>	Signal to be output
Options	Listed in Table 7.4.2-4 “Marker Connector”.
Default	M2A

**Programming Example**

To set the signal output from the Marker 2 connector to SG1 Marker 1 A.

```
ROUT:OUTP:MARK2 M1A
ROUT:OUTP:MARK2?
> M1A
```

### Marker 3 connector: Marker 3

**Top>**  **>Route Connectors>Route Output Connectors>Marker 3**

Selects the signal output from the Marker 3 connector.

In MG3740A, this can be selected only when option-020/120 is installed.

Press **F3 Marker 3** on the Output Connectors function menu to select the signal.

Options	Listed in Table 7.4.2-2 “Marker Connector Function Menu”.
Default	SG1 Marker 3 A

#### Remote command

#### Select the signal output from the Marker 3 connector

##### Command

```
:ROUTe[:CONNectors]:OUTPut:MARKer3  
M1A|M1B|M2A|M2B|M3A|M3B|SG2M1A|SG2M1B|SG2M2A|SG2M2B|SG2M  
3A|SG2M3B|SYNC|PT1|PT2|PT3|PS1|POINT|PSY|SG2PSY|PVID|SG2  
PVID|SET|SG2SET
```

##### Query

```
:ROUTe[:CONNectors]:OUTPut:MARKer3?
```

##### Response

```
<mode>
```

##### Parameter

```
<mode> Signal to be output
```

Options Listed in Table 7.4.2-4 “Marker Connector”.

Default M3A

##### Programming Example

To set the signal output from the Marker 3 connector to SG1 Marker 1 A.

```
ROUT:OUTP:MARK3 M1A  
ROUT:OUTP:MARK3?  
> M1A
```

## Pulse Video

Top>  >Route Connectors>Route Output Connectors>Pulse Video

Selects the signal output from the Pulse Video connector.

Press **F4 Pulse Video** on the Output Connectors function menu to select the signal.

Options	Listed in Table 7.4.2-2 “Marker Connector Function Menu”.
Default	SG1 Pulse Video

### Remote command

**Select the signal output from the Pulse Video connector**

#### Command

```
:ROUte[:CONNectors]:OUTPut:PULSe:VIDeo
M1A|M1B|M2A|M2B|M3A|M3B|SG2M1A|SG2M1B|SG2M2A|SG2M2B|SG2M
3A|SG2M3B|SYNC|PT1|PT2|PT3|PS1|POINT|PSY|SG2PSY|PVID|SG2
PVID|SET|SG2SET
```

#### Query

```
:ROUte[:CONNectors]:OUTPut:PULSe:VIDeo?
```

#### Response

```
<mode>
```

#### Parameter

<mode> Signal to be output

Options Listed in Table 7.4.2-4 “Marker Connector”.

Default PVID

#### Programming Example

To set the signal output from the Pulse Video connector to SG1 Marker 1 A.

```
ROUT:OUTP:PULS:VID M1A
ROUT:OUTP:PULS:VID?
> M1A
```

## Pulse Sync

**Top>**  **Route Connectors>Route Output Connectors>Pulse Sync**

Selects the signal output from the Pulse Sync connector.

Press **F5 Pulse Sync** on the Output Connectors function menu to select the signal.

Options Listed in Table 7.4.2-2 “Marker Connector Function Menu”.

Default SG1 Pulse Sync

### Remote command

**Select the signal output from the Pulse Sync connector**

#### Command

```
:ROUTe[:CONNectors]:OUTPut:PULSe:SYNC
```

```
M1A|M1B|M2A|M2B|M3A|M3B|SG2M1A|SG2M1B|SG2M2A|SG2M2B|SG2M3A|SG2M3B|SYNC|PT1|PT2|PT3|PS1|POINT|PSY|SG2PSY|PVID|SG2PVID|SET|SG2SET
```

#### Query

```
:ROUTe[:CONNectors]:OUTPut:PULSe:SYNC?
```

#### Response

```
<mode>
```

#### Parameter

```
<mode>
```

Signal to be output

Options

Listed in Table 7.4.2-4 “Marker Connector”.

Default

PSY

#### Programming Example

To set the signal output from the Pulse Sync connector to SG1 Marker 1 A.

```
ROUT:OUTP:PULS:SYNC M1A
```

```
ROUT:OUTP:PULS:SYNC?
```

```
> M1A
```

## Sync Trig Out

Top>>Route Connectors>Route Output Connectors>Sync Trig Out

Selects the signal output from the Sync Trig Out connector.  
In MG3740A, this can be selected only when option-020/120 is installed.

Press **F6 Sync Trig Out** on the Output Connectors function menu to select the signal.

Options	Listed in Table 7.4.2-2 “Marker Connector Function Menu”.
Default	Sync Trigger Out

## Remote command

**Select the signal output from the Sync Trig Out connector**

**Command**

```
:ROUTe[:CONNectors]:OUTPut:SYNC
M1A|M1B|M2A|M2B|M3A|M3B|SG2M1A|SG2M1B|SG2M2A|SG2M2B|SG2M
3A|SG2M3B|SYNC|PT1|PT2|PT3|PS1|POINT|PSY|SG2PSY|PVID|SG2
PVID|SET|SG2SET
```

**Query**

```
:ROUTe[:CONNectors]:OUTPut:SYNC?
```

**Response**

```
<mode>
```

**Parameter**

```
<mode> Signal to be output
```

Options Listed in Table 7.4.2-4 “Marker Connector”.

Default SYNC

**Programming Example**

To set the signal output from the Sync Trig Out connector to SG1 Marker 1 A.

```
ROUT:OUTP:SYNC M1A
```

```
ROUT:OUTP:SYNC?
```

```
> M1A
```

## 7.5 AWGN

### Top>→>AWGN

Executes the digital-addition of AWGN signal or outputs independently for the selected waveform pattern.

This cannot be used in MG3740A.

This can be used when AWGN option (MG3710A-049/079/149/179) is installed.




Figure 7.5-1 AWGN Addition Function

Press **F1 AWGN** on page 2 of the top function menu to open the AWGN function menu.

Table 7.5-1 AWGN Function Menu

Page	Key No.	Menu Display	Function
1	F1	AWGN Off On	Enables/disables the AWGN.
	F2	Noise Bandwidth 128.000000 MHz	Sets the bandwidth of AWGN.
	F3	Carrier Level -110.00 dBm	Sets the carrier signal output level.
	F4	Noise Level -20.00 dBm	Sets the noise level of the noise bandwidth conversion when no carrier exists, and sets the noise level of the carrier bandwidth conversion when the carrier exists.
	F5	C/N Ratio 40.00 dB	Sets the in-band Noise Power with the ratio to Carrier Power when AWGN is added.
	F6	C/N Set Signal Carrier	Sets the target for level change on CN Ratio change.(The option which is not selected is fixed.)



## AWGN On/Off: AWGN

**Top** >  **AWGN** > **AWGN**

Enables/disables the AWGN addition.

Press **F1 AWGN** on the AWGN function menu to set On/Off.

On	Outputs AWGN.
Off	Does not output AWGN (Default).

The signal with AWGN added is output when AWGN is On.  
While the combination of baseband signal (A+B) is being executed, the AWGN cannot be set to On.

**Remote command****Enable/disable AWGN****Command**

[:SOURce[1]|2]:RADio:ARB:NOISe[:STATe] &lt;boolean&gt;

**Query**

[:SOURce[1]|2]:RADio:ARB:NOISe[:STATe]?

**Response**

&lt;boolean&gt; 0 or 1

**Parameter**

&lt;boolean&gt; AWGN output On/Off

ON|1 On

OFF|0 Off

**Details**

The signal with AWGN added is output when AWGN is On.  
While the combination of baseband signal (A+B) is being executed, the AWGN cannot be set to On.

**Programming Example**


To add AWGN to the output signal.

RAD:ARB:NOIS ON

RAD:ARB:NOIS?

&gt; 1

Noise Bandwidth

Top>  AWGN>Noise Bandwidth

Sets the bandwidth of AWGN.

Press **F2 Noise Bandwidth** on the AWGN function menu to set with the **Noise Bandwidth** dialog box.

Range See table below.

**Note:**


The table below describes the setting range when it is output with single AWGN.

**Table 7.5-2 AWGN Noise Bandwidth**

Output waveform status	Upper limit	Lower limit
A, A + AWGN, Long, Long + Awgn	Sampling Rate A × 0.8	Sampling Rate A × 0.2
B, A + B, Awgn, CW No Signal, B + Awgn Multi	Sampling Rate B × 0.8	Sampling Rate B × 0.2
Seq (A), Seq (A + B) Seq (A + Awgn)	16 kHz to 160 MHz	16 kHz to 160 MHz

Resolution 1 Hz  
 Default 128 MHz

This parameter indicates the bandwidth of the flat part.



**Figure 7.5-2 AWGN Noise Bandwidth**

**Remote command**

**Set the bandwidth of AWGN**

**Command**

[ :SOURce [1] | 2 ] :RADio:ARB:NOISE: BANDWidth <freq>

**Query**

[ :SOURce [1] | 2 ] :RADio:ARB:NOISE: BANDWidth?

**Response**

<freq> Unit: HZ

**Parameter**

<freq>	Frequency
Range	Refer to Table 7.5-2
Resolution	1 Hz
Default	128 MHz
Suffix code	HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ When omitted: HZ

**Programming Example**

To set the bandwidth of AWGN to 10 MHz.

```
RAD:ARB:NOIS:BANDW 10MHZ
```

```
RAD:ARB:NOIS:BANDW?
```

```
> 10000000
```

**Carrier Level****Top>  AWGN>Carrier Level**

Sets the carrier signal output level.

Press **F3 Carrier Level** on the AWGN function menu to set with the **Carrier Level** dialog box.

Same value with Level A. When Level A is changed, also Carrier Level is changed with the same value. And vice versa.

Range	Output level range of MG3710A
Resolution	0.01 dB
Default	-110.00 dBm

**Remote command****Set the carrier signal output level****Command**

```
[ :SOURce[1] | 2 ] :RADio:ARB:NOISe:POWer:CARRier <ampl>
```

**Query**

```
[ :SOURce[1] | 2 ] :RADio:ARB:NOISe:POWer:CARRier?
```

**Response**

```
<ampl> Unit: dBm
```

**Parameter**

<ampl>	Carrier signal level when AWGN is ON
Range	Output level range of MG3710A
Resolution	0.01 dB
Default	-110.00 dBm
Suffix code	DBM, DM, DBUV, DBUVE When omitted: DBM

**Programming Example**

To set the carrier signal level when AWGN is ON to  $-55.00$  dBm.

```
RAD:ARB:NOIS:POW:CARR -55
RAD:ARB:NOIS:POW:CARR?
> -55.00
```

**Noise Level**

**Top** > **AWGN** > **Noise Level**


Sets the noise level of AWGN.

The noise level of the noise bandwidth conversion is set when no carrier exists, and the noise level of the carrier bandwidth conversion is set when the carrier exists.

Press **F4 Noise Level** on the AWGN function menu to set with the **Noise Level** dialog box.

Resolution                    0.01 dB  
 Default                         $-20$  dBm

The noise level of the noise bandwidth conversion is set when no carrier exists, and the noise level of the carrier bandwidth conversion is set when the carrier exists.



**Figure 7.5-3 AWGN Noise Level**

**Remote command**

**Set the noise level of AWGN**

**Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:NOISe:POWer:NOISe <ampl>
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:NOISe:POWer:NOISe?
```

**Response**

```
<ampl>                                Unit: dBm
```

**Parameter**

<ampl>	Output level
Resolution	0.01 dB
Default	-20 dBm
Suffix code	DBM, DM, DBUV, DBUVE When omitted: DBM

**Programming Example**

To set the AWGN noise level to -30.00 dBm.

```
RAD:ARB:NOIS:POW:NOIS -30.00
```

```
RAD:ARB:NOIS:POW:NOIS?
```

```
> -30.00
```

**C/N Ratio****Top** > **AWGN** > **C/N Ratio**

Sets the ratio of in-band AWGN Noise Level to Carrier Level when AWGN is On.

Press **F5 C/N Ratio** on the AWGN function menu to set with the **C/N Ratio** dialog box.

Range	-40 dB to 40 dB
Resolution	0.01 dB
Default	40 dB




Figure 7.5-4 AWGN Noise Level

**Remote command**

**Set the ratio of in-band AWGN Noise Level to Carrier Level when AWGN is On**

**Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:NOISe:CN <rel_ampl>
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:NOISe:CN?
```

**Response**

```
<rel_ampl> Unit: dB
```

**Parameter**

<rel_ampl>	C/N
Range	-40 dB to 40 dB
Resolution	0.01
Default	40.00
Suffix code	DB, When omitted: DB

**Details**

When the RF output level is near the upper limit or lower limit, the settable range may become narrow.

**Programming Example**

To set the C/N to 3 dB.  
 RAD:ARB:NOIS:CN 3DB  
 RAD:ARB:NOIS:CN?  
 > 3.00

C/N setting: C/N Set Signal

**Top**  **AWGN** > **C/N Set Signal**

Sets the target for level change on C/N Ratio change. (The option which is not selected is fixed.)

Press **F6 C/N Set Signal** on the AWGN function menu to set the target.

Carrier	Fixes Noise and changes Carrier.
Noise	Fixes Carrier and changes Noise.
Constant	Fixes the output level and changes Carrier and Noise (Default).

**Remote command**

**Set the target for level change on C/N Ratio change**

**Command**

```
[ :SOURce [1] | 2 ] :RADio:ARB:NOISe:POWer:CONTrol [ :MODE ]
TOTal | CARRier | NOISe
```

**Query**

```
[ :SOURce [1] | 2 ] :RADio:ARB:NOISe:POWer:CONTrol [ :MODE ] ?
```

**Response**

```
<mode> TOT, CARR or NOIS
```

**Parameter**

<mode>	Parameter to be changed
CARRier	Changes Carrier.
NOISe	Changes Noise.
TOTal	Fixes the output level and changes Carrier and Noise (Default).

**Programming Example**

To set the parameter to be changed when C/N is set to AWGN.

```
RAD:ARB:NOIS:POW:CONT NOIS
```

```
RAD:ARB:NOIS:POW:CONT?
```

```
> NOIS
```

## 7.6 I/Q Modulation

 or **Top** >  > **I/Q**

Sets the vector modulation with the external I/Q signal and correction, adjustment, and routing for the vector modulation.

In MG3740A, this can be used only when option-020/120 is installed.

Press **I/Q** of the main function key or **F2 I/Q** on page 2 of the top function menu to open the I/Q function menu.

**Table 7.6-1 IQ Function Menu**

Page	Key No.	Menu Display	Function
1	F1	I/Q Source Internal	Sets the I/Q signal source. This is available in MG3710A only when option-018/118 is installed. This is not available in MG3740A.
	F2	I/Q Output RF	Sets the output destination for baseband signals. This is not available in MG3740A.
	F3	Internal Channel Correction <u>Off</u> On	Enables/disables the baseband in-band correction. This is not available in MG3740A.
	F5	I/Q Calibration	Displays the IQ Calibration function menu to set the settings related to I/Q quadrature modulator calibration.  Refer to 7.6.1 "I/Q Calibration".
	F6	Wideband <u>Off</u> On	Selects the switching mode for RF output bandwidth. This is not available in MG3740A.
2	F1	Analog I/Q Input Adjustments	Displays the Analog I/Q Input function menu to adjust and set the analog I/Q input. This is available in MG3710A only when option-018/118 is installed. This is not available in MG3740A. Refer to 7.6.2 "Analog I/Q Input Adjustments".
	F2	Analog I/Q Output Adjustments	Displays the Analog I/Q Output function menu to adjust and set the analog I/Q output. This is available in MG3710A only when option-018/118 is installed. This is not available in MG3740A. Refer to 7.6.3 "Analog I/Q Output Adjustments".
	F3	Internal Baseband Adjustments	Displays the Internal Baseband Adjustments function menu to adjust the I/Q signal generated in the internal Baseband. Refer to 7.6.4 "Internal Baseband Adjustments".



## I/Q Source

 or **Top**  **I/Q, >I/Q Source**

Selects the I/Q signal source for the vector modulation with the external I/Q signal.

This can be used only when option-018/118 is installed in MG3710A.  
This cannot be used in MG3740A.

Press **F1 I/Q Source** on the I/Q function menu to select from the I/Q Source function menu.

Internal	I/Q signal generated with the internal Baseband (Default).
Analog I/Q In	Signal input from Analog I/Q In connector (available only for SG1) This is displayed when the option 018/118 is installed.

Internal is selected during Sweep/List execution.

## Remote command

**Set the I/Q signal source****Command**

```
[ :SOURce [1] | 2 ] :DM:SOURce INTernal | AEXTernal
```

**Query**

```
[ :SOURce [1] | 2 ] :DM:SOURce?
```

**Response**

```
<mode> INT or AEXT
```

**Parameter**

<mode>	I/Q signal source
INTernal	Internal (Default)
AEXTernal	Analog I/Q In

**Programming Example**

To set the I/Q signal source to the I/Q signal generated with the internal Baseband.

```
DM:SOUR INT
DM:SOUR?
> INT
```

**Operation description** The setting procedure for the vector modulation with the external I/Q signal is described below.

Analog I/Q Input




Figure 7.6-1 Analog I/Q Input Connector

The Analog I/Q Input connectors are internally terminated with 50 Ω. When the effective value voltage of  $\sqrt{I^2 + Q^2}$  is 0.5 V in the 50 Ω termination status, RF signal that corresponds to the output level setting is output. Input the I/Q signal with 0.2 V of the effective value voltage of  $\sqrt{I^2 + Q^2}$  when the vector modulation is actually executed. Also input the maximum I/Q signal within the range of ±1 V for each.




Figure 7.6-2 I/Q Signal Input Level

Example: To execute the vector modulation with the external I/Q signal.

1. Press **F1 I/Q Source** on the I/Q function menu to switch **F1 Internal** to **F2 Analog I/Q In**. The display for “Src:” is switched to “Analog I/Q In” in the I/Q block in the figure below.




Figure 7.6-3 External I/Q Signal Input Status

2. Press  of RF Output to set the RF output to On. Press  to light the lamp (green) of the key to start the vector modulation. External input of “Analog I/Q In” is indicated between the I/Q block and the Pulse Mod block in the figure below. In addition, a line is displayed at the right side of the Pulse Mod block and it indicates that RF Output is On.




Figure 7.6-4 Modulation Status with External I/Q Signal

When the modulation is executed with the external I/Q signal and if the I/Q signal with  $\sqrt{I^2 + Q^2} = 0.5$  V is input, the output level corresponds to the displayed level.

## I/Q Output

**I/Q** or **Top** → **I/Q**, **>I/Q Output**

Can output the I/Q signal generated at the digital modulation unit from the I/Q signal output connector on the rear panel.

This cannot be used in MG3740A.




Figure 7.6-5 Analog I/Q Output Connector

Select the output destination for the Baseband signal.

Press **F2 I/Q Output** on the I/Q function menu to select from the I/Q Output function menu.

RF	RF terminal (Default)
Analog I/Q Out	Analog I/Q Out terminal (selectable only with SG1)
	RF terminal output is CW.
	This is displayed when the option 018/118 is installed.

### Remote command

#### Set the output destination for baseband signals

##### Command

`[ :SOURce [1] | 2 ] :DM:OUTPut RFOut | AEXternal`

##### Query

`[ :SOURce [1] | 2 ] :DM:OUTPut ?`

##### Response

`<mode>` RFO or AEXT

##### Parameter

<code>&lt;mode&gt;</code>	Baseband signal output destination
RFOut	RF terminal (Default)
AEXternal	Analog I/Q Out

**Programming Example**

To set the output destination for baseband signals to Analog I/Q Out terminal.

```
DM:OUTP AEXT
```

```
DM:OUTP?
```

```
> AEXT
```

**Operation method**


**Example: To output the I/Q signal from the I/Q signal output connector.**


**Note:**

When the power is turned on while the I/Q signal output is set to On, the DC voltage of +1 V is output for tens of microseconds during the power activation. Do not turn on the MG3710A/MG3740A while a low-voltage device or others are connected to the I/Q signal output.

1. Press **F2 I/Q Output** on the I/Q function menu to switch **F1 RF** to **F2 Analog I/Q Out**.

The display for “Out:” is switched to “Analog I/Q Out” in the I/Q block in the figure below.

2. Press  to light the lamp (green) of the key to start the vector modulation. External output of “Analog I/Q Out” is indicated between the I/Q block and the Pulse Mod block.



**Figure 7.6-6 I/Q Signal Output Status**

Baseband in-band correction: Internal Channel Correction

 or **Top**  **I/Q, Internal Channel Correction**, or  **Internal Channel Correction**

Enables/disables the baseband in-band correction.

This cannot be set in MG3740A.

Press **F3 Internal Channel Correction** on the I/Q function menu to set the correction.

- Off Does not execute the baseband in-band correction (Default).
- On Executes the baseband in-band correction.

When it is set to On, the in-band flatness becomes better; however, the switching time for the frequency and pattern change becomes longer because the correction filter recalculation time and filter passing time become longer. If the in-band characteristics are not important, setting this function to Off allows the high-speed operation. When CW is output, this function has no effect.

**Remote command**

**Enable/disable the baseband in-band correction**

**Command**

`[ :SOURce [1] | 2 ] :DM:INTernal:CHANnel:CORRection[:STATe] <boolean>`

**Query**

`[ :SOURce [1] | 2 ] :DM:INTernal:CHANnel:CORRection[:STATe]?`

**Response**

`<boolean>` 0 or 1

**Parameter**

- `<boolean>` On/Off of the baseband in-band correction
- OFF | 0 Does not execute the baseband in-band correction (Default).
- ON | 1 Executes the baseband in-band correction.

**Programming Example**

To execute the baseband in-band correction.

```
DM:INT:CHAN:CORR ON
DM:INT:CHAN:CORR?
> 1
```

## Baseband in-band correction: Wideband

 or **Top**  **I/Q, >Wideband**

Selects the switching mode for RF output bandwidth.

This cannot be used in MG3740A.

Press **F6 Wideband** on the I/Q function menu to select the mode.

**Off** Harmonics distortion characteristic has priority (Default).

**On** In-band flatness has priority.  
This function allows using the maximum modulation bandwidth with low frequency. (Harmonics cut filter has no effect.)

When CW is output, this function has no effect.

## Remote command

## Enable/disable the wideband output

## Command

```
[ :SOURce [1] | 2 ] :DM:WIDeband <boolean>
```

## Query

```
[ :SOURce [1] | 2 ] :DM:WIDeband?
```

## Response

```
<boolean> 0 or 1
```

## Parameter

```
<boolean> Wideband output switching mode On/Off  
OFF | 0 Does not execute the wideband output (Default).  
ON | 1 Executes the wideband output.
```

## Programming Example


To execute the wideband output.

```
DM:WID ON
```

```
DM:WID?
```

```
> 1
```

### 7.6.1 I/Q Calibration

 or **Top** >  > **I/Q**, > **I/Q Calibration**, or  > **I/Q Cal**

Sets the settings related to the I/Q quadrature modulator calibration.

Press **F5 I/Q Calibration** on the I/Q function menu to open the I/Q Calibration Info dialog box and I/Q Calibration function menu.





Figure 7.6.1-1 I/Q Calibration

Table 7.6.1-1 I/Q Calibration Function Menu

Page	Key No.	Menu Display	Function
1	F1	Execute	Executes the calibration for the I/Q gain balance, origin offset, and I/Q quadrature angle.
	F2	Cal Type DC Full	Sets the calibration method for the I/Q calibration execution.
	F8	Restore Default	Returns the calibration value to factory setting status.

#### Execute Cal

 or **Top** >  > **I/Q**, > **I/Q Calibration** > **Execute**

Executes the calibration for the I/Q gain balance, origin offset, and I/Q quadrature angle.

Press **F1 Execute Cal** on the I/Q Calibration function menu to execute the calibration.

This function cannot be executed during Sweep/List execution.

#### Remote command

**Execute the calibration for the I/Q quadrature modulator optimal in the current instrument setting status**

#### Command

:CALibration[1] | 2:IQ:DC

#### Programming Example

To execute the optimal adjustment for SG1 in the current instrument setting status

CAL:IQ:DC



**Remote command**      **Execute the calibration for the I/Q quadrature modulator with the range of all frequencies**

**Command**



```
:CALibration[1]|2:IQ:FULL
```

**Programming Example**

To execute the calibration of SG1 for the range of all frequencies.

```
CAL:IQ:FULL
```

## Cal Type

 or **Top** >  > **I/Q**, > **I/Q Calibration** > **Cal Type**

Selects the calibration method for the I/Q calibration execution.

Press **F2 Cal Type** on the I/Q Calibration function menu to select the method.

DC	Executes the optimal adjustment with the currently specified frequency. (Default) For other frequency points, the existing correction value is used without change.
Full	Executes the calibration with the range of all frequencies.

**Remote command**      **Select the calibration method for the I/Q calibration execution**

**Command**

```
:CALibration[1]|2:IQ:TYPE DC|FULL
```

**Query**

```
:CALibration[1]|2:IQ:TYPE?
```

**Response**

```
<type>
```

**Parameter**

<type>	Calibration method for the I/Q calibration execution
DC	Executes the optimal adjustment with the currently specified frequency. (Default)
FULL	Executes the calibration with the range of all frequencies.

**Programming Example**

To set the calibration method for the SG1 I/Q calibration execution to the range of all frequencies.

```
CAL:IQ:TYPE FULL
CAL:IQ:TYPE?
> FULL
```

**Remote command**

**Query the calibration method for the calibration execution**

**Query**

```
:CALibration[1]|2:IQ:INFomation:TYPE?
```

**Response**

<type>	Calibration method for the I/Q calibration execution
DC	Executes the optimal adjustment with the currently specified frequency.
FULL	Executes the calibration with the range of all frequencies.

**Programming Example**

To query the calibration method for the SG1 calibration execution.

```
CAL:IQ:INF:TYPE?
> FULL
```

**Remote command**

**Query the latest date when the calibration has been executed**

**Query**

```
:CALibration[1]|2:IQ:INFomation:DATE?
```

**Response**

<date>	yyyy/mm/dd
Default	2000/01/01



**Programming Example**

To query the date when the calibration for SG1 has been executed.

```
CAL:IQ:INF:DATE?
> 2011/01/01
```

**Remote command****Query the latest time when the calibration has been executed****Query**`:CALibration[1]|2:IQ:INFomation:TIME?`**Response**`<time> hh:mm:ss``Default 00:00:00`**Programming Example**

To query the time when the calibration for SG1 has been executed.

`CAL:IQ:INF:TIME?``> 01:01:01`**Restore Default** or **Top**  **>I/Q, >I/Q Calibration>Restore Default**

Returns the calibration value to factory setting status.

Press **F8 Restore Default** on the I/Q Calibration function menu to execute the function.

This function cannot be executed during Sweep/List execution.

**Remote command****Return the calibration value to factory setting status****Command**`:CALibration[1]|2:IQ:DEFault`**Programming Example**

To return the SG1 calibration value to factory setting status.

`CAL:IQ:DEF`

## 7.6.2 Analog I/Q Input Adjustments

 or **Top** >  > **I/Q**, >  > **Analog I/Q Input Adjustments**

Adjusts/sets the analog I/Q input.

This is available in MG3710A only when option-018/118 is installed.

This is not available in MG3740A.

Press **F1 Analog I/Q Input Adjustments** on page 2 of the I/Q function menu to open the Analog I/Q Input Adjust function menu.

**Table 7.6.2-1 Analog I/Q Input Adjust Function Menu**

Page	Key No.	Menu Display	Function
1	F1	I Offset 0.000 V	Sets the offset for the I-phase.
	F2	Q Offset 0.000 V	Sets the offset for the Q-phase.

### I Offset

 or **Top** >  > **I/Q**, >  > **Analog I/Q Input Adjustments** > **I Offset**

Sets the offset for the I-phase.

This is available in MG3710A only when option-018/118 is installed.

This is not available in MG3740A.

Press **F1 I Offset** on the Analog I/Q Input Adjust function menu to set with the **I Offset** dialog box.

Range	-100 mV to 100 mV
Resolution	1 mV
Default	0 mV

**Remote command****Set the offset for the I-phase****Command**

```
[ :SOURce[1] ] :DM:IQADjustment:EXTernal:IOFFset <voltage>
```

**Query**

```
[ :SOURce[1] ] :DM:IQADjustment:EXTernal:IOFFset?
```

**Response**

```
<voltage> Unit: V
```

**Parameter**

<voltage>	I-phase offset value
Range	-100 mV to 100 mV
Resolution	1 mV
Default	0 mV
Suffix code	V, MV, UV, When omitted: V

**Programming Example**

To set the offset for the I-phase to 50 mV.

```
DM:IQAD:EXT:IOFF 50MV
```

```
DM:IQAD:EXT:IOFF?
```

```
> 0.050
```

**Q Offset**

 or **Top**  **I/Q**,  **Analog I/Q Input Adjustments** **Q Offset**

Sets the offset to the Q-phase.

This is available in MG3710A only when option-018/118 is installed.

This is not available in MG3740A.

Press **F2 Q Offset** on the Analog I/Q Input Adjust function menu to set the offset with the **Q Offset** dialog box.

Range	-100 mV to 100 mV
Resolution	1 mV
Default	0 mV

**Remote command**

**Set the offset for the Q-phase**

**Command**

`[ :SOURce[1] ] :DM:IQADjustment:EXTernal:QOFFset <voltage>`

**Query**

`[ :SOURce[1] ] :DM:IQADjustment:EXTernal:QOFFset?`

**Response**

`<voltage>`                      Unit: V

**Parameter**

<code>&lt;voltage&gt;</code>	Q-phase offset value
Range	-100 mV to 100 mV
Resolution	1 mV
Default	0 mV
Suffix code	V, MV, UV, When omitted: V

**Programming Example**

To set the offset for the Q-phase to 50 mV.

```
DM:IQAD:EXT:QOFF 50MV
```

```
DM:IQAD:EXT:QOFF?
```

```
> 0.050
```

### 7.6.3 Analog I/Q Output Adjustments

 or Top >  > I/Q, >  > Analog I/Q Output Adjustments

Adjusts/sets the analog I/Q output.

This is available in MG3710A only when option-018/118 is installed.

This is not available in MG3740A.

Press **F2 Analog I/Q Output Adjustments** on page 2 of the I/Q function menu to open the Analog I/Q Output Adjust function menu.

**Table 7.6.3-1 Analog I/Q Output Adjust Function Menu**

Page	Key No.	Menu Display	Function
1	F1	I Level Trimming 100.0%	Adjusts the I-phase output level gain.
	F2	Q Level Trimming 100.0%	Adjusts the Q-phase output level gain.
	F3	I/Q Common Offset 0.0000 V	Adjusts the I/Q inphase output DC offset level.
	F4	I Diff Offset 0.0000 V	Adjusts the I-phase differential output DC offset level.
	F5	Q Diff Offset 0.0000 V	Adjusts the Q-phase differential output DC offset level.


**Set the I/Q signal output**

The I/Q signal output voltage and DC offset can be adjusted. The output voltage is set with the ratio (%) to the output voltage defined with the setting of the digital modulation unit.

These voltages are always indicated by open voltage.


**Setting ranges of output voltage and DC offset**

Setting range of output voltage	0.0 to 120.0%
Minimum setting resolution	0.1%
Setting range of inphase DC offset	-2.500 to 5.000 V
Minimum setting resolution	2 mV
Setting range of differential DC offset	-50.00 to 50.00 mV
Minimum setting resolution	0.1 mV



**Figure 7.6.3-1 I/Q Signal Output Adjustment Image**

Example: To set the I/Q signal output voltage to 150 mV (rms), inphase DC offset to +1 V, and differential DC offset to 0.5 mV. However, the output voltage defined with the waveform pattern setting is 141 mV (rms).



**Figure 7.6.3-2 I/Q Signal Output Image**



1. Press **F1 I level Trimming** to display the **I level Trimming** dialog box.
2. Set “106%” ( $150/141 \times 100 = 106$  [%]) to the **I level Trimming** dialog box.
3. Press **F2 Q level Trimming** to display the **Q level Trimming** dialog box.
4. Set “106%” ( $150/141 \times 100 = 106$  [%]) to the **Q level Trimming** dialog box.
5. Press **F3 I/Q Common Offset** to display the **I/Q Common Offset** dialog box.
6. Set “1 V” to the **I/Q Common Offset** dialog box.
7. Press **F4 I Diff Offset** to display the **I Diff Offset** dialog box.
8. Set “0.5 mV” to the **I Diff Offset** dialog box.
9. Press **F5 Q Diff Offset** to display the **Q Diff Offset** dialog box.
10. Set “0.5 mV” to the **Q Diff Offset** dialog box.

## I Level Trimming

 or **Top**  **I/Q**,  **Analog I/Q Output Adjustments** **I Level Trimming**

Adjusts the I-phase output level gain.

This is available in MG3710A only when option-018/118 is installed.  
This is not available in MG3740A.

Press **F1 I Level Trimming** on the Analog I/Q Output Adjust function menu to set with the **I Level Trimming** dialog box.

Range	0% to 120%
Resolution	0.1%
Default	100%

### Remote command

#### Adjust the I-phase output level gain Command

```
[ :SOURce [1] ] :DM:IQADjustment:EXTernal:ITRimming <percent>
```

#### Query

```
[ :SOURce [1] ] :DM:IQADjustment:EXTernal:ITRimming?
```

#### Response

```
<percent> Unit: PCT
```

#### Parameter

<percent>	I-phase output level gain
Range	0% to 120%
Resolution	0.1%
Default	100%
Suffix code	PCT (%), When omitted: PCT

#### Programming Example

To adjust the I-phase output level gain to 50%.

```
DM:IQAD:EXT:ITR 50
DM:IQAD:EXT:ITR?
> 50.0
```

## Q Level Trimming

 or **Top**  **I/Q**,  **Analog I/Q Output Adjustments** **Q Level Trimming**

Adjusts the Q-phase output level gain.

This is available in MG3710A only when option-018/118 is installed.

This is not available in MG3740A.

Press **F2 Q Level Trimming** on the Analog I/Q Output Adjust function menu to set with the **Q Level Trimming** dialog box.

Range	0% to 120%
Resolution	0.1%
Default	100%

### Remote command

#### Adjust the Q-phase output level gain Command

```
[ :SOURce [1] ] :DM:IQADjustment:EXTernal:QTRimming <percent>
```

#### Query

```
[ :SOURce [1] ] :DM:IQADjustment:EXTernal:QTRimming?
```

#### Response

```
<percent> Unit: PCT
```

#### Parameter

<percent>	Q-phase output level gain
Range	0% to 120%
Resolution	0.1%
Default	100%
Suffix code	PCT (%), When omitted: PCT

#### Programming Example




To adjust the Q-phase output level gain to 50%.

```
DM:IQAD:EXT:QTR 50
```

```
DM:IQAD:EXT:QTR?
```

```
> 50.0
```

## I/Q Common Offset

 or Top  I/Q, >  Analog I/Q Output Adjustments > I/Q  
**Common Offset**

Adjusts the I/Q inphase output DC offset level.

This is available in MG3710A only when option-018/118 is installed.  
 This is not available in MG3740A.

Press **F3 I/Q Common Offset** on the Analog I/Q Output Adjust function menu to set with the **I/Q Common Offset** dialog box.

Range	-2.5 V to 5 V
Resolution	2 mV
Default	0 V

### Remote command

**Adjust the I/Q inphase output DC offset level**  
**Command**

`[ :SOURce [1] ] :DM:IQADjustment:EXTernal:COFFset <voltage>`

### Query

`[ :SOURce [1] ] :DM:IQADjustment:EXTernal:COFFset?`

### Response

`<voltage>` Unit: V

### Parameter




<code>&lt;voltage&gt;</code>	I-phase inphase output DC offset level
Range	-2.5 V to 5 V
Resolution	2 mV
Default	0 V
Suffix code	V, MV, UV, When omitted: V

### Programming Example

To adjust the I-phase inphase output DC offset level to 50 mV.

```
DM:IQAD:EXT:COFF 50MV
DM:IQAD:EXT:COFF?
> 0.050
```

## I Diff Offset

 or Top >  I/Q, >  Analog I/Q Output Adjustments > I Diff Offset

Adjusts the I-phase differential output DC offset level.

This is available in MG3710A only when option-018/118 is installed.

This is not available in MG3740A.

Press **F4 I Diff Offset** on the Analog I/Q Output Adjust function menu to set with the **I Diff Offset** dialog box.

Range	-50 mV to 50 mV
Resolution	0.1 mV
Default	0 V

## Remote command

**Adjust the I-phase differential output DC offset level****Command**

```
[ :SOURce[1] ] :DM:IQADjustment:EXTernal:DIOffset <voltage>
```

**Query**

```
[ :SOURce[1] ] :DM:IQADjustment:EXTernal:DIOffset?
```

**Response**

```
<voltage> Unit: V
```

**Parameter**

```
<voltage> I-phase differential output DC offset level
```

Range	-50 mV to 50 mV
-------	-----------------

Resolution	0.1 mV
------------	--------

Default	0 V
---------	-----

Suffix code	V, MV, UV, When omitted: V
-------------	----------------------------

**Programming Example**

To adjust the I-phase differential output DC offset level to 5 mV.

```
DM:IQAD:EXT:DIOF 5MV
```

```
DM:IQAD:EXT:DIOF?
```

```
> 0.0050
```

## Q Diff Offset

 or **Top**  **I/Q**, **>**  **Analog I/Q Output Adjustments** **>** **Q Diff Offset**

Adjusts the Q-phase differential output DC offset level.

This is available in MG3710A only when option-018/118 is installed.

This is not available in MG3740A.

Press **F5 Q Diff Offset** on the Analog I/Q Output Adjust function menu to set with the **Q Diff Offset** dialog box.

Range	-50 mV to 50 mV
Resolution	0.1 mV
Default	0 V

### Remote command

#### Adjust the Q-phase differential output DC offset level

##### Command

```
[ :SOURce[1] ] :DM:IQADjustment:EXTernal:DQOOffset <voltage>
```

##### Query

```
[ :SOURce[1] ] :DM:IQADjustment:EXTernal:DQOOffset?
```

##### Response

```
<voltage> Unit: V
```

##### Parameter

<voltage>	Q-phase differential output DC offset level
Range	-50 mV to 50 mV
Resolution	0.1 mV
Default	0 V
Suffix code	V, MV, UV, When omitted: V

#### Programming Example

To adjust the Q-phase differential output DC offset level to 5 mV.

```
DM:IQAD:EXT:DQOF 5MV
```

```
DM:IQAD:EXT:DQOF?
```

```
> 0.0050
```

## 7.6.4 Internal Baseband Adjustments

 or **Top** >  > **I/Q**, >  > **Internal Baseband Adjustments**

Adjusts the I/Q signal generated in the internal Baseband.

In MG3740A, this can be used only when option-020/120 is installed.

Press **F3 Internal Baseband Adjustments** on page 2 of I/Q function menu to open the **Internal Baseband Adjustments** dialog box and Internal Baseband Adjust function menu.

**Table 7.6.4-1 Internal Baseband Adjust Function Menu**

Page	Key No.	Menu Display	Function
1	F1	I Offset 0.000 %	Sets the DC offset for the I-phase.
	F2	Q Offset 0.000 %	Sets the DC offset for the Q-phase.
	F3	Gain Balance 0.000 dB	Adjusts the I/Q phase gain balance.
	F4	Quad. Angle 0.00 deg	Adjusts the quadrature angle of I/Q phase.
	F5	I/Q Phase 0.00 deg	Adjusts the Baseband signal phases.
	F6	I/Q Skew 0.000000000000 s	Adjusts the I/Q phase time difference (timing).
	F7	I/Q Delay 0.000000000000 s	Adjusts the Baseband signal output timing.

### I Offset

 or **Top** >  > **I/Q**, >  > **Internal Baseband Adjustments** > **I Offset**

Sets the DC offset for the I-phase.

Press **F1 I Offset** on the Internal Baseband Adjust function menu to set with the **I Offset** dialog box.

Range	-20% to 20%
Resolution	0.025%
Default	0%

**Remote command**

**Set the DC offset for the I-phase**

**Command**

[ :SOURce[1] | 2 ] :DM:IQADjustment:IOFFset <percent>

**Query**

[ :SOURce[1] | 2 ] :DM:IQADjustment:IOFFset?

**Response**

<percent> PCT

**Parameter**

<percent>	DC offset value
Range	-20% to 20%
Resolution	0.025%
Default	0%
Suffix code	PCT (%), When omitted: PCT

**Programming Example**

To adjust the I-phase DC offset to 10%.

```
DM:IQAD:IOFF 10
```

```
DM:IQAD:IOFF?
```

```
> 10.000
```



## Q Offset

 or **Top**  **I/Q**, **>**  **Internal Baseband Adjustments** **>** **Q Offset**

Sets the DC offset for the Q-phase.

Press **F2 Q Offset** on the Internal Baseband Adjust function menu to set with the **Q Offset** dialog box.

Range	-20% to 20%
Resolution	0.025%
Default	0%

## Remote command

**Set the DC offset for the Q-phase****Command**

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:QOFFset <percent>
```

**Query**

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:QOFFset?
```

**Response**

```
<percent> Unit: PCT
```

**Parameter**

<percent>	Q-phase DC offset value
Range	-20% to 20%
Resolution	0.025%
Default	0%
Suffix code	PCT, When omitted: PCT

**Programming Example**

To adjust the Q-phase DC offset to 10%.

```
DM:IQAD:QOFF 10
```

```
DM:IQAD:QOFF?
```

```
> 10.000
```

Gain Balance

**I/Q** or **Top** > **I/Q**, > **Internal Baseband Adjustments** > **Gain Balance**

Adjusts the I/Q phase gain balance.

Press **F3 Gain Balance** on the Internal Baseband Adjust function menu to set with the **Gain Balance** dialog box.

Range	-1 dB to 1 dB
Resolution	0.001 dB
Default	0 dB

When the positive value is set, Gain of the I-phase becomes larger than the Q-phase.

The amplitude ratio of the I/Q phase is the gain balance [dB].

Even if the gain balance is changed, RMS value is not changed.




Figure 7.6.4-1 Gain Balance

Remote command

**Adjust the I/Q phase gain balance**

**Command**

`[ :SOURCE[1] | 2 ] :DM:IQADjustment:GAIN <rel_ampl>`

**Query**

`[ :SOURCE[1] | 2 ] :DM:IQADjustment:GAIN?`

**Response**

`<rel_ampl>` Unit: dB

**Parameter**

<code>&lt;rel_ampl&gt;</code>	Gain balance of the I/Q phase
Range	-1 dB to 1 dB
Resolution	0.001 dB
Default	0 dB
Suffix code	DB, When omitted: DB

**Programming Example**

To set the gain balance of I/Q phase to 1 dB.

```
DM:IQAD:GAIN 1
DM:IQAD:GAIN?
> 1.000
```

**Quad. Angle**

**I/Q** or **Top** > **I/Q**, > **Internal Baseband Adjustments** > **Quad. Angle**

Adjusts the quadrature angle of I/Q phase.

Press **F4 Quad. Angle** on the Internal Baseband Adjust function menu to set with the **Quad. Angle** dialog box.

Range	-10 deg to 10 deg
Resolution	0.01 deg
Default	0 deg

The positive value increases the I/Q quadrature angle from 90 degrees, and the negative value decreases the I/Q quadrature angle from 90 degrees. For zero, the I/Q quadrature angle is 90 degrees.




Figure 7.6.4-2 Quadrature Angle

**Remote command****Adjust the I/Q phase quadrature angle****Command**

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:QSKew <angle>
```

**Query**

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:QSKew?
```

**Response**

```
<angle> Unit: deg
```

**Parameter**

<angle>	Quadrature angle of the I/Q phase
Range	-10 deg to 10 deg
Resolution	0.01 deg
Default	0 deg
Suffix code	DEG, When omitted: DEG

**Programming Example**

To adjust the quadrature angle of I/Q phase to 90 deg + 5 deg.

```
DM:IQAD:QSK 5
DM:IQAD:QSK?
> 5.00
```

I/Q Phase

 or **Top** >  > **I/Q**, >  > **Internal Baseband Adjustments** > **I/Q Phase**

Adjusts the Baseband signal phase.

This is used to adjust multiple SGs signal phases with MIMO or beam forming. The setting is same as **F7 I/Q Phase** in Table 7.3.15-1 “Sync Multi SG Function Menu”.

Press **F5 I/Q Phase** on the Internal Baseband Adjust function menu to set with the **I/Q Phase** dialog box.

Range	-360 deg to 360 deg
Resolution	0.01 deg
Default	0 deg

When the positive value is set, the phase is adjusted to be promoted.

**Remote command**

**Adjust the Baseband signal phase**

**Command**

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:PHASe <phase>
```

**Query**

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:PHASe?
```

**Response**

<phase> Unit: deg

**Parameter**

<phase>	Baseband signal phase
Range	-360 deg to 360 deg
Resolution	0.01 deg
Default	0 deg
Suffix code	DEG, When omitted: DEG

**Programming Example**

To set the Baseband signal IQ phase to 5 deg.

```
DM:IQAD:PHAS 5
```

```
DM:IQAD:PHAS?
```

```
> 5.00
```

**I/Q time difference: I/Q Skew**

 or **Top**  **I/Q**,  **Internal Baseband Adjustments**  **I/Q Skew**

Adjusts the I/Q phase time difference (timing).

Press **F6 I/Q Skew** on the Internal Baseband Adjust function menu to set with the **I/Q Skew** dialog box.

Range -800 ns to 800 ns

Resolution 1 ps

Default 0 s

When the positive value is set, the I-phase is delayed against the Q-phase.

**Remote command****Adjust the time difference (timing) between I-phase and Q-phase Command**

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:SKEW <time>
```

**Query**

```
[ :SOURce [1] | 2 ] :DM:IQADjustment:SKEW?
```

**Response**

```
<time> Unit: S
```

**Parameter**

```
<time> Time difference between the I-phase and Q-phase
```

Range -800 ns to 800 ns

Resolution 1 ps

Default 0 s

Suffix code S, MS, US, NS, PS, When omitted: S

**Programming Example**

To set the time difference between I-phase and Q-phase to 500 ps.

```
DM:IQAD:SKEW 500PS
```

```
DM:IQAD:SKEW?
```

```
> 0.000000000500
```

## I/Q Delay

 or **Top**  **I/Q**, **>**  **Internal Baseband Adjustments** **>** **I/Q Delay**

Adjusts the Baseband signal output timing.

This is used when multiple SGs are to be synchronized and timings for signals to reach to DUT are to be adjusted. The setting is same as **F8 I/Q Delay** in Table 7.3.15-1 “Sync Multi SG Function Menu”.

Press **F7 I/Q Delay** on the Internal Baseband Adjust function menu to set with the **I/Q Delay** dialog box.

Range	-400 ns to 400 ns
Resolution	1 ps
Default	0 s

### Remote command

#### Adjust the Baseband signal output timing

##### Command

```
[ :SOURce[1] | 2 ] :DM:IQADjustment:DELay <time>
```

##### Query

```
[ :SOURce[1] | 2 ] :DM:IQADjustment:DELay?
```

##### Response

```
<time> Unit: S
```

##### Parameter

<time>	Baseband signal output timing
Range	-400 ns to 400 ns
Resolution	1 ps
Default	0 s
Suffix code	S, MS, US, NS, PS, When omitted: S

#### Programming Example

To set the time difference between I-phase and Q-phase to 300 ns.

```
DM:IQAD:DEL 300NS
DM:IQAD:DEL?
> 0.000000300000
```

# Chapter 8 BER Measurement

---

This chapter describes the operations and screen display of the BER measurement function.

Note on remote command:

When the language mode is SCPI, the target SG can be selected with the beginning node of commands for controlling individual functions. Refer to Appendix E.7.6 “Selecting SG1/2” for details.

8.1	Function, Performance, and Communication .....	8-2
8.1.1	Function and performance .....	8-2
8.1.2	External connection .....	8-5
8.2	Display Description .....	8-6
8.2.1	BER dialog box.....	8-6
8.3	Performing BER Measurement.....	8-12
8.3.1	Starting/stopping BER measurement.....	8-14
8.3.2	Measure Mode.....	8-19
8.3.3	Measurement end conditions: Count Mode ...	8-21
8.3.4	Data Type .....	8-24
8.3.5	Resync Condition .....	8-26
8.3.6	BER Interface .....	8-32
8.4	PN Fix Pattern.....	8-35
8.4.1	Setting PN_Fix Pattern: PN Fix Pattern.....	8-36
8.4.2	Synchronization establishing conditions of PN_Fix patterns .....	8-39
8.4.3	Examples of using PN_Fix patterns .....	8-41
8.5	User Defined Pattern .....	8-43
8.5.1	Displaying user defined patterns .....	8-45
8.5.2	Setting user defined patterns: User Pattern ...	8-48
8.5.3	Loading user defined patterns: Open.....	8-51
8.6	BER Log.....	8-54
8.6.1	Deleting BER logs: Clear.....	8-57
8.6.2	Saving BER logs: Save .....	8-58
8.7	About BER Measurement Operations .....	8-61

## 8.1 Function, Performance, and Communication

 or **Top** >  > **Auxiliary**, > **BER**

When the MG3710A/MG3740A has the option 021/121 BER measurement function installed, it can measure Bit Error Rates (BER) of externally input signals.

To switch the MG3710A/MG3740A to the BER measurement mode, press **Aux Fctn** on the main function menu or press **F5 Auxiliary** on page 2 of the top function menu to display the Auxiliary function menu, and press **F2 BER**.

This chapter assumes that the MG3710A/MG3740A is in the BER measurement mode, unless otherwise specified.

### 8.1.1 Function and performance

The BER measurement function of the MG3710A/MG3740A has the following functions and performance:

**Input signal**

Data, Clock, and Enable (Polarity inversion is enabled.)

**Input level**

TTL

**Input bit rate**

100 bps to 40 Mbps

**Measurable patterns**

PN9, PN11, PN15, PN20, PN23, ALL0, ALL1, Alternate (repetition of 01), PN9Fix, PN11Fix, PN15Fix, PN20Fix, PN23Fix, and user defined patterns

**Number of measurable bits**

$\leq 4294967295$  bits =  $(2^{32} - 1)$  bit

**Number of measurable error bits**

$\leq 4294967295$  bits =  $(2^{32} - 1)$  bit

**Measurement end condition**

Selectable between the number of measurement bits and the number of measurement error bits

**Operation mode**

Measure Mode : Continuous, Single, Endless

Count Mode : Data, Error

Auto Resync : On, Off



Synchronization establishing condition

Depends on measured patterns.

PN 9, 11, 15, 20, 23 : (PN order × 2) bit continuous error free

PN\_Fix pattern : Establish the synchronization with PN signal by PN order × 2 bits error free, and then establish the synchronization with PNfix signal from the start bit of PNfix signal by PN order error free.

ALL0, ALL1, repetition of 01 : 10 bit continuous error free

User defined patterns : 8 to 1024 bit (variable) error free  
The start bit to be used for detecting synchronization can also be selected.

Probabilities of synchronization

For PN signals on the MG3710A/MG3740A, the synchronization establishing condition is (PN order × 2) bit continuous error free. For PN signals including random errors, probabilities of a section in which (PN order × 2) bit continuous error free occurs are shown in the table below. The probabilities can be deemed as those of synchronizing with PN signals with a certain error rate in 1 cycle.

**Table 8.1.1-1 Probabilities of Synchronizing with PN Signals (%)**

PN signal error rate (%) \ PN order	PN9	PN15	PN23
10	15.0	4.2	0.79
3	57.8	40.1	24.6
1	83.5	74.0	63.0
0.1	98.2	97.0	95.5

Detection of SyncLoss

When the Auto Resync setting is ON, the SyncLoss detection conditions are as follows:

x/y: y = number of measurement bit: selectable among 500, 5000 and 50000 bits  
x = number of error bits among y bits: selectable in the range from 1 to y/2

(When Auto Resync is Off, SyncLoss is not detected)

Resynchronization judgment

Based on detection of SyncLoss.

Resynchronization operations

Selectable between Clear BER Count and Count Keep

**Display**

Status, Error Rate, Error Count, SyncLoss Count, number of measurement bits

**Measurement result clearing function**

This function can start the measurement from 0 by clearing the measurement values while keeping synchronization during the BER measurement.

## 8.1.2 External connection

BER measurement requires signals to be input externally. The signals are input via the AUX connector on the rear panel. Refer to Table 3.1.2-1 “AUX Connectors”.




Figure 8.1.2-1 BER Measurement Input Connector

BER measurement uses three terminals of the AUX connectors:

- BER CLK terminal: Inputs clock signals for BER measurement (TTL level and DC coupling).
- BER Enable terminal: Inputs Enable signals for BER measurement of burst signals (TTL level and DC coupling).
- BER Data terminal: Inputs data signals for BER measurement (TTL level and DC coupling).

When Enables signals are not used, do not connect to the Enable terminal and set Enable Active to “Disable”. Refer to 8.3.6 “BER Interface”.

## 8.2 Display Description

This section describes display items of the BER measurement function.

### 8.2.1 BER dialog box

 or **Top** >  > **Auxiliary**, > **BER**

Press **Aux Fctn** on the main function menu or **F5 Auxiliary** on page 2 of the top function menu to display the Auxiliary function menu. Press **F2 BER** to display the **BER** dialog box.

The **BER** dialog box shows a measurement result.




Figure 8.2.1-1 BER Dialog Box

When BER is not measured, Error Rate 0, Error Count 0, and Data Count 0 are displayed in the **BER** dialog box.

Table 8.2.1-1 Display Items of BER Dialog Box

No.	Display	Description
1	Status	Indicates the status of measurement.
2	Error	Explains an error when it occurs.
3	Sync Loss Count	Indicates a SyncLoss count and a reason why it stopped.
4	Error Rate	Indicates an error rate in index and percentage.
5	Error Count	Indicates the number of error bits.
6	Data Count	Indicates the number of measurement bits.

## Status

Indicates the status of the BER measurement.

**Table 8.2.1-2 Measurement Status**

Display	Description
Stop	Measurement stopped.
Synchronizing	Synchronization is being established.
Measuring	Measurement is in progress.
OverflowDataCount	Measurement stopped because the number of measurement bits exceeded the maximum value ( $2^{32} - 1$ bit).
OverflowSyncLoss	Measurement stopped because the SyncLoss count exceeded the maximum value (65535).

### Remote command

#### Query the status of the BER measurement

##### Query

```
[ :SENSe ] :BERT [ :BASEband ] :MEASure?
```

##### Response

```
<status>
```

##### Parameter

<status>	Measurement status
0	Stop
1	Measuring
2	Synchronizing
3	Stopped because a measurement error occurs.
4	Stopped because the SyncLoss count exceeded the maximum value. OverflowSyncLoss
5	Stopped because the number of count bits exceeded the maximum value. OverflowDataCount

##### Details

When a measurement error occurs,

[ :SENSe ] :BERT [ :BASEband ] :ERRor? can be used to query the details of the error.

##### Programming Example

To query the current operation status.

```
BERT:MEAS?
```

```
> 0
```

Error

Indicates the error information of the BER measurement.

**Table 8.2.1-3 Explanation of Errors**

Display	Description
Bit Error	An error bit occurred.
SyncLoss	SyncLoss occurred.
ClockError	The input clock signal was abnormal.
EnableError	The input enable signal was abnormal.

**Remote command**

**Query the error information of the BER measurement**

**Query**

[ :SENSe ] :BERT [ :BASEband ] :ERRor?

**Response**

<status>

**Parameter**

<status>

Value

Measurement status

= bit0 + bit1 + bit2 + bit3 + bit4 + bit5 + bit6  
+ bit7 + bit8 + bit9 + bit10 + bit11 + bit12  
+ bit13 + bit14 + bit15

When a target application is BER, bits are assigned as follows:

bit0 : 2 <sup>0</sup> = 1	Sync Loss occurred
bit1 : 2 <sup>1</sup> = 2	Clock Error occurred
bit2 : 2 <sup>2</sup> = 4	Enable Error occurred
bit3 : 2 <sup>3</sup> = 8	(Not Used)
bit4 : 2 <sup>4</sup> = 16	(Not Used)
bit5 : 2 <sup>5</sup> = 32	(Not Used)
bit6 : 2 <sup>6</sup> = 64	(Not Used)
bit7 : 2 <sup>7</sup> = 128	(Not Used)
bit8 : 2 <sup>8</sup> = 256	(Not Used)
bit9 : 2 <sup>9</sup> = 512	(Not Used)
bit10 : 2 <sup>10</sup> = 1024	(Not Used)
bit11 : 2 <sup>11</sup> = 2048	(Not Used)
bit12 : 2 <sup>12</sup> = 4096	(Not Used)
bit13 : 2 <sup>13</sup> = 8192	(Not Used)
bit14 : 2 <sup>14</sup> = 16384	(Not Used)
bit15 : 2 <sup>15</sup> = 32768	(Not Used)

Range

0 to 65535

**Details**

0 is returned if both SG and BER operate normally.

**Programming Example**

To query the current operation status.

```
BERT:ERR?
> 0
```

**SyncLoss Count**

Displays a Sync Loss count of the BER measurement.

**Remote command****Query a Sync Loss count of the BER measurement Query**

```
[ :SENSe ] :BERT [ :BASEband ] :SYNLoss :COUNT?
```

**Response**

```
<count>
```

**Parameter**

<count>	Sync Loss count
Range	0 to 65535

**Programming Example**

To query a Sync Loss count.

```
BERT:SYNL:COUN?
> 500
```

**Error Rate**

Displays a bit error rate of the BER measurement function.

Error Rate is represented in two ways: in index; and in percentage. Each representation follows the rules:

**In index**

The rate is rounded to the digit of a ten-thousandth of the maximum digit and represented before the digit of a ten-thousandth.

Example: 0.00978495 is displayed as 9.785E-03.

**In percentage**

The rate is represented in percentage, rounded to four decimal places, and represented before four decimal places.

Example: 0.00978495 is displayed as 0.978%.

**Remote command**

**Query the bit error rate of the BER measurement function**

**Query**

:FETCh:BERT:ERRor:RATE? EP|ER

**Response**

<rate>

**Parameter**

EP	Returns the bit error rate in percentage.
ER	Returns the bit error rate as an index.
<rate>	Value of the bit error rate
EP	0.000 to 100.000 %
ER	0.000E+00 to 1.000E+02

**Programming Example**

To query the bit error rate of the BER measurement function in percentage.

```
FETC:BERT:ERR:RATE? EP  
> 5.000
```

**Error Count**

Displays the number of error bits of the BER measurement.

**Remote command**

**Query the number of error bits of the BER measurement**

**Query**

:FETCh:BERT:ERRor:COUNt?

**Response**

<bit>

**Parameter**

<bit>	Number of error bits
Range	0 to $2^{32}-1$ bit

**Programming Example**

To query the number of error bits.

```
FETC:BERT:ERR:COUN?  
> 500
```



### Number of measurement bits: Data Count

Displays the number of measurement bits of the BER measurement.

**Remote command**

**Query the number of measurement bits of the BER measurement  
Query**

:FETCh:BERT:DATA:COUNt?

**Response**

<bit>

**Parameter**

<bit>

Number of measurement bits

Range

0 to  $2^{32}-1$  bit

**Programming Example**

To query the number of measurement bits.

```
FETC:BERT:DATA:COUN?
```

```
> 10000
```

## 8.3 Performing BER Measurement

 or Top>  >Auxiliary, >BER

Use the BER function menu to set and perform the BER measurement.

1. Following the explanation in 8.1.2 “External connection”, input signals externally.
2. Use **F4 Measure Mode** to select a mode for the BER measurement.
3. Use **F5 Count Mode** to set the measurement end conditions.
4. Use **F6 Data Type** to select data pattern for measurement.
5. Use **F1 Resync Condition** on page 2 of the function menu to set the automatic resynchronization function.
6. Use **F2 BER Interface** on page 2 of the function menu to set the interface for the BER measurement.
7. Use **F1 Start BER** and **F2 Stop BER** to start and stop the measurement, respectively.

### BER function menu

 or Top>  >Auxiliary, >BER

Press **Aux Fctn** on the main function menu or **F5 Auxiliary** on page 2 of the top function menu to display the Auxiliary function menu. Press **F2 BER** to display the BER function menu.

Table 8.3-1 BER Function Menu

Page	Key No.	Menu Display	Function
1	F1	Start BER Test	Starts the BER measurement. Refer to 8.3.1 “Starting/stopping BER measurement”.
	F2	Stop BER Test	Stops the BER measurement. Refer to 8.3.1 “Starting/stopping BER measurement”.
	F3	Clear BER Count	Clears Data Count, ErrorCount, or SyncLossCount. Refer to 8.3.1 “Starting/stopping BER measurement”.
	F4	Measure Mode Continuous	Selects a mode for the BER measurement from Single, Continuous, or Endless. Refer to 8.3.2 “Measure Mode”.
	F5	Count Mode	Selects either the number of measurement bits or the number of error bits for the measurement end condition. Refer to 8.3.3 “Measurement end conditions: Count Mode”.
	F6	Data Type PN9	Selects data pattern for measurement. Refer to 8.3.4 “Data Type”.
	F7	PN Fix Pattern	Sets the PN Fix pattern. Refer to 8.4 “PN Fix Pattern”.
	F8	User Pattern	Queries or sets user defined patterns. Refer to 8.5 “User Defined Pattern”.

**Table 8.3-1 BER Function Menu (Cont'd)**

Page	Key No.	Menu Display	Function
2	F1	Resync Condition	Sets the automatic resynchronization function. Refer to 8.3.5 "Resync Condition".
	F2	BER Interface	Sets the interface for the BER measurement. Refer to 8.3.6 "BER Interface".
	F3	Show Log	Displays, saves, or deletes a log of the BER measurement result. Refer to 8.6 "BER Log".
	F4	Auto Restart <u>Off</u> On	Sets whether to auto-restart BER measurement when output level is changed. Refer to 8.3.1 "Starting/stopping BER measurement".
	F7	Level -144.00 dBm	Sets the output level. Refer to 5.2 "Output Level Setting Method: Level".

### 8.3.1 Starting/stopping BER measurement

#### Start BER Test

 or **Top** >  > **Auxiliary, >BER>Start BER Test**

Starts the BER measurement.

Press **F1 Start BER Test** to start the BER measurement.

If this is pressed during measurement, measurement values obtained during measurement are cleared and nothing remains in the log.

Measurement starts over after stopping.

#### Remote command

#### Start the BER measurement

##### Command

`:INITiate:BERT[:IMMEDIATE]`

##### Programming Example

To start the BER measurement.

`INIT:BERT`

#### Stop BER Test

 or **Top** >  > **Auxiliary, >BER>Stop BER Test**

Stops the BER measurement.

Pressing **F2 Stop BER Test** during BER measurement stops measurement and saves measurements while stopped to the log.

#### Remote command

#### Stop the BER measurement

##### Command

`:ABORt:BERT`

##### Programming Example

To stop the BER measurement.

`ABOR:BERT`

#### Operation description

#### Other measurement end conditions

Other measurement end conditions depend on operation modes.

**Table 8.3.1-1 Measurement End Conditions of BER Measurement (Single Measurement Mode)**

Auto Resync Count Mode	On	Off
Data	<ul style="list-style-type: none"> <li>• Reaches the specified number of the measurement bits.</li> <li>• Reaches the maximum SyncLoss count (65535).</li> </ul>	<ul style="list-style-type: none"> <li>• Reaches the specified number of the measurement bits.</li> </ul>
Error	<ul style="list-style-type: none"> <li>• Reaches the specified number of the measurement error bits.</li> <li>• Reaches the maximum number of measurement bits (<math>2^{32} - 1</math> bit).</li> <li>• Reaches the maximum SyncLoss count (65535).</li> </ul>	<ul style="list-style-type: none"> <li>• Reaches the specified number of the measurement error bits.</li> <li>• Reaches the maximum number of measurement bits (<math>2^{32} - 1</math> bit).</li> </ul>

Setting parameters stops measurements (except for BER Interface).

In the Continuous measurement mode, if the condition in Table 8.3.1-1 is met, the measurement stops. Then, it starts again.

The BER measurement continues even if you navigate to other screens during the BER measurement.

When you turn the power off and restart the MG3710A/MG3740A during measurement, the BER measurement becomes the stop status.

When 40 Mbps signals are measured, the result reaches the upper limit of bit count at the longest 107.4 seconds or so, and the measurement stops.

## Clear BER Count

 or **Top** >  > **Auxiliary, >BER>Clear BER Count**

Clears the result of the BER measurement.

Press **F3 Clear BER Count** to clear the result of the BER measurement.

This is not available when Measurement Mode is Continuous.

### Remote command

#### Clear the result of the BER measurement

##### Command

```
[ :SENSe ] :BERT [ :BASEband ] :COUNT :CLEAr
```

##### Programming Example

To clear Error Rate, ErrorCount and SyncLossCount.

```
BERT :COUN :CLE
```

### Operation description

#### When Clear BER Count is pressed during synchronizing/measuring


The number of measurement bits, the number of error bits, and the SyncLoss count are cleared during measurement while keeping synchronization. However, the displayed measurement status is not cleared. Therefore, if you perform Clear BER Count during measurement, and the measurement finishes, then the number of measurement bits is less than the specified number of measurement bits. Operations of the number of error bits and the SyncLoss count are similar to this.

When you press **Clear BER Count**, the measurement values (Data Count, Error Count, and Sync Loss Count) are stored as offset values. Then, the displayed values are updated by subtracting the offset values from the measurement values. These offset values are reset to 0 when the measurement finishes or stops.


Executing **Clear BER Count** during measurement saves CLEAR to the log.

Example: The displayed result of measuring 100000 bits when you press Clear BER Count.


1. Start the measurement.



- Press **F3 Clear BER Count**. When the key is pressed, the number of count bits is 35612, but the “0 bit” is displayed.






- When the measurement finishes, the total count bit is 100000 bits, but the “64388 bit” (100000 - 35612) is displayed.




**When Clear BER Count is pressed after the measurement is finished or stopped**

The number of measurement bits, the number of error bits, the SyncLoss count, the error rate, and the status displayed on the screen are cleared. Executing **Clear BER Count** saves CLEAR to the log.

**Auto Restart**

 or **Top** >  **Auxiliary**, >**BER**>  **Auto Restart**

Enables/disables the Auto Restart.  
 Press  to display the page 2 of BER function menu. Press **F4 Auto Restart** to select the Auto Restart setting after changing output level.  
 On            Auto Restart enabled.  
 Off           Auto Restart disabled. (Default).

**Remote command**

**Enable/disable the Auto Restart.**

**Command**

`[ :SENSe ] :BERT : [BASEband] :RStArt :AUTO <boolean>`

**Query**

`[ :SENSe ] :BERT : [BASEband] :RStArt :AUTO?`

**Response**

`<boolean>    0 or 1`

**Parameter**

`<boolean>`    Auto Restart setting  
 ON | 1        Auto Restart enabled.  
 OFF | 0       Auto Restart disabled (Default).

**Programming Example**

To enable Auto Restart.

```
BERT:RST:AUTO ON
BERT:RST:AUTO?
> 1
```



### 8.3.2 Measure Mode

 or **Top** >  > **Auxiliary, >BER>Measure Mode**

Selects a mode for the BER measurement.

Press **F4 Measure Mode** to display the Measure Mode function menu to select a measurement mode.

- Single Measures selected data patterns until a result reaches the specified number of bits or the specified number of error bits.
- Continuous Repeats Single measurements (Default).
- Endless Measures data until a result reaches the upper limit of the measurement count bit (4294967295 bits).

**Remote command**

**Select a mode for the BER measurement**

**Command**

`[ :SENSe ] :BERT [ :BASEband ] :MODE SINGLE | CONTInuous | ENDLess`

**Query**

`[ :SENSe ] :BERT [ :BASEband ] :MODE?`

**Response**

`<mode> SING, CONT, or ENDL`

**Parameter**

- `<mode>`
- SINGLE Measures selected data patterns until a result reaches the specified number of bits or the specified number of error bits.
- CONTInuous Repeats Single measurements (Default).
- ENDLess Measures data until a result reaches the upper limit of the measurement count bit (4294967295 bits).

**Programming Example**


To set the measurement mode to Continuous.  
`BERT:MODE CONT`  
`BERT:MODE?`  
`> CONT`

**Operation description Display the BER measurement mode**

Displayed measurement results by BER measurement modes are shown below. Refer to Figure 8.2.1-1 “BER Dialog Box” for displayed status and error rates during measurement.

When Measure Mode is Continuous:


Status, Error, and Sync Loss Count are updated as required during measurement. When measurement starts again, the measurement results are cleared to 0.



**Figure 8.3.2-1 Measure Mode: Continuous**

When Measure Mode is Single or Endless:

Error, Error Rate, Error Count, Data Count, and Status (only for Single) are updated as required during measurement. When the measurement finishes, updating stops.



**Figure 8.3.2-2 Measure Mode: Single or Endless**

8.3.3 Measurement end conditions: Count Mode



 or Top>>Auxiliary, >BER>Count Mode

Sets the measurement end conditions.  
 This function is not available when Measure Mode is set to Endless.  
 Press **F5 Count Mode** to display the BER Count mode function menu to set the measurement end conditions.

Table 8.3.3-1 Count Mode Function Menu

Page	Key No.	Menu Display	Function
1	F1	Count Mode Data Error	Selects a measurement end condition.
	F2	Data 1000	Sets the number of measurement bits.
	F3	Error 1	Sets the number of measurement error bits.

Selecting measurement end conditions: Count Mode

 or Top>>Auxiliary, >BER>Count Mode>Count Mode

Selects a measurement end condition.  
 This function is not available if Measure Mode is set to Endless.  
 Press **F1 Count Mode** on the BER Count mode function menu to select a measurement end condition.

- Data Specifies the number of measurement bits(Default).
- Error Specifies the number of measurement error bits.

Remote command

Select a measurement end condition  
 Command

```
[ :SENSe ] :BERT [ :BASEband ] :STOP:CRITeria [ :SElect ] EBIT | NONE
```

Query

```
[ :SENSe ] :BERT [ :BASEband ] :STOP:CRITeria [ :SElect ] ?
```

Response

```
<mode>
```

Parameter

- <mode>
- NONE Specifies the condition to the number of measurement bits (Default).
- EBIT Specifies the condition to the number of measurement error bits.

**Programming Example**

To set the Count mode to the number of measurement bits.

```
BERT:STOP:CRIT NONE
BERT:STOP:CRIT?
> NONE
```

Setting the number of measurement bits: Data

 or **Top**  **>Auxiliary, >BER>Count Mode>Data**

Sets the number of measurement bits when Count Mode is Data.

This function is not available if Measure Mode is set to Endless.

Press **F2 Data** on the Count mode function menu to specify the number of measurement bits in the **Data** dialog box. When accumulated measurement bits reach the specified number of bits, the measurement stops.

**Table 8.3.3-2 Setting Range**

Setting range	1000 bit to $2^{32}-1$ (4294967295) bit
Resolution	1 bit
Default	1000 bit

**Remote command**

**Set the number of measurement bits when Count Mode is Data Command**

```
[[:SENSe]:BERT[:BASEband]:TBITs <ext_integer>
```

**Query**

```
[[:SENSe]:BERT[:BASEband]:TBITs?
```

**Response**

```
<ext_integer>
```

**Parameter**

```
<ext_integer>
```

Based on Table 8.3.3-2 “Setting Range”.

**Programming Example**

To set the number of measurement bits to 2000 bits.

```
BERT:TBIT 2000
BERT:TBIT?
> 2000
```

Setting the number of measurement error bits: Error

**AUX Fctn** or **Top** → **Auxiliary, >BER>Count Mode>Error**

Sets the number of measurement error bits when Count Mode is Error. This function is not available if Measure Mode is set to Endless. Press **F3 Error** on the Count mode function menu to specify the number of measurement error bits in the **Error** dialog box. When accumulated measurement error bits reach the specified number of bits, the measurement stops.

**Table 8.3.3-3 Setting Range**

Setting range	1 bit to $2^{32} - 1$ (4294967295) bit
Resolution	1 bit
Default	1 bit

**Remote command**

**Set the number of measurement error bits when Count Mode is Error Command**

`[ :SENSe ] :BERT [ :BASEband ] :STOP:CRITeria:EBIT <ext_integer>`

**Query**

`[ :SENSe ] :BERT [ :BASEband ] :STOP:CRITeria:EBIT?`

**Response**

`<ext_integer>`

**Parameter**

`<ext_integer>`

Based on Table 8.3.3-3 “Setting Range”.


**Programming Example**

To set the number of measurement error bits to 2000 bits.  
`BERT:STOP:CRIT:EBIT 2000`  
`BERT:STOP:CRIT:EBIT?`  
`> 2000`

### 8.3.4 Data Type

 or **Top** >  > **Auxiliary, >BER>Data Type**

Select a data type.

Press **F6 Data Type** to display the Data type function menu to select a data pattern for the measurement. Use  to display page 2.

Options            PN9, PN11, PN15, PN20, PN23,  
                       PN9Fix, PN11Fix, PN15Fix, PN20Fix, PN23Fix,  
                       ALL0 (all 0s), ALL1 (all 1s), Alternate (0, 1, 0, 1),  
                       User Defined (user defined patterns)

**Note:**

The PN\_Fix pattern is a pattern consisting of repeated parts of PN patterns and PN patterns with length shorter than 1 cycle. Refer to 8.4 “PN Fix Pattern” and 8.5 “User Defined Pattern” for details of PN\_Fix and UserDefined.

**Remote command**

**Select a data type**

**Command**

```
[ :SENSe ] :BERT [ :BASeband ] :PRBS [ :DATA ]
PN9 | PN11 | PN15 | PN20 | PN23 | ALL0 | ALL1 | ALT | FPN9 | FPN11 | FPN15 | F
PN20 | FPN23 | USER
```

**Query**

```
[ :SENSe ] :BERT [ :BASeband ] :PRBS [ :DATA ] ?
```

**Response**

```
<pattern>
```

**Parameter**

<pattern>	Type of data patterns
PN9	PN9 (Default)
PN11	PN11
PN15	PN15
PN20	PN20
PN23	PN23
FPN9	PN9Fix
FPN11	PN11Fix
FPN15	PN15Fix
FPN20	PN20Fix
FPN23	PN23Fix
ALL0	All 0s (00...0)
ALL1	All 1s (11...1)
ALT	Repetitions of 0, 1 (0, 1, 0, 1, ...)
USER	User defined patterns

**Programming Example**




To set the data pattern for measurement to PN23.

```
BERT:PRBS PN23
```


```
BERT:PRBS?
```

```
> PN23
```

### 8.3.5 Resync Condition

 or **Top**  **Auxiliary, >BER>**  **Resync Condition**

Sets the automatic resynchronization function.

Press  to display page 2 of the BER function menu. Press **F1 Resync Condition** to display the Resync Condition function menu and set the automatic resynchronization function for the BER measurement.

**Table 8.3.5-1 Resync Condition Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Auto Resync Off <u>On</u>	Specifies whether or not to automatically perform resynchronization when a Sync Loss occurs.
	F2	Threshold X 200	Specifies the number of bits to determine if Sync Loss occurs (numerator).
	F3	Threshold Y 500 bits	Specifies the number of bits to determine if Sync Loss occurs (denominator).
	F4	at SyncLoss <u>Clear</u> Keep	Specifies whether or not to clear the measurement results when a Sync Loss is detected.

#### Details of Auto Resync

There are differences between Auto Resync On and Off.

##### Auto Resync On:

After establishing synchronization, if errors are more than the specified threshold values, then it is determined that SyncLoss occurred. The measurement stops, and resynchronization is performed. If thresholds are set to 200/500 (Default), and error bits are less than 200 of 500 bits, then it is not determined that SyncLoss occurred and the measurement continues.

To measure signals with high error rate, you can avoid SyncLoss in a condition where a block error occurs due to fading by specifying the thresholds to high values such as 200/500.

To measure signals with low error rate, you can immediately detect SyncLoss and perform resynchronization when an error occurs by specifying the thresholds to low values such as 50/500.

##### Auto Resync Off:

SyncLoss is not detected during measurement. Signals with high error rate can be measured without interruption. However, when clock is not reproduced at the DUT-side, the clock and data may not be synchronized. In this case, use AutoReEsync On for measurement.



Measured error rates and the corresponding recommended settings are as follows:

**Table 8.3.5-2 Measured Error Rates and Recommended Settings**

Value Measured error rate	AutoResync On		AutoResync Off
	Threshold Value 50/500	Threshold Value 200/500	
Less than 0.3%	Optimal setting	Measurable	Measurable
0.3% or more	√	Optimal setting	Measurable

√ SyncLoss may occur frequently.

Reference:

- The default threshold values of the MG3700A: 200/500
- The specified threshold values of the MP1201C:200/512
- The default threshold values of the MD6420A: 200/512
- The specified threshold values of the MT8820A (WCDMA) BER function: 23/64


There are differences between Auto Resync on the MG3710A/MG3740A and Auto Sync on the MP1201C or MD6420A.

**Details of Auto Resync on the MG3710A/MG3740A**

Auto Resync on the MG3710A/MG3740A behaves as follows:

**Auto Resync On**


The MG3710A/MG3740A performs synchronization when it starts measurement. It starts measurement after the synchronization is established. After the measurement starts, the MG3710A/MG3740A automatically performs resynchronization when it detects SyncLoss.



**Figure 8.3.5-1 Auto Resync On**

**Auto Resync Off**

The MG3710A/MG3740A performs synchronization when it starts measurement. It starts measurement after the synchronization is established. SyncLoss is not detected during measurement.




**Figure 8.3.5-2 Auto Resync Off**

**Details of Auto Sync on the MP1201C or MD6420A**

Auto Sync on the MP1201C or MD6420A behaves as follows:

**Auto Sync On**


The MP1201C or MD6420A performs synchronization when it starts measurement. It starts measurement after the synchronization is established. After the measurement starts, the MP1201C or MD6420A automatically performs resynchronization when it detects SyncLoss.



**Figure 8.3.5-3 Auto Sync On**

**Auto Sync Off**

The MP1201C or MD6420A assumes synchronization is established when it starts measurement. SyncLoss is not detected during measurement.



**Figure 8.3.5-4 Auto Sync Off**

**Note:**

To get BER curve, set Auto Sync to On and establish synchronization in good S/N condition, and then change Auto Sync to Off and perform measurement with varying S/N.

Auto Resync

 or Top >  > Auxiliary, > BER >  > Resync Condition > Auto Resync

Enables/disables the automatic resynchronization.  
 Press **F1 Auto Resync** on the Resync Condition function menu to select operations of resynchronization when Sync Loss occurs.

On	Automatically performs resynchronization(Default).
Off	Does not automatically perform resynchronization.

**Remote command**

**Enable/disable the automatic resynchronization**

**Command**  
 [:SENSe]:BERT[:BASEband]:RSYNc[:STATe] <boolean>

**Query**  
 [:SENSe]:BERT[:BASEband]:RSYNc[:STATe]?

**Response**  
 <boolean>                      0 or 1




**Parameter**  
 <boolean>                      Set the automatic resynchronization  
 ON | 1                              Automatically performs resynchronization (Default).  
 OFF | 0                             Does not automatically perform resynchronization.

**Programming Example**

To set automatic resynchronization to On.  
 BERT:RSYN ON  
 BERT:RSYN?  
 > 1

Conditions for detecting Sync Loss: Threshold X, Threshold Y

Threshold X

 or Top >  Auxiliary, >BER>  Resync Condition>

**Threshold X**

Sets conditions for detecting Sync Loss of the BER measurement. Set values of X and Y so that when X bits in Y bits become error, it is determined that SyncLoss occurred.




Press **F2 Threshold X** on the Resync Condition function menu to set a value of X in the **Threshold X** dialog box.

This function is available when Auto Resync is **On**.

**Table 8.3.5-3 Setting Range**

Setting range	1 bit to (Y/2) bits
Resolution	1 bit
Default	200 bits

Threshold Y

 or Top >  Auxiliary, >BER>  Resync Condition>

**Threshold Y**

Press **F3 Threshold Y** on the Resync Condition function menu to select a value of Y on the Threshold function menu.

This function is available when Auto Resync is **On**.

Options 500 bits (Default), 5000 bits, 50000 bits

**Remote command**

**Set conditions for detecting Sync Loss of the BER measurement**

**Command**

[ :SENSe ] :BERT [ :BASEband ] :RSYNc :THReshold  
<ext\_integer>, 500 | 5000 | 50000

**Query**

[ :SENSe ] :BERT [ :BASEband ] :RSYNc :THReshold?

**Response**

<ext\_integer>, <Y>




**Parameter**

<ext\_integer> Numerator of the threshold  
Based on Table 8.3.5-3 “Setting Range”.  
<Y> Denominator of the threshold  
500 500 bits (Default)  
5000 5000 bits  
50000 50000 bits

**Programming Example**

```
To set conditions for determining Sync Loss to 123/500 bits.
BERT:RSYN:THR 123,500
BERT:RSYN:THR?
> 123,500
```

Operations when detecting Sync Loss: at SyncLoss

 or Top >  Auxiliary, >BER>  Resync Condition > at SyncLoss

Specifies to clear or hold the measurement results when a SyncLoss is detected.

Press **F4 at SyncLoss** on the Resync Condition function menu to select a parameter. This function is available when Auto Resync is On.

- Clear   Clears the measurement results(Default).
- Keep   Holds the measurement results.

**Remote command**

**Specify to clear or hold the measurement results when a SyncLoss is detected**

**Command**  
[:SENSe]:BERT[:BASEband]:RSYNc:COUNt:ACTion CLEar|KEEP

**Query**  
[:SENSe]:BERT[:BASEband]:RSYNc:COUNt:ACTion?

**Response**  
<mode>   CLE or KEEP

**Parameter**


- <mode>   Operation mode
- CLEar   Clears the measurement results (Default).
- KEEP   Holds the measurement results.

**Details**  
This function is available when Auto Resync is On.


**Programming Example**

```
To clear the count value when a Sync Loss occurs.
BERT:RSYN:COUN:ACT CLE
BERT:RSYN:COUN:ACT?
> CLE
```

### 8.3.6 BER Interface

 or Top>  >Auxiliary, >BER>  >BER Interface

Sets input signals for the BER measurement.

Press  to display page 2 of the BER function menu. Press **F2 BER Interface** to display the BER Interface function menu to set an input interface for the BER measurement. You can set the input interface during measurement.

**Table 8.3.6-1 BER Interface Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Clock Edge Fall <u>Rise</u>	Specifies an enabled edge for Clock.
	F2	Data Polarity Negative <u>Positive</u>	Specifies a polarity of the Data connector.
	F3	Enable Active Disable	Specifies a polarity of the Enable connector and whether or not to use it.

#### Clock Edge

 or Top>  >Auxiliary, >BER>  >Resync Condition> BER Interface>Clock Edge

Sets a detection edge for Clock signals.

Press **F1 Clock Edge** on the BER Interface function menu to select a parameter.

- Rise Detects Data at the rising edge of Clock signals(Default).
- Fall Detects Data at the falling edge of Clock signals.

#### Remote command

#### Set a detection edge for Clock signals

##### Command

:INPut:BERT[:BASEband]:CLOCK:POLarity POSitive|NEGative

##### Query

:INPut:BERT[:BASEband]:CLOCK:POLarity?

##### Response

<mode> POS or NEG

**Parameter**

<mode>	Detection edge of Clock signals
POSitive	Detects Data at the rising edge of Clock signals (Default).
NEGative	Detects Data at the falling edge of Clock signals.

**Programming Example**

To specify to detect Data at the rising edge of Clock signals.

```
INP:BERT:CLOC:POL POS
INP:BERT:CLOC:POL?
> POS
```

Data Polarity

 or Top  Auxiliary, >BER  Resync Condition > BER Interface > Data Polarity

Sets the logic for Data signals.

Press **F2 Data Polarity** on the BER Interface function menu to select a parameter.

Positive	Sets the logic for Data signals to positive logic(Default).
Negative	Sets the logic for Data signals to negative logic.

**Remote command**

**Set the logic for Data signals**

**Command**

```
:INPut:BERT[:BASEband]:DATA:POLarity POSitive|NEGative
```

**Query**

```
:INPut:BERT[:BASEband]:DATA:POLarity?
```

**Response**

```
<mode> POS or NEG
```

**Parameter**

<mode>	Logic for Data signals
POSitive	Positive logic (Default)
NEGative	Negative logic

**Programming Example**

To set the polarity for Data signals to positive logic.

```
INP:BERT:DATA:POL POS
INP:BERT:DATA:POL?
> POS
```

## Enable Active

 or Top >  Auxiliary, > BER >  Resync Condition > BER Interface > Enable Active

Sets the logic for Enable signals of the BER measurement.

Press **F3 Enable Active** on the BER Interface function menu to select a value on the Enable Active function menu.

Disable	Does not use Enable signals(Default).
High	Measures the signals when High input.
Low	Measures the signals when Low input.

## Remote command

### Set the logic for Enable signals of the BER measurement Command

```
:INPut:BERT[:BASEband]:CGATe:POLarity
POSitive|NEGative|DISable
```

### Query

```
:INPut:BERT[:BASEband]:CGATe:POLarity?
```

### Response

```
<mode> POS, NEG, or DIS
```

### Parameter

<mode>	Logic for Enable signals
DISable	Does not use Enable signals (Default).
POSitive	Measures the signals when High input.
NEGative	Measures the signals when Low input.

### Programming Example

To perform measurement when Enable signals are High input.

```
INP:BERT:CGAT:POL POS
INP:BERT:CGAT:POL?
> POS
```



## 8.4 PN Fix Pattern

For the BER measurement, you can use special PN patterns known as PN\_Fix patterns.

The PN\_Fix pattern is a pattern consisting of repeated parts of PN patterns and PN patterns with length shorter than 1 cycle.




Figure 8.4-1 PN\_Fix Pattern

### 8.4.1 Setting PN\_Fix Pattern: PN Fix Pattern

 or Top >  > Auxiliary, > BER > PN Fix Pattern

Sets a PN\_Fix pattern.

A PN\_Fix pattern can be set when PN9Fix, PN11Fix, PN15Fix, PN20Fix, or PN23Fix is selected for Data Type.

Press **F7 PN Fix Pattern** on the BER function menu to display the PN Fix Pattern function menu and set a PN Fix pattern.

**Table 8.4.1-1 PN Fix Pattern Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Initial 1FF	Specifies an initial value of PN Pattern for PN Fix.
	F2	Length 96 Bits	Specifies a length of 1 cycle in bit unit for PN Fix.

#### Initial Pattern

 or Top >  > Auxiliary, > BER > PN Fix Pattern > Initial Pattern

Sets an initial pattern of PN\_Fix patterns.

Press **F1 Initial Pattern** on the PN Fix Pattern function menu to set an initial pattern of PN\_Fix patterns in the **Initial Pattern** dialog box.

**Table 8.4.1-2 Initial Pattern Setting Value**

Data Type	Initial Pattern Setting Range		Resolution	Default
	Binary	Hex		
PN9Fix	00000000 to 11111111 (9 bits)	000 to 1FF	1	1FF
PN11Fix	0000000000 to 1111111111 (11 bits)	000 to 7FF	1	7FF
PN15Fix	00000000000000 to 11111111111111 (15 bits)	0000 to 7FFF	1	7FFF
PN20Fix	000000000000000000 to 111111111111111111 (20 bits)	00000 to FFFFF	1	FFFFF
PN23Fix	00000000000000000000 to 11111111111111111111 (23 bits)	000000 to 7FFFFFF	1	7FFFFFF

<Cautions for setting PN\_Fix>

When you set all initial values of PN\_Fix pattern to 0, the following signals are output:

- PN9Fix, PN11Fix, or PN20Fix: ALL0 signals
- PN15Fix or PN23Fix: ALL1 signals

**Remote command****Set an initial pattern of PN\_Fix patterns****Command**

```
[ :SENSe] :BERT[:BASEband] :PRBS:PNFix:INITial <binary>
```

**Query**

```
[ :SENSe] :BERT[:BASEband] :PRBS:PNFix:INITial?
```

**Response**

```
<binary>
```

**Parameter**

```
<binary>
```

Based on Table 8.4.1-2 “Initial Pattern Setting Value”.

**Details**

You can set patterns using this function only when PN Fix pattern is selected for Data Type.

Add the character string “#B”, which indicates binary, before the parameter.

**Programming Example**

To set an initial value of PN9 Fix to “101010101”.

```
BERT:PRBS:PNF:INIT #B101010101
```

```
BERT:PRBS:PNF:INIT?
```

```
> 101010101
```

**Pattern length: Length**

or Top > → >Auxiliary, >BER>PN Fix Pattern>Length

Sets a length of PN\_Fix patterns.

Press **F2 Length** on the PN Fix Pattern function menu to set a length of PN\_Fix patterns in the **Length** dialog box.

**Table 8.4.1-3 Setting Range**

Setting range	96 bits to 134217728 bits (0x8000000)
Resolution	1 bit
Default	96 bit

**Remote command**

**Set a length of PN\_Fix patterns**

**Command**

```
[ :SENSe ] :BERT [ :BASEband ] :PRBS :PNFix :LENGth <ext_integer>
```

**Query**

```
[ :SENSe ] :BERT [ :BASEband ] :PRBS :PNFix :LENGth?
```

**Response**

```
<ext_integer>
```

**Parameter**

```
<ext_integer>
```

Based on Table 8.4.1-3 “Setting Range”.

**Details**

You can set patterns using this function only when PN Fix pattern is selected for Data Type.

**Programming Example**

To set a bit length of PN Fix patterns to 1024 bits.

```
BERT : PRBS : PNF : LENG 1024
```

```
BERT : PRBS : PNF : LENG?
```

```
> 1024
```

## 8.4.2 Synchronization establishing conditions of PN\_Fix patterns

This section describes synchronization establishing conditions of PN\_Fix patterns.

Assumptions:

x: PN order(If PN9, x = 9)

Synchronization is established in 3 phases:

1. Establish synchronization with PN patterns by detecting  $(x \times 2)$  bit error free.
2. Detect the last bit of PN<sub>x</sub>Fix pattern from the initial bit pattern length of the specified PN pattern.
3. Establish synchronization with PN\_Fix pattern overall by detecting x bit error free from the start PN\_Fix pattern.

For example, synchronization establishing of PN9Fix pattern is as follows:




Figure 8.4.2-1 Example: Synchronization Establishing of PN9Fix Pattern


### 8.4.3 Examples of using PN\_Fix patterns

This section describes examples of how to use PN\_Fix patterns.

Imagine that a communication system has a frame format shown in Figure 8.4.3-1, in which the fixed bit A is 10 bits and the communication channel B is 1000 bits.

When the communication channel uses PN9, the number of bits per frame (1000 bits) does not match with the cycle of PN9 (511 bits). Therefore, the cycle must be 511 frames to keep continuity of PN 9 signals of the communication channel.

However, on a signal generator using a waveform generator like the MG3710A/MG3740A, increasing frames and samples of waveform patterns may decrease patterns stored in the waveform memory, or may cause over capacity of waveform memory.




**Figure 8.4.3-1 Example: PN9Fix Patterns**

In such a case, to perform the BER measurement for PN9 signals that discontinues in the frame shown in Figure 8.4.3-1, use short-cycle signals, for example, 2-frame cycles generated by IQproducer™ shown in Figure 8.4.3-2, and select PN Fix pattern for Data Type.

Refer to an operation manual of each IQproducer™ for how to set PN\_Fix signals on IQproducer™.

When PN\_Fix signals are used for measurement, pseudorandom signals lose some of their randomness.




**Figure 8.4.3-2 BER Measurement with PN\_Fix Data**



## 8.5 User Defined Pattern

The BER measurement can use a pattern created by a user, which is called a user defined pattern.

A user defined pattern is an arbitrary binary string that is 8 to 1024 bit length and that consists of a data bit string to determine if synchronization is established and a data bit string used as measurement data. Refer to 8.5.2 “Setting user defined patterns: User Pattern” for how to specify bits to determine if synchronization is established.



**Figure 8.5-1 User Defined Pattern**

You can create user defined patterns in text file formats using PCs. Load the file from USB memories or internal hard disks of the MG3710A/MG3740A. Following the explanation below, create a file and specify “.bpn” as an extension.

Table 8.5-1 lists items that can be included in user defined patterns.

**Table 8.5-1 Items to Be Included in User Defined Patterns**

Character		Description
0, 1	Single-byte number	Loaded as bit data. Characters, including numbers, spaces, and CR/LF must be continuous.
Space	Single-byte space	Used for improving readability when editing bit data.
New line	CR/LF	Used for improving readability when editing bit data.
#	Single-byte #	Indicates comments.

For example, a file can have following content:

Example 1:

```
#20070216 Marked by Anritsu Co.
0010 0111 0110 0011 0000 1111 0101
```

Example 2:

```
#UserPattern Start  
0000 0000 1111 1111  
#mark001  
0101 0101  
#mark002  
1111 1111 0000 0000
```

### 8.5.1 Displaying user defined patterns

**AUX Fctn** or **Top** → **Auxiliary**, **>BER>User Pattern**

To use user defined patterns, press **F6 Data Type** on the BERTEST function menu and select **F6 User Defined** on page 2 of the BERDataType function menu.

When you press **F8 User Pattern**, loaded parameters of user defined patterns are displayed in the **BERT User Defined Pattern** dialog box on the main screen. When no user defined pattern is loaded, “- -” is displayed.




Figure 8.5.1-1 BERT User Defined Pattern Dialog Box

1. Pattern File Name  
Indicates a loaded User Pattern name.
2. Pattern Length  
Indicates a loaded User Pattern length (number of bits).
3. Sync Position Start  
Indicates a bit at which synchronizing User Patterns starts.  
Refer to 8.5.2 “Setting user defined patterns: User Pattern”.
4. Sync Position Length  
Indicates a length (number of bits) at which matching is performed for synchronizing User Pattern.  
Refer to 8.5.2 “Setting user defined patterns: User Pattern”.
5. User Defined Pattern  
Displays content of loaded User Pattern in hexadecimal formats.

## Pattern File Name

Displays a loaded user defined pattern name of the BER measurement.

### Remote command

**Query a loaded user defined pattern name of the BER measurement**

#### Query

```
[ :SENSe ] :BERT [ :BASEband ] :PRBS :USER :PATTern?
```

#### Response

```
<pattern>,<drive>
```

#### Details

If there is no user defined pattern file, the command returns \*\*\*.

#### Parameter

<pattern>

User defined pattern file name  
Character string within 100 characters,  
excluding an extension (bpn)

<drive>

Drive name where the user defined pattern file  
is loaded

#### Programming Example

To query a user defined pattern name.

```
BERT :PRBS :USER :PATT?
```

```
> TEST1,D
```

Response when a corresponding pattern does not exist:

```
> ***
```

## Pattern Length

Displays a pattern length of a user defined pattern for the BER measurement.

### Remote command

**Query a pattern length of a user defined pattern for the BER measurement**

#### Query

```
[ :SENSe ] :BERT [ :BASEband ] :PRBS :USER :LENGth?
```

#### Response

```
<integer>
```

#### Parameter

<integer>

Pattern length of the user defined pattern  
Range  
8 to 1024 bits

**Programming Example**

To query the pattern length of the user defined pattern.

```
BERT:PRBS:USER:LENG?  
> 1024
```

**Bit string of user defined pattern: User Defined Pattern**

Displays a bit string of a user defined pattern for the BER measurement.

**Remote command****Query a bit string of a user defined pattern for the BER measurement****Query**

```
[ :SENSe ] :BERT [ :BASEband ] :PRBS:USER:BIT?
```

**Response**

```
<binary>
```

**Parameter**

```
<binary>
```

Bit string of the user defined pattern

Range

Pattern from 8 to 1024 bits

**Details**

If the language mode is MS269xA, the “#B” is not added at the start.

If there is no user defined pattern, the command returns #B\*\*\*.

**Note:**

1024 "0s" are inserted at \*\*\*.

**Programming Example**

To query the bit string of the user defined pattern.

```
BERT:PRBS:USER:BIT?  
> #B0010111101000101
```

### 8.5.2 Setting user defined patterns: User Pattern

 or Top >  > Auxiliary, > BER > User Pattern

Loads and sets user defined patterns.

Select **User Defined** on the Data Type function menu, and then press **F8 User Pattern**. The User Pattern function menu is displayed and you can set user defined patterns.


**Table 8.5.2-1 User Pattern Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Sync Start 1	Specifies the start bit to determine if synchronization of user defined patterns is established.
	F2	Sync Length 32	Specifies a length to determine if synchronization of user defined patterns is established.
	F7	Open	Loads user defined patterns. Refer to 8.5.3 "Loading user defined patterns: Open".

#### Setting synchronization establishing conditions of user defined patterns



Sets a synchronization establishing condition after loading a user defined pattern file.

Specify a start bit and a bit length to determine if synchronization is established. When error free is detected at the locations specified here, it is determined that synchronization is established.



**Figure 8.5.2-1 Specifying the Location to Determine if Synchronization Is Established**

## Setting the start bit: Sync Start

 or Top >  > Auxiliary, > BER > User Pattern > Sync Start

Sets the start bit of the part for judging the synchronization establishment.

Press **F1 Sync Start** on the User Pattern function menu to set a length to set the start bit of the part for judging the synchronization establishment in the Sync Start dialog box.

**Table 8.5.2-2 Setting Range**

Setting range	1 bit to (Pattern Length) bit
Resolution	1 bit
Default	1 bit

## Remote command

**Set the start bit to determine if synchronization is established****Command**

```
[ :SENSe ] :BERT [ :BASEband ] :PRBS :USER :SYNC :START
<ext_integer>
```

**Query**

```
[ :SENSe ] :BERT [ :BASEband ] :PRBS :USER :SYNC :START?
```

**Response**

```
<ext_integer>
```

**Parameter**

```
<ext_integer>
```

Based on Table 8.5.2-2 “Setting Range”.

**Details**

You can set the start bit using this function only when User Defined is selected for Data Type.

**Programming Example**

To set the 31st bit from the start of the user defined pattern as the start of the bit string to determine if synchronization is established.

```
BERT : PRBS : USER : SYNC : STAR 31
BERT : PRBS : USER : SYNC : STAR?
> 31
```

## Sync Length



or Top > Auxiliary, >BER>User Pattern>Sync Length

Sets a length to determine if synchronization is established.

Press **F2 Sync Length** on the User Pattern function menu to set a length to determine if synchronization is established in the **Sync Length** dialog box.

**Table 8.5.2-3 Setting Range**

Setting range	8 bits to 1024 bits
Resolution	1 bit
Default	32 bit

### Remote command

**Set a length to determine if synchronization is established**

#### Command

```
[ :SENSe] :BERT [ :BASEband] :PRBS:USER:SYNC:LENGth
<ext_integer>
```

#### Query

```
[ :SENSe] :BERT [ :BASEband] :PRBS:USER:SYNC:LENGth?
```

#### Response

```
<ext_integer>
```

#### Parameter

```
<ext_integer>
```

Based on Table 8.5.2-3 “Setting Range”.

#### Details

You can set the length using this function only when **User Defined** is selected for Data Type.


#### Programming Example

To specify 65 bit as a length of the user bit string to determine if synchronization is established.

```
BERT:PRBS:USER:SYNC:LENG 65
BERT:PRBS:USER:SYNC:LENG?
> 65
```



### 8.5.3 Loading user defined patterns: Open

 or Top>  >Auxiliary, >BER>User Pattern>Open

Loads user defined patterns for the BER measurement.

Place user defined pattern files directly below the specified USB memories or Hard Disk (internal hard disk) (Root) or  
[Device]:\Anritsu\MG3710A\User Data\BERT BitPattern\.

#### Remote command

#### Load a user defined pattern

##### Command

```
:MMEMory:LOAD:BERT:PATtern <string>[,<device>]
```

##### Parameter

<string>	File name excluding extension Character string within 100 characters enclosed by double quotes (") or single quotes ('') (excluding extension)
<device>	Number of the drive
Options	A to Z, currently selected drive when omitted

##### Details

Only a file with the extension “.bpn” can be loaded.

If a corresponding user defined pattern file does not exist, the command returns an error.

##### Programming Example

To load the user defined pattern file “USERPATTERN.bpn” from D drive.

```
MMEM:LOAD:BERT:PATT "USERPATTERN",D
```

#### Remote command

#### Load a list of user defined pattern files

##### Query

```
:MMEMory:LIST:BERT:PATtern? [<device>]
```

##### Response

```
<s1>,<s2>,<s3>.....,<s999>,<s1000>
```

##### Parameter

<device>	Number of the drive
Options	A to Z, currently selected drive when omitted
<s1>,<.....>,<s1000>	Existing user defined pattern file names (up to 1000) Within 100 characters

**Details**

If there is no user defined pattern file, the command returns \*\*\*.  
Files are listed alphabetically in a response message.

**Programming Example**

To load a list of user pattern files in C drive for the BER measurement.

```
MMEM:LIST:BERT:PATT?
> TEST1,TEST2,TEST3
```

**Operation method**


**Load a user defined pattern.**

1. Press **F7 Open** on the User Pattern function menu to display the User Pattern Open function menu, File List, and the **User Pattern Open** dialog box.

**Table 8.5.3-1 User Pattern Open Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Specifies a drive of the device containing user patterns to select.
	F7	Open	Loads user defined pattern files.
	F8	Cancel	Returns to the previous menu.

2. Press **F1 Device** to select a device containing the user defined pattern files to load.
3. Select user defined pattern files to load from File List and press **F7 Open**.



**Figure 8.5.3-1 User Pattern Open Dialog Box and File List**

When selecting files, only files with the extension “bpn” are displayed.

Place user defined pattern files in:

[Device]:\Anritsu\MG3710A\User Data\BERT BitPattern\  
File names are listed in alphanumeric order.

If no user defined pattern file exists, “File not found” is displayed.

If no user defined pattern file exists, the “No file to read” is displayed.

If the length of user defined patterns are out of available range, the following errors are displayed:

Less than 8 bits : “Bit pattern is too short.”


More than 1024 bits : “Bit pattern is too long.”

If user defined pattern files include characters other than “0”, “1”, or CR/LF, or comments starting with #, then “Illegal character exists.” is displayed.


## 8.6 BER Log

 or Top>  >Auxiliary, >BER>  >Show Log

Displays the past results of the BER measurement and saves them as files.

Press  to display page 2 of the BER function menu and press **F3 Show Log** to display BER Test Log. You can display up to 1000 logs. The BER Log function menu is displayed, too.

Logs are displayed in the following format:



	1	2	3	4	5	6	7
	Date	Status	Mode	Error Rate	Error Count	Bit Count	Sync Loss
1	2011/12/26 13:48:34	OK	Continuous #1	1.400E-002	14	1000	0
2	2011/12/26 13:48:34	OK	Continuous #2	1.400E-002	14	1000	0
3	2011/12/26 13:48:35	OK	Continuous #3	1.000E-002	10	1000	0
4	2011/12/26 13:48:35	OK	Continuous #4	1.000E-002	10	1000	0
5	2011/12/26 13:48:36	OK	Continuous #5	1.100E-002	11	1000	0
6	2011/12/26 13:48:36	OK	Continuous #6	1.200E-002	12	1000	0
7	2011/12/26 13:48:36	OK	Continuous #7	1.200E-002	12	1000	0
8	2011/12/26 13:48:37	OK	Continuous #8	1.000E-002	10	1000	0
9	2011/12/26 13:48:37	OK	Continuous #9	8.000E-003	8	1000	0
10	2011/12/26 13:48:37	OK	Continuous #10	8.000E-003	8	1000	0
11	2011/12/26 13:48:38	OK	Continuous #11	6.000E-003	6	1000	0
12	2011/12/26 13:48:38	OK	Continuous #12	4.000E-003	4	1000	0
13	2011/12/26 13:48:38	OK	Continuous #13	4.000E-003	4	1000	0
14	2011/12/26 13:48:39	OK	Continuous #14	5.000E-003	5	1000	0
15	2011/12/26 13:48:39	OK	Continuous #15	6.000E-003	6	1000	0

Figure 8.6-1 BER Test Log

Table 8.6-1 Display Items of BER Test Log

No.	Item	Description
1	Date	Indicates the time when the measurement ended.
2	Status	Indicates the reason why the measurement ended.
3	Mode	Indicates the mode when the measurement was performed (Continuous, Single, or Endless).
4	Error Rate	Indicates an error rate in index.
5	Error Count	Indicates the number of error bits.
6	Bit Count	Indicates the number of measurement bits.
7	Sync Loss	Indicates a SyncLoss count(only for Auto Resync On).

Table 8.6-2 End Reasons

Display	Description
OK	Indicates that the specified bits or error bits were exceeded and the test completed successfully.
STOP	Indicates that you pressed <b>F2 Stop BER Test</b> to stop the measurement or specified parameters and the measurement stopped.
OVERFLOW_ DATACOUNT	Indicates that the measurement bits exceeded the maximum value and the measurement stopped.
OVERFLOW_ SYNCLOSS	Indicates that the SyncLoss count exceeded the maximum value and the measurement stopped.
ABNORMAL_ COUNT	Indicates that a malfunction of the BER measurement circuit resulted in the measurement stop.
CLEAR	Indicates that you pressed <b>F3 Clear BER Count</b> to clear the measurement value. This does not mean the measurement stopped.

Remote commands for items in BER Test Log are as follows:

## BER Test Log

Queries logs of the BER measurement results.

### Remote command

#### Query logs of the BER measurement results

##### Query

```
[ :SENSe ] :BERT [ :BASEband ] :LOG? <ext_integer>
```

##### Response

```
<string>
```

##### Parameter

```
<ext_integer>
```

Log No.

```
Range
```

1 to log count

```
<string>
```

The Log Date, Time, Status, Measure mode, Error Rate, Error Count, Bit Count, and Sync Loss for the specified number are output according to Figure 8.6-1 BER Test Log.

#### Programming Example

To query log #11 of the BER measurement.

```
BERT:LOG? 11
```

```
> 2011/09/01 10:35:42,OK,Continuous,1.800E-002,18,1000,0
```

## BER Test Log Count

Queries a count of logs for the BER measurement results.

### Remote command

#### Query a count of logs for the BER measurement results Query

[ :SENSe ] :BERT [ :BASEband ] :LOG:COUNT?

#### Response

<integer>

#### Parameter

<integer>                      Count of logs for the measurement results

Range                              0 to 1000

#### Details

This function is available only for remote commands.

#### Programming Example

To query a count of logs for the BER measurement results.




BERT:LOG:COUN?

> 1000

**Table 8.6-3 BER Log Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Clear	Deletes logs stored in the memory. Turning the power of the MG3710A/MG3740A off also deletes logs. Refer to 8.6.1 "Deleting BER logs: Clear".
	F8	Save	Saves BER Test Log as a file in the text format. Refer to 8.6.2 "Saving BER logs: Save".

### 8.6.1 Deleting BER logs: Clear

 or Top >  Auxiliary, > BER >  Show Log > Clear

Deletes logs of the BER measurement.

Press **F1 Clear** on the BER Log function menu to delete logs stored in the memory. Turning the power of the MG3710A/MG3740A off also deletes logs.

#### Remote command

**Delete logs of the BER measurement**

#### Command




```
[ :SENSe ] :BERT [ :BASEband ] :LOG:CLEAr
```

#### Programming Example

To delete logs stored in the memory.

```
BERT:LOG:CLE
```

### 8.6.2 Saving BER logs: Save

 or Top >  > Auxiliary, > BER >  > Show Log > Save

Saves logs of the BER measurement as a text file.

The latest 1000 logs are kept. Logs are not stored in HDD unless SaveLog is performed. Therefore, turning the power off deletes the data.

#### Remote command

#### Save logs of the BER measurement as a text file

##### Command

:MMEMory:STORe:BERT:LOG [<string>[,<device>]]

##### Parameter

<string>

File name excluding extension

Character string within 100 characters enclosed by double quotes (" ") or single quotes (' ') (excluding extension)

The following characters cannot be used:

\ / : \* ? " ' \ ' < > |

Automatically named as

"Bert\_[Date]\_[Additional number].log" when omitted.

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

<device>

Number of the drive

Options

A to Z, currently selected drive when omitted

##### Details

A space or dot "." at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

A destination path to save the file is the following directory in the specified drive.

Anritsu\MG3710A\User Data\BERT Log\

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

##### Programming Example

To name a BER Log file as "BER123" and saves it in D drive.

MMEM:STOR:BERT:LOG "BER123",D



## Operation method

**Example: To name a log file of the measurement results as “ABC” and save it**

1. Press **F8 Save** on the BER Log function menu to display the BER log Save function menu, File List in the function information frame, and the **BER Log Save** dialog box in the active function frame.

Table 8.6.2-1 BER Log Save Function Menu

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Specifies a drive of the device to save BER Test Log.
	F4	Change Focus	Moves the cursor between dialog box and file list.
	F5	Delete	Deletes BER Test Log files.
	F7	Save	Saves BER Test Log as a file.
	F8	Cancel	Returns to the previous menu.

2. Press **F1 Drive** to select a destination drive for the file.
3. In the **BER Log Save** dialog box, enter “ABC” as a name of BER Log file and press **F7 Save** to save the log.




Figure 8.6.2-1 BER Log Save Dialog Box and File List

**Note:**

When you input a file name, an extension is automatically added. You cannot specify an extension.

The maximum 100 characters are allowed for a file name.

Destination path: Anritsu\MG3710A\UserData\BERT Log\

Default destination name: Bert\_[Date]\_[Additional number].csv

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

Characters available for file names are displayed on the character pallet.

The following characters cannot be used:

\ / : \* ? " ' < > |

A space or dot “.” at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

Deleting BER log files: Delete

 or Top>  >Auxiliary, >BER>  >Show Log>Save>Delete

Deletes BER Log files.

Remote command

Delete BER Log files

Command

:MMEMory:DELeTe:BERT:LOG <string>[,<device>]

Parameter

<string>

File name excluding extension

Character string within 100 characters enclosed by double quotes ( " ") or single quotes ( ' ) (excluding extension)

<device>

Number of the drive

Options

A to Z, currently selected drive when omitted

Programming Example

To delete the BER Log file “BER123” from D drive.

MMEM:DEL:BERT:LOG "BER123",D

Operation method

Example: To select and delete BER Log files

1. Press **F8 Save** on the BER Log function menu to display the BER log Save function menu, File List in the function information frame, and the **BER Log Save** dialog box in the active function frame.
2. Press **F1 Drive** to select a destination drive for the file.
3. Select the BER Log files to delete from File List. When you press **F5 Delete**, the Confirmation function menu is displayed for your confirmation.

Table 8.6.2-2 Confirmation Function Menu

Page	Key No.	Menu Display	Function
1	F7	Confirm Deletion	Deletes files.
	F8	Cancel	Returns to the previous menu.

4. Press **F7 Confirm Deletion** to delete files.

## 8.7 About BER Measurement Operations

This section describes the BER measurement operations from synchronization to finishing.

### **Auto Resync Off:**

Overview of the measurement operations when Auto Resync is set to Off is as follows: In this mode, an error rate is checked immediately after synchronization to determine if the synchronization failed. If the error rate immediately after the synchronization is 30% or more, it is determined that the synchronization failed. Resynchronization is performed.




Figure 8.7-1 Auto Resync Off

- \*1: If the number of measurement bits is less than 1000 bits and the measurement finishes, an error rate is not checked. The measurement result, therefore, may not be correct.
- \*2: If the error rate is 30% or more and the number of measurement bits is 1000 or more, it is determined that synchronization failed.
- \*3: The measurement finishes when one of the following conditions is met:
  - The number of measurement bits or measurement error bits reaches the specified number of bits.
  - The number of measurement bits exceeds the maximum value.
  - The SyncLoss count exceeds the maximum value.

### **Auto Resync On:**

Overview of the measurement operations when Auto Resync is set to On is as follows: In this mode, when a SyncLoss occurs, resynchronization is automatically performed.




Figure 8.7-2 Auto Resync On

- \*1: To check SyncLoss conditions, bits specified with the denominator of SyncLoss Threshold must be received. Therefore, it may take time to start counting after synchronization is established.
- \*2: When a SyncLoss occurs, the operation specified with at SyncLoss is performed.
- \*3: The measurement finishes when one of the following conditions is met:
  - The number of measurement bits or measurement error bits reaches the specified number of bits.
  - The number of measurement bits exceeds the maximum value.
  - The SyncLoss count exceeds the maximum value.





## Chapter 9 Other Functions

---



This chapter describes other functions such as Auxiliary, Utility, and panel key functions.

Note on remote command:

When the language mode is SCPI, the target SG can be selected with the beginning node of commands for controlling individual functions. Refer to Appendix E.7.6 “Selecting SG1/2” for details.

9.1	Auxiliary Function .....	9-2
9.2	Power Meter.....	9-3
9.2.1	Power Meter setting: Channel A/B Setup .....	9-8
9.2.2	Setting connection to power meters : Connection Settings .....	9-10
9.2.3	Power Meter setting: Channel Settings .....	9-13
9.3	Alarm History .....	9-20
9.3.1	Saving Alarm History: Save.....	9-21
9.4	Utility Function .....	9-24
9.4.1	Interface Settings.....	9-25
9.4.2	System Settings.....	9-29
9.4.3	Instrument Info.....	9-31
9.4.4	Install .....	9-43
9.4.5	Displaying Error Information: Error Info .....	9-48
9.4.6	Changing Boot Loader Service .....	9-51
9.5	Panel Keys.....	9-52
9.5.1	Preset .....	9-52
9.5.2	Switching Remote/Local: Local .....	9-55
9.5.3	Saving parameter file: Save .....	9-56
9.5.4	Recalling Parameter File: Recall .....	9-67
9.5.5	Screen copy: Copy .....	9-70
9.5.6	Functions specific to remote commands .....	9-75
9.5.7	Calibration .....	9-77
9.6	Touch Panel.....	9-78
9.7	Setting Windows .....	9-79
9.7.1	Displaying Windows desktop.....	9-80
9.7.2	Setting control panel.....	9-81
9.7.3	Using external display .....	9-89
9.7.4	General notes .....	9-91
9.7.5	Storage device configuration .....	9-92
9.7.6	System Recovery Functions.....	9-93

## 9.1 Auxiliary Function

 or **Top** >  > **Auxiliary**

Press **Aux Fctn** on the main function key or **F5 Auxiliary** on page 2 of the top function menu to display the Auxiliary function menu. On this menu, you can set Power Meter, the BER measurement, and Alarm History.

This section describes the Auxiliary function menu.

**Table 9.1-1 Auxiliary Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Power Meter	Sets Power Meter. Refer to 9.2 "Power Meter"
	F2	BER	Performs the BER measurement. Refer to Chapter 8 "BER Measurement".
	F4	Alarm History	Saves Alarm History. Refer to 9.3 "Alarm History".

## 9.2 Power Meter

 or **Top**  **>Auxiliary, >Power Meter**

You can connect two USB power sensors to the MG3710A/MG3740A, simultaneously control them, and show their measurement values individually.

The two power sensor measurements are displayed at Ch. A and Ch. B of the power meter.

Press **F1 Power Meter** on the Auxiliary function menu to display the **Power Meter Measurements** dialog box and the Power Meter function menu.




Figure 9.2-1 Power Meter Measurements Dialog Box

Table 9.2-1 Power Meter Measurements Dialog Box

No	Display	Description
1	COM	COM Port number
2	Model	Model name of power sensor
3	Connection	Connection status of the power sensor Off : The power sensor is Off. Connected : The power sensor is On and measurement is in progress. Disconnected : The power sensor is On and measurement is not in progress.(Not connected)
4	Measurement value	Indicates a measurement result in dBm or W
5	Frequency	Measurement frequency of the power sensor
6	Offset	Offset level value to be added to the power sensor reading
7	Average	Averaging count for the measurement values with the power sensor

## Measurement value

Indicates a measurement value of a power sensor. When a power sensor is on, this value is updated constantly. It includes a level offset.

### Remote command

#### Query the power sensor measurement display value

##### Query

`:SYSTEM:PMETER[1]|2:MEASUER?`

##### Response

`<power>`                      “-999.0” is returned when there is no value.

##### Parameter

`<power>`                      Level

Resolution                      0.01 dB when dBm, 1 nW when W

##### Details

As for node `:PMETER[1]|2`, select Ch. A or B of power meter. Set as follows:

Ch. A: `:PMETER1` or `:PMETER`

Ch. B: `:PMETER2`

##### Programming Example

To measure using the Ch. A power sensor and read the result.

```
SYST:PMET:MEAS?
```

```
> -10.00
```

---

## Connection

Displays the connection status of power sensor.	
Off	Power sensor is turned off. (Default)
Connected	Power sensor is turned on and measuring
Disconnected	Power sensor is turned on but not measuring. (Disconnected)

**Remote command****Querying the power sensor connection status****Query**

```
:SYSTem:PMETer[1]|2:CONNECTION?
```

**Response**

```
<connect>
```

**Parameter**

<connect>	Connection
CONN	Connected
DISC	Disconnected, or OFF

**Details**

As for node :PMETer[1]|2, select Ch. A or B of power meter. Set as follows:

```
Ch. A: :PMETer1 or :PMETer
```

```
Ch. B: :PMETer2
```

**Programming Example**

To query the connection status of the Ch. A power sensor.

```
SYST:PMET:CONN?
```

```
> CONN
```

Information about the connection and measurement results are displayed in the resident frame below the function display frame.




Figure 9.2-2 Power Meter in Resident Frame

Table 9.2-2 Power Meter in Resident Frame

No	Display	Description
1	A :	Connection status or a measurement value of Ch. A
2	B :	Connection status or a measurement value of Ch. B

Table 9.2-3 Power Meter Function Menu

Page	Key No.	Menu Display	Function
1	F1	Channel A Off On	Enables/disables measurement performed by the Ch. A power sensor.
	F2	Channel A Setup	Channel Setup Refer to 9.2.1 “Power Meter setting: Channel A/B Setup”.
	F3	Channel B Off On	Enables/disables measurement performed by the Ch. B power sensor.
	F4	Channel B Setup	Channel Setup Refer to 9.2.1 “Power Meter setting: Channel A/B Setup”.

Ch A/B power sensor On/Off: Channel A/B

**AUX Fctn** or **Top** > **→** > **Auxiliary**, > **Power Meter** > **Channel A or Channel B**

Enables/disables measurement performed by Ch. A or Ch. B power sensor.

Press **F1 Channel A** or **F3 Channel B** to set On/Off.



On Measures.

Off Does not measure (Default).

---

<b>Remote command</b>	<b>Enable/disable measurement performed by Channel A or Channel B power sensor</b>
	<b>Command</b>
	<code>:SYSTem:PMETer[1] 2[:STATe] &lt;boolean&gt;</code>
	<b>Query</b>
	<code>:SYSTem:PMETer[1] 2[:STATe]?</code>
	<b>Response</b>
	<code>&lt;boolean&gt;</code> 0 or 1
	<b>Parameter</b>
	<code>&lt;boolean&gt;</code> Measurement On/Off
	ON 1                            Measures.
	OFF 0                          Does not measure (Default).
	<b>Details</b>
	As for node <code>:PMETer[1] 2</code> , select Ch. A or B of power meter. Set as follows:
	Ch. A: <code>:PMETer1</code> or <code>:PMETer</code>
	Ch. B: <code>:PMETer2</code>
	<b>Programming Example</b>
	To enable measurement performed by Channel B.
	<code>SYST:PMET2 ON</code>
	<code>SYST:PMET2?</code>
	<code>&gt; 1</code>

## 9.2.1 Power Meter setting : Channel A/B Setup

 or Top >  > Auxiliary, > Power Meter > Channel A Setup or Channel B Setup

Press **F2 Channel A Set up** or **F4 Channel B Setup** on the Power Meter function menu to display the Ch A/B Setup function menu. Ch. A and Ch. B can be set individually.

**Table 9.2.1-1 Ch A/B Setup Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Connection Settings	Displays the PMC Connection function menu where you can set connection of power meters. Refer to 9.2.2 "Setting connection to power meters : Connection Settings".
	F2	Channel Settings	Displays the Channel Settings function menu where you can set measurement. Refer to 9.2.3 "Power Meter setting: Channel Settings".
	F4	Zero Sensor	Zeros the levels of power sensors.

### Zero adjustment: Zero Sensor

 or Top >  > Auxiliary, > Power Meter > Channel A Setup or Channel B Setup, > Zero Sensor

Execute the zero adjustment for the power sensor.

Press **F4 Zero Sensor** on the Ch A/B Setup function menu to execute the zero adjustment for the power sensor. Channel A Zero Sensor can be executed when Channel A is **On**, and Channel B Zero Sensor can be executed when Channel B is **On**.

"Executing \*\*%" is displayed during the adjustment, and keys other than the power key are disabled.

#### Remote command

#### Execute the zero adjustment

##### Command

:SYSTem:PMETer[1]|2:ZERoset

##### Details

As for node :PMETer[1]|2, select Ch. A or B of power meter. Set as follows:

Ch. A: :PMETer1 or :PMETer

Ch. B: :PMETer2

##### Programming Example

To execute the zero adjustment for the Ch. A power sensor.

SYST:PMET:ZER



**Operation method**

Example: To execute the zero adjustment for the power sensor.

1. Connect the USB terminal of the power sensor to the USB terminal of the MG3710A/MG3740A.
2. Enter the information of the connected power sensor with Com Port number and Model to the MG3710A/MG3740A.
3. Turn “On” Channel A or Channel B to be used.
4. Connect the RF Input terminal of the power sensor to the RF output connector of the MG3710A/MG3740A.



**CAUTION**

---

**The power sensor may be damaged depending on the output level of the MG3710A/MG3740A. Beware not to apply excessive input when the terminal is connected.**

---

5. Perform ZeroSensor.  
While the Zero adjustment is in progress, the RF Output of the MG3710A/MG3740A is automatically set to Off.

## 9.2.2 Setting connection to power meters : Connection Settings

 or **Top**  **>Auxiliary, >Power Meter>Channel A Setup or Channel B Setup, >Connection Settings**



Sets the connection to power meters.

Press **F1 Connection Settings** on the Ch A/B Setup function menu to display the Ch A/B Connection function menu.

**Table 9.2.2-1 Ch A/B Connection Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Com Port 2	Sets the COM Port number allocated to the power sensor.
	F2	Model MA24106A	Displays the Model function menu for selection of the model name of the power sensor to be used.
	F3	Open Device Manager	Displays Windows Device Manager. This is used for checking the COM port number of connected power sensor.

### COM Port setting: COM Port

 or **Top**  **>Auxiliary, >Power Meter>Channel A Setup or Channel B Setup, >Connection Settings>COM Port**

Sets the COM Port number of the power sensor.

Press **F1 COM Port** to display the **COM Port** dialog box in the active function frame. Enter numbers and press **F1 Enter** to set the COM Port number.

Setting range            2 to 8  
Resolution                1  
Default                     2



**Figure 9.2.2-1 COM Port Dialog Box**

#### Remote command

#### Set the COM Port number

##### Command

:SYSTem:PMETer[1]|2:COMMunicate:USB:PORT <ext\_integer>

##### Query

:SYSTem:PMETer[1]|2:COMMunicate:USB:PORT?

##### Response

<ext\_integer>

**Parameter**

<ext_integer>	COM Port number
Setting range	2 to 8
Resolution	1
Default	2

**Details**

As for node :PMETer[1] |2, select Ch. A or B of power meter. Set as follows:

Ch. A: :PMETer1 or :PMETer

Ch. B: :PMETer2

**Programming Example**



To set the COM Port number of Ch. A to 8.

```
SYST:PMET:COMM:USB:PORT 8
```

```
SYST:PMET:COMM:USB:PORT?
```

```
> 8
```

Model setting: Model

 or Top >  > Auxiliary, > Power Meter > Channel A Setup or Channel B Setup, > Connection Settings > Model

Selects the model name of the power sensor.

Press **F2 Model** to display the Model function menu, and press the function key of the power sensor to be used to set the model.

**Table 9.2.2-2 Sensor Model Function Menu**

Page	Key No.	Menu Display	Function
1	F1	MA24104A	600 MHz to 4 GHz
	F2	MA24105A	350 MHz to 4 GHz
	F3	MA24106A	50 MHz to 6 GHz (Default)
	F4	MA24108A	10 MHz to 8 GHz
	F5	MA24118A	10 MHz to 18 GHz
	F6	MA24126A	10 MHz to 26 GHz

**Notes:**

If Windows Device Manager does not display the available USB power sensor, the older version of PowerXpert software may be the cause.

Download and install the latest PowerXpert software from Anritsu website.

Use PowerXpert Ver. 2.11 or later for MA24105A, use PowerXpert Ver. 2.00 or later for other power sensor.

**Remote command**

**Select the model name for the power sensor**

**Command**

```
:SYSTem:PMETer[1]|2:SENSe:MODe1  
MA24104A|MA24105A|MA24106A|MA24108A|MA24118A|MA24126A
```

**Query**

```
:SYSTem:PMETer[1]|2:SENSe:MODe1?
```

**Response**

```
<model>
```

**Parameter**

<model>	Model name of power sensor
Options	MA24104A, MA24105A, MA24106A (Default), MA24108A, MA24118A, MA24126A

**Details**

As for node :PMETer[1]|2, select Ch. A or B of power meter. Set as follows:

```
Ch. A: :PMETer1 or :PMETer  
Ch. B: :PMETer2
```

**Programming Example**

To select the MA24118A for the power sensor.

```
SYST:PMET:SENS:MOD MA24118A  
SYST:PMET:SENS:MOD?  
> MA24118A
```

### 9.2.3 Power Meter setting: Channel Settings

 or Top >  > Auxiliary, > Power Meter > Channel A Setup or Channel B Setup, > Channel Settings

Performs the measurement-related settings.

Press **F2 Channel Settings** on the Ch A/B Setup function menu to display the Ch A/B Settings function menu.

**Table 9.2.3-1 Ch A/B Setup Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Channel Freq 1.000000000 GHz	Sets a measurement frequency for the power sensor.
	F2	Channel Offset <u>Off</u> On	Enables/disables adding level offset to the value measured by the power sensor.
	F3	Channel Offset Value 0.00 dB	Sets the offset level value to be added to the power sensor reading.
	F4	Averaging <u>Off</u> On	Enables/disables the averaging for the measurement value with the power sensor.
	F5	Averaging Count Value 1024	Sets the averaging count for the measurement values with the power sensor.
	F6	Measurement Units <u>dBm</u> W	Sets a unit to be used for displaying the value measured by the power sensor.

Channel Freq

 or **Top**  **>Auxiliary, >Power Meter>Channel A Setup or Channel B Setup, >Channel Settings>Channel Freq**

Sets a measurement frequency for the power sensor.

Press **F1 Channel Freq** on the Ch A/B Settings function menu to display the **Channel Freq** dialog box. Enter the numbers and press the unit key of the Unit function menu to set the offset level value.

**Table 9.2.3-2 Power Sensor Setting Range**

Power Sensor	Minimum Value	Maximum Value	Resolution	Default
MA24104A	600 MHz	4 GHz	1 kHz	1 GHz
MA24105A	350 MHz	4 GHz	100 kHz	1 GHz
MA24106A	50 MHz	6 GHz	1 kHz	1 GHz
MA24108A	10 MHz	8 GHz	100 kHz	1 GHz
MA24118A	10 MHz	18 GHz	100 kHz	1 GHz
MA24126A	10 MHz	26 GHz	100 kHz	1 GHz

**Remote command**

**Set a measurement frequency for the power sensor**

**Command**

`:SYSTEM:PMETER[1|2]:SENSE:FREQUENCY[:CW|:FIXED] <freq>`

**Query**

`:SYSTEM:PMETER[1|2]:SENSE:FREQUENCY[:CW|:FIXED]?`

**Response**

`<freq>` Unit: Hz

**Parameter**

`<freq>` Frequency  
 Range Refer to Table 9.2.3-2 Power Sensor Setting  
 Range  
 Resolution

MA24104A, MA24106A	1 kHz
MA24105A	100 kHz
MA24108A, MA24118, MA24126	100 kHz

Default 1 GHz  
 Suffix code HZ, KHZ, KZ, MHZ, MZ, GHZ, GZ  
 When omitted Hz

**Details**

As for node :PMETer[1]|2, select Ch. A or B of power meter. Set as follows:

Ch. A: :PMETer1 or :PMETer

Ch. B: :PMETer2

**Programming Example**

To set a measurement frequency of Ch. B to 800 MHz.

```
SYST:PMET2:SENS:FREQ 800000000
```

```
SYST:PMET2:SENS:FREQ?
```

```
> 800 000 000
```

**Level Offset: Channel Offset**

 or **Top**  **>Auxiliary, >Power Meter>Channel A Setup or Channel B Setup, >Channel Settings>Channel Offset**

Enables/disables adding level offset to the value measured by the power sensor.

Press **F2 Channel Offset** on the Ch A/B Settings function menu to set it.

Off Does not add level offset (Default).

On Adds level offset.

**Remote command****Enable/disable the level offset for the power sensor****Command**

```
:SYSTem:PMETer[1]|2:SENSe:CORRection:GAIN2:STATE  
<boolean>
```

**Query**

```
:SYSTem:PMETer[1]|2:SENSe:CORRection:GAIN2:STATE?
```

**Response**

```
<boolean> 0 or 1
```

**Parameter**

```
<boolean> Level offset On/Off
```

```
OFF|0 Off (Default)
```

```
ON|1 On
```

**Details**

As for node :PMETer[1]|2, select Ch. A or B of power meter. Set as follows:

Ch. A: :PMETer1 or :PMETer

Ch. B: :PMETer2

**Programming Example**

To set a level offset for the Ch. B power sensor to ON.

```

SYST:PMET2:SENS:CORR:GAIN2:STAT ON
SYST:PMET2:SENS:CORR:GAIN2:STAT?
> 1
    
```

**Channel Offset Value**

 or **Top**  **>Auxiliary, >Power Meter>Channel A Setup or Channel B Setup, >Channel Settings>Channel Offset Value**

Sets the offset level value to be added to the power sensor reading.

Press **F3 Channel Offset Value** on the Ch A/B Settings function menu to display the **Channel Offset Value** dialog box. Enter the numbers and press the unit key of the Unit function menu to set the offset level value.

Setting range	-100 dB to 100 dB
Resolution	0.01 dB
Default	0.00 dB

**Remote command**

**Set an offset level for the power sensor**

**Command**

```

:SYSTem:PMETer[1]|2:SENSe:CORRection:GAIN2[:INPut][:MAGN
itude] <rel_ampl>
    
```

**Query**

```

:SYSTem:PMETer[1]|2:SENSe:CORRection:GAIN2[:INPut][:MAGN
itude]?
    
```

**Response**

```

<rel_ampl> Unit: dB
    
```

**Parameter**

<rel_ampl>	Offset level
Setting range	-100 to +100 dB
Resolution	0.01 dB
Default	0.00 dB
Suffix code	DB, when omitted: DB

**Details**

As for node :PMETer[1]|2, select Ch. A or B of power meter. Set as follows:

```

Ch. A: :PMETer1 or :PMETer
Ch. B: :PMETer2
    
```



**Programming Example**

To set an offset level for the Ch. B power sensor to -15.00 dB.

```
SYST:PMET2:SENS:CORR:GAIN2 -15.00
SYST:PMET2:SENS:CORR:GAIN2?
> -15.00
```

**Averaging**

 or **Top** >  > **Auxiliary**, > **Power Meter** > **Channel A Setup** or **Channel B Setup**, > **Channel Settings** > **Averaging**

Enables/disables the averaging for the measurement value with the power sensor.

Press **F4 Averaging** on the Ch A/B Settings function menu to set it.

Off	Does not perform averaging. (Default)
On	Performs averaging.

**Remote command****Enable/disable averaging****Command**

```
:SYSTem:PMETer[1]|2:SENSe:AVERage[:STATe] <boolean>
```

**Query**

```
:SYSTem:PMETer[1]|2:SENSe:AVERage[:STATe]?
```

**Response**

```
<boolean> 0 or 1
```

**Parameter**

<boolean>	Averaging On/Off
OFF 0	Off (Default)
ON 1	On

**Details**

As for node :PMETer[1]|2, select Ch. A or B of power meter. Set as follows:

Ch. A: :PMETer1 or :PMETer

Ch. B: :PMETer2

**Programming Example**

To set Ch. B power meter averaging to ON.

```
SYST:PMET2:SENS:AVER ON
SYST:PMET2:SENS:AVER?
> 1
```

## Averaging Count Value

 or **Top**  **>Auxiliary, >Power Meter>Channel A Setup or Channel B Setup, >Channel Settings>Averaging Count Value**

Sets the averaging count for the measurement values with the power sensor.

Press **F5 Averaging Count Value** on the Ch A/B Settings function menu to display the **Averaging Count Value** dialog box. Enter the numbers and press **F1 Enter** to set the averaging count.

Setting range	1 to 2048
Resolution	1
Default	1024

### Remote command

#### Set the averaging count

##### Command

```
:SYSTem:PMETer[1]|2:SENSe:AVERAge:COUNT <ext_integer>
```

##### Query

```
:SYSTem:PMETer[1]|2:SENSe:AVERAge:COUNT?
```

##### Response

```
<ext_integer>
```

##### Parameter

<ext_integer>	The number of measurement points
Setting range	1 to 2048
Resolution	1
Default	1024

##### Details

As for node :PMETer[1]|2, select Ch. A or B of power meter. Set as follows:

Ch. A: :PMETer1 or :PMETer

Ch. B: :PMETer2

##### Programming Example

To set Ch. B power meter averaging to 1024 times.

```
SYST:PMET2:SENS:AVER:COUN 1024
```

```
SYST:PMET2:SENS:AVER:COUN?
```

```
> 1024
```

## Measurement Units

 or **Top**  **>Auxiliary, >Power Meter>Channel A Setup or Channel B Setup, >Channel Settings>Measurements Units**

Sets a unit to be used for displaying the value measured by the power sensor.

Press **F6 Measurement Units** on the Ch A/B Settings function menu to set it.

dBm	Displays in dBm (Default).
W	Displays in W.

### Remote command

#### Set the output level unit

##### Command

```
:SYSTem:PMETer[1]|2:UNIT:POWer DBM|W
```

##### Query

```
:SYSTem:PMETer[1]|2:UNIT:POWer?
```

##### Response

```
<unit>
```

##### Parameter

<unit>	Output level unit
DBM	dBm
W	W

##### Details

As for node :PMETer[1]|2, select Ch. A or B of power meter. Set as follows:

For Ch. A: :PMETer1 or :PMETer

For Ch. B: :PMETer2

#### Programming Example

To set a unit to be used for displaying the output level of the Ch. B power meter to dBm.

```
SYST:PMET2:UNIT:POW DBM
```

```
SYST:PMET2:UNIT:POW?
```


```
> DBM
```

## 9.3 Alarm History

 or **Top**  **>Auxiliary, >Alarm History**

The MG3710A/MG3740A can store occurred alarm histories up to 100 in files.

Press **F4 Alarm History** on the Auxiliary function menu to display the **Alarm History** dialog box and the Alarm History function menu.



Alarm History									
	Date	[7]RSVD	[6]RSVD	[5]RSVD	[4]RPP	[3]BB	[2]ALC	[1]RSVD	[0]REF
▶ 1	2011/11/22 19:45:56	OK	OK	OK	OK	NG	OK	OK	OK
2	2011/11/22 19:47:57	OK	OK	OK	OK	NG	OK	OK	NG
3	2011/11/22 19:53:38	OK	OK	OK	OK	NG	OK	OK	OK
4	2011/11/22 19:55:24	OK	OK	OK	OK	NG	OK	OK	NG
5	2011/12/22 10:32:27	OK	OK	OK	OK	NG	OK	OK	OK
6	2011/12/22 10:34:37	OK	OK	OK	OK	NG	OK	OK	NG

Figure 9.3-1 Alarm History Dialog Box

Table 9.3-1 Alarm History Display

Display	Description
Date	Alarm occurrence date, time
[7]RSVD	Not used
[6]RSVD	Not used
[5]RSVD	Not used
[4]RPP	RPP Alarm
[3]BB	Baseband Reference Clock PLL Alarm
[2]ALC	ALC Alarm
[1]RSVD	Not used
[0]REF	Reference Oscillator PLL Alarm
OK	Normal
NG	Alarm occurred.

For measures for Alarm, refer to 11.6 “Troubleshooting”.

Table 9.3-2 Alarm History Function Menu

Page	Key No.	Menu Display	Function
1	F8	Save	Displays the Save Alarm History function menu where you can set alarm histories to save. Refer to 9.3.1 “Saving Alarm History: Save”.

### 9.3.1 Saving Alarm History: Save

 or Top>  >Auxiliary, >Alarm History>Save:

When an error occurs during operation of the MG3710A/MG3740A, an alarm is displayed, describing details. The alarm is kept as Alarm History. Using this function, you can save histories of alarms.

#### Remote command

#### Save Alarm History in an alarm file

##### Command

```
:MMEMory[1] | 2:STORe:ALARm:LOG [<string>[, <device>]]
```

##### Parameter

<string>

File name excluding extension

Character string within 100 characters enclosed by double quotes (" ") or single quotes (' ') (excluding extension)

The following characters cannot be used:

```
\ / : * ? " " \ ' < > |
```

Automatically named as

“Alarm\_[Date]\_[Additional number].log” when omitted.

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

<device>

Number of the drive

Options

A to Z, currently selected drive when omitted

##### Details

A space or dot “.” at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

A destination path to save the file is the following directory in the specified drive.

```
Anritsu\MG3710A\User Data\Alarm History\
```

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

##### Programming Example

To name an alarm file as "TEST" and saves it in D drive.

```
MMEM:STOR:ALAR:LOG "TEST",D
```

**Operation method**

Example: To name the currently displayed file as "Alarm20110624\_000" and save it.

1. Press **F8 Save** on the Alarm History function menu to display the **Alarm Save** dialog box on the active function menu, the **File List** dialog box in the function display frame, and the Alarm Save function menu in the function menu frame.

**Table 9.3.1-1 Alarm Save Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Displays the Drive function menu and sets the destination Drive.
	F4	Change Focus	Moves the cursor between dialog box and file list.
	F7	Save	Saves the file to the Drive selected with <b>F1 Drive</b> .
	F8	Cancel	Returns to the previous menu.

2. Press **F1 Drive** to select the destination Drive.  
Options All connected Drives  
Default C
3. The File List dialog box of the device selected in Step 2 is displayed, and the files are displayed.



**Figure 9.3.1-1 Alarm Save Dialog Box**

4. Enter the file name to the text box in the active function frame.  
By default, the "Alarm[Date]\_Additional number" is displayed in the text box.
5. Enter "Alarm20110624\_0000" in the text box and press **F7 Save**. The file with the entered file name is saved, and the Alarm Save dialog box closes.

**Note:**

When you input a file name, an extension is automatically added.  
You cannot specify an extension.

The maximum 100 characters are allowed for a file name.

Destination path: Anritsu\MG3710A\User Data\Alarm History\

Default destination name: Alarm[Date]\_[Additional number].log

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

Characters available for file names are displayed on the character pallet.


The following characters cannot be used:

\ / : \* ? " ' < > |

A space or dot “.” at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

## 9.4 Utility Function

 or **Top** >  > **Utility**

When you press the **Utility** of the main function key, the MG3710A/MG3740A becomes the utility setting mode and displays the Utility function menu. On this menu, you can save or call parameters or set networks and other functions.

This section assumes that the MG3710A/MG3740A is in the utility setting mode, unless otherwise explained.

**Table 9.4-1 Utility Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Interface Settings	Sets the interface for remote control. Refer to 9.4.1 “Interface Settings”.
	F2	System Settings	Performs common settings in the system. Refer to 9.4.2 “System Setting”.
	F3	Instrument Info	Displays the status and factory shipment defaults of the MG3710A/MG3740A. Refer to 9.4.3. “Instrument Info”.
	F4	Install	Adds or deletes firmware, waveform licenses, and options. Refer to 9.4.4 “Install”.
	F5	Error Info	Displays the error information. Refer to 9.4.5 “Displaying Error Information: Error Info”.



### 9.4.1 Interface Settings

 or **Top**  **>Utility, >Interface Settings**



The MG3710A/MG3740A allows the remote control with GPIB, Ethernet, and USB. Press **F1 Interface Settings** on the Utility function menu to display the Interface Settings function menu. Set the interface for remote control.

For details, refer to Appendix E “Remote Control”.

**Table 9.4.1-1 Interface Setting Function Menu**

Page	Key No.	Menu Display	Function
1	F1	GPIB 3	Sets GPIB Address.
	F2	Terminator CR LF EOI	Sets a terminator (end code) for a response message of controller sending, which is sent by a measuring instrument via remote control.
	F3	Language SCPI	Selects a language mode during remote control.
	F4	Raw Socket Port Number 49158	Specifies a TCP/IP port number for transmitting the waveform data from IQproducer, which locates on an external PC, to the MG3710A/MG3740A.

GPIB address: GPIB

 or **Top**  **>Utility, >Interface Settings>GPIB**

Sets GPIB Address.

Press **F1 GPIB** on the Interface Settings function menu to display the **GPIB** dialog box on the active function frame. Enter numbers and press **Enter** to set it.

Setting range	1 to 30
Default	3
Resolution	1

#### Remote command

#### Set GPIB Address

##### Command

```
:SYSTem:COMMunicate:GPIB:ADDRess <ext_integer>
```

##### Query

```
:SYSTem:COMMunicate:GPIB:ADDRess?
```

##### Response

```
<ext_integer>
```

**Parameter**

<ext_integer>	GPIB address
Setting range	1 to 30
Default	3
Resolution	1

**Programming Example**

To set GPIB Address to 2.

```

SYST:COMM:GPIB:ADDR 2
SYST:COMM:GPIB:ADDR?
> 2
    
```

Terminator

 or **Top**  **>Utility, >Interface Settings>Terminator**

Sets a terminator (end code) for a response message of controller sending, which is sent by a measuring instrument via remote control.

Press **F2 Terminator** on the Interface Settings function menu to select a terminator.

CR	Adds CR+LF to transmit EOI (Default).
LF	Adds LF to transmit EOI.
EOI	Transmits EOI without adding any characters.

**Remote command**

**Set a terminator (end code)**

**Command**

```
:SYSTem:COMMunicate:GPIB:TERMinator LF|CRLF|EOI
```

**Query**

```
:SYSTem:COMMunicate:GPIB:TERMinator?
```

**Response**

```
<terminator>
```

**Parameter**

<terminator>	Terminator
CRLF	Adds CR+LF to transmit EOI (Default).
LF	Adds LF to transmit EOI.
EOI	Transmits EOI without adding any characters.



**Programming Example**

To set a terminator to CRLF.

```

SYST:COMM:GPIB:TERM CRLF
SYST:COMM:GPIB:TERM?
> CRLF
    
```

## Selecting control language: Language

 or **Top**  **>Utility, >Interface Settings>Language**

Selects a language mode during remote control.

Press **F3 Language** on the Interface Settings function menu to select an assignment from options displayed on the function menu.

SCPI	Sets a language mode to SCPI mode (Default).
MG3700A	Sets a language mode to the MG3700 mode.
MS269xA	Sets a language mode to the MS269x mode.
MS2830A	Sets a language mode to the MS2830 mode.
MG364x	Sets a language mode to the MG364x mode.

**Remote command****Set a language mode****Command**

```
:SYSTem:LANGuage SCPI |MG3700 |MS269X |MS2830 |MG364X
```

**Query**

```
:SYSTem:LANGuage?
```

**Response**

```
<language>
```

**Parameter**

<language>	Language mode
SCPI	Sets to the SCPI mode (Default).
MG3700	Sets to the MG3700 mode (Native).
MS269X	Sets to the MS269x mode (Native).
MS2830	Sets to the MS2830 mode (Native).
MG364X	Sets to the MG364x mode (Native).

**Programming Example**

To set a language mode to the MS2830 mode.

```
SYST:LANG MS2830A
```

```
SYST:LANG?
```

```
> MS2830A
```

### TCP/IP port number: Raw Socket Port Number

 or **Top** >  > **Utility**, > **Interface Settings** > **Raw Socket Port Number**

Specifies a TCP/IP port number for transmitting the waveform data from IQproducer, which locates on an external PC, to the MG3710A/MG3740A.

Press **F4 Raw Socket Port Number** on the Interface Settings function menu to display the **Raw Socket Port Number** dialog box in the active function frame. Enter numbers and press **Enter** to set it.

Setting range	49152 to 65535
Default	49158
Resolution	1

## 9.4.2 System Settings

 or **Top** >  > **Utility, >System Settings**

Press **F2 System Settings** on the Utility function menu to display the System Setting function menu. Set common items in the system.

**Table 9.4.2-1 System Settings Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Beep Sound <u>Off</u> On	Specifies On to make a beep or Off not to make it when displaying an error message.
	F3	Power On <u>Preset</u> Last	Specifies status of parameters when the power is on.

### Beep

 or **Top** >  > **Utility, >System Settings>Beep Sound**

Enables/disables a beep when displaying an error message.

Press **F1 Beep Sound** on the System Setting function menu to enable/disable a beep.

On                                      Enables a beep (Default).  
Off                                        Disables a beep.

#### Remote command

#### Enable/disable a beep

##### Command

```
:SYSTem:BEEPer <boolean>
```

##### Query

```
:SYSTem:BEEPer?
```

##### Response

```
<boolean>                              0 or 1
```

##### Parameter

```
<boolean>                              Beep  
ON|1                                    Enables a beep (Default).  
Off|0                                   Disables a beep.
```

#### Programming Example



To disable a beep.

```
SYST:BEEP OFF
```

```
SYST:BEEP?
```


```
> 0
```

Parameters at power-on: Power On

 or **Top**  **>Utility, >System Setting>Power On**

Specifies status of parameters when the power is on.

Press **F3 Power On** of the System Setting function menu to set the status.

- |        |   |
|--------|---|
| Last   | Keeps the status when the power is on and recovers them if the power goes on (Default).   |
| Preset | Does not keep the status when the power is on and uses default values if the power goes on. Pressing <b>Preset</b>  performs the same operation as initializing by pressing <b>F1 Preset</b> . |

Remote command

**Specify status of parameters when the power is on**

**Command**

:SYSTem:PON:TYPE PRESet | LAST


**Query**

:SYSTem:PON:TYPE?

**Response**

<type> PRES or LAST

**Parameter**

- |        |  |
|--------|--|
| <type> | Status of parameters   |
| LAST   | Keeps the status when the power is off and recovers them if the power goes on (Default).   |
| PRESet | Does not keep the status when the power is off and uses default values if the power goes on. Pressing <b>Preset</b>  performs the same operation as initializing by pressing <b>F1 Preset</b> . |

**Programming Example**

To set status of parameters when the power is on to the default values.

SYST:PON:TYPE PRES

SYST:PON:TYPE?

> PRES

### 9.4.3 Instrument Info

 or **Top**  **>Utility, >Instrument Info**

Press **F3 Instrument Info** on the Utility function menu to display the Instrument Info function menu. This function displays the status and factory shipment defaults of the system.

**Table 9.4.3-1 Instrument Info Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Product Info	Displays the Product Information dialog box where you can see the product information.
	F2	Instrument Options	Displays the Instrument Options dialog box where you can see the option information.
	F3	Board Info	Displays the Board Information dialog box where you can see the revision number of the board.
	F4	FPGA Info	Displays the FPGA Info dialog box where you can see the FPGA version.
	F5	Waveform Licenses	Displays the Waveform Licenses dialog box where you can see the license number of the waveform data.

#### Product Info

 or **Top**  **>Utility, >Instrument Info>Product Info** Displays the product information.

Press **F1 Product Info** on the Instrument Info function menu to display the **Product Information** dialog box.

Product Name	Product name
Product Model	Product model name
Serial Number	Serial number of the system (hardware)
Firmware Version	Version of this application
USB Product ID	Product ID of the USB port for remote control
USB Vendor ID	Vendor ID of the USB port for remote control
USB Serial Number	Serial number of the USB port for remote control
Power On (Hours:Minutes:Seconds)	Elapsed time since the power is turned to on
SG1 Frequency Setting Range	SG1 Frequency Setting Range
SG1 Level Setting Range	SG1 Level Setting Range
SG1 ARB Memory Size	SG1 Waveform Memory Size (MSamples)
SG1 AWGN	SG AWGN function On/Off
SG1 RPP Count	Number of circuit breaker trips by SG1 RPP

SG2 Frequency Setting Range	SG2 Frequency Setting Range
SG2 Level Setting Range	SG2 Level Setting Range
SG2 ARB Memory Size	SG2 Waveform Memory Size (MSamples)
SG2 AWGN	SG2 AWGN function On/Off
SG2 RPP Count	Number of circuit breaker trips by SG2 RPP

**Note:**

RPP Count is displayed when the reverse input power protection option (Opt-043/143/073/173) is installed.

Remote commands for displaying the product information are as follows:

**Remote command**

**Device information**

**Query Product Type (product model name), Serial Number (serial number), Firmware Version (version of this application), or the information common to IEEE488.2**

**Query**

\*IDN?

**Response**

company,model,serialnumber,firmware

**Parameter**

company	Manufacturer (ANRITSU)
model	Product model name (7 alphanumeric characters)
serialnumber	Serial number specific to the product (10-digit numbers)
firmware	Version number of this application

**Programming Example**

To query the device information.

\*IDN?

> ANRITSU, MG3710A, 6100000000, 1.00.00.



**Remote command**      **Query the Product Type (product model name)****Query**

```
:SYSTem:INFormation:MODEl?
```

**Response**

```
<model>
```

**Parameter**

```
<model>                    Product model name
```

**Programming Example**

To query the product model name.

```
SYST:INF:MOD?
```

```
> MG3710A
```

**Remote command**      **Query Product Name (product name)****Query**

```
:SYSTem:INFormation:TYPE?
```

**Response**

```
<type>
```

**Parameter**

```
<type>                    Product name
```

**Programming Example**

To query the product name.

```
SYST:INF:TYPE?
```

```
> SIGNAL GENERATOR
```

**Remote command**      **Query Serial Number (serial number)****Query**

```
:SYSTem:INFormation:SERial?
```

**Response**

```
<serial>
```

**Parameter**

```
<serial>                    Serial number
```

**Programming Example**

To query the serial number.

```
SYST:INF:SER?
```

```
> 6100000000
```

**Remote command**

**Query Running Time (available time)**

**Query**

:SYSTem:INFormation:RTIME?

**Response**

<time>

**Parameter**

<time>

Running time

Suffix code

None, Unit: m (minutes)

**Programming Example**

To query the running time.

SYST:INF:RTIM?



> 100

**Remote command**

**Query Firmware Version (the version of this application)**

Refer to the explanation of "\*IDN?".

**Instrument Options**

 or **Top**  **>Utility, >Instrument Info>Instrument**

**Options** Displays the option information of the system.

Press **F2 Instrument Options** on the Instrument Info function menu to display the Instrument Options dialog box in the function display frame.

Number	Number of the installed hardware option
Name	Name of the hardware option
State	Status of On/Off switch

**Remote command**

**Query the option information**

**Query**

:SYSTem:HARDware:OPTion:CATalog?

**Response**

<total>,<number1>,<switch1>,<name1>,<number2>,<switch2>,<name2>...

**Parameter**

<total>

Total number of selectable options

<number>

Number of the option

<switch>

Status of the option (On or Off) ON, OFF

<name>



Name of the option

**Programming Example**

To query the option information.

```
SYST:HARD:OPT:CAT?
> 1,001,ON,Rubidium Reference Oscillator
```

**Board Info**

 or **Top**  **Utility, >Instrument Info>Board Info**

Displays Revision of the system board.

Press **F3 Board Info** on the Instrument Info function menu to display the Board Information dialog box in the function display frame.

ID	ID number of the board
Board Name	Name of the board
Revision	Revisions
Ext.ID	ID number of the expansion board
Ext. Board Name	Name of the expansion board
Ext. Revision	Revisions of the expansion board

**Remote command****Query the revision number of the specified hardware****Query**

```
:SYSTem:HARDware:REVision? <hardware>
```

**Response**

```
<revision>
```

**Parameter**

<hardware>	Hardware type
MAIN	Main Board (With BER option)
MAIN_NO_BER	Main Board (Without BER option)
VSG1	1st VSG Board
VSG2	2nd VSG Board
MAIN_IB	Interface Board (With BER option)
MAIN_NO_BER_IB	Interface Board (Without BER option)
VSG1_ANALOG_IQ	1st VSG Analog I/Q Board
VSG1_SG_BB	1st VSG Baseband Board
VSG1_SG_RF	1st VSG RF Board
VSG2_ANALOG_IQ	2nd VSG Analog I/Q Board
VSG2_SG_BB	2nd VSG Baseband Board
VSG2_SG_RF	2nd VSG RF Board
<revision>	Revision number

**Details**

This command queries the revision number of the specified hardware. “-” is returned when reading a version number of hardware not installed. To query in batch all hardware names and revision numbers, use:  
:SYSTem:HARDware:REVision:CATalog?

**Programming Example**

To query the revision number of Main Board.  
SYST:HARD:REV? MAIN  
> 2

**Remote command**

**Query revision numbers of all the hardware**

**Query**

:SYSTem:HARDware:REVision:CATalog?

**Response**

<hardware1>,<revision1>,<hardware2>,<revision2>,...

**Parameter**

<hardware>	Hardware type
MAIN	Main Board (With BER option)
MAIN_NO_BER	Main Board (Without BER option)
VSG1	1st VSG Board
VSG2	2nd VSG Board
MAIN_IB	Interface Board (With BER option)
MAIN_NO_BER_IB	Interface Board (Without BER option)
VSG1_ANALOG_IQ	1st VSG Analog I/Q Board
VSG1_SG_BB	1st VSG Baseband Board
VSG1_SG_RF	1st VSG RF Board
VSG2_ANALOG_IQ	2nd VSG Analog I/Q Board
VSG2_SG_BB	2nd VSG Baseband Board
VSG2_SG_RF	2nd VSG RF Board
<revision>	Revision number



**Details**

This command queries revision numbers of all the hardware. No response is returned when the hardware does not exist.

**Programming Example**

To query all revision numbers.  
SYST:HARD:REV:CAT?  
> MAIN,2,VSG1,4,VSG\_SG\_RF,0,VSG1\_SG\_BB,1

## FPGA Info

 or **Top**  **>Utility, >Instrument Info>FPGA Info**

Displays FPGA Version of the system.

Press **F4 FPGA Info** on the Instrument Info function menu to display the FPGA Info dialog box in the function display frame.

Name	FPGA name
Board	Installed FPGA board name
Version	Versions

## Remote command

**Query the version number of FPGA****Query**

```
:SYSTem:FPGA:VERSion? <hardware>
```

**Response**

```
<version>
```

**Parameter**

<hardware>	FPGA type
CNTR_KEY	ControlPIdAndPanel
HWC	HardwareControlFpga
MEAS_COM	MeasureComDsp
MEAS_CORE	MeasureCoreFpga
MEAS_PCI	MeasurePciFpga
SGBB	SgBbHardwareControlFpga
SGCTRL	SgControlFpga
SGRF	SgRfFpga
<version>	Version number of FPGA

**Details**

This command queries the version number of the specified FPGA.

“.” is returned when reading a version number of hardware not installed.

To acquire in batch the version numbers of all the FPGAs, use:

```
:SYSTem:FPGA:VERSion:CATalog?
```

**Programming Example**

To query the version number of HWC FPGA.

```
SYST:FPGA:VERS? CNTR_KEY
```

```
> 5
```

**Remote command**

**Query the version numbers of all FPGAs**

**Query**

:SYSTem:FPGA:VERSion:CATalog?

**Response**

<hardware1>,<version1>,<hardware2>,<version2>...

**Parameter**

<hardware>	FPGA type
ControlPldAndPanel	ControlPldAndPanel
HardwareControlFpga	HardwareControlFpga
MeasureComDsp	MeasureComDsp
MeasureCoreFpga	MeasureCoreFpga
MeasurePciFpga	MeasurePciFpga
SgBbHardwareControlFpga	SgBbHardwareControlFpga
SgControlFpga	SgControlFpga
SgRfFpga	SgRfFpga
<version>	Version number of FPGA

**Details**

This command queries the version number of all FPGAs.

No response is returned when the hardware does not exist.



**Programming Example**

To query the version number of all FPGAs.

SYST:FPGA:VERS:CAT?

```
> HardwareControlFpga,6,MeasurePciFpga,15,  
  MeasureComDsp,46,MeasureCoreFpga,21,SgBbHardwareContro  
  lFpga,3,SgRfFpga,5,SgControlFpga,7,ControlPldAndPanel,  
  5
```

Waveform Licenses

 or **Top**  **>Utility, >Instrument Info>Waveform Licenses** Displays waveform licenses.

Press **F5 Waveform Licenses** on the Instrument Info function menu to display the Waveform Licenses dialog box and the Waveform Licenses function menu.

License Name	Names of waveform licenses
Serial Number	Serial number
Version Limit	Versions are limited. Only the files with the displayed version number or earlier can be worked with.
Note	Remarks

**Table 9.4.3-2 Waveform Licenses Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Install	Displays the Waveform Licenses function menu and the Waveform License Install dialog box.
	F2	Uninstall	Selects a waveform license in the Waveform Licenses dialog box and deletes it.

Remote commands for Waveform license information are as follows:

**Remote command**

**Query the total number of waveform licenses**

**Query**

`:SYSTem:WAVEform:LICense:COUNT?`

**Response**

`<integer>` Total number of waveform licenses

**Programming Example**

To query the total number of waveform licenses.

```
SYST:WAV:LIC:COUN?
> 3
```

**Remote command**

**Query a license name of waveform license specified with a number**

**Query**

`:SYSTem:WAVEform:LICense:NAME? <integer>`

**Response**

`<string>`

**Parameter**

<integer>	Number
Setting range	0 to (license count – 1)
Resolution	1
<string>	License name of the waveform license Character string within 100 characters enclosed by double quotes (" ") or single quotes ( ' ') (excluding extension)

**Programming Example**

To query the license name of waveform license with #5.  
 SYST:WAV:LIC:NAME? 5  
 > "W-CDMA Waveform"

**Remote command**

**Query a version number of waveform license specified with a number  
Query**

:SYSTem:WAVeform:LICense:VERSion? <integer>

**Response**

<numeric>

**Parameter**

<integer>	No.
Setting range	0 to (license count – 1)
Resolution	1
<numeric>	Version number

**Programming Example**

To query a version number of waveform license with #5.  
 SYST:WAV:LIC:VERS? 5  
 > 1.23

**Remote command**

**Delete the waveform license specified with a name  
Command**

:SYSTem:WAVeform:LICense:DELeTe <string>

**Parameter**

<string>	Name of waveform license  Character string within 100 characters enclosed by double quotes (" ") or single quotes ( ' ) (excluding file extension)
----------	--

**Programming Example**

To delete the "W-CDMA License" waveform license.  
 SYST:WAV:LIC:DEL "W-CDMA License"



**Remote command****Install a waveform license by specifying a license file****Command**

```
:SYSTem:WAVeform:LiCense:INSTall <string>[,<device>]
```

**Parameter**

<string>                      Name of a license file  
                                  Character string within 100 characters enclosed  
                                  by double quotes (" ") or single quotes ( ' ')  
                                  (excluding extension)

<device>                      Drive number: A to Z, currently selected drive  
                                  when omitted

**Programming Example**

To install the license file "LicenseFile" in D drive.

```
SYST:WAV:LiC:INST "LicenseFile",D
```

**Operation method**

Install or uninstall waveform licenses

Example: To install a waveform license.

1. Press **F1 Install** on the Waveform Licenses function menu to display the **Waveform License Install** dialog box and the Waveform License function menu.

File Name	File name
License Name	Name of waveform license
State	Not used
Serial Number	Serial number
Version Limit	Versions are limited. Only the files with the displayed version number or earlier can be worked with.

**Table 9.4.3-3 Waveform License Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Displays the Drive function menu where you can select a drive containing waveform licenses.
	F7	Install	Installs selected waveform license files.

2. Press **F1 Drive** to select a drive for containing waveform licenses.
  - Options All connected drives
  - Default C
3. The File List dialog box for the device selected in Step 2 appears and shows files.

4. When **Waveform License Install** is selected from the dialog box and **F7 Install** is pressed, the Confirmation function menu is displayed.

**Table 9.4.3-4 Confirmation Function Menu**

Page	Key No.	Menu Display	Function
1	F7	Confirm installation	Performs installation.
	F8	Cancel	Returns to the menu before this menu is opened.

5. Press **F7 Confirm installation**.

Example: Uninstalling Waveform License

1. Select the waveform license to be uninstalled at the **Waveform License** dialog box.

License Name	Names of waveform licenses
Serial Number	Serial number
Version Limit	Versions are limited. Only the files with the displayed version number or earlier can be worked with.
Note	Remarks

2. Press **F2 Uninstall** at the Waveform Licenses function menu to display the **Waveform License** dialog box and Confirmation function menu.

**Table 9.4.3-5 Confirmation Function Menu**

Page	Key No.	Menu Display	Function
1	F7	Confirm Uninstallation	Performs Uninstallation.
	F8	Cancel	Returns to the menu before this menu is opened.

3. Press **F7 Confirm installation**.

## 9.4.4 Install

 or **Top** >  > **Utility, >Install**

Updates the firmware and adds or deletes waveform licenses.

Press **F4 Install** on the Utility function menu to display the Install function menu.

**Table 9.4.4-1 Install Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Firmware	Updates the firmware.
	F2	Waveform Licenses	Displays the Waveform Licenses dialog box where you can add or delete waveform licenses.
	F3	Options	Adds options.
	F8	Factory Preset	Initializes parameters to the level at which past status does not affect operations at all.

### Updating firmware: Firmware

 or **Top** >  > **Utility, >Install>Firmware**

Updates the firmware.

#### Note:

After installing the firmware, the auto-saved parameter file at power off “LastParameterSetting.xml” will be deleted. After power on, the setting returns to the default setting.

Example: To install a firmware file.

1. Copy the installer file “Setup.msi” and “update.bat ” to a root folder on any drives or to the following folder:  
[Drive] \Anritsu\MG3710A\User Data\Install
2. Press **F1 Firmware** on the Install function menu to display the Firmware Install function menu and the **Installer List** dialog box.

**Table 9.4.4-2 Firmware Install Function Menu**

Page	Key No.	Menu Display	Function
1	F7	Install	Displays the Confirmation function menu.

3. Make sure the **Installer List** dialog box shows the information about the installer file “Setup.msi”.
4. Select a file to install and press **F7 Install** to display the Confirmation function menu.


**Table 9.4.4-3 Confirmation Function Menu**

Page	Key No.	Menu Display	Function
1	F7	Confirm installation	Performs installation.
	F8	Cancel	Returns to the previous menu.

5. Press **F7 Confirm installation**.
6. Install is performed after quitting the application and uninstalling. Then a restart is performed; this all occurs automatically.

**Note:**

When installing the firmware, “Now Processing” displays.



**Adding/deleting waveform licenses: Waveform Licenses**

**Utility** or **Top** > **Utility**, >**Install**>**Waveform Licenses**

Adds or deletes waveform licenses.

Press **F2 Waveform Licenses** on the Install function menu to display the Waveform Licenses function menu and the **Waveform Licenses** dialog box.

Refer to Table 9.4.3-2 “Waveform Licenses Function Menu” for how to add or delete waveform licenses.

## Adding options: Options

 or **Top**  **>Utility, >Install>Options**

Adds options.

Press **F3 Options** on the Install function menu to display the **Option Install** dialog box and the Option Install function menu.

Number                      Number of the option  
Name                         Name of the option  
State                         Indicates On/Off of the option.

**Table 9.4.4-4 Option Install Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Displays the Drive function menu where you can select a drive containing options.
	F7	Install	Displays the Confirmation function menu.

Example: To install an option.



- Press **F1 Drive** on the Option Install function menu to select a drive containing options.  
Options    All connected drives  
Default    C
- Select options to install in the **Option Install** dialog box and press **F7 Install**. The Confirmation function menu is displayed.

**Table 9.4.4-5 Confirmation Function Menu**

Page	Key No.	Menu Display	Function
1	F7	Confirm installation	Performs installation.
	F8	Cancel	Returns to the previous menu.

- Press **F7 Confirm installation** to perform installation.

## Factory Preset

 or **Top**  **Utility, >Install>Factory Preset**

Factory Preset is initialization with the largest target range available with normal panel operations and remote control commands. It initializes parameters to the level at which past status before the initialization does not affect operations at all.

Any folders excluding Waveform in the UserData folder created by the MG3710A/MG3740A are deleted, and a reboot is executed after the following processings are executed.

- I/Q Calibration Restore Default Setting
- Preset Reference Clock, Correction Table Clear
- Channel Table Clear
- List Table Clear
- The following folders are deleted:
  - Anritsu\MG3710A\User Data\Corrections\
  - Anritsu\MG3710A\User Data\Copy Files\
  - Anritsu\MG3710A\User Data\Parameter Setting\
  - Anritsu\MG3710A\User Data\ChannelTable\
  - Anritsu\MG3710A\User Data>ListTable\
  - Anritsu\MG3710A\User Data\Alarm History\
  - Anritsu\MG3710A\User Data\BERT BitPattern\
  - Anritsu\MG3710A\User Data\BERT Log\

Press **F8 Factory Preset** to display the Factory Preset function menu and **Factory Preset** message.




Figure 9.4.4-1 Factory Preset Message

Table 9.4.4-6 Factory Preset Function Menu

Page	Key No.	Menu Display	Function
1	F7	Confirm Reset To Factory Default	Performs System Preset and initialize parameters to the level at which past status does not affect operations at all.
	F8	Cancel	Returns the menu before this menu is opened.

### Confirm Reset To Factory Default

 or **Top**  **>Utility, >Install>Factory Preset>Confirm Reset To Factory Default**

Performs Factory Preset and initialize parameters to the level at which past status does not affect operations at all.

#### Remote command

**Initialize parameters to the level at which past status does not affect operations at all**

Command `Factory`  
`:SYSTem:FPReset`

#### Programming Example

To perform the factory-level initialization.

`SYST:FPR`

### 9.4.5 Displaying Error Information: Error Info

**Utility** or **Top** → **Utility**, **Error Info**

Displays the error information.

Refer to Appendix B “Error Messages”.

**Note:**

The **Error Queue** dialog box displays the most recent 30 screen operation errors.

Press **F5 Error Info** on the Utility function menu to display the Error Info function menu and **Error Queue** dialog box.

ID	Error	Description
-310	System Error	Failed to load list file.
-222	Data out of range	Setting value out of range
-222	Data out of range	Setting value out of range
-222	Data out of range	Setting value out of range
-222	Data out of range	Setting value out of range
-222	Data out of range	Setting value out of range
-222	Data out of range	Setting value out of range
-222	Data out of range	Setting value out of range
-222	Data out of range	Setting value out of range
-222	Data out of range	Setting value out of range
-222	Data out of range	Setting value out of range

Figure 9.4.5-1 Error Queue Dialog Box

ID	Shows error code.
Error	Displays error message.
Description	Describes error content

**Note:**

Error information caused by remote control can be read using the following remote commands. The most recent 30 errors are saved.

Remote commands related to remote operation errors are shown below.

**Remote command**

**To read remote control error code and error message**

**Query**

:SYSTem:ERRor[:NEXT]?

**Response**

<code> Error code number  
 0, “No Error” returns where there is no error.

**Programming Example**

```
SYST:ERR?
> 0, "No error"
```



**Remote command****To read remote control error code****Query**

```
:SYSTem:ERRor:CODE[:NEXT]?
```

**Response**

```
<code> Error code number
"0" returns where there is no error.
```

**Programming Example**

```
SYST:ERR:CODE?
> 0
```

**Remote command****Select the mode to display error messages when an error occurs during remote control****Command**

```
:DISPlay:ERRor:MODE NORMal|REMain|LAST
```

**Query**

```
:DISPlay:ERRor:MODE?
```

**Response**

```
<mode> NORM, REM or LAST
```

**Parameter**

<mode>	Display mode for error messages
NORMal	Clears the error message when the next command is received (Default).
REMain	Keeps the first error message displayed.
LAST	Keeps the last error message displayed.

**Details**

This is a function only with a remote command.

The setting of the mode to display error messages is not included in the initialization by 9.5.1 "Preset". The setting with this command can be initialized with Factory Preset in 9.4.4 "Install".

**Programming Example**

```
To keep the first error message displayed.
DISP:ERR:MODE REM
DISP:ERR:MODE?
> REM
```

Table 9.4.5-1 Error Info Function Menu

Page	Key No.	Menu Display	Function
1	F7	Clear	Deletes error information.

Deleting Error Information: Clear

 or **Top** >  > **Utility, >Error Info>Clear**

Deletes the error information.

## 9.4.6 Changing Boot Loader Service

The Boot Loader Service program runs immediately after the MG3710A/MG3740A is powered-up to read and boot from the MG3710A/MG3740A firmware. This section explains the procedure for changing the Boot Loader Service program.

The procedure is performed in the following sequence:

Disabling Boot Loader Service Start (Boot)

Installing Boot Loader Service

### Disabling Boot Loader Service Start (Boot)

1. Power-up the MG3710A/MG3740A.
2. Click the Windows **Start** button and select **All Programs > Startup > Shortcut to Boot Loader Service**, and then right-click to display the context menu.
3. Select **Delete** so that Boot Loader Service does not run automatically immediately after Windows starts.
4. Power-down the MG3710A/MG3740A.
5. Power-up the MG3710A/MG3740A.

**Note:**

Subsequently, neither the Boot loader Service program nor the MG3710A/MG3740A applications will start when Windows starts.

### Installing Boot Loader Service

1. Disable the Boot Loader Service program as described above.
2. Click the Windows **Start** button and select **Control Panel > Add or Remove Programs**.  
(For Windows 7, select **Control Panel > Uninstall a program**.)
3. Select “Anritsu Boot Loader Service for MG3710A” and delete it.
4. Connect a USB memory stick to the external PC and copy the installer file for the Boot Loader Service to be updated to the root folder of the USB memory stick.
5. Dismount the USB memory stick from the external PC and connect it to the MG3710A/MG3740A.
6. Run the Boot Loader Service installer file and follow the install wizard instructions.
7. The updated Boot Loader Service is enabled automatically at the next restart.

## 9.5 Panel Keys

This section describes functions available only from keys on the front panel.

### 9.5.1 Preset




Press **Preset** of the panel key to display the Preset function menu.

**Table 9.5.1-1 Preset Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Preset	Performs Preset and resets all parameters managed by this application to default values, excluding those of the Utility function.
	F3	Preset All	Resets parameters managed by this application to default values, including those of the Utility function. The user correction data is not reset to default values.
	F7	Restart	Turns the power OFF and executes restart.
	F8	Cancel	Returns to the previous menu.

### Preset



Performs Preset and resets all parameters managed by this application to default values, excluding those of the Utility function.

The power meter COM Port number and model name are not initialized. Initialize with **Preset All**.

Press **F1 Preset** for execution.

#### Remote command

**Initialize a device. A command common to IEEE488.2**

#### Command

\*RST

#### Details

This command initializes the settings and status of the currently loaded all applications.

#### Programming Example

To initialize a device.

\*RST

---

**Remote command**      **Initialize the settings and status of the currently selected application**

**Command**`:SYSTem:PRESet`**Programming Example**

To initialize the settings and status of the currently selected application.

`SYST:PRES`**Preset All**

 **Preset All**

Resets parameters managed by this application to default values, including those of the Utility function. In addition, List Table, Channel Table, and the waveform memory (with loaded waveform file) are initialized. However, the user correction data is not initialized. Press **F3 Preset All** for execution.

**Remote command**      **Reset parameters managed by this application to default values, including those of the Utility function**

**Command System All**`:SYSTem:PRESet:ALL`**Programming Example**

To reset parameters including those of the Utility function.

`SYST:PRES:ALL`**Restart**

 **Restart**

Turns the power OFF and executes restart. It resets Remote/Local to Local, Display On/Off to On, SignalGenerator function menu to the default values, and IEEE488.2 event status processing to the power on-equivalent.

**Remote command**

**Restart**

**Command**

:SYSTem:REBoot

**Details**

This function turns the power OFF and executes restart. It resets Remote/Local to Local, Display On/Off to On, SignalGenerator function menu to the default values, and IEEE488.2 event status processing to the power on-equivalent.

**Programming Example**

To restart.

SYST:REB

## 9.5.2 Switching Remote/Local: Local



When you press **Local** of the panel key, the remote-control state is changed to the local-control state. Then, the lit Remote LED (Remote) goes off (Local).

### Remote command

**Switch the remote-control state to the local-control state**  
**Command**

```
:SYSTem:COMMunicate:GTLocal
```

### Programming Example

To switch the state to the local-control state.

```
SYST:COMM:GTL
```

### 9.5.3 Saving parameter file: Save

The MG3710A/MG3740A can restore the settings by saving and loading settings of frequencies, output levels, or modulation parameters. This section describes how to save the settings.



Press **Save** of the panel key to display the **Parameter Save** dialog box, the **File List** dialog box, and the Parameter Save function menu.

**Table 9.5.3-1 Parameter Save Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Displays the Drive function menu where you can set a destination drive for saving files.
	F4	Change Focus	Moves the cursor between dialog box and file list.
	F5	Delete	Deletes the specified parameter file.
	F7	Save	Saves the settings and the status of the application in a parameter file.
	F8	Cancel	Returns to the previous menu.

#### Saving Parameter File: Save



**Save**

Saves the settings and the status of the application in a parameter file.

#### Remote command

**Save the settings and the status of the application in a parameter file**

#### Command

:MMEMory:STORe:STATe [<string>[,<device>]]

#### Parameter

<string>

File name excluding extension

Character string enclosed by double quotes (" ") or single quotes (' ') (excluding extension)

The following characters cannot be used:

\ / : \* ? " ' < > |

Automatically named as

“Param[Date]\_[Additional number].xml” when omitted.

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

<device>

Number of the drive



Options A to Z, currently selected drive when omitted

### Details

A space or dot “.” at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

A destination path to save the file is the following directory in the specified drive.

Anritsu\MG3710A\User Data\Parameter Setting\

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

### Programming Example

To name a parameter file as "TEST" and saves it in D drive.

```
MMEM:STOR:STAT "TEST",D
```

## Deleting Parameter File: Delete



Deletes the specified parameter file.

When the parameter file to be deleted is selected and **F5 Delete** is pressed, the **Confirmation** function menu is displayed.

**Table 9.5.3-2 Confirmation Function Menu**

Page	Key No.	Menu Display	Function
1	F7	Confirm Deletion	Executes delete.
	F8	Cancel	Returns to the menu before this menu is opened.

Press **F7 Confirm Deletion** to delete files.

### Remote command

#### Delete the specified parameter file

##### Command

```
:MMEMory:DELeTe:STATe <filename>[,<device>]
```

##### Parameter

<filename>

File name excluding extension

<device>

Number of the drive

Options

A to Z, currently selected drive when omitted

### Programming Example

To delete the parameter file “TEST” stored in D drive.

```
MMEM:DEL:STAT "TEST",D
```

**Operation method**

The procedure of saving parameters is as follows:

Example: To save the currently displayed parameters in "ABC".



**Figure 9.5.3-1 File Name Input Window**

1. Press **Save** of the panel key to display the Parameter Save function menu, the **Parameter Save** dialog box, and the **File List** dialog box.
2. Press **F1 Drive** to specify a destination drive.
  - Options A to Z
  - Default C
3. Enter "ABC" for a file name in the text box in the **Parameter Save** dialog box.
 

By default, the "Param[Date]\_[Additional number].xml" is displayed in the text box.
4. Press **F7 Save** to save a parameter file with the entered file name.

**Note:**

Do not turn the power off while saving parameter files because they may be damaged.

When you input a file name, an extension is automatically added. You cannot specify an extension.

Destination path: Anritsu\MG3710A\User Data\Parameter Setting\

Default destination name: Param[Date]\_[Additional number].xml  
 The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

Characters available for file names are displayed on the character pallet.

The following characters cannot be used:

\ / : \* ? " " \ ' < > |

A space or dot “.” at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

**Description of Function** This function allows you to save the following items:

\*: Setting item common to SG1 and SG2. Other items are saved for SG1 or SG2.

**Table 9.5.3-3 Items Saved in a Parameter File**

System	Items
<p><b>Frequency setting function</b></p>	<p>Frequency                      Frequency Relative Display On/Off                      Frequency Relative Value                      Frequency Offset On/Off                      Frequency Offset                      Frequency Offset Multiplier On/Off                      Frequency Offset Multiplier                      Frequency/Channel Display                      Frequency Display On/Off                      Channel Group                      Channel Selection                      Channel Table *                      Frequency Synchronization On/Off *                      Frequency Synchronization Mode *                      Phase Noise Optimization                      RF Spectrum                      Reference Frequency Source *                      Reference Frequency *                      Local Signal Source                      Local Signal Output *                      Local Signal Phase</p>
<p><b>Output level function</b></p>	<p>RF Output On/Off                      Output Level                      Display Unit                      Output Level Relative Display On/Off                      Output Level Relative Value                      Output Level Offset On/Off                      Output Level Offset                      Limit Level On/Off                      Limit Level                      Output Level Synchronization On/Off *                      User Correction On/Off                      User Correction Table *                      S/N Optimization On/Off</p>
<p><b>User correction</b></p>	<p>Com Port                      Model                      Start Freq                      Stop Freq                      Level Offset On/Off                      Level Offset value                      Correction Points                      Averaging On/Off                      Averaging Count</p>

Table 9.5.3-3 Items Saved in a Parameter File (Continued)

System	Items
<b>Sweep/List function</b>	Sweep/List Freq On/Off Sweep/List Freq On/Off Sweep/List Type * Sweep Repeat * Sweep Direction * Manual Mode On/Off * Manual Point * Sweep Out Setting * Sweep Start Frequency Sweep Stop Frequency Sweep Center Frequency Sweep Span Frequency Sweep Start Level Sweep Stop Level Sweep Point Sweep Dwell Time Sweep Type List Frequency Setting List Level Setting List Table *

**Table 9.5.3-3 Items Saved in a Parameter File (Continued)**

System	Items
<b>Modulation function</b>	Modulation On/Off AM Modulation On/Off AM Depth Scale AM Depth (Lin) AM Depth (Log) AM Modulation Frequency FM Modulation On/Off FM Frequency Deviation FM Modulation Frequency $\phi$ M Modulation On/Off $\phi$ M Deviation Angle $\phi$ M Modulation Frequency Pulse Modulation On/Off Pulse Modulation Source Pulse Modulation Frequency Pulse Modulation Period Pulse Modulation Delay Pulse Modulation Width Pulse 2 Delay Pulse 2 Width Pulse Sync/Pulse Video Output Signal Polarity Pulse Mod input signal polarity ARB On/Off RMS Adjustment Pattern Generation Mode Pattern A On/Off Pattern B On/Off Pattern A Output Level Pattern B Output Level Object of Level Change Level Ratio Setting Sampling Rate A Sampling Rate B Frequency Offset Frequency Offset A Frequency Offset B Reference Frequency Start Offset Spectrum Reverse A Spectrum Reverse B Waveform Load List Focus * Load Waveform Package Name * Load Waveform Pattern Name * Sub Item * Waveform Load Target Memory Waveform Selection List Focus * Waveform Selection Target Memory

Table 9.5.3-3 Items Saved in a Parameter File (Continued)

System	Items
<b>Modulation function</b>	Selected Waveform Package Name * Selected Waveform Pattern Name * Waveform Copy List Focus * RF Gate On/Off RF Gate Edit On/Off RF Gate Line RF Gate Offset 1 RF Gate Width 1 RF Gate Offset 2 RF Gate Width 2 RF Gate Frequency Start/Frame Trigger On/Off Start/Frame Trigger Mode Start/Frame Trigger Source Start/Frame Trigger Delay Start/Frame Trigger Edge Start/Frame Trigger Event Baseband Reference Clock Source Baseband Reference Clock Division * Baseband Reference Clock Out * Marker1 Edit Mode A On/Off Marker1 Offset A Marker1 Width A Marker1 Cycle A Marker1 Polarity A Marker1 Edit Mode B On/Off Marker1 Offset B Marker1 Width B Marker1 Cycle B Marker1 Polarity B Marker2 Edit Mode A On/Off Marker2 Offset A Marker2 Width A Marker2 Cycle A Marker2 Polarity A Marker2 Edit Mode B On/Off Marker2 Offset B Marker2 Width B Marker2 Cycle B Marker2 Polarity B Marker3 Edit Mode A On/Off Marker3 Offset A Marker3 Width A Marker3 Cycle A Marker3 Polarity A Marker3 Edit Mode B On/Off Marker3 Offset B

**Table 9.5.3-3 Items Saved in a Parameter File (Continued)**

System	Items
<b>Modulation function</b>	Marker3 Width B Marker3 Cycle B Marker1 Polarity B Sequence Play Mode Sequence Repeat Mode Pattern Trigger On/Off Pattern Trigger 1 On/Off Pattern Trigger 1 Source Pattern Trigger 1 Edge Pattern Trigger 2 On/Off Pattern Trigger 2 Source Pattern Trigger 2 Edge Pattern Trigger 3 On/Off Pattern Trigger 3 Source Pattern Trigger 3 Edge Pattern Trigger Switching Point Sync Type * Number of Slaves * Slave Position * LO Sync * I/Q Phase I/Q Delay
<b>Route Connectors</b>	S/F Trigger * Pattern Trigger 1 * Pattern Trigger 2 * Pattern Trigger 3 * Pattern Status 1 * Pulse Mod * Pattern Trigger Type * Marker1 * Marker2 * Marker3 * Pulse Video * Pulse Sync * Sync Trig Out *
<b>AWGN</b>	AWGN On/Off Noise Bandwidth Carrier Level Noise Level C/N Ratio C/N Set Signal



Table 9.5.3-3 Items Saved in a Parameter File (Continued)

System	Items
<b>I/Q modulation</b>	I/Q Source I/Q Output Internal Channel Correction Cal Type Wideband Analog I/Q Input I Offset * Analog I/Q Input Q Offset * Analog I/Q Output I Level Trimming * Analog I/Q Output Q Level Trimming * Analog I/Q Output I/Q Common Offset* Analog I/Q Output I Diff Offset * Analog I/Q Output Q Diff Offset * Internal Baseband I Offset Internal Baseband Q Offset Internal Baseband Gain Balance Internal Baseband Quad. Angle Internal Baseband I/Q Phase Internal Baseband I/Q Skew Internal Baseband I/Q Delay
<b>BER measurement</b>	Measure Mode * Data Type * Count Mode Data * Error * Auto Resync * Threshold X * Threshold Y * at SyncLoss * BER Interface Clock Edge * BER Interface Data Polarity * BER Interface Enable Active * PN Fix Pattern Length * User Defined Pattern Pattern Length * User Defined Pattern Sync Start * User Defined Pattern Sync Length * PN Fix9 Pattern Initial PN Fix11 Pattern Initial PN Fix15 Pattern Initial PN Fix20 Pattern Initial PN Fix23 Pattern Initial Pattern Length Sync Start Sync Length

**Table 9.5.3-3 Items Saved in a Parameter File (Continued)**

System	Items
<b>Power Meter</b>	Channel A On/Off * Channel A Com Port * Channel A Model * Channel A Freq * Channel A Offset On/Off * Channel A Offset value* Channel A Averaging On/Off * Channel A Averaging Count value * Channel A Measurement Units * Channel B On/Off * Channel B Com Port * Channel B Model * Channel B Freq * Channel B Offset On/Off * Channel B Offset value * Channel B Averaging On/Off * Channel B Averaging Count value * Channel B Measurement Units *
<b>Utility</b>	GPIB Address * Terminator * Raw Socket Port Number * Beep Sound * Power On *
<b>Others</b>	File Type * Color *

The following items are not saved:

- Remote-control state (Remote or Local)
- The type of the displayed function menu. The MG3710A/MG3740A always displays the top-level function menu after loading the setting.
- Status of entered/displayed dialog boxes
- Display On/Off. Display is always recalled as On.
- Regenerating points of output signals. After loading settings, regeneration restarts based on the current conditions.

The following items are stored in settings.

- The system information (model name, product name)
- File version. It is an integer in decimal number, starting 0.
- Parameter information (ID, type, name, value, min/max value for each parameter)

A parameter file is in the xml format. It can be transmitted from an external PC to multiple MG3710As/MG3740As. Refer to *MG3700A/MG3710A Vector Signal Generator MG3740A Analog Signal Generator Operation Manual (IQproducer™)* for how to transmit it.

## 9.5.4 Recalling Parameter File: Recall



Press the **Recall** key of the panel key to display the Parameter Recall function menu, the **Parameter Recall** dialog box, and the **File List** dialog box.

**Note:**

Do not turn the power off when loading a parameter file. When you turn the power off during loading, the MG3710A/MG3740A may start with undefined parameters.

**Note:**

The set parameter settings file cannot be recalled with a different option configuration.

**Table 9.5.4-1 Parameter Recall Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Displays the Drive function menu where you can set a source drive for loading files.
	F7	Open	Performs loading settings.
	F8	Cancel	Returns to the previous menu.

### Open



Loads the parameter file specified in the **File List** dialog box. Press **F7 Open** to load a setting file.

### Remote command

#### Recall the application settings and status into a parameter file Command

```
:MMEMory:LOAD:STATe <string>[,<device>]
```

#### Parameter

<string>

File name excluding extension

Character string enclosed by double quotes (" ") or single quotes (') (excluding extension)

<device>

Number of the drive

Options

A to Z, currently selected drive when omitted

#### Programming Example

To recall settings of all applications based on the parameter file "TEST", which is saved in D drive.

```
MMEM:LOAD:STAT "TEST",D
```

## Displaying a parameter file list

Reads out a list of all parameter files in the specified device.

### Remote command

**Query a list of all parameter files in the specified device**

#### Query

:MMEMemory:CATalog:STATe? <device>

#### Response

<number>,<filename\_1>,<filename\_2>...

#### Parameter

<device>

Number of the drive

#### Options

A to Z, currently selected drive when omitted

<number>

Number of files: 0 to 1000

<filename\_n>

File name

When files more than 1000 exist, the command sorts them by file name and returns the top 1000 files.

### Programming Example

To query a list of parameter files saved in D drive.

```
MMEM:CAT:STAT? D
```

```
> 3,Param_00,Param_01,Param_02
```

**Operation method**

The procedure of loading parameters is as follows:

Example: To load a parameter file.



**Figure 9.5.4-1 Parameter Recall Dialog Box**

1. Press **Recall** of the panel key to display the Parameter Recall function menu, the **Parameter Recall** dialog box, and the **File List** dialog box.
2. Press **F1 Drive** to select a device containing parameters to load.
  - Options All connected drives
  - Default C
3. Parameter files in the default folder of currently specified drive are listed. To select, place the cursor on files to load.
4. Press **F7 Open** to load target files and the **Parameter Recall** dialog box closes.

**Note:**

File names are listed in alphanumeric order.

If no parameter file exists, the “File not found” is displayed.

Parameter files created with one MG3710A/MG3740A can be loaded by another MG3710A/MG3740A, but check firmware versions installed on each MG3710A/MG3740A. When the firmware version of the MG3710A/MG3740A that loads parameter files is older than the one that saves files, files cannot be loaded successfully.

### 9.5.5 Screen copy: Copy



Copies the screen displayed on the MG3710A/MG3740A and saves it in the specified folder.

Press **Copy** of the panel key to display the **Screen Copy** dialog box, the **File List** dialog box, and the Screen Copy function menu.

**Table 9.5.5-1 Screen Copy Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Drive C:	Displays the Drive function menu where you can set a destination drive for saving the screen copy.
	F2	File Type BMP <u>P</u> NG	Sets the file format of the screen copy.
	F3	Color Normal	Sets the color of the screen copy.
	F4	Change Focus	Moves the cursor between dialog box and file list.
	F7	Save	Copies the screen.
	F8	Cancel	Returns to the previous menu.

#### Setting a destination drive for screen copies: Drive



Displays the Drive function menu where you can set a destination drive for saving the screen copy.

Press **F1 Drive** on the Screen Copy function menu to display the Drive function menu and set copy.

Options	All connected drives
Default	C

#### Setting a file format for screen copies: File Type



Sets the file format of the screen copy.

Press **F2 File Type** on the Screen Copy function menu to set the copy.

BMP	Saves a copy in the BMP file format.
PNG	Saves a copy in the PNG file format (Default).

**Remote command****Set the file format of the screen copy****Command**

```
:MMEMory:STORe:SCReen:MODE BMP|PNG
```

**Query**

```
:MMEMory:STORe:SCReen:MODE?
```

**Response**

```
<mode>
```

**Parameter**

<mode>	File format
BMP	BMP format
PNG	PNG format (Default)

**Programming Example**

To save a hardcopy in the PNG format.

```
MMEM:STOR:SCR:MODE PNG
```

```
MMEM:STOR:SCR:MODE?
```

```
> PNG
```

## Setting a color scheme for screen copies: Color



Sets the color of the screen copy.

Press **F3 Color** on the Screen Copy function menu to display the Copy Color function menu and set copy.

Normal	Color, the same as the displayed screen (Default)
Reverse	Color, reversed
Monochrome	Monochrome
Reversed Monochrome	Monochrome, reversed

**Remote command****Set the color of the screen hardcopy****Command**

```
:MMEMory:STORe:SCReen:THEME  
NORMal|REVERSE|MONochrome|MREVERSE
```

**Query**

```
:MMEMory:STORe:SCReen:THEME?
```

**Response**

<mode> NORM, REV, MONO or MREV

**Parameter**

<mode>	Settings of colors
NORMal	Color, the same as the displayed screen (Default)
REVerse	Color, reversed
MONochrome	Monochrome
MREVerse	Monochrome, reversed

**Programming Example**

To set the screen hardcopy to reverse color.

```
MMEM:STOR:SCR:THEM REV
MMEM:STOR:SCR:THEM?
> REV
```

Copying screens: Save



Copies the screen.

Press **F7 Save** on the Screen Copy function menu to copy the screen.

**Remote command**

**Specify file and drive names and save the screen copy**

**Command**

```
:MMEMory:STORe:SCReen [<string>[,<device>]]
```

**Parameter**

<string>	File name excluding extension Character string within 100 characters enclosed by double quotes (" ") or single quotes (' ') (excluding extension) The following characters cannot be used: \ / : * ? " ' \ ' < >   Automatically named as "Copy_[Date]_[Additional number].bmp" or "Copy_[Date]_[Additional number].png" when omitted. The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.
<device>	Number of the drive
Options	A to Z, currently selected drive when omitted



**Details**

A space or dot “.” at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

A destination path to save the file is the following directory in the specified drive.

Anritsu\MG3710A\User Data\COPY Files\

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

**Programming Example**

To name the screen copy as “TEST” and save it in D drive.

```
MMEM:STOR:SCR "TEST",D
```

Operation method

**Example: To name the currently displayed screen as "ABC" and save it in monochrome.**

1. Press **Copy** of the panel key to display the **Screen Copy** dialog box, the **File List** dialog box, and the Screen Copy function menu.
2. Press **F1 Drive** to select a destination drive.
 

Options	All connected drives
Default	C
3. Press **F2 File Type** to set a file format of the screen copy to “BMP”.
4. Press **F3 Color** to set colors of the screen copy to “Monochrome”.
5. Enter "ABC" for a file name in the text box in the **Screen Copy** dialog box. By default, the “Copy [Date]\_Additional number” is displayed in the text box.
6. Press **F7 Save**. The file with the entered file name is saved, and the Screen Copy dialog box closes. To return to the previous screen without saving the Copy file, press **F8 Cancel**.

**Note:**

When you input a file name, an extension is automatically added. You cannot specify an extension.

The maximum 100 characters are allowed for a file name.

Destination path: Anritsu\MG3710A\User Data\COPY Files\

Default destination name:

Copy[Date]\_[Additional number].bmp

or Copy[Date]\_[Additional number].png

The additional number will be the minimum three-digit numerical number within 000 to 999 which does not exist.

Characters available for file names are displayed on the character pallet.

The following characters cannot be used:

\ / : \* ? " ' < > |

A space or dot “.” at the beginning or the end of a file name causes a file name error, and the file cannot be saved.

Up to 1000 files can be saved in a single folder. Saving more than 1000 files in a folder cause an error, and the file cannot be saved.

## 9.5.6 Functions specific to remote commands

This section describes the functions available only for remote commands.

### Screen display On/Off function

Turns the LCD backlight and the display ON/OFF. Turning Off the display quickens operations because drawing is omitted.

#### Remote command

#### Turn the display On/Off

##### Command

```
:DISPlay:ENABle <boolean>
```

##### Query

```
:DISPlay:ENABle?
```

##### Response

```
<boolean>          0 or 1
```

##### Parameter

```
<boolean>          Screen display On/Off
OFF|0              Does not display.
ON|1               Displays (Default)
```

#### Details

When you press the **Local**, the LCD backlight automatically turns ON.

#### Programming Example

To disable displaying screens.

```
DISP:ENAB OFF
DISP:ENAB?
> 0
```

## Screen power On/Off function

Turns the screen power and display On/Off. Turning the screen power Off with this command can reduce the radiated interference from the monitor. However, operating a mouse, key board, panel key, and touch panel turns the power on again with the control of Windows.

### Remote command

#### Turn On the screen power

##### Command

:DISPlay:POWer:ON

#### Turn Off the screen power

##### Command

:DISPlay:POWer:OFF

#### Programming Example

To turn Off the screen power.

```
DISP:POW:OFF
```

## 9.5.7 Calibration



Press **Cal** of the panel key to display the Calibration function menu.

**Table 9.5.7-1 Calibration Function Menu**

Page	Key No.	Menu Display	Function
1	F1	Calibrate Level	Performs the level calibration. Refer to 5.3.6 "Calibrate Level".
	F2	I/Q Cal	Displays the IQ Calibration function menu to set the settings related to I/Q quadrature modulator calibration. Refer to 7.6.1 "I/Q Calibration".
	F3	Internal Channel Correction <u>Off</u> On	Enables/disables the baseband in-band correction. Refer to 7.6 "IQ Modulation".
	F8	Cancel	Returns to the menu before this menu is opened.


**Note:**

- Execute Calibrate Level while the device to be tested is connected to the RF connector of the MG3710A/MG3740A.
- Executing Calibrate Level with the RF connector opened may degrade the level accuracy of output signals because of reflection.

## 9.6 Touch Panel

The MG3710A/MG3740A has the touch panel function. Aged deterioration of touch panels may cause constellations to be less accurate than at the time of deployment. In such a case, we recommend you to calibrate them again. This section describes how to calibrate them. For details, refer to the operation manual for the DMC touch panel application included in the attached CD.

To calibrate the touch panel:

1. Press  on the front panel or right click, and click the **Show the Desktop** on the displayed menu.
2. Select **Start** → **All Program** → **DMC** → **DMC Touch Panel Configuration** to start the property.

When the property starts, the **User Account Control** may be displayed. Then, click **Yes**.

3. In the setting tool, click the **Calibration** button on the upper left. Set calibration screen points (Calibration points) and calibration timeout (Timeout(s)) in second.

**Note:**

Do not change other settings.

4. In the setting tool, click the **Calibration** button on the upper right. The calibration screen is displayed.
5. Touch calibration points, which are intersection points in the calibration screen and displayed sequentially. When you touch one calibration point, the next one is displayed.
6. After touching all calibration points, the **OK** button is displayed. When you touch all points successfully, press the **OK** button.

**Note:**

When you touch items other than calibration points by mistake, press the Esc key or just wait for 15 seconds\* with doing nothing. The **Timed out** dialog box is displayed after 15 s. Press the **OK** button to discard the executed calibration without saving it and return to the status for performing calibration again. Pressing **Cancel** returns to step 4 in the procedure.

\* 15 seconds is the default timeout value. It can be changed at Timeout(s).

## 9.7 Setting Windows

The MG3710A/MG3740A uses Microsoft Windows Embedded Standard 2009 or Windows 7 Professional (hereinafter, referred to as “Windows”) as the operating system. Settings for Windows and the system can be operated by connecting a mouse and a keyboard.

This section describes how to perform operations on Windows installed to the MG3710A/MG3740A and general notes.

### Setting Windows

The MG3710A/MG3740A is set to default settings at factory shipment so as to perform optimal measurements. Changing the Windows settings is outside the scope of operation warranty. In addition, performance may drop or functions may not operate correctly when Windows settings are changed. Carefully read the general notes of this section when changes to Windows settings are required.

When the system fails to operate correctly due to Windows operation, execute system recovery functions to restore the MG3710A/MG3740A to its status at factory shipment. Refer to 9.7.6 “System Recovery Functions” for details.

---

### **WARNING**

**MG3710A/MG3740A operations are not guaranteed when Windows settings are changed from their default shipment status, or when a program not guaranteed by Anritsu Corporation is installed.**

**Windows Embedded prohibits the installation of applications by user.**

---

---



### **WARNING**

**Performing system recovery will cause software installation (including updates) after factory shipment of the MG3710A/MG3740A and application settings to be lost. In addition, data (measurements, parameters, etc.) recorded by the customer may be deleted depending on the method to perform system recovery.**

---


### 9.7.1 Displaying Windows desktop

Connect a mouse and a keyboard to operate Windows. Use the USB mouse included as standard equipment and a compatible keyboard (USB).

The following are methods to display the Windows Desktop. To display applications of the MG3710A/MG3740A again, press  or , or select an application in the Windows Taskbar.

#### Mouse

Click the “Minimize” button located in the upper right corner of the application window of the MG3710A/MG3740A. Minimizing all applications displays the Desktop.

Press  on the front panel or right click, and click the **Show the Desktop** on the displayed menu.

#### Keyboard

Pressing the [Windows] key + [D] key minimizes all windows and displays the Windows Desktop.



## 9.7.2 Setting control panel

Various Windows settings can be configured using the Control Panel. The following describes general notes on each setting. Although each setting can be set without using the Control Panel, use within the scope of the following restrictions (Table 9.7.2-1 and 9.7.2-2).

Avoid changing settings listed in Table 9.7.2-1 and 9.7.2-2.

Click **Start** in the Taskbar and then click **Control Panel** to open the Control Panel. The Taskbar is displayed by moving the cursor to the bottom edge of the screen.




Figure 9.7.2-1 Control Panel (Windows Embedded)

Table 9.7.2-1 Description of Control Panel (Windows Embedded)

















Setting Type	Description
	<p><u>Add Hardware</u></p> <ul style="list-style-type: none"> <li>Do not delete devices already installed, or update or remove drivers.</li> <li>The MG3710A/MG3740A may not operate normally due to conflicts with device drivers when new hardware is added.</li> </ul>
	<p><u>Add or Remove Programs</u></p> <ul style="list-style-type: none"> <li>Do not update or remove programs installed at factory shipment.</li> <li>MG3710A/MG3740A operations are not guaranteed when programs not guaranteed by Anritsu Corporation are installed.</li> </ul>
	<p><u>Administrative Tools</u></p> <ul style="list-style-type: none"> <li>Do not change settings.</li> </ul>
	<p><u>Automatic Update</u></p> <ul style="list-style-type: none"> <li>Not available</li> </ul>
	<p><u>Date and Time</u></p> <ul style="list-style-type: none"> <li>You can change the date, time and time zone.</li> <li>Internet Time is set to Off at factory shipment. Operations may be affected; therefore, do not change this setting.</li> </ul>
	<p><u>Display</u> <u>Intel® GMA Driver for Mobile</u></p> <ul style="list-style-type: none"> <li>This setting must be changed when connecting an external monitor to the VGA connector of the MG3710A/MG3740A for use. See 9.7.3 “Using external display” for details.</li> <li>Changing the screen resolution, refresh rate or monitor power management, or enabling the screen saver may cause operations to be performed abnormally.</li> </ul>
	<p><u>Fonts</u></p> <ul style="list-style-type: none"> <li>Fonts required for applications of the MG3710A/MG3740A are installed at factory shipment; therefore, do not delete these fonts.</li> </ul>

Table 9.7.2-1 Description of Control Panel (Windows Embedded) (Continued)

Setting Type	Description
	<p><u>Network Connections</u></p> <ul style="list-style-type: none"> <li>• TCP/IP settings may change when the MG3710A/MG3740A is remote-controlled via the Ethernet. Refer to Appendix E.3.2 “Ethernet interface settings” for details.</li> <li>• The IP address is set to use DHCP at factory shipment. Ensure that the network administrator settings are appropriate when connecting the MG3710A/MG3740A to a network.</li> </ul>
	<p><u>Power Options</u></p> <ul style="list-style-type: none"> <li>• The settings for the Auto Power Off function (Turn off Monitor) of the display can be changed.</li> <li>• The Power Off function of the hard disk (Turn off Hard Disks) is disabled (Never). Do not change settings.</li> <li>• Do not change power option settings other than those described above. The MG3710A/MG3740A will not operate normally after recovering from hibernation.</li> </ul>
	<p><u>Printer and Faxes</u></p> <ul style="list-style-type: none"> <li>• Printers and fax machines can be set. However, operations are not guaranteed in the event print drivers or relevant applications affect the MG3710A/MG3740A.</li> </ul>
	<p><u>Regional and Language Options</u></p> <ul style="list-style-type: none"> <li>• Do not change this setting. Applications may not operate normally.</li> </ul>
	<p><u>Security Center</u></p> <ul style="list-style-type: none"> <li>• Firewall settings are set to Off at factory shipment. When settings are set to On, a dialog for checking whether the Windows Firewall blocks applications of the MG3710A/MG3740A when the applications are started the next time is displayed. Select “Unblock” at this time.</li> <li>• Antivirus software is not installed at factory shipment. The remote control function using the Ethernet of the MG3710A/MG3740A and IQproducer may not operate in the event functions for blocking external communications are operating.</li> <li>• Warnings from the Security Center are set to not be displayed at factory shipment.</li> </ul>

**Table 9.7.2-1 Description of Control Panel (Windows Embedded) (Continued)**

Setting Type	Description
	<p><u>System</u></p> <ul style="list-style-type: none"> <li>• The Computer Name can be changed. The name is set as “SN” + “Serial Number” at factory shipment.</li> <li>• Do not change Hardware or Advanced settings.</li> </ul>
	<p><u>Taskbar and Start Menu</u></p> <ul style="list-style-type: none"> <li>• Do not change settings.</li> </ul>
	<p><u>User Accounts</u></p> <ul style="list-style-type: none"> <li>• Automatic login is set under the following settings at factory shipment. Do not change the User Account settings shown below. <ul style="list-style-type: none"> <li>Account Name           “ANRITSU”</li> <li>Password               “anritsu”</li> <li>Account Type           Computer Administrator</li> </ul> </li> <li>• New user accounts can be created. Specify “Computer Administrator” for the account type of the user account to be created. Applications will not startup normally with user accounts created using Limited (Power User).</li> </ul>
	<p><u>Windows Firewall</u></p> <ul style="list-style-type: none"> <li>• Firewall settings are set to Off at factory shipment. When settings are set to On, a dialog for checking whether the Windows Firewall blocks applications of the MG3710A/MG3740A when applications are started the next time is displayed. Be sure to select “Unblock” at this time.</li> </ul>




Figure 9.7.2-2 Control Panel (Windows 7)

**Table 9.7.2-2 Control Panel (Windows 7)**


















Setting Type	Description
	<p><u>Administrative Tools</u></p> <ul style="list-style-type: none"> <li>• Configures computer management related settings.</li> <li>• Do not change this setting.</li> </ul>
	<p><u>Date and Time</u></p> <ul style="list-style-type: none"> <li>• Sets date, time and time zone.</li> <li>• These settings may be changed if necessary.</li> <li>• Internet Time is set to Off at factory shipment. Operations may be affected; therefore, do not change this setting.</li> </ul>
	<p><u>Device Manager</u></p> <ul style="list-style-type: none"> <li>• Displays and changes hardware settings.</li> <li>• Do not delete devices already installed, or update or remove drivers.</li> <li>• The MG3710A/MG3740A may not operate normally due to conflicts with device drivers when new hardware is added.</li> </ul>
	<p><u>Device and Printers</u></p> <ul style="list-style-type: none"> <li>• Displays and manages devices, printers and print jobs.</li> <li>• Printers and fax machines can be set. However, operations are not guaranteed in the event print drivers or relevant applications affect the MG3710A/MG3740A.</li> </ul>
	<p><u>Display</u></p> <ul style="list-style-type: none"> <li>• Changes display settings for easier reading of screen displays.</li> <li>• This setting must be changed when connecting an external monitor to the VGA connector of the MG3710A/MG3740A for use. See 9.7.3 “Using external display” for details.</li> <li>• Changing the screen resolution, refresh rate or monitor power management, or enabling the screen saver may cause operations to be performed abnormally.</li> </ul>
	<p><u>Fonts</u></p> <ul style="list-style-type: none"> <li>• Adds, updates and manages computer fonts.</li> <li>• Fonts required for applications of the MG3710A/MG3740A are installed at factory shipment; therefore, do not delete these fonts.</li> </ul>
	<p><u>Networking and Sharing Center</u></p> <ul style="list-style-type: none"> <li>• Checks network status, changes network settings, and sets file and printer sharing.</li> <li>• When performing remote control over Ethernet, sometimes the TCP/IP settings are changed. For details, refer to Appendix E.3.2 “Setting Ethernet Interface”.</li> <li>• The IP address is set to use DHCP at factory shipment. Ensure that the network administrator settings are appropriate when connecting the MG3710A/MG3740A to a network.</li> </ul>

Table 9.7.2-2 Control Panel (Windows 7) (Continued)

Setting Type	Description
	<p><u>Power Options</u></p> <ul style="list-style-type: none"> <li>• Selects computer power management methods to optimize performance with different power sources.</li> <li>• The settings for the Auto Power Off function (Turn off Monitor) of the display can be changed.</li> <li>• The Power Off function of the hard disk (Turn off Hard Disks) is disabled (Never). Do not change this setting.</li> <li>• Do not change power option settings other than those described above. The MG3710A/MG3740A will not operate normally after recovering from hibernation.</li> </ul>
	<p><u>Programs and Features</u></p> <ul style="list-style-type: none"> <li>• Installs and changes programs installed on computer.</li> <li>• Do not update or remove programs installed at factory shipment.</li> <li>• MG3710A/MG3740A operations are not guaranteed when programs not guaranteed by Anritsu Corporation are installed.</li> </ul>
	<p><u>Recovery</u></p> <ul style="list-style-type: none"> <li>• Not available</li> </ul>
	<p><u>Region and Language</u></p> <ul style="list-style-type: none"> <li>• Customizes language, numeric, time and date style settings.</li> <li>• Do not change this setting. Applications may not operate normally.</li> </ul>
	<p><u>System</u></p> <ul style="list-style-type: none"> <li>• Displays information on computer and changes hardware, performance and remote connection settings.</li> <li>• The Computer Name can be changed. The name is set as “SN” + “Serial Number” at factory shipment.</li> <li>• Do not change Hardware or Advanced settings.</li> </ul>
	<p><u>Taskbar and Start Menu</u></p> <ul style="list-style-type: none"> <li>• Customizes items and displays in Start menu and Taskbar.</li> <li>• Do not change this setting.</li> </ul>
	<p><u>User Account</u></p> <ul style="list-style-type: none"> <li>• Sets computer user accounts and password settings.</li> <li>• Automatic login is set under the following settings at factory shipment. Do not change the User Account settings shown below. <ul style="list-style-type: none"> <li>Account Name           “ANRITSU”</li> <li>Password                “anritsu”</li> <li>Account Type            Computer Administrator</li> </ul> </li> <li>• New user accounts can be created. Specify “Computer Administrator” for the account type of the user account to be created. Applications will not startup normally with user accounts created using Limited (Power User).</li> </ul>

**Table 9.7.2-2 Control Panel (Windows 7) (Continued)**

Setting Type	Description
	<u>Windows Anytime Upgrade</u> <ul style="list-style-type: none"><li>• Not available</li></ul>
	<u>Windows Firewall</u> <ul style="list-style-type: none"><li>• Helps assure security against hackers and malicious software by setting firewall security.</li><li>• Firewall settings are set to Off at factory shipment. When settings are set to On, a dialog for checking whether the Windows Firewall blocks applications of the MG3710A/MG3740A when applications are started the next time is displayed. Be sure to select “Unblock” at this time.</li><li>• Antivirus software is not installed at factory shipment. Blocking external communications may prevent remote control over Ethernet and IQproducer operations.</li></ul>
	<u>Windows Update</u> <ul style="list-style-type: none"><li>• Not available</li></ul>



### 9.7.3 Using external display

An external display can be connected to the VGA connector on the rear side of the MG3710A/MG3740A, to display screens of the MG3710A/MG3740A and show multiple displays. The following describes the operation procedure for this function.




Figure 9.7.3-1 Intel® GMA Driver Setting Screen

<Procedure>

1. Connect the display to the VGA connector on the rear side of the MG3710A/MG3740A.  
When using Windows 7, the connected external display and the main unit display are set automatically to the same display (mirroring).
2. Display the Intel® GMA Driver Settings screen using any of the following methods.
  - Execute “Intel® GMA Driver for Mobile” from the Windows Control Panel. For the Control Panel display method, refer to sections 9.7.1 “Displaying Windows Desktop” and 9.7.2 “Setting Control Panel”.
  - Press **Ctrl + Alt + F12** on the keyboard.

3. Change the Display Devices settings as shown below:

When not using an external display

- Single Display Notebook

When using only an external display

- Single Display Monitor

When displaying the MG3710A/MG3740A display to an external display

- Multiple Display           Twin or Intel® Dual Display Clone
- Primary Device            Notebook  
   (MG3710A/MG3740A display)
- Secondary Device         Monitor

When displaying with the MG3710A/MG3740A and external display connected

- Multiple Display         Extended Desktop
- Primary Device         Notebook  
   (MG3710A/MG3740A display)
- Secondary Device        Monitor

4. Press either the **OK** or **Apply** button.

---

 **CAUTION**

---

Turning the MG3710A/MG3740A power On when an external display is not connected to the VGA connector initializes to mainframe display only. When continuously using an external display, it is recommended to keep the external monitor connected for use.

---

---

 **CAUTION**

---

Do not change the resolution, refresh rate or power management settings of the mainframe monitor.

---

#### **9.7.4 General notes**

Besides the general notes on the previous section, note the following operations.

- Operation of the MG3710A/MG3740A is guaranteed at factory shipment status. Operation is not guaranteed when programs, including Windows Update, are added or updated.
- When third party software is installed and/or executed, this may affect MG3710A/MG3740A operations.
- Note that the MG3710A/MG3740A may not operate normally when registries are changed.

### 9.7.5 Storage device configuration

The MG3710A/MG3740A has a built-in hard disk for storing the operating system, application software, user data, and the like.

The hard disk of the MG3710A/MG3740A consists of the following partitions.

#### Volume C : System Disk

Windows, application software and files required for operation of the MG3710A/MG3740A are stored. Also, it is used as the destination for file input or output for application software of the MG3710A/MG3740A. The MG3710A/MG3740A may not operate normally when data necessary for operations of the MG3710A/MG3740A is changed or deleted.

#### Volume D : 2nd Hard Disk (when the 2ndary HDD option is installed)

This volume is used mainly for inputting files to and as the output destination for the application software of the MG3710A/MG3740A. Adding data to this volume or deleting data on it will not affect MG3710A/MG3740A operations.

A USB memory, used for installing application software and inputting or outputting data, is included as standard equipment with the MG3710A/MG3740A.

#### Volume D : USB memory (when the 2ndary HDD option is not installed)

#### Volume E : USB memory (when the 2ndary HDD option is installed)

Note the following items when operating MG3710A/MG3740A:


- Do not change the partition configuration. Doing so may affect system operation.
- Do not format the hard disk of the MG3710A/MG3740A. Besides the above, data for system recovery is stored within this hard disk. Recovery may become inoperable when the hard disk is formatted.
- The volumes and folders described above are not set to be shared at factory shipment. Although sharing is an effective means for transferring data to and from an external PC, be mindful of security when connecting to a network.

## 9.7.6 System Recovery Functions

The MG3710A/MG3740A has system recovery functions to restore data on the hard disk to the factory shipment status. These functions can be used in the event of system instability.

The MG3710A/MG3740A comes with factory-installed recovery software, Phoenix Recover Pro or Paragon Drive Backup. To confirm the installed recovery software, start the MG3710A/MG3740A, and press the **F4** key on the BIOS screen to start the recovery software.

<Procedure>

1. Disconnect the MG3710A/MG3740A from the network if connected.
2. Connect the keyboard and mouse to the mainframe, and then turn the MG3710A/MG3740A power On. The BIOS screen will appear in a few seconds after.
3. Press the **F4** key (not  on the front panel of the mainframe) while the screen in Step 2 is displayed.
4. Only when the screen displays the message “Press F4 to start recovery from Backup Capsule”, press the **F4** key again.
5. According to the software instructions on the screen, perform a system recovery.

Phoenix Always

Refer to “Phoenix Recover Pro” in this section.

Paragon Drive Backup

Refer to “Paragon Drive Backup” in this section.

---

### CAUTION

To execute these functions, understand the following items for their use.

- All applications and updates added after factory shipment will be lost. Additionally, all data recorded to C Drive will be restored to the factory shipment status. Backup important data before executing these functions.
  - For Windows 7, the area of D Drive can be restored to the factory shipment status depending on the function to be selected. So as not to lose important user data due to incorrect operations, it is recommended to backup data in D Drive before executing these functions.
  - Data deleted by these functions cannot be restored.
-

 **CAUTION**

- **When the Paragon Drive Backup software is installed, the backup data is saved to an unknown partition on the Disk 0. If the unknown partition is accidentally deleted, the backup data required for system recovery is deleted as well.**

The backup can be obtained by copying the User Data folder in the path: C:\Anritsu\MG3710A. For Windows 7, copy the User Data folder in the path: D:\Anritsu\MG3710A as well, because some data may be stored there.

## Phoenix Recover Pro

This subsection describes how to perform a system recovery with factory-installed recovery software “Phoenix Recover Pro”.

### Restore System drive (partition) only

This function restores only C Drive, in which Windows, application software, and files required for operations of the MG3710A/MG3740A are stored, to the factory shipment status.

### Restore entire hard disk

This function restores C Drive to the factory shipment status. For Windows 7, it restores D Drive to the factory shipment status as well, deleting all data.

### <Procedure>

1. After the screen displaying “Phoenix Always” appears, the following alternatives are displayed on the screen:

Restore System drive (partition) only

Recovers only C Drive.

Restore entire hard disk

Recovers C Drive (including D Drive for Windows 7).

Select one of the two alternatives, and then click [NEXT]. To cancel, press and hold the [Power] button of the mainframe to power off.

2. After clicking [NEXT], the confirmation screen appears. Click [OK] to start a system recovery. Although the required time for recovery varies depending on the conditions, it normally takes between 10 and 30 minutes. The progress of recovery is shown during recovery. Although the progress indicator may close during recovery, this is a normal operation.

The MG3710A/MG3740A will restart automatically then normal startup will be executed.

## Paragon Drive Backup

This subsection describes how to perform a system recovery with factory-installed recovery software “Paragon Drive Backup”.

### Type: Partition

This function restores only C Drive, in which Windows, application software, and files required for operations of the MG3710A/MG3740A are stored, to the factory shipment status.

### Type: Disk

This function restores C Drive to the factory shipment status. For Windows 7, it restores D Drive to the factory shipment status as well, deleting all data.

### <Procedure>

1. After the screen displaying “Drive Backup” appears, the following alternatives are displayed on the screen:

#### Normal Mode

#### Safe Mode

Select [Normal Mode] with the arrow keys, and then press the **Enter** key.

2. When the menu screen appears in about a minute, double-click [Simple Restore Wizard].
3. The [Paragon Simple Restore Wizard] appears, so click [Next].
4. The following alternatives are displayed on the screen:

#### Type: Partition

Recovers only C Drive.

#### Type: Disk

Recovers C Drive (including D Drive for Windows 7).

Double-click either of them, and then click [NEXT].

5. When the confirmation screen appears, click [Yes] to start a system recovery. Then, the [Progress information] dialog box appears, and the recovery process starts.  
Do not click [Cancel] when a system recovery is in progress. Although the required time for recovery varies depending on the conditions, it normally takes between 10 and 30 minutes. The progress of recovery is shown during recovery. Although the progress indicator may close during recovery, this is a normal operation.

6. Upon completion of the recovery process, click [Close]. ([Close] appears after the recovery process is completed.)
7. When the completion screen appears, click [Finish] to return to the menu screen described in Step 5. Click [Reboot the computer] to reboot the MG3710A/MG3740A, or click [Power off] to turn the power Off.



# *Chapter 10 Performance Test*

---

This chapter describes measurement devices, setup methods, configuration procedures, and performance test procedures required for performing performance tests as preventive maintenance.

10.1	Overview of Performance Test .....	10-2
10.1.1	Performance test .....	10-2
10.1.2	MG3710A performance test items and instruments used .....	10-3
10.2	Frequency Performance Test .....	10-4
10.2.1	Frequency.....	10-4
10.3	Output Level Performance Test.....	10-7
10.3.1	Output level frequency characteristics .....	10-7
10.4	Vector Modulation Performance Test .....	10-11
10.4.1	Vector accuracy.....	10-11

## 10.1 Overview of Performance Test

### 10.1.1 Performance test

Performance tests are performed as preventive maintenance in order to prevent degradation of the performance. Perform the tests when required for acceptance inspection, routine inspection, and performance verification after repairs.

If the tests results do not meet the specifications, failures are considered. Contact an Anritsu Service and Sales office.

---

 **CAUTION**

---

**When the performance tests are performed, warm up the MG3710A/MG3740A and devices to be used with the tests for 30 minutes or more to stabilize them sufficiently. Also maximum measurement accuracy requires conducting performance tests under ambient temperatures and with little AC power supply voltage fluctuations (100 to 120 VAC, 200 to 240 VAC), as well as the absence of noise, vibrations, dust, humidity, and other problems.**

---

### 10.1.2 MG3710A/MG3740A performance test items and instruments used

The MG3710A/MG3740A performance test items and instruments to be used for each item are described in Table 10.1.2-1.

**Table 10.1.2-1 Performance Test Items and Instruments Used**

Item		Summary	Main Instrument (Anritsu Model Name)
Frequency	Frequency	The frequency is set and the output frequency is measured.	Counter (MF2412C)
Output level	Output level frequency characteristics	The absolute accuracy (frequency characteristics) is measured by using a power meter.	Power Meter (ML2437A) Power Sensor (MA24002A)
Vector modulation	Vector accuracy	A modulated pattern signal is generated through internal modulation and the vector accuracy is measured by using a Signal Analyzer.	Signal Analyzer (MS2690A/91A/92A) W-CDMA/HSPA Downlink Measurement Software (MX269011A) GSM/EDGE Measurement Software (MX269013A) LTE Downlink Measurement Software (MX269020A)

For items judged as important, perform the performance tests regularly as the preventive maintenance. It is recommended that those tests are performed around once or twice a year.

## 10.2 Frequency Performance Test

### 10.2.1 Frequency

Set the frequency of the MG3710A/MG3740A within 9 kHz to upper limit frequency and measure the frequency with the frequency counter (MF2412C) to confirm the set frequency is correctly output.

Test standards

Frequency range

9 kHz to 2700 MHz

(when MG3710A/MG3740A-032/062/162 is installed)


9 kHz to 4000 MHz

(when MG3710A/MG3740A-034/064/164 is installed)

9 kHz to 6000 MHz


(when MG3710A/MG3740A-036/066/166 is installed)

Resolution 0.01 Hz



Test procedure

Set the frequency within 9 kHz to upper limit frequency of the MG3710A/MG3740A.

1. Connect the reference signal output (10 MHz) of the frequency counter to the external reference input (REF Input) of the MG3710A/MG3740A for frequency synchronization.
2. Press  to preset the MG3710A/MG3740A.
3. Set the output level of the MG3710A/MG3740A to 0 dBm and turn On the 1st RF Output.

4. Set the output frequency of the MG3710A/MG3740A to the value [FR (x)] in Table 10.2.1-1.
  - 4.1 When  $x = 1$ 

Connect RF Output of this equipment to Input2 of the frequency counter.

Select **Input2** at **Input >F1 Input CH**.

Select **1 M  $\Omega$**  at **Input >F2 Impd2**.

Set the measurement resolution of the frequency counter to 100 Hz.
  - 4.2 When  $x = 2, 3, 4$ 

Connect RF Output of this equipment to Input2 of the frequency counter.

Select **Input2** at **Input >F1 Input CH**.

Select **50  $\Omega$**  at **Input >F2 Impd2**.

Set the measurement resolution of the frequency counter to 1 MHz.
  - 4.3 When  $x = 5$  to 16

Connect RF Output of this equipment to Input1 of the frequency counter.

Select **Input1** at **Input >F1 Input CH**.

Set the measurement resolution of the frequency counter to 1 MHz.
5. Check whether the frequency set to the MG3710A/MG3740A is equal to the frequency displayed on the frequency counter.
6. Change the frequency [FR (x)] according to Table 10.2.1-1 to repeat the measurement.
7. If the 2nd RF is installed, change the connection to the 2nd RF Output to perform Step 3 to 6.

**Table 10.2.1-1 Frequency Setting Table**

<b>x</b>	<b>FR (x) (MHz)</b>
1	0.009
2	100
3	300
4	600
5	1000
6	1500
7	2000
8	2500
9	2700
10	3000
11	3500
12	4000
13	4500
14	5000
15	5500
16	6000

X ≥ 10 are available only when the Upper limit frequency 4 GHz and 6 GHz options are installed.

X ≥ 13 are available only when the Upper limit frequency 6 GHz option is installed.

## 10.3 Output Level Performance Test

### 10.3.1 Output level frequency characteristics

Measure the level of each frequency of the MG3710A/MG3740A for the reference level with the power meter (Anritsu ML2437A) and power sensor (MA24002A).

Test standards

Absolute accuracy (18° to 28°C in CW mode)

**Table 10.3.1-1 Test Standards**

Composition	Output Level	Frequency				
		50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz	3 GHz< , $\leq$ 4 GHz	4 GHz< , $\leq$ 5 GHz	5 GHz< , $\leq$ 6 GHz
1st RF	-40 dBm< <+2 dBm	$\pm 0.5$ dB	$\pm 0.5$ dB	$\pm 0.7$ dB	$\pm 0.8$ dB	$\pm 0.8$ dB
2nd RF	-40 dBm< <+2 dBm	$\pm 0.5$ dB	$\pm 0.5$ dB	$\pm 0.7$ dB	$\pm 0.8$ dB	$\pm 0.8$ dB


For the 1st RF, when Option-043/143 is not installed.

For the 2nd RF, when Option-073/173 is not installed.

Composition	Output Level	Frequency				
		50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz	3 GHz< , $\leq$ 4 GHz	4 GHz< , $\leq$ 5 GHz	5 GHz< , $\leq$ 6 GHz
1st RF	-40 dBm< <-1 dBm	$\pm 0.5$ dB	$\pm 0.5$ dB	$\pm 0.7$ dB	$\pm 0.8$ dB	$\pm 0.8$ dB
2nd RF	-40 dBm< <-1 dBm	$\pm 0.5$ dB	$\pm 0.5$ dB	$\pm 0.7$ dB	$\pm 0.8$ dB	$\pm 0.8$ dB


For the 1st RF, when Option-043/143 is installed.

For the 2nd RF, when Option-073/173 is installed.



Measure the level according to Table 10.3.1-2 “Frequency Table”.

#### Test procedure

1. Press  on the MG3710A/MG3740A and ML2437A to preset them.
2. Connect the MA24002A to the Cal Output connector of the ML2437A.
3. Calibrate the ML2437A.
4. Set Average Mode of the ML2437A to “Moving”.
5. Set Average Count of the ML2437A to “10”.
6. Connect the MA24002A to the RF Output connector of the ML3710A.
7. Perform the sensor calibration (zero point and sensitivity) for the ML2437A.
8. Turn On the 1st RF Output of the MG3710A/MG3740A.
9. Set the output level of the MG3710A/MG3740A to the value [LEV (1)] in Table 10.3.1-2.
10. Set frequencies of the MG3710A/MG3740A and ML2437A to the value [FR (1)] in Table 10.3.1-2.
11. Measure the level with the ML2437A.
12. Change the output level [LEV (x)] and frequency [FR (x)] according to Table 10.3.1-2 to repeat Step 9 to 11 to obtain measured values.
13. If the 2nd RF is installed, change the connection of the MA24002A to the 2nd RF Output to perform Step 7 to 12.



**Table 10.3.1-2 Absolute Accuracy Measurement Frequency Setting**  
**Table 1**

<b>x</b>	<b>FR (x) (MHz)</b>	<b>LEV (x) (dBm)</b>
1	50	-5
2	97	-5
3	98	-7
4	100	-7
5	399	-7
6	400	-7
7	500	-7
8	1000	-7
9	1500	-7
10	2000	-7
11	2500	-7
12	2700	-7
13	3000	-7
14	3001	-7
15	3500	-7
16	4000	-7
17	4001	-7
18	4500	-7
19	5000	-7
20	5001	-7
21	5500	-7
22	6000	-7

X ≥ 13 are available only when the Upper limit frequency 4 GHz and 6 GHz options are installed.

X ≥ 17 are available only when the Upper limit frequency 6 GHz option is installed.

For the 1st RF, when Option-043/143 is not installed.

For the 2nd RF, when Option-073/173 is not installed.

**Table 10.3.1-3 Absolute Accuracy Measurement Frequency Setting  
Table 2**

<b>x</b>	<b>FR (x) (MHz)</b>	<b>LEV (x) (dBm)</b>
1	50	-5
2	97	-5
3	98	-10
4	100	-10
5	399	-10
6	400	-10
7	500	-10
8	1000	-10
9	1500	-10
10	2000	-10
11	2500	-10
12	2700	-10
13	3000	-10
14	3001	-10
15	3500	-10
16	4000	-10
17	4001	-10
18	4500	-10
19	5000	-10
20	5001	-10
21	5500	-10
22	6000	-10

X ≥ 13 are available only when the Upper limit frequency 4 GHz and 6 GHz options are installed.

X ≥ 17 are available only when the Upper limit frequency 6 GHz option is installed.

For the 1st RF, when Option-043/143 is installed.

For the 2nd RF, when Option-073/173 is installed.

## 10.4 Vector Modulation Performance Test

### 10.4.1 Vector accuracy

The baseband signal is generated with the internal waveform pattern, and the vector modulation is performed with the MG3710A. The vector error in the modulated RF signal is measured by using a signal analyzer (MS2690A/91A/92A) in which signal analysis software has been installed.

The vector modulation performance test is unnecessary because waveform patterns are not stored in the MG3740A.

#### Test standards

When MG3710A-043/143/073/173 is not installed

##### W-CDMA (Test Model 4)

Output level  $\leq +7$  dBm (When MG3710A-041/141/071/171 is not installed),

Output level  $\leq +13$  dBm (When MG3710A-041/141/071/171 is installed),

Output frequency: 800 to 900 MHz, 1800 to 2200 MHz,

After CAL execution at 18 to 28°C

$\leq 0.62\%$  (rms) (0.6% (rms) typ.)

##### GSM

Output level  $\leq +7$  dBm (When MG3710A-041/141/071/171 is not installed),

Output level  $\leq +13$  dBm (When MG3710A-041/141/071/171 is installed),

Output frequency: 800 to 900 MHz, 1800 to 1900 MHz,

After CAL execution at 18 to 28°C

$\leq 0.84^\circ$  (rms) (0.8° (rms) typ.)

##### EDGE

Output level  $\leq +7$  dBm (When MG3710A-041/141/071/171 is not installed),

Output level  $\leq +13$  dBm (When MG3710A-041/141/071/171 is installed),

Output frequency: 800 to 900 MHz, 1800 to 1900 MHz,

After CAL execution at 18 to 28°C

$\leq 0.84\%$  (rms) (0.8% (rms) typ.)

LTE (20 MHz Test Model 3.1)

Output level  $\leq +7$  dBm (When MG3710A-041/141/071/171 is not installed),

Output level  $\leq +13$  dBm (When MG3710A-041/141/071/171 is installed),

Output frequency 600 to 2700 MHz,

After CAL execution at 18 to 28°C

$\leq 0.82\%$  (rms) (0.8% (rms) typ.)

Output level  $\leq +4$  dBm (When MG3710A-041/141/071/171 is not installed),

Output level  $\leq +10$  dBm (When MG3710A-041/141/071/171 is installed),

Output frequency 3400 to 3800 MHz,

After CAL execution at 18 to 28°C

$\leq 0.82\%$  (rms) (0.8% (rms) typ.)

When MG3710A-043/143/073/173 is installed

W-CDMA (Test Model 4)

Output level  $\leq +4$  dBm (When MG3710A-041/141/071/171 is not installed),

Output level  $\leq +10$  dBm (When MG3710A-041/141/071/171 is installed),

Output frequency: 800 to 900 MHz, 1800 to 2200 MHz,

After CAL execution at 18 to 28°C

$\leq 0.62\%$  (rms) (0.6% (rms) typ.)

GSM

Output level  $\leq +4$  dBm (When MG3710A-041/141/071/171 is not installed),

Output level  $\leq +10$  dBm (When MG3710A-041/141/071/171 is installed),

Output frequency: 800 to 900 MHz, 1800 to 1900 MHz,

After CAL execution at 18 to 28°C

$\leq 0.84\%$  (rms) (0.8% (rms) typ.)

EDGE

Output level  $\leq +4$  dBm (When MG3710A-041/141/071/171 is not installed),

Output level  $\leq +10$  dBm (When MG3710A-041/141/071/171 is installed),

Output frequency: 800 to 900 MHz, 1800 to 1900 MHz,

After CAL execution at 18 to 28°C

$\leq 0.84\%$  (rms) (0.8% (rms) typ.)

LTE (20 MHz Test Model 3.1)

Output level  $\leq +4$  dBm (When MG3710A-041/141/071/171 is not installed),

Output level  $\leq +10$  dBm (When MG3710A-041/141/071/171 is installed),

Output frequency 600 to 2700 MHz,

After CAL execution at 18 to 28°C

$\leq 0.82\%$  (rms) (0.8% (rms) typ.)


Output level  $\leq +1$  dBm (When MG3710A-041/141/071/171 is not installed),

Output level  $\leq +7$  dBm (When MG3710A-041/141/071/171 is installed),


Output frequency 3400 to 3800 MHz,

After CAL execution at 18 to 28°C

$\leq 0.82\%$  (rms) (0.8% (rms) typ.)




Test procedure W-CDMA (Test Model 4)


1. Press  of the MG3710A and MS2690A/91A/92A to preset them.
2. Load the W-CDMA/HSPA Downlink Measurement Software (MX269011A) to the MS2690A/91A/92A.
3. Perform Band Cal. for the MS2690A/91A/92A.
4. Set the MS2690A/91A/92A as follows:
  - Chanel Detection : Test Model 4
  - Origin Ofst. : Incl.
  - ScramblingCode Synchronization : User Defined
  - Storage Mode : Average & Max
  - Average count : 10

5. Turn On the RF Output of the MG3710A.
6. Turn On the vector modulation of the MG3710A to apply modulation with the TestModel\_4 of standard waveform pattern.
7. Set the output level of the MG3710A and the input level of the MS2690A/91A/92A to the values in Table 10.4.1-1.
8. Set frequencies of the MG3710A and MS2690A/91A/92A to the value [FR (1)] in Table 10.4.1-2.
9. Set the Cal Type of IQ Cal. of the MG3710A to DC to perform Cal.
10. Measure EVM (rms) (the maximum value for Storage Count) with the MS2690A/91A/92A.
11. Change the output level and frequency [FR (x)] according to Table 10.4.1-1 and 10.4.1-2 to repeat Step 7 to 10 to obtain measured values.
12. If the 2nd RF is installed, change the connection of the MS2690A/91A/92A to the 2nd RF Output to perform Step 5 to 11.

Test procedure GSM


1. Press  of the MG3710A and MS2690A/91A/92A to preset them.
2. Load the GSM/EDGE Measurement Software (MX269013A) to the MS2690A/91A/92A.
3. Perform Band Cal. for the MS2690A/91A/92A.
4. Set the MS2690A/91A/92A as follows:
  - RF Signal : Normal Burst
  - Modulation : GMSK.
  - Storage Mode : Average & Max
  - Average count : 10
5. Turn On the RF Output of the MG3710A.
6. Turn On the vector modulation of the MG3710A to apply modulation with the NB\_GMSK of standard waveform pattern.
7. Set the output level of the MG3710A and the input level of the MS2690A/91A/92A to the values in Table 10.4.1-1.
8. Set frequencies of the MG3710A and MS2690A/91A/92A to the value [FR (1)] in Table 10.4.1-3.
9. Set the Cal Type of IQ Cal. of the MG3710A to DC to perform Cal.
10. Measure Phase Error (rms) (the maximum value for Storage Count) with the MS2690A/91A/92A.
11. Change the output level and frequency [FR (x)] according to Table 10.4.1-1 and 10.4.1-3 to repeat Step 7 to 10 to obtain measured values.
12. If the 2nd RF is installed, change the connection of the MS2690A/91A/92A to the 2nd RF Output to perform Step 5 to 11.

Test procedure (EGDE)

1. Press  of the MG3710A and MS2690A/91A/92A to preset them.
  2. Load the GSM/EDGE Measurement Software (MX269013A) to the MS2690A/91A/92A.
  3. Perform Band Cal. for the MS2690A/91A/92A.
  4. Set the MS2690A/91A/92A as follows:
    - RF Signal : Normal Burst
    - Modulation : 8PSK
    - Storage Mode : Average & Max
    - Average count : 10
  5. Turn On the RF Output of the MG3710A.
  6. Turn On the vector modulation of the MG3710A to apply modulation with the NB\_8PSK of standard waveform pattern.
  7. Set the output level of the MG3710A and the input level of the MS2690A/91A/92A to the values in Table 10.4.1-1.
  8. Set frequencies of the MG3710A and MS2690A/91A/92A to the value [FR (1)] in Table 10.4.1-4.
  9. Set the Cal Type of IQ Cal. of the MG3710A to DC to perform Cal.
  10. Measure EVM (rms) (the maximum value for Storage Count) with the MS2690A/91A/92A.
-

11. Change the output level and frequency [FR (x)] according to Table 10.4.1-1 and 10.4.1-4 to repeat Step 7 to 10 to obtain measured values.
12. If the 2nd RF is installed, change the connection of the MS2690A/91A/92A to the 2nd RF Output to perform Step 5 to 11.

Test procedure LTE (20 MHz Test Model 3.1)

1. Press  of the MG3710A and MS2690A/91A/92A to preset them.
2. Load the LTE Downlink Measurement Software (MX269020A) to the MS2690A/91A/92A.
3. Perform Band Cal. for the MS2690A/91A/92A.
4. Set the MS2690A/91A/92A as follows:
  - Channel Bandwidth : 20 MHz
  - Test Model: E-TM3.1
  - Analysis Time : 10 Subframe
  - Storage Mode : Average & Max
  - EVM Window Length : W, 136
  - Average count : 10
5. Turn On the RF Output of the MG3710A.
6. Turn On the vector modulation of the MG3710A to apply modulation with the E-TM\_3-1\_20M of standard waveform pattern.
7. Set the output level of the MG3710A and the input level of the MS2690A/91A/92A to the values in Table 10.4.1-1.
8. Set frequencies of the MG3710A and MS2690A/91A/92A to the value [FR (1)] in Table 10.4.1-5.
9. Set the Cal Type of IQ Cal. of the MG3710A to DC to perform Cal.
10. Measure EVM (rms) (the maximum value for Storage Count) with the MS2690A/91A/92A.
11. Change the output level and frequency [FR (x)] according to Table 10.4.1-1 and 10.4.1-5 to repeat Step 7 to 10 to obtain measured values.
12. If the 2nd RF is installed, change the connection of the MS2690A/91A/92A to the 2nd RF Output to perform Step 5 to 11.



**Table 10.4.1-1 Modulation Accuracy Measurement Level**

<b>Composition</b>	<b>For the 1st RF, when Option-043/143 is not installed</b> <b>For the 2nd RF, when Option-073/173 is not installed</b>	<b>For the 1st RF, when Option-043/143 is installed</b> <b>For the 2nd RF, when Option-073/173 is installed</b>
<b>For the 1st RF, when Option-041/14 1 is not installed</b> For the 2nd RF, when Option-071/171 is not installed	W-CDMA: +7 dBm GSM:+7 dBm EDGE:+7 dBm LTE:+7 dBm (600 to 2700 MHz) LTE:+4 dBm (3400 to 3800 MHz)	W-CDMA: +4 dBm GSM:+4 dBm EDGE:+4 dBm LTE:+4 dBm (600 to 2700 MHz) LTE:+1 dBm (3400 to 3800 MHz)
<b>For the 1st RF, when Option-041/14 1 is installed</b> For the 2nd RF, when Option-071/171 is installed	W-CDMA: +13 dBm GSM:+13 dBm EDGE:+13 dBm LTE:+13 dBm (600 to 2700 MHz) LTE:+10 dBm (3400 to 3800 MHz)	W-CDMA: +10 dBm GSM:+10 dBm EDGE:+10 dBm LTE:+10 dBm (600 to 2700 MHz) LTE:+7 dBm (3400 to 3800 MHz)

**Table 10.4.1-2 W-CDMA Test Model 4 Modulation Accuracy Measurement Frequency Table**

<b>x</b>	<b>FR (x) (MHz)</b>
1	800
2	900
3	1800
4	2000
5	2200

**Table 10.4.1-3 GSM Modulation Accuracy Measurement Frequency Table**

<b>x</b>	<b>FR (x) (MHz)</b>
1	800
2	900
3	1800
4	1900

**Table 10.4.1-4 EDGE Modulation Accuracy Measurement Frequency Table**

<b>x</b>	<b>FR (x) (MHz)</b>
1	800
2	900
3	1800
4	1900

**Table 10.4.1-5 LTE (20 MHz Test Model 3.1) Modulation Accuracy Measurement Frequency Table**

<b>x</b>	<b>FR (x) (MHz)</b>
1	600
2	800
3	1500
4	2000
5	2400
6	2700
7	3400
8	3500
9	3600
10	3700
11	3800

# Chapter 11 Maintenance

---

This chapter describes cautions related to daily maintenance, storage, and shipping of the MG3710A/MG3740A, as well as the calibration procedure to be used as preventive maintenance.

11.1	Daily Maintenance and Storage.....	11-2
11.1.1	Daily maintenance .....	11-2
11.1.2	Cautions before long-term storage.....	11-2
11.1.3	How to store USB memory .....	11-3
11.2	Repacking and Transportation upon Return.....	11-4
11.2.1	Repacking.....	11-4
11.2.2	Transportation .....	11-4
11.3	Disposal .....	11-5
11.4	Calibration.....	11-6
11.4.1	Calibration .....	11-6
11.4.2	Device to be used for calibration .....	11-6
11.4.3	Calibrating frequency with oscilloscope .....	11-7
11.5	How to Replace Hard Disk.....	11-10
11.6	Troubleshooting .....	11-12

## 11.1 Daily Maintenance and Storage

### 11.1.1 Daily maintenance

Before maintenance, be sure to turn the power off and unplug it from the AC outlet.

#### Panel surface dirt

When the panel surface dirt is noticeable, or when the MG3710A/MG3740A has been used in a dusty place, or before long-term storage, wipe the MG3710A/MG3740A with a cloth soaked in soapy water and wrung dry.

#### Screen surface dirt

If the screen surface is dirty, first wipe it dry with a soft cloth. When the dirt is terrible, wipe it lightly with a cloth soaked in soapy water and wrung dry.

#### Loose screws

Use a Phillips screwdriver to tighten screws.

### 11.1.2 Cautions before long-term storage

Before storage, wipe off dust, grime, other dirt, or stains attached to the MG3710A/MG3740A. Put the power cable, DVD-R and other accessories in the accessory box and store with the MG3710A/MG3740A. Also, avoid storage in the following places.

- In direct sunlight for extended periods
- Outdoors
- In excessively dusty locations
- Where condensation may occur
- In liquids, such as water, oil, or organic solvents, and medical fluids, or places where these liquids may adhere
- In salty air or in place chemically active gases (sulfur dioxide, hydrogen sulfide, chlorine, ammonia, nitrogen oxide, or hydrogen chloride etc.) are present
- Where toppling over may occur
- In the presence of lubricating oil mists
- At low atmospheric pressure
- In the presence of frequent vibration or mechanical shock, such as in cars, ships, or airplanes
- Where temperature range and relative humidity exceed  $-20^{\circ}$  to  $60^{\circ}\text{C}$  and 90%, respectively

**Recommended storage conditions**

For long-term storage, it is recommended that the MG3710A/MG3740A is stored within the ranges of the environmental conditions below along with that the conditions for cautions before storage above are met.

- Temperature           The range of 0 to 45°C
- Humidity               The range of 40 to 80%
- A place with small change of temperature and humidity during a day

### **11.1.3 How to store USB memory**

Store a USB memory in a place with temperature 4 to 53°C and humidity of 8 to 90% (no condensation). Also, avoid storing it in places below:

- Dusty and humid places
- Places near magnetized items
- Places exposed to direct sunlight
- Places near thermal sources

## **11.2 Repacking and Transportation upon Return**

Cautions needed on transportation of the MG3710A/MG3740A are explained.

### **11.2.1 Repacking**

#### **Repacking**

Repack the MG3710A/MG3740A using the packing material (box) in which the MG3710A/MG3740A had been packed first. If the packing material has been discarded or damaged, repack the MG3710A/MG3740A with the method below:

1. Pack the MG3710A/MG3740A with vinyl or others.
2. Prepare a cardboard box, wooden box, or aluminum box which is large enough for the MG3710A/MG3740A and buffer material to surround the MG3710A/MG3740A to be put in the box.
3. Put the MG3710A/MG3740A in the box. Place the buffer material around the MG3710A/MG3740A not to move in the box.
4. Tie up the box with packing rope, adhesive tape, band, or others.

### **11.2.2 Transportation**

It is recommended to transport the MG3710A/MG3740A after the recommended storage conditions are satisfied and avoiding vibration as much as possible.

## **11.3 Disposal**

When the MG3710A/MG3740A is to be discarded, comply with regulations of each country and local government.

Before discarding the MG3710A/MG3740A, dismantle or physically destroy any memory media it contains to ensure that any data saved in memory cannot be recovered by third parties.

## 11.4 Calibration

### 11.4.1 Calibration

Calibration is performed as preventive maintenance in order to prevent degradation of the performance. It should be performed regularly to maintain the performance of the MG3710A/MG3740A even if it operates normally.

It is desired that calibration is performed around once or twice a year. If the calibration result does not meet the specification, a failure is considered. Contact an Anritsu Service and Sales office.

 **CAUTION**

---

**When the calibration is performed, warm up the MG3710A/MG3740A and the device to be used with the calibration for 30 minutes or more to stabilize them sufficiently. Also maximum measurement accuracy requires conducting the calibration under the temperature of 23°C ±5°C and with little AC power supply voltage fluctuations (100 to 120 VAC, 200 to 240 VAC), as well as the absence of noise, vibrations, dust, humidity, and other problems.**

---

### 11.4.2 Device to be used for calibration

Devices to be used for the calibration of the MG3710A/MG3740A are described in the table below.

**Table 11.4.2-1 Measuring Instrument for Calibration List**

Recommended Device	Required Performance	Calibration Item
Oscilloscope	1 GHz measurement available External trigger input supported	Reference oscillator frequency accuracy
Signal generator	1 GHz signal output available (Resolution: 0.01 Hz or more)	Reference oscillator frequency accuracy
Frequency standard device	Standard electrical wave receiver or device with equivalent function (Accuracy: $1 \times 10^{-11}$ order or more)	Reference oscillator frequency accuracy



### 11.4.3 Calibrating frequency with oscilloscope


Calibrate the reference oscillator frequency using an oscilloscope. Use a frequency standard device (signal synchronized with a standard electric wave and rubidium atomic standard device) with accuracy sufficiently better than the reference oscillator.

**Table 11.4.3-1 Calibration Standard**

Reference Oscillator	Aging Rate	Temperature Stability
Internal reference oscillator	$\pm 1 \times 10^{-6}$ /year	$\pm 2.5 \times 10^{-6}$ (5° to 45°C)
High stability reference oscillator (Option 002/102 installed)	$\pm 1 \times 10^{-7}$ /year	$\pm 2 \times 10^{-8}$ (5° to 45°C)
Rubidium reference oscillator (Option 001/101 installed)	$\pm 1 \times 10^{-10}$ /month	$\pm 2 \times 10^{-9}$ (5° to 45°C)


#### Calibration procedure

The frequency calibration procedure with an oscilloscope is described.



**Figure 11.4.3-1 Frequency Calibration Connection with Oscilloscope**

1. Connect the signal of 10 MHz output from the frequency standard device to the reference signal input connector (Reference In) of the signal generator 1.
2. Connect the reference signal output (Buffer Out) on the rear side of the MG3710A/MG3740A to the reference signal input connector (Reference In) of the signal generator 2.
3. Connect the RF output connector of the signal generator 1 to CH1 of the input connector of the oscilloscope and the RF output connector of the signal generator 2 to CH2 of the input connector of the oscilloscope.
4. Set the frequency of the signal generator 1 and 2 to 1 GHz and output the signal.
5. Adjust the oscilloscope to enable observation of the input waveform of each signal generator.



**Figure 11.4.3-2 Oscilloscope Waveform Display**

From the figure above, set the trigger to the signal waveform of CH1 which outputs the reference signal.

The stationary displayed waveforms of the signal generator 1 and 2 (CH1 and CH2) input to the oscilloscope indicate that the frequency of the reference oscillator of the MG3710A/MG3740A is synchronized with the standard frequency and has a normal value.

However, if the displayed waveforms move to the right or left without synchronization, the reference oscillator of the MG3710A/MG3740A must be adjusted.

6. For synchronization, adjust the value of Reference Clock.  
For the adjustment method for Reference Clock, Refer to 4.6.6 “Ref Clock Adjustment”.
7. When it is adjusted and the output frequency of the MG3710A/MG3740A meets the standard frequency, the displayed waveform of the oscilloscope rests.

**Note:**

In actuality, the complete correspondence between waveforms of the output frequency and the standard frequency is not possible. Make the adjustment for the phase fluctuation to be the minimum.

## 11.5 How to Replace Hard Disk

Use the following procedure to replace the internal hard disk (Main HDD) of the equipment with the exchange HDD (MG3710A/MG3740A-313). The reference waveforms have been written to the exchange HDD already at factory shipment. Waveform patterns saved by the customer after purchasing this equipment should be rewritten to the exchange HDD after replacing the Main HDD. (Be sure to backup important waveform patterns.) )

A backup can be obtained by copying the User Data folder in the path C:\Anritsu\MG3710A.

If the internal HDD and secondary HDD are faulty, contact our service representative for factory repair.

### Replacement procedure

- \* **Turn off the power of the MG3710A/MG3740A and disconnect the power cable from the power outlet before replacement. Also, put the MG3710A/MG3740A on a flat horizontal bench top when working on it.**

### <Procedure>

1. Remove two screws for HDD ASSY replacement on the rear panel with a flat head screwdriver.
2. Pull out the current hard disk (HDD ASSY).
3. Insert the new hard disk (HDD ASSY).
4. Tighten up the two screws for HDD ASSY replacement on the rear panel with a flat head screwdriver.




Figure 11.5-1 HDD ASSY Replacement

**Note:**

If the Hard Disk lamp on the front panel keeps lighting after HDD ASSY replacement, the HDD ASSY may not be inserted correctly. If so, turn off the power, disconnect the power cable from the power outlet, remove the HDD ASSY once, and insert it again.

## 11.6 Troubleshooting

This section explains possible causes and measures for them when the MG3710A/MG3740A does not operate correctly.

If any troubles are not described in this section or taking measures below does not improve the symptoms, contact an Anritsu Service and Sales office.

**Table 11.6-1 Troubleshooting**




Problem	Possible Cause	Measure
Cannot be powered on.	The power cord is disconnected. The plug is not securely connected to the inlet.	Connect the power cord correctly.
	The power switch is not pressed securely.	Hold down the power switch for three seconds or more.
The initialization screen is not finished even when ten minutes or more have passed after the power on.		Turn off the power once, and turn on it again. If you have the same state after that, immediately turn off the power, and contact an Anritsu Service and Sales office.
Nothing is displayed on the screen.	The command to set the screen display to Off has been sent with the remote control.	Send the command to set the screen display to On.
Parameters cannot be set.	Knob Hold has been set.	Press  on the screen to cancel Knob Hold.
	The remote control mode has been enabled.	Press  to switch to the local control mode.
	The parameter stands out of the specified range.	Set the parameter with the value within the specified range.
	The setting condition is not met.	Check the parameter setting condition.
The function menu cannot be found.	It is displayed on another menu page.	Press  to switch the page.
	The displayed mode is different.	Switch to the mode which displays the menu to be set.
When the parameter is to be set, "Out of Range" is displayed.	The parameter stands out of the specified range.	Set the parameter with the value within the specified range.

Table 11.6-1 Troubleshooting (Continued)





Problem	Possible Cause	Measure
The remote control mode is not enabled with GPIB.	Remote control has been executed with Ethernet.	Disconnect Ethernet, press  to switch to the local control mode, and then execute the connection with GPIB again.
	GPIB address is wrong.	Set the same GPIB address to the interface setup screen and the controller side.
	The GPIB cable is not connected correctly.	Connect the cable correctly based on the GPIB network condition.
	The GPIB board setup on the PC is not correct.	Refer to the GPIB board operation manual you use.
The remote control mode is not enabled with Ethernet.	Remote control has been executed with GPIB.	Disconnect GPIB, press  to switch to the local control mode, and then execute the connection with Ethernet again.
	The port number is wrong.	Set the same port number to the interface setup screen and the PC.
	The LAN cable type you use is wrong.	Select the cable correctly according to the connection method. Refer to “E.2.2 Connection by Ethernet”.
	The LAN cable is not connected correctly.	Connect the cable correctly based on the Ethernet network condition.
	The LAN board setup on the PC is not correct.	Refer to the LAN board operation manual you use.
The connection to IQproducer™ by LAN is unavailable.	IP address is wrong.	Set the same IP address to the interface setup screen and the IQproducer™ side.
	The User ID or password is wrong.	Set the same user ID/password to the interface setup screen and the IQproducer™ side.
A waveform pattern is not displayed on the Waveform List to Play list in Baseband Mode.	The waveform pattern has not been loaded to the memory.	Load the waveform pattern to the memory. Refer to 7.3.4 “Loading waveform pattern: Load”.
A waveform pattern cannot be loaded to the memory.	The license key has not been installed.	Install the license key which corresponds to each pattern. Refer to 9.4.4 “Install”.
A signal is not output from the RF output.	The RF output is Off.	Press  to switch the RF output to On.
A modulated signal is not output from the RF output.	The modulation is Off.	Press  to switch the RF output modulation to On.

Table 11.6-1 Troubleshooting (Continued)

Problem	Possible Cause	Measure
A modulated signal is not output from the I/Q output.	I/Q output is Off.	Press  to enable the I/Q setting mode and switch the I/Q Output to “Analog I/Q Out”. Refer to 7.6 “IQ Modulation”.
The BER measurement does not operate normally.	The connected connector is wrong.	Connect to the correct connector according to the type of the signal to be input.
UNLOCK is displayed.	When Ref Source is Auto	Check if the reference signal input externally is correct.
	When Baseband Clock Source is Ext	Check if the Baseband Clock signal input externally is correct.
	Cases other than the above	The MG3710A/MG3740A may be broken. Contact an Anritsu Service and Sales office.
NG is displayed to [0] REF with Alarm History.	Failure in circuit	The MG3710A/MG3740A may be broken. Contact an Anritsu Service and Sales office.
ALC is displayed. NG is displayed to [2] ALC with Alarm History.	When using the MG3710A/MG3740A beyond the range of the product specification (output level accuracy)	The output level may not have reached the specified value. Change the setting so that the specified output level accuracy can be obtained.
	When using the MG3710A/MG3740A within the range of the product specification (output level accuracy)	The MG3710A/MG3740A may be broken. Contact an Anritsu Service and Sales office.
NG is displayed to [3] BB with Alarm History.	Failure in circuit	The MG3710A/MG3740A may be broken. Contact an Anritsu Service and Sales office.
NG is displayed to [4] RPP with Alarm History.	High-level RF signal has been input to the RF Output terminal externally.	Check for the output level of connected devices, cable disconnection, short, and impedance inconsistency. Refer to 3.3.10 “RPP”.
BBDAC is displayed.	Clipping by over flow has occurred with Baseband DAC or digital block.	Lower the RMS Value Tuning setting.
EXTMOD is displayed.	The level of signal input to the External Modulation Input connector is greater than 2.03 Vp-p.	Decrease the level of signal input to the External Modulation Input connector to 2 Vp-p or less.
	The level of signal input to the External Modulation Input connector is not greater than 2.03 Vp-p.	The MG3710A/MG3740A may be broken. Contact an Anritsu Service and Sales office.



## Appendix A Specifications

### A.1 Electrical Characteristics

Typ. value is not the guaranteed performance with this specification; it is for reference.

Nominal values are not guaranteed.

It is a common specification for MG3710A and MG3740A, if not specified.

#### <Conditions>

Unless otherwise noted, function and performance are specified in the following conditions.	
Common to CW mode and modulation mode	Measurement at a constant ambient temperature, after a warm up of 30 minutes Pulse modulation      Off ATT Hold      :      Off Optimize S/N Mode:      Off In the frequency range over 2.7 GHz, this condition is applied only when MG3710A/MG3740A-034/036 (or 064/066/164/166 for 2nd SG) is installed. At frequencies over 4 GHz, this condition applies only when the MG3710A/MG3740A-036 (2nd SG is 066/166) is installed.
Only in modulation mode	Assuming that the RMS value of the waveform pattern is RMSw [linear value], the following must be met: -3.00 dB ≤ RMSnom ≤ +3.00 dB Exceptions: RMSnom = 20 • log (RMSw/4628) (when specified in 16 bit data) RMSnom = 20 • log (RMSw/2314) (when specified in 15 bit data) RMSnom = 20 • log (RMSw/1157) (when specified in 14 bit data) After CAL execution All the above are also applied to 2nd SG (MG3710A/MG3740A-062/064/066/162/164/166).

<Frequency>

Items	Specifications
Range	
1st SG	9 kHz to 2.7 GHz (MG3710A/MG3740A-032) 9 kHz to 4 GHz (MG3710A/MG3740A-034) 9 kHz to 6 GHz (MG3710A/MG3740A-036)
2nd SG	9 kHz to 2.7 GHz (MG3710A/MG3740A-062/162) 9 kHz to 4 GHz (MG3710A/MG3740A-064/164) 9 kHz to 6 GHz (MG3710A/MG3740A-066/166)
Resolution	0.01 Hz
Phase adjustment	
Setting range	-180.00 deg to 180.00 deg
Resolution	0.01 deg
Frequency switching time	Under the condition of frequency > 187.5 MHz, Phase Noise Optimize: Offset < 200 kHz, this is defined as the period from the detection of a List function execution trigger to the time when the frequency falls within $\pm 0.1$ ppm or 100 Hz tolerance of the final target value. When MG3710A/MG3740A-041/141 or MG3710A/MG3740A-071/171 not installed and output level $\leq +7$ dBm: $\leq 600 \mu\text{s}$
Internal reference oscillator	
Aging rate	When MG3710A/MG3740A-001/101/002/102 is not installed: $\pm 1 \times 10^{-6}$ /year
Temperature stability	$\pm 2.5 \times 10^{-6}$ (5 to 45°C)
Aging rate	When MG3710A/MG3740A-001/101 is installed: $\pm 1 \times 10^{-10}$ /month
Temperature stability	$\pm 2 \times 10^{-9}$ (5 to 45°C)
Activation characteristics	Based on frequency 24 hours after power application, at 23°C $\pm 1 \times 10^{-9}$ (7.5 minutes after power application)
Aging rate	When MG3710A/MG3740A-002/102 is installed: $\pm 1 \times 10^{-7}$ /year
Temperature stability	$\pm 2 \times 10^{-8}$ (5 to 45°C)
Activation characteristics	Based on frequency 24 hours after power application, at 23°C $\pm 5 \times 10^{-7}$ (2 minutes after power application) $\pm 5 \times 10^{-8}$ (5 minutes after power application)

## &lt;Output level&gt;

Items	Specifications
Setting range	<p>1st SG: MG3710A/MG3740A-043/143 not installed, 2nd SG: MG3710A/MG3740A-073/173 not installed</p> <p>1st SG: MG3710A/MG3740A-041/141 not installed, 042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171 not installed, 072/172 not installed</p> <p>-110 dBm to +17 dBm</p> <p>1st SG: MG3710A/MG3740A-041/141 installed, 042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171 installed, 072/172 not installed</p> <p>-110 dBm to +30 dBm</p> <p>1st SG: MG3710A/MG3740A-041/141 not installed, 042/142 installed, 2nd SG: MG3710A/MG3740A-071/171 not installed, 072/172 installed</p> <p>-144 dBm to +17 dBm</p> <p>1st SG: MG3710A/MG3740A-041/141 installed, 042/142 installed, 2nd SG: MG3710A/MG3740A-071/171 installed, 072/172 installed</p> <p>-144 dBm to +30 dBm</p> <p>1st SG: MG3710A/MG3740A-043/143 installed, 2nd SG: MG3710A/MG3740A-073/173 installed</p> <p>1st SG: MG3710A/MG3740A-041/141 not installed, 042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171 not installed, 072/172 not installed</p> <p>-110 dBm to +17 dBm</p> <p>1st SG: MG3710A/MG3740A-041/141 installed, 042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171 installed, 072/172 not installed</p> <p>-110 dBm to +25 dBm</p> <p>1st SG: MG3710A/MG3740A-041/141 not installed, 042/142 installed, 2nd SG: MG3710A/MG3740A-071/171 not installed, 072/172 installed</p> <p>-144 dBm to +17 dBm</p> <p>1st SG: MG3710A/MG3740A-041/141 installed, 042/142 installed, 2nd SG: MG3710A/MG3740A-071/171 installed, 072/172 installed</p> <p>-144 dBm to +25 dBm</p>
Resolution	0.01 dB
Unit Unit of electrical power Unit of voltage	<p>dBm</p> <p>dB<sub>μ</sub>V (terminal voltage display) and dB<sub>μ</sub>V<sub>emf</sub> (open voltage display)</p>
Level switching time	<p>Under the condition of frequency &gt; 187.5 MHz, this is defined as the period from the detection of a List function execution trigger to the time when the frequency falls within ±0.2 dB tolerance of the final target value.</p> <p>When MG3710A/MG3740A-041/141 or MG3710A/MG3740A-071/171 not installed and output level ≤ +7 dBm:</p> <p>≤600 μs</p>

<Output level> Continued

Items	Specifications		
Accuracy	CW, at 18 to 28°C		
	1st SG: MG3710A/MG3740A-043/143 not installed, 2nd SG: MG3710A/MG3740A-073/173 not installed		
	1st SG: MG3710A/MG3740A-041/141/042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171/072/172 not installed		
	Level	Frequency	
	-100 dBm<, ≤+5 dBm	100 kHz≤, <1 MHz	
		±0.5 dB typ.	
	Level	Frequency	
	+5 dBm<, ≤+10 dBm	1 MHz≤, <10 MHz	10 MHz≤, <50 MHz
		±0.7 dB typ.	
	-110 dBm<, ≤+5 dBm	±0.5 dB typ.	
		±0.5 dB typ.	
	Level	Frequency	
	+1 dBm≤, ≤+13 dBm	50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz
		±0.5 dB	
	-40 dBm<, <+1 dBm	±0.5 dB	
±0.5 dB			
-110 dBm<, ≤-40 dBm	±0.5 dB		
	±0.5 dB		
Level	Frequency		
+11 dBm<, ≤+13 dBm	3 GHz<, ≤4 GHz	4 GHz<, ≤5 GHz	
	±0.7 dB		
+1 dBm≤, ≤+11 dBm	±0.7 dB		
	±0.8 dB		
-40 dBm<, <+1 dBm	±0.7 dB		
	±0.8 dB		
-100 dBm<, ≤-40 dBm	±0.7 dB		
	±0.8 dB		
-110 dBm<, ≤-100 dBm	±0.7 dB		
	±0.8 dB		
Level	Frequency		
+1 dBm≤, ≤+11 dBm	5 GHz<, ≤6 GHz		
	±0.8 dB		
-40 dBm<, <+1 dBm	±0.8 dB		
	±0.8 dB		
-100 dBm<, ≤-40 dBm	±0.8 dB		
	±0.8 dB		
-110 dBm<, ≤-100 dBm	±0.8 dB		
	±0.8 dB		

<Output level> Continued

Items	Specifications																								
Accuracy	1st SG: MG3710A/MG3740A-041/141 installed, 042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171 installed, 072/172 not installed																								
	<table border="1"> <thead> <tr> <th data-bbox="520 591 852 638">Level</th> <th colspan="2" data-bbox="852 591 1396 638">Frequency</th> </tr> <tr> <td data-bbox="520 638 852 685"></td> <td colspan="2" data-bbox="852 638 1396 685">100 kHz<math>\leq</math>, &lt;1 MHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 685 852 730">-100 dBm&lt;, <math>\leq</math>+5 dBm</td> <td colspan="2" data-bbox="852 685 1396 730"><math>\pm</math>0.5 dB typ.</td> </tr> </tbody> </table>	Level	Frequency			100 kHz $\leq$ , <1 MHz		-100 dBm<, $\leq$ +5 dBm	$\pm$ 0.5 dB typ.																
	Level	Frequency																							
		100 kHz $\leq$ , <1 MHz																							
	-100 dBm<, $\leq$ +5 dBm	$\pm$ 0.5 dB typ.																							
	<table border="1"> <thead> <tr> <th data-bbox="520 770 852 817">Level</th> <th colspan="2" data-bbox="852 770 1396 817">Frequency</th> </tr> <tr> <td data-bbox="520 817 852 864"></td> <td data-bbox="852 817 1118 864">1 MHz <math>\leq</math>, &lt;10 MHz</td> <td data-bbox="1118 817 1396 864">10 MHz<math>\leq</math>, &lt;50 MHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 864 852 911">+5 dBm&lt;, <math>\leq</math>+10 dBm</td> <td colspan="2" data-bbox="852 864 1396 911"><math>\pm</math>0.7 dB typ.</td> </tr> <tr> <td data-bbox="520 911 852 943">-110 dBm&lt;, <math>\leq</math>+5 dBm</td> <td data-bbox="852 911 1118 943"><math>\pm</math>0.5 dB typ.</td> <td data-bbox="1118 911 1396 943"><math>\pm</math>0.5 dB typ.</td> </tr> </tbody> </table>	Level	Frequency			1 MHz $\leq$ , <10 MHz	10 MHz $\leq$ , <50 MHz	+5 dBm<, $\leq$ +10 dBm	$\pm$ 0.7 dB typ.		-110 dBm<, $\leq$ +5 dBm	$\pm$ 0.5 dB typ.	$\pm$ 0.5 dB typ.												
	Level	Frequency																							
		1 MHz $\leq$ , <10 MHz	10 MHz $\leq$ , <50 MHz																						
	+5 dBm<, $\leq$ +10 dBm	$\pm$ 0.7 dB typ.																							
	-110 dBm<, $\leq$ +5 dBm	$\pm$ 0.5 dB typ.	$\pm$ 0.5 dB typ.																						
	<table border="1"> <thead> <tr> <th data-bbox="520 983 852 1030">Level</th> <th colspan="2" data-bbox="852 983 1396 1030">Frequency</th> </tr> <tr> <td data-bbox="520 1030 852 1077"></td> <td data-bbox="852 1030 1118 1077">50 MHz<math>\leq</math>, &lt;400 MHz</td> <td data-bbox="1118 1030 1396 1077">400 MHz<math>\leq</math>, <math>\leq</math>3 GHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1077 852 1124">+20 dBm&lt;, <math>\leq</math>+23 dBm</td> <td colspan="2" data-bbox="852 1077 1396 1124"><math>\pm</math>0.6 dB</td> </tr> <tr> <td data-bbox="520 1124 852 1171">+13 dBm&lt;, <math>\leq</math>+20 dBm</td> <td data-bbox="852 1124 1118 1171"><math>\pm</math>0.6 dB</td> <td data-bbox="1118 1124 1396 1171"><math>\pm</math>0.6 dB</td> </tr> <tr> <td data-bbox="520 1171 852 1218">+1 dBm<math>\leq</math>, <math>\leq</math>+13 dBm</td> <td data-bbox="852 1171 1118 1218"><math>\pm</math>0.5 dB</td> <td data-bbox="1118 1171 1396 1218"><math>\pm</math>0.5 dB</td> </tr> <tr> <td data-bbox="520 1218 852 1265">-40 dBm&lt;, &lt;+1 dBm</td> <td data-bbox="852 1218 1118 1265"><math>\pm</math>0.5 dB</td> <td data-bbox="1118 1218 1396 1265"><math>\pm</math>0.5 dB</td> </tr> <tr> <td data-bbox="520 1265 852 1312">-110 dBm&lt;, <math>\leq</math>-40 dBm</td> <td data-bbox="852 1265 1118 1312"><math>\pm</math>0.5 dB</td> <td data-bbox="1118 1265 1396 1312"><math>\pm</math>0.5 dB</td> </tr> </tbody> </table>	Level	Frequency			50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz	+20 dBm<, $\leq$ +23 dBm	$\pm$ 0.6 dB		+13 dBm<, $\leq$ +20 dBm	$\pm$ 0.6 dB	$\pm$ 0.6 dB	+1 dBm $\leq$ , $\leq$ +13 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB	-40 dBm<, <+1 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB	-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB			
	Level	Frequency																							
		50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz																						
	+20 dBm<, $\leq$ +23 dBm	$\pm$ 0.6 dB																							
	+13 dBm<, $\leq$ +20 dBm	$\pm$ 0.6 dB	$\pm$ 0.6 dB																						
	+1 dBm $\leq$ , $\leq$ +13 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB																						
	-40 dBm<, <+1 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB																						
	-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB																						
	<table border="1"> <thead> <tr> <th data-bbox="520 1319 852 1366">Level</th> <th colspan="2" data-bbox="852 1319 1396 1366">Frequency</th> </tr> <tr> <td data-bbox="520 1366 852 1413"></td> <td data-bbox="852 1366 1118 1413">3 GHz&lt;, <math>\leq</math>4 GHz</td> <td data-bbox="1118 1366 1396 1413">4 GHz&lt;, <math>\leq</math>5 GHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1413 852 1460">+13 dBm&lt;, <math>\leq</math>+20 dBm</td> <td data-bbox="852 1413 1118 1460"><math>\pm</math>0.7 dB</td> <td data-bbox="1118 1413 1396 1460"></td> </tr> <tr> <td data-bbox="520 1460 852 1507">+11 dBm&lt;, <math>\leq</math>+13 dBm</td> <td data-bbox="852 1460 1118 1507"><math>\pm</math>0.7 dB</td> <td data-bbox="1118 1460 1396 1507"><math>\pm</math>0.8 dB</td> </tr> <tr> <td data-bbox="520 1507 852 1554">+1 dBm<math>\leq</math>, <math>\leq</math>+11 dBm</td> <td data-bbox="852 1507 1118 1554"><math>\pm</math>0.7 dB</td> <td data-bbox="1118 1507 1396 1554"><math>\pm</math>0.8 dB</td> </tr> <tr> <td data-bbox="520 1554 852 1601">-40 dBm&lt;, &lt;+1 dBm</td> <td data-bbox="852 1554 1118 1601"><math>\pm</math>0.7 dB</td> <td data-bbox="1118 1554 1396 1601"><math>\pm</math>0.8 dB</td> </tr> <tr> <td data-bbox="520 1601 852 1637">-100 dBm&lt;, <math>\leq</math>-40 dBm</td> <td data-bbox="852 1601 1118 1637"><math>\pm</math>0.7 dB</td> <td data-bbox="1118 1601 1396 1637"><math>\pm</math>0.8 dB</td> </tr> <tr> <td data-bbox="520 1637 852 1684">-110 dBm&lt;, <math>\leq</math>-100 dBm</td> <td data-bbox="852 1637 1118 1684"><math>\pm</math>0.7 dB</td> <td data-bbox="1118 1637 1396 1684"><math>\pm</math>0.8 dB</td> </tr> </tbody> </table>	Level	Frequency			3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 5 GHz	+13 dBm<, $\leq$ +20 dBm	$\pm$ 0.7 dB		+11 dBm<, $\leq$ +13 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB	+1 dBm $\leq$ , $\leq$ +11 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB	-40 dBm<, <+1 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB	-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB	-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB
	Level	Frequency																							
	3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 5 GHz																							
+13 dBm<, $\leq$ +20 dBm	$\pm$ 0.7 dB																								
+11 dBm<, $\leq$ +13 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB																							
+1 dBm $\leq$ , $\leq$ +11 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB																							
-40 dBm<, <+1 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB																							
-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB																							
-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB																							
<table border="1"> <thead> <tr> <th data-bbox="520 1691 852 1738">Level</th> <th colspan="2" data-bbox="852 1691 1396 1738">Frequency</th> </tr> <tr> <td data-bbox="520 1738 852 1785"></td> <td data-bbox="852 1738 1118 1785">5 GHz&lt;, <math>\leq</math>6 GHz</td> <td data-bbox="1118 1738 1396 1785"></td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1785 852 1832">+1 dBm<math>\leq</math>, <math>\leq</math>+11 dBm</td> <td data-bbox="852 1785 1118 1832"><math>\pm</math>0.8 dB</td> <td data-bbox="1118 1785 1396 1832"></td> </tr> <tr> <td data-bbox="520 1832 852 1879">-40 dBm&lt;, &lt;+1 dBm</td> <td data-bbox="852 1832 1118 1879"><math>\pm</math>0.8 dB</td> <td data-bbox="1118 1832 1396 1879"></td> </tr> <tr> <td data-bbox="520 1879 852 1926">-100 dBm&lt;, <math>\leq</math>-40 dBm</td> <td data-bbox="852 1879 1118 1926"><math>\pm</math>0.8 dB</td> <td data-bbox="1118 1879 1396 1926"></td> </tr> <tr> <td data-bbox="520 1926 852 1973">-110 dBm&lt;, <math>\leq</math>-100 dBm</td> <td data-bbox="852 1926 1118 1973"><math>\pm</math>0.8 dB</td> <td data-bbox="1118 1926 1396 1973"></td> </tr> </tbody> </table>	Level	Frequency			5 GHz<, $\leq$ 6 GHz		+1 dBm $\leq$ , $\leq$ +11 dBm	$\pm$ 0.8 dB		-40 dBm<, <+1 dBm	$\pm$ 0.8 dB		-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.8 dB		-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.8 dB								
Level	Frequency																								
	5 GHz<, $\leq$ 6 GHz																								
+1 dBm $\leq$ , $\leq$ +11 dBm	$\pm$ 0.8 dB																								
-40 dBm<, <+1 dBm	$\pm$ 0.8 dB																								
-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.8 dB																								
-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.8 dB																								










<Output level> Continued

Items	Specifications																													
Accuracy	1st SG: MG3710A/MG3740A-041/141 not installed, 042/142 installed, 2nd SG: MG3710A/MG3740A-071/171 not installed, 072/172 installed																													
	<table border="1"> <thead> <tr> <th data-bbox="520 524 852 573">Level</th> <th colspan="2" data-bbox="852 524 1396 573">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 573 852 622"></td> <td colspan="2" data-bbox="852 573 1396 622">100 kHz<math>\leq</math>, &lt;1 MHz</td> </tr> <tr> <td data-bbox="520 622 852 663">-100 dBm&lt;, <math>\leq</math>+5 dBm</td> <td colspan="2" data-bbox="852 622 1396 663"><math>\pm</math>0.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			100 kHz $\leq$ , <1 MHz		-100 dBm<, $\leq$ +5 dBm	$\pm$ 0.5 dB typ.																			
	Level	Frequency																												
		100 kHz $\leq$ , <1 MHz																												
	-100 dBm<, $\leq$ +5 dBm	$\pm$ 0.5 dB typ.																												
	<table border="1"> <thead> <tr> <th data-bbox="520 698 852 748">Level</th> <th colspan="2" data-bbox="852 698 1396 748">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 748 852 797"></td> <td data-bbox="852 748 1129 797">1 MHz<math>\leq</math>, &lt;10 MHz</td> <td data-bbox="1129 748 1396 797">10 MHz<math>\leq</math>, &lt;50 MHz</td> </tr> <tr> <td data-bbox="520 797 852 846">+5 dBm&lt;, <math>\leq</math>+10 dBm</td> <td colspan="2" data-bbox="852 797 1396 846"><math>\pm</math>0.7 dB typ.</td> </tr> <tr> <td data-bbox="520 846 852 878">-120 dBm&lt;, <math>\leq</math>+5 dBm</td> <td data-bbox="852 846 1129 878"><math>\pm</math>0.5 dB typ.</td> <td data-bbox="1129 846 1396 878"><math>\pm</math>0.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			1 MHz $\leq$ , <10 MHz	10 MHz $\leq$ , <50 MHz	+5 dBm<, $\leq$ +10 dBm	$\pm$ 0.7 dB typ.		-120 dBm<, $\leq$ +5 dBm	$\pm$ 0.5 dB typ.	$\pm$ 0.5 dB typ.															
	Level	Frequency																												
		1 MHz $\leq$ , <10 MHz	10 MHz $\leq$ , <50 MHz																											
	+5 dBm<, $\leq$ +10 dBm	$\pm$ 0.7 dB typ.																												
	-120 dBm<, $\leq$ +5 dBm	$\pm$ 0.5 dB typ.	$\pm$ 0.5 dB typ.																											
	<table border="1"> <thead> <tr> <th data-bbox="520 913 852 963">Level</th> <th colspan="2" data-bbox="852 913 1396 963">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 963 852 1012"></td> <td data-bbox="852 963 1129 1012">50 MHz<math>\leq</math>, &lt;400 MHz</td> <td data-bbox="1129 963 1396 1012">400 MHz<math>\leq</math>, <math>\leq</math>3 GHz</td> </tr> <tr> <td data-bbox="520 1012 852 1061">+1 dBm<math>\leq</math>, <math>\leq</math>+13 dBm</td> <td data-bbox="852 1012 1129 1061"><math>\pm</math>0.5 dB</td> <td data-bbox="1129 1012 1396 1061"><math>\pm</math>0.5 dB</td> </tr> <tr> <td data-bbox="520 1061 852 1111">-40 dBm&lt;, &lt;+1 dBm</td> <td data-bbox="852 1061 1129 1111"><math>\pm</math>0.5 dB</td> <td data-bbox="1129 1061 1396 1111"><math>\pm</math>0.5 dB</td> </tr> <tr> <td data-bbox="520 1111 852 1160">-110 dBm&lt;, <math>\leq</math>-40 dBm</td> <td data-bbox="852 1111 1129 1160"><math>\pm</math>0.5 dB</td> <td data-bbox="1129 1111 1396 1160"><math>\pm</math>0.5 dB</td> </tr> <tr> <td data-bbox="520 1160 852 1209">-120 dBm&lt;, <math>\leq</math>-110 dBm</td> <td data-bbox="852 1160 1129 1209"><math>\pm</math>0.5 dB</td> <td data-bbox="1129 1160 1396 1209"><math>\pm</math>0.5 dB</td> </tr> <tr> <td data-bbox="520 1209 852 1258">-127 dBm&lt;, <math>\leq</math>-120 dBm</td> <td data-bbox="852 1209 1129 1258"><math>\pm</math>0.7 dB</td> <td data-bbox="1129 1209 1396 1258"><math>\pm</math>0.7 dB</td> </tr> <tr> <td data-bbox="520 1258 852 1308">-136 dBm&lt;, <math>\leq</math>-127 dBm</td> <td data-bbox="852 1258 1129 1308"><math>\pm</math>1.5 dB typ.</td> <td data-bbox="1129 1258 1396 1308"><math>\pm</math>1.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz	+1 dBm $\leq$ , $\leq$ +13 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB	-40 dBm<, <+1 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB	-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB	-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB	-127 dBm<, $\leq$ -120 dBm	$\pm$ 0.7 dB	$\pm$ 0.7 dB	-136 dBm<, $\leq$ -127 dBm	$\pm$ 1.5 dB typ.	$\pm$ 1.5 dB typ.			
	Level	Frequency																												
		50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz																											
	+1 dBm $\leq$ , $\leq$ +13 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB																											
	-40 dBm<, <+1 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB																											
	-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB																											
	-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.5 dB	$\pm$ 0.5 dB																											
	-127 dBm<, $\leq$ -120 dBm	$\pm$ 0.7 dB	$\pm$ 0.7 dB																											
	-136 dBm<, $\leq$ -127 dBm	$\pm$ 1.5 dB typ.	$\pm$ 1.5 dB typ.																											
	<table border="1"> <thead> <tr> <th data-bbox="520 1281 852 1330">Level</th> <th colspan="2" data-bbox="852 1281 1396 1330">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 1330 852 1379"></td> <td data-bbox="852 1330 1129 1379">3 GHz&lt;, <math>\leq</math>4 GHz</td> <td data-bbox="1129 1330 1396 1379">4 GHz&lt;, <math>\leq</math>5 GHz</td> </tr> <tr> <td data-bbox="520 1379 852 1429">+11 dBm&lt;, <math>\leq</math>+13 dBm</td> <td data-bbox="852 1379 1129 1429"><math>\pm</math>0.7 dB</td> <td data-bbox="1129 1379 1396 1429"><math>\pm</math>0.8 dB</td> </tr> <tr> <td data-bbox="520 1429 852 1478">+1 dBm<math>\leq</math>, <math>\leq</math>+11 dBm</td> <td data-bbox="852 1429 1129 1478"><math>\pm</math>0.7 dB</td> <td data-bbox="1129 1429 1396 1478"><math>\pm</math>0.8 dB</td> </tr> <tr> <td data-bbox="520 1478 852 1527">-40 dBm&lt;, &lt;+1 dBm</td> <td data-bbox="852 1478 1129 1527"><math>\pm</math>0.7 dB</td> <td data-bbox="1129 1478 1396 1527"><math>\pm</math>0.8 dB</td> </tr> <tr> <td data-bbox="520 1527 852 1576">-100 dBm&lt;, <math>\leq</math>-40 dBm</td> <td data-bbox="852 1527 1129 1576"><math>\pm</math>0.7 dB</td> <td data-bbox="1129 1527 1396 1576"><math>\pm</math>0.8 dB</td> </tr> <tr> <td data-bbox="520 1576 852 1626">-110 dBm&lt;, <math>\leq</math>-100 dBm</td> <td data-bbox="852 1576 1129 1626"><math>\pm</math>0.7 dB</td> <td data-bbox="1129 1576 1396 1626"><math>\pm</math>0.8 dB</td> </tr> <tr> <td data-bbox="520 1626 852 1675">-120 dBm&lt;, <math>\leq</math>-110 dBm</td> <td data-bbox="852 1626 1129 1675"><math>\pm</math>0.7 dB</td> <td data-bbox="1129 1626 1396 1675"><math>\pm</math>1.0 dB</td> </tr> <tr> <td data-bbox="520 1675 852 1724">-127 dBm&lt;, <math>\leq</math>-120 dBm</td> <td data-bbox="852 1675 1129 1724"><math>\pm</math>2.5 dB typ.</td> <td data-bbox="1129 1675 1396 1724"><math>\pm</math>2.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 5 GHz	+11 dBm<, $\leq$ +13 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB	+1 dBm $\leq$ , $\leq$ +11 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB	-40 dBm<, <+1 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB	-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB	-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB	-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.7 dB	$\pm$ 1.0 dB	-127 dBm<, $\leq$ -120 dBm	$\pm$ 2.5 dB typ.	$\pm$ 2.5 dB typ.
	Level	Frequency																												
		3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 5 GHz																											
	+11 dBm<, $\leq$ +13 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB																											
	+1 dBm $\leq$ , $\leq$ +11 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB																											
-40 dBm<, <+1 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB																												
-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB																												
-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.7 dB	$\pm$ 0.8 dB																												
-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.7 dB	$\pm$ 1.0 dB																												
-127 dBm<, $\leq$ -120 dBm	$\pm$ 2.5 dB typ.	$\pm$ 2.5 dB typ.																												
<table border="1"> <thead> <tr> <th data-bbox="520 1688 852 1738">Level</th> <th colspan="2" data-bbox="852 1688 1396 1738">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 1738 852 1787"></td> <td data-bbox="852 1738 1129 1787">5 GHz&lt;, <math>\leq</math>6 GHz</td> <td data-bbox="1129 1738 1396 1787"></td> </tr> <tr> <td data-bbox="520 1787 852 1836">+1 dBm<math>\leq</math>, <math>\leq</math>+11 dBm</td> <td data-bbox="852 1787 1129 1836"><math>\pm</math>0.8 dB</td> <td data-bbox="1129 1787 1396 1836"></td> </tr> <tr> <td data-bbox="520 1836 852 1886">-40 dBm&lt;, &lt;+1 dBm</td> <td data-bbox="852 1836 1129 1886"><math>\pm</math>0.8 dB</td> <td data-bbox="1129 1836 1396 1886"></td> </tr> <tr> <td data-bbox="520 1886 852 1935">-100 dBm&lt;, <math>\leq</math>-40 dBm</td> <td data-bbox="852 1886 1129 1935"><math>\pm</math>0.8 dB</td> <td data-bbox="1129 1886 1396 1935"></td> </tr> <tr> <td data-bbox="520 1935 852 1984">-110 dBm&lt;, <math>\leq</math>-100 dBm</td> <td data-bbox="852 1935 1129 1984"><math>\pm</math>0.8 dB</td> <td data-bbox="1129 1935 1396 1984"></td> </tr> <tr> <td data-bbox="520 1984 852 2020">-120 dBm&lt;, <math>\leq</math>-110 dBm</td> <td data-bbox="852 1984 1129 2020"><math>\pm</math>1.0 dB</td> <td data-bbox="1129 1984 1396 2020"></td> </tr> <tr> <td data-bbox="520 2020 852 2051">-127 dBm&lt;, <math>\leq</math>-120 dBm</td> <td data-bbox="852 2020 1129 2051"><math>\pm</math>2.5 dB typ.</td> <td data-bbox="1129 2020 1396 2051"></td> </tr> </tbody> </table>			Level	Frequency			5 GHz<, $\leq$ 6 GHz		+1 dBm $\leq$ , $\leq$ +11 dBm	$\pm$ 0.8 dB		-40 dBm<, <+1 dBm	$\pm$ 0.8 dB		-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.8 dB		-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.8 dB		-120 dBm<, $\leq$ -110 dBm	$\pm$ 1.0 dB		-127 dBm<, $\leq$ -120 dBm	$\pm$ 2.5 dB typ.					
Level	Frequency																													
	5 GHz<, $\leq$ 6 GHz																													
+1 dBm $\leq$ , $\leq$ +11 dBm	$\pm$ 0.8 dB																													
-40 dBm<, <+1 dBm	$\pm$ 0.8 dB																													
-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.8 dB																													
-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.8 dB																													
-120 dBm<, $\leq$ -110 dBm	$\pm$ 1.0 dB																													
-127 dBm<, $\leq$ -120 dBm	$\pm$ 2.5 dB typ.																													

<Output level> Continued

Items	Specifications																															
Accuracy	1st SG: MG3710A/MG3740A-041/141/042/142 installed, 2nd SG: MG3710A/MG3740A-071/171/072/172 installed																															
	<table border="1"> <thead> <tr> <th data-bbox="520 524 863 573">Level</th> <th colspan="2" data-bbox="863 524 1396 573">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 573 863 663" rowspan="2">-100 dBm&lt;, ≤+5 dBm</td> <td data-bbox="863 573 1137 622" rowspan="2"></td> <td data-bbox="1137 573 1396 622">100 kHz≤, &lt;1 MHz</td> </tr> <tr> <td data-bbox="1137 622 1396 663">±0.5 dB typ.</td> </tr> </tbody> </table>	Level	Frequency		-100 dBm<, ≤+5 dBm		100 kHz≤, <1 MHz	±0.5 dB typ.																								
	Level	Frequency																														
	-100 dBm<, ≤+5 dBm		100 kHz≤, <1 MHz																													
			±0.5 dB typ.																													
	<table border="1"> <thead> <tr> <th data-bbox="520 698 863 748">Level</th> <th colspan="2" data-bbox="863 698 1396 748">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 748 863 797" rowspan="2">+5 dBm&lt;, ≤+10 dBm</td> <td data-bbox="863 748 1137 797">1 MHz≤, &lt;10 MHz</td> <td data-bbox="1137 748 1396 797">10 MHz≤, &lt;50 MHz</td> </tr> <tr> <td data-bbox="863 797 1137 875" rowspan="2">±0.5 dB typ.</td> <td data-bbox="1137 797 1396 875">±0.5 dB typ.</td> </tr> </tbody> </table>	Level	Frequency		+5 dBm<, ≤+10 dBm	1 MHz≤, <10 MHz	10 MHz≤, <50 MHz	±0.5 dB typ.	±0.5 dB typ.																							
	Level	Frequency																														
	+5 dBm<, ≤+10 dBm	1 MHz≤, <10 MHz	10 MHz≤, <50 MHz																													
		±0.5 dB typ.	±0.5 dB typ.																													
	<table border="1"> <thead> <tr> <th data-bbox="520 911 863 960">Level</th> <th colspan="2" data-bbox="863 911 1396 960">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 960 863 1010" rowspan="2">+20 dBm&lt;, ≤+23 dBm</td> <td data-bbox="863 960 1137 1010">50 MHz≤, &lt;400 MHz</td> <td data-bbox="1137 960 1396 1010">400 MHz≤, ≤3 GHz</td> </tr> <tr> <td data-bbox="863 1010 1137 1088" rowspan="2">±0.6 dB</td> <td data-bbox="1137 1010 1396 1088">±0.6 dB</td> </tr> <tr> <td data-bbox="520 1088 863 1137">+13 dBm&lt;, ≤+20 dBm</td> <td data-bbox="863 1088 1137 1137"></td> <td data-bbox="1137 1088 1396 1137"></td> </tr> <tr> <td data-bbox="520 1137 863 1187">+1 dBm≤, ≤+13 dBm</td> <td data-bbox="863 1137 1137 1187"></td> <td data-bbox="1137 1137 1396 1187"></td> </tr> <tr> <td data-bbox="520 1187 863 1236">-40 dBm&lt;, &lt;+1 dBm</td> <td data-bbox="863 1187 1137 1236"></td> <td data-bbox="1137 1187 1396 1236"></td> </tr> <tr> <td data-bbox="520 1236 863 1285">-110 dBm&lt;, ≤-40 dBm</td> <td data-bbox="863 1236 1137 1285"></td> <td data-bbox="1137 1236 1396 1285"></td> </tr> <tr> <td data-bbox="520 1285 863 1335">-120 dBm&lt;, ≤-110 dBm</td> <td data-bbox="863 1285 1137 1335"></td> <td data-bbox="1137 1285 1396 1335"></td> </tr> <tr> <td data-bbox="520 1335 863 1384">-127 dBm&lt;, ≤-120 dBm</td> <td data-bbox="863 1335 1137 1384"></td> <td data-bbox="1137 1335 1396 1384"></td> </tr> <tr> <td data-bbox="520 1384 863 1433">-136 dBm&lt;, ≤-127 dBm</td> <td data-bbox="863 1384 1137 1433">±1.5 dB typ.</td> <td data-bbox="1137 1384 1396 1433">±1.5 dB typ.</td> </tr> </tbody> </table>		Level	Frequency		+20 dBm<, ≤+23 dBm	50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz	±0.6 dB	±0.6 dB	+13 dBm<, ≤+20 dBm			+1 dBm≤, ≤+13 dBm			-40 dBm<, <+1 dBm			-110 dBm<, ≤-40 dBm			-120 dBm<, ≤-110 dBm			-127 dBm<, ≤-120 dBm			-136 dBm<, ≤-127 dBm	±1.5 dB typ.	±1.5 dB typ.	
	Level	Frequency																														
	+20 dBm<, ≤+23 dBm	50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz																													
		±0.6 dB	±0.6 dB																													
	+13 dBm<, ≤+20 dBm																															
	+1 dBm≤, ≤+13 dBm																															
	-40 dBm<, <+1 dBm																															
	-110 dBm<, ≤-40 dBm																															
	-120 dBm<, ≤-110 dBm																															
	-127 dBm<, ≤-120 dBm																															
	-136 dBm<, ≤-127 dBm	±1.5 dB typ.	±1.5 dB typ.																													
<table border="1"> <thead> <tr> <th data-bbox="520 1359 863 1408">Level</th> <th colspan="2" data-bbox="863 1359 1396 1408">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 1408 863 1458" rowspan="2">+13 dBm&lt;, ≤+20 dBm</td> <td data-bbox="863 1408 1137 1458">3 GHz&lt;, ≤4 GHz</td> <td data-bbox="1137 1408 1396 1458">4 GHz&lt;, ≤5 GHz</td> </tr> <tr> <td data-bbox="863 1458 1137 1536" rowspan="2">±0.7 dB</td> <td data-bbox="1137 1458 1396 1536">±0.8 dB</td> </tr> <tr> <td data-bbox="520 1536 863 1585">+11 dBm&lt;, ≤+13 dBm</td> <td data-bbox="863 1536 1137 1585"></td> <td data-bbox="1137 1536 1396 1585"></td> </tr> <tr> <td data-bbox="520 1585 863 1635">+1 dBm≤, ≤+11 dBm</td> <td data-bbox="863 1585 1137 1635"></td> <td data-bbox="1137 1585 1396 1635"></td> </tr> <tr> <td data-bbox="520 1635 863 1684">-40 dBm&lt;, &lt;+1 dBm</td> <td data-bbox="863 1635 1137 1684"></td> <td data-bbox="1137 1635 1396 1684"></td> </tr> <tr> <td data-bbox="520 1684 863 1733">-100 dBm&lt;, ≤-40 dBm</td> <td data-bbox="863 1684 1137 1733"></td> <td data-bbox="1137 1684 1396 1733"></td> </tr> <tr> <td data-bbox="520 1733 863 1783">-110 dBm&lt;, ≤-100 dBm</td> <td data-bbox="863 1733 1137 1783"></td> <td data-bbox="1137 1733 1396 1783"></td> </tr> <tr> <td data-bbox="520 1783 863 1832">-120 dBm&lt;, ≤-110 dBm</td> <td data-bbox="863 1783 1137 1832"></td> <td data-bbox="1137 1783 1396 1832"></td> </tr> <tr> <td data-bbox="520 1832 863 1881">-127 dBm&lt;, ≤-120 dBm</td> <td data-bbox="863 1832 1137 1881">±2.5 dB typ.</td> <td data-bbox="1137 1832 1396 1881">±2.5 dB typ.</td> </tr> </tbody> </table>	Level	Frequency		+13 dBm<, ≤+20 dBm	3 GHz<, ≤4 GHz	4 GHz<, ≤5 GHz	±0.7 dB	±0.8 dB	+11 dBm<, ≤+13 dBm			+1 dBm≤, ≤+11 dBm			-40 dBm<, <+1 dBm			-100 dBm<, ≤-40 dBm			-110 dBm<, ≤-100 dBm			-120 dBm<, ≤-110 dBm			-127 dBm<, ≤-120 dBm	±2.5 dB typ.	±2.5 dB typ.			
Level	Frequency																															
+13 dBm<, ≤+20 dBm	3 GHz<, ≤4 GHz	4 GHz<, ≤5 GHz																														
	±0.7 dB	±0.8 dB																														
+11 dBm<, ≤+13 dBm																																
+1 dBm≤, ≤+11 dBm																																
-40 dBm<, <+1 dBm																																
-100 dBm<, ≤-40 dBm																																
-110 dBm<, ≤-100 dBm																																
-120 dBm<, ≤-110 dBm																																
-127 dBm<, ≤-120 dBm	±2.5 dB typ.	±2.5 dB typ.																														

<Output level> Continued

Items	Specifications																									
Accuracy	<table border="1"> <thead> <tr> <th data-bbox="520 506 863 600" rowspan="2">Level</th> <th colspan="2" data-bbox="863 506 1394 555">Frequency</th> </tr> <tr> <th data-bbox="863 555 1137 600">5 GHz&lt;, ≤6 GHz</th> <th data-bbox="1137 555 1394 600"></th> </tr> </thead> <tbody> <tr> <td data-bbox="520 600 863 645">+1 dBm≤, ≤+11 dBm</td> <td data-bbox="863 600 1137 645">±0.8 dB</td> <td data-bbox="1137 600 1394 645"></td> </tr> <tr> <td data-bbox="520 645 863 678">-40 dBm&lt;, &lt;+1 dBm</td> <td data-bbox="863 645 1137 678">±0.8 dB</td> <td data-bbox="1137 645 1394 678"></td> </tr> <tr> <td data-bbox="520 678 863 723">-100 dBm&lt;, ≤-40 dBm</td> <td data-bbox="863 678 1137 723">±0.8 dB</td> <td data-bbox="1137 678 1394 723"></td> </tr> <tr> <td data-bbox="520 723 863 768">-110 dBm&lt;, ≤-100 dBm</td> <td data-bbox="863 723 1137 768">±0.8 dB</td> <td data-bbox="1137 723 1394 768"></td> </tr> <tr> <td data-bbox="520 768 863 813">-120 dBm&lt;, ≤-110 dBm</td> <td data-bbox="863 768 1137 813">±1.0 dB</td> <td data-bbox="1137 768 1394 813"></td> </tr> <tr> <td data-bbox="520 813 863 835">-127 dBm&lt;, ≤-120 dBm</td> <td data-bbox="863 813 1137 835">±2.5 dB typ.</td> <td data-bbox="1137 813 1394 835"></td> </tr> </tbody> </table>			Level	Frequency		5 GHz<, ≤6 GHz		+1 dBm≤, ≤+11 dBm	±0.8 dB		-40 dBm<, <+1 dBm	±0.8 dB		-100 dBm<, ≤-40 dBm	±0.8 dB		-110 dBm<, ≤-100 dBm	±0.8 dB		-120 dBm<, ≤-110 dBm	±1.0 dB		-127 dBm<, ≤-120 dBm	±2.5 dB typ.	
	Level	Frequency																								
		5 GHz<, ≤6 GHz																								
	+1 dBm≤, ≤+11 dBm	±0.8 dB																								
	-40 dBm<, <+1 dBm	±0.8 dB																								
	-100 dBm<, ≤-40 dBm	±0.8 dB																								
	-110 dBm<, ≤-100 dBm	±0.8 dB																								
	-120 dBm<, ≤-110 dBm	±1.0 dB																								
	-127 dBm<, ≤-120 dBm	±2.5 dB typ.																								
	1st SG: MG3710A/MG3740A-043/143 installed, 2nd SG: MG3710A/MG3740A-073/173 installed																									
1st SG: MG3710A/MG3740A-041/141/042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171/072/172 not installed																										
<table border="1"> <thead> <tr> <th data-bbox="520 1055 863 1149" rowspan="2">Level</th> <th colspan="2" data-bbox="863 1055 1394 1104">Frequency</th> </tr> <tr> <td data-bbox="863 1104 1137 1149" style="text-align: center;"></td> <td data-bbox="1137 1104 1394 1149">100 kHz≤, &lt;1 MHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1149 863 1189">-100 dBm&lt;, ≤+2 dBm</td> <td data-bbox="863 1149 1137 1189" style="text-align: center;"></td> <td data-bbox="1137 1149 1394 1189">±0.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			100 kHz≤, <1 MHz	-100 dBm<, ≤+2 dBm		±0.5 dB typ.																
Level	Frequency																									
		100 kHz≤, <1 MHz																								
-100 dBm<, ≤+2 dBm		±0.5 dB typ.																								
<table border="1"> <thead> <tr> <th data-bbox="520 1232 863 1326" rowspan="2">Level</th> <th colspan="2" data-bbox="863 1232 1394 1281">Frequency</th> </tr> <tr> <th data-bbox="863 1281 1137 1326">1 MHz≤, &lt;10 MHz</th> <th data-bbox="1137 1281 1394 1326">10 MHz≤, &lt;50 MHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 1326 863 1370">+2 dBm&lt;, ≤+7 dBm</td> <td data-bbox="863 1326 1137 1370" style="text-align: center;"></td> <td data-bbox="1137 1326 1394 1370">±0.7 dB typ.</td> </tr> <tr> <td data-bbox="520 1370 863 1406">-110 dBm&lt;, ≤+2 dBm</td> <td data-bbox="863 1370 1137 1406">±0.5 dB typ.</td> <td data-bbox="1137 1370 1394 1406">±0.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency		1 MHz≤, <10 MHz	10 MHz≤, <50 MHz	+2 dBm<, ≤+7 dBm		±0.7 dB typ.	-110 dBm<, ≤+2 dBm	±0.5 dB typ.	±0.5 dB typ.													
Level	Frequency																									
	1 MHz≤, <10 MHz	10 MHz≤, <50 MHz																								
+2 dBm<, ≤+7 dBm		±0.7 dB typ.																								
-110 dBm<, ≤+2 dBm	±0.5 dB typ.	±0.5 dB typ.																								
<table border="1"> <thead> <tr> <th data-bbox="520 1449 863 1543" rowspan="2">Level</th> <th colspan="2" data-bbox="863 1449 1394 1498">Frequency</th> </tr> <tr> <th data-bbox="863 1498 1137 1543">50 MHz≤, &lt;400 MHz</th> <th data-bbox="1137 1498 1394 1543">400 MHz≤, ≤3 GHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 1543 863 1588">-2 dBm≤, ≤+10 dBm</td> <td data-bbox="863 1543 1137 1588">±0.5 dB</td> <td data-bbox="1137 1543 1394 1588">±0.5 dB</td> </tr> <tr> <td data-bbox="520 1588 863 1632">-40 dBm&lt;, &lt;-2 dBm</td> <td data-bbox="863 1588 1137 1632">±0.5 dB</td> <td data-bbox="1137 1588 1394 1632">±0.5 dB</td> </tr> <tr> <td data-bbox="520 1632 863 1659">-110 dBm&lt;, ≤-40 dBm</td> <td data-bbox="863 1632 1137 1659">±0.5 dB</td> <td data-bbox="1137 1632 1394 1659">±0.5 dB</td> </tr> </tbody> </table>			Level	Frequency		50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz	-2 dBm≤, ≤+10 dBm	±0.5 dB	±0.5 dB	-40 dBm<, <-2 dBm	±0.5 dB	±0.5 dB	-110 dBm<, ≤-40 dBm	±0.5 dB	±0.5 dB										
Level	Frequency																									
	50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz																								
-2 dBm≤, ≤+10 dBm	±0.5 dB	±0.5 dB																								
-40 dBm<, <-2 dBm	±0.5 dB	±0.5 dB																								
-110 dBm<, ≤-40 dBm	±0.5 dB	±0.5 dB																								
<table border="1"> <thead> <tr> <th data-bbox="520 1700 863 1794" rowspan="2">Level</th> <th colspan="2" data-bbox="863 1700 1394 1749">Frequency</th> </tr> <tr> <th data-bbox="863 1749 1137 1794">3 GHz&lt;, ≤4 GHz</th> <th data-bbox="1137 1749 1394 1794">4 GHz&lt;, ≤5 GHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 1794 863 1839">+8 dBm&lt;, ≤+10 dBm</td> <td data-bbox="863 1794 1137 1839">±0.7 dB</td> <td data-bbox="1137 1794 1394 1839">±0.8 dB</td> </tr> <tr> <td data-bbox="520 1839 863 1883">-2 dBm≤, ≤+8 dBm</td> <td data-bbox="863 1839 1137 1883">±0.7 dB</td> <td data-bbox="1137 1839 1394 1883">±0.8 dB</td> </tr> <tr> <td data-bbox="520 1883 863 1928">-40 dBm&lt;, &lt;-2 dBm</td> <td data-bbox="863 1883 1137 1928">±0.7 dB</td> <td data-bbox="1137 1883 1394 1928">±0.8 dB</td> </tr> <tr> <td data-bbox="520 1928 863 1973">-100 dBm&lt;, ≤-40 dBm</td> <td data-bbox="863 1928 1137 1973">±0.7 dB</td> <td data-bbox="1137 1928 1394 1973">±0.8 dB</td> </tr> <tr> <td data-bbox="520 1973 863 1986">-110 dBm&lt;, ≤-100 dBm</td> <td data-bbox="863 1973 1137 1986">±0.8 dB</td> <td data-bbox="1137 1973 1394 1986">±0.8 dB</td> </tr> </tbody> </table>			Level	Frequency		3 GHz<, ≤4 GHz	4 GHz<, ≤5 GHz	+8 dBm<, ≤+10 dBm	±0.7 dB	±0.8 dB	-2 dBm≤, ≤+8 dBm	±0.7 dB	±0.8 dB	-40 dBm<, <-2 dBm	±0.7 dB	±0.8 dB	-100 dBm<, ≤-40 dBm	±0.7 dB	±0.8 dB	-110 dBm<, ≤-100 dBm	±0.8 dB	±0.8 dB				
Level	Frequency																									
	3 GHz<, ≤4 GHz	4 GHz<, ≤5 GHz																								
+8 dBm<, ≤+10 dBm	±0.7 dB	±0.8 dB																								
-2 dBm≤, ≤+8 dBm	±0.7 dB	±0.8 dB																								
-40 dBm<, <-2 dBm	±0.7 dB	±0.8 dB																								
-100 dBm<, ≤-40 dBm	±0.7 dB	±0.8 dB																								
-110 dBm<, ≤-100 dBm	±0.8 dB	±0.8 dB																								



<Output level> Continued

Items	Specifications																									
Accuracy	<table border="1"> <thead> <tr> <th data-bbox="520 506 863 600">Level</th> <th colspan="2" data-bbox="863 506 1414 555">Frequency</th> </tr> <tr> <td data-bbox="520 600 863 645"></td> <td colspan="2" data-bbox="863 555 1414 600">5 GHz&lt;, ≤6 GHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 645 863 678">-2 dBm≤, ≤+8 dBm</td> <td colspan="2" data-bbox="863 645 1414 678">±0.8 dB</td> </tr> <tr> <td data-bbox="520 678 863 712">-40 dBm&lt;, &lt;-2 dBm</td> <td colspan="2" data-bbox="863 678 1414 712">±0.8 dB</td> </tr> <tr> <td data-bbox="520 712 863 745">-100 dBm&lt;, ≤-40 dBm</td> <td colspan="2" data-bbox="863 712 1414 745">±0.8 dB</td> </tr> <tr> <td data-bbox="520 745 863 757">-110 dBm&lt;, ≤-100 dBm</td> <td colspan="2" data-bbox="863 745 1414 757">±0.8 dB</td> </tr> </tbody> </table>			Level	Frequency			5 GHz<, ≤6 GHz		-2 dBm≤, ≤+8 dBm	±0.8 dB		-40 dBm<, <-2 dBm	±0.8 dB		-100 dBm<, ≤-40 dBm	±0.8 dB		-110 dBm<, ≤-100 dBm	±0.8 dB						
	Level	Frequency																								
		5 GHz<, ≤6 GHz																								
	-2 dBm≤, ≤+8 dBm	±0.8 dB																								
	-40 dBm<, <-2 dBm	±0.8 dB																								
	-100 dBm<, ≤-40 dBm	±0.8 dB																								
	-110 dBm<, ≤-100 dBm	±0.8 dB																								
	1st SG: MG3710A/MG3740A-041/141 installed, 042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171 installed, 072/172 not installed																									
	<table border="1"> <thead> <tr> <th data-bbox="520 902 863 996">Level</th> <th colspan="2" data-bbox="863 902 1414 952">Frequency</th> </tr> <tr> <td data-bbox="520 996 863 1043"></td> <td colspan="2" data-bbox="863 952 1414 996">100 kHz≤, &lt;1 MHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1043 863 1077">-100 dBm&lt;, ≤+2 dBm</td> <td colspan="2" data-bbox="863 1043 1414 1077">±0.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			100 kHz≤, <1 MHz		-100 dBm<, ≤+2 dBm	±0.5 dB typ.															
	Level	Frequency																								
		100 kHz≤, <1 MHz																								
	-100 dBm<, ≤+2 dBm	±0.5 dB typ.																								
	<table border="1"> <thead> <tr> <th data-bbox="520 1081 863 1176">Level</th> <th colspan="2" data-bbox="863 1081 1414 1131">Frequency</th> </tr> <tr> <td data-bbox="520 1176 863 1209"></td> <td data-bbox="863 1131 1137 1176">1 MHz≤, &lt;10 MHz</td> <td data-bbox="1137 1131 1414 1176">10 MHz≤, &lt;50 MHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1209 863 1243">+2 dBm&lt;, ≤+7 dBm</td> <td colspan="2" data-bbox="863 1209 1414 1243">±0.7 dB typ.</td> </tr> <tr> <td data-bbox="520 1243 863 1256">-110 dBm&lt;, ≤+2 dBm</td> <td data-bbox="863 1243 1137 1256">±0.5 dB typ.</td> <td data-bbox="1137 1243 1414 1256">±0.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			1 MHz≤, <10 MHz	10 MHz≤, <50 MHz	+2 dBm<, ≤+7 dBm	±0.7 dB typ.		-110 dBm<, ≤+2 dBm	±0.5 dB typ.	±0.5 dB typ.											
	Level	Frequency																								
		1 MHz≤, <10 MHz	10 MHz≤, <50 MHz																							
	+2 dBm<, ≤+7 dBm	±0.7 dB typ.																								
	-110 dBm<, ≤+2 dBm	±0.5 dB typ.	±0.5 dB typ.																							
	<table border="1"> <thead> <tr> <th data-bbox="520 1294 863 1388">Level</th> <th colspan="2" data-bbox="863 1294 1414 1344">Frequency</th> </tr> <tr> <td data-bbox="520 1388 863 1422"></td> <td data-bbox="863 1344 1137 1388">50 MHz≤, &lt;400 MHz</td> <td data-bbox="1137 1344 1414 1388">400 MHz≤, ≤3 GHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1422 863 1456">+17 dBm&lt;, ≤+20 dBm</td> <td colspan="2" data-bbox="863 1422 1414 1456">±0.6 dB</td> </tr> <tr> <td data-bbox="520 1456 863 1489">+10 dBm&lt;, ≤+17 dBm</td> <td colspan="2" data-bbox="863 1456 1414 1489">±0.6 dB</td> </tr> <tr> <td data-bbox="520 1489 863 1523">-2 dBm≤, ≤+10 dBm</td> <td colspan="2" data-bbox="863 1489 1414 1523">±0.6 dB</td> </tr> <tr> <td data-bbox="520 1523 863 1556">-40 dBm&lt;, &lt;- 2 dBm</td> <td colspan="2" data-bbox="863 1523 1414 1556">±0.5 dB</td> </tr> <tr> <td data-bbox="520 1556 863 1585">-110 dBm&lt;, ≤-40 dBm</td> <td colspan="2" data-bbox="863 1556 1414 1585">±0.5 dB</td> </tr> </tbody> </table>			Level	Frequency			50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz	+17 dBm<, ≤+20 dBm	±0.6 dB		+10 dBm<, ≤+17 dBm	±0.6 dB		-2 dBm≤, ≤+10 dBm	±0.6 dB		-40 dBm<, <- 2 dBm	±0.5 dB		-110 dBm<, ≤-40 dBm	±0.5 dB			
	Level	Frequency																								
		50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz																							
+17 dBm<, ≤+20 dBm	±0.6 dB																									
+10 dBm<, ≤+17 dBm	±0.6 dB																									
-2 dBm≤, ≤+10 dBm	±0.6 dB																									
-40 dBm<, <- 2 dBm	±0.5 dB																									
-110 dBm<, ≤-40 dBm	±0.5 dB																									
<table border="1"> <thead> <tr> <th data-bbox="520 1624 863 1718">Level</th> <th colspan="2" data-bbox="863 1624 1414 1673">Frequency</th> </tr> <tr> <td data-bbox="520 1718 863 1751"></td> <td data-bbox="863 1673 1137 1718">3 GHz&lt;, ≤4 GHz</td> <td data-bbox="1137 1673 1414 1718">4 GHz&lt;, ≤5 GHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1751 863 1785">+10 dBm&lt;, ≤+17 dBm</td> <td colspan="2" data-bbox="863 1751 1414 1785">±0.7 dB</td> </tr> <tr> <td data-bbox="520 1785 863 1818">+8 dBm&lt;, ≤+10 dBm</td> <td colspan="2" data-bbox="863 1785 1414 1818">±0.7 dB</td> </tr> <tr> <td data-bbox="520 1818 863 1852">-2 dBm≤, ≤+8 dBm</td> <td colspan="2" data-bbox="863 1818 1414 1852">±0.7 dB</td> </tr> <tr> <td data-bbox="520 1852 863 1886">-40 dBm&lt;, &lt;-2 dBm</td> <td colspan="2" data-bbox="863 1852 1414 1886">±0.7 dB</td> </tr> <tr> <td data-bbox="520 1886 863 1919">-100 dBm&lt;, ≤-40 dBm</td> <td colspan="2" data-bbox="863 1886 1414 1919">±0.7 dB</td> </tr> <tr> <td data-bbox="520 1919 863 1951">-110 dBm&lt;, ≤-100 dBm</td> <td colspan="2" data-bbox="863 1919 1414 1951">±0.7 dB</td> </tr> </tbody> </table>			Level	Frequency			3 GHz<, ≤4 GHz	4 GHz<, ≤5 GHz	+10 dBm<, ≤+17 dBm	±0.7 dB		+8 dBm<, ≤+10 dBm	±0.7 dB		-2 dBm≤, ≤+8 dBm	±0.7 dB		-40 dBm<, <-2 dBm	±0.7 dB		-100 dBm<, ≤-40 dBm	±0.7 dB		-110 dBm<, ≤-100 dBm	±0.7 dB	
Level	Frequency																									
	3 GHz<, ≤4 GHz	4 GHz<, ≤5 GHz																								
+10 dBm<, ≤+17 dBm	±0.7 dB																									
+8 dBm<, ≤+10 dBm	±0.7 dB																									
-2 dBm≤, ≤+8 dBm	±0.7 dB																									
-40 dBm<, <-2 dBm	±0.7 dB																									
-100 dBm<, ≤-40 dBm	±0.7 dB																									
-110 dBm<, ≤-100 dBm	±0.7 dB																									

<Output level> Continued

Items	Specifications																												
Accuracy	<table border="1"> <thead> <tr> <th data-bbox="520 506 863 600">Level</th> <th colspan="2" data-bbox="863 506 1414 553">Frequency</th> </tr> <tr> <td data-bbox="520 600 863 647"></td> <td colspan="2" data-bbox="863 553 1414 600">5 GHz&lt;, ≤6 GHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 647 863 680">-2 dBm≤, ≤+8 dBm</td> <td colspan="2" data-bbox="863 600 1414 647">±0.8 dB</td> </tr> <tr> <td data-bbox="520 680 863 714">-40 dBm&lt;, &lt;-2 dBm</td> <td colspan="2" data-bbox="863 647 1414 680">±0.8 dB</td> </tr> <tr> <td data-bbox="520 714 863 748">-100 dBm&lt;, ≤-40 dBm</td> <td colspan="2" data-bbox="863 680 1414 714">±0.8 dB</td> </tr> <tr> <td data-bbox="520 748 863 757">-110 dBm&lt;, ≤-100 dBm</td> <td colspan="2" data-bbox="863 714 1414 748">±0.8 dB</td> </tr> </tbody> </table>			Level	Frequency			5 GHz<, ≤6 GHz		-2 dBm≤, ≤+8 dBm	±0.8 dB		-40 dBm<, <-2 dBm	±0.8 dB		-100 dBm<, ≤-40 dBm	±0.8 dB		-110 dBm<, ≤-100 dBm	±0.8 dB									
	Level	Frequency																											
		5 GHz<, ≤6 GHz																											
	-2 dBm≤, ≤+8 dBm	±0.8 dB																											
	-40 dBm<, <-2 dBm	±0.8 dB																											
	-100 dBm<, ≤-40 dBm	±0.8 dB																											
	-110 dBm<, ≤-100 dBm	±0.8 dB																											
	1st SG: MG3710A/MG3740A-041/141 not installed, 042/142 installed, 2nd SG: MG3710A/MG3740A-071/171 not installed, 072/172 installed																												
	<table border="1"> <thead> <tr> <th data-bbox="520 902 863 996">Level</th> <th colspan="2" data-bbox="863 902 1414 949">Frequency</th> </tr> <tr> <td data-bbox="520 996 863 1039"></td> <td colspan="2" data-bbox="863 949 1414 996">100 kHz≤, &lt;1 MHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1039 863 1039">-100 dBm&lt;, ≤+2 dBm</td> <td colspan="2" data-bbox="863 996 1414 1039">±0.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			100 kHz≤, <1 MHz		-100 dBm<, ≤+2 dBm	±0.5 dB typ.																		
	Level	Frequency																											
		100 kHz≤, <1 MHz																											
	-100 dBm<, ≤+2 dBm	±0.5 dB typ.																											
	<table border="1"> <thead> <tr> <th data-bbox="520 1077 863 1171">Level</th> <th colspan="2" data-bbox="863 1077 1414 1124">Frequency</th> </tr> <tr> <td data-bbox="520 1171 863 1218"></td> <td data-bbox="863 1124 1137 1171">1 MHz≤, &lt;10 MHz</td> <td data-bbox="1137 1124 1414 1171">10 MHz≤, &lt;50 MHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1218 863 1252">+2 dBm&lt;, ≤+7 dBm</td> <td colspan="2" data-bbox="863 1171 1414 1218">±0.7 dB typ.</td> </tr> <tr> <td data-bbox="520 1252 863 1256">-120 dBm&lt;, ≤+2 dBm</td> <td data-bbox="863 1218 1137 1252">±0.5 dB typ.</td> <td data-bbox="1137 1218 1414 1252">±0.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			1 MHz≤, <10 MHz	10 MHz≤, <50 MHz	+2 dBm<, ≤+7 dBm	±0.7 dB typ.		-120 dBm<, ≤+2 dBm	±0.5 dB typ.	±0.5 dB typ.														
	Level	Frequency																											
		1 MHz≤, <10 MHz	10 MHz≤, <50 MHz																										
	+2 dBm<, ≤+7 dBm	±0.7 dB typ.																											
	-120 dBm<, ≤+2 dBm	±0.5 dB typ.	±0.5 dB typ.																										
	<table border="1"> <thead> <tr> <th data-bbox="520 1294 863 1388">Level</th> <th colspan="2" data-bbox="863 1294 1414 1341">Frequency</th> </tr> <tr> <td data-bbox="520 1388 863 1435"></td> <td data-bbox="863 1341 1137 1388">50 MHz≤, &lt;400 MHz</td> <td data-bbox="1137 1341 1414 1388">400 MHz≤, ≤3 GHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1435 863 1469">-2 dBm≤, ≤+10 dBm</td> <td data-bbox="863 1388 1137 1435">±0.5 dB</td> <td data-bbox="1137 1388 1414 1435">±0.5 dB</td> </tr> <tr> <td data-bbox="520 1469 863 1503">-40 dBm&lt;, &lt;-2 dBm</td> <td colspan="2" data-bbox="863 1435 1414 1469">±0.5 dB</td> </tr> <tr> <td data-bbox="520 1503 863 1536">-110 dBm&lt;, ≤-40 dBm</td> <td colspan="2" data-bbox="863 1469 1414 1503">±0.5 dB</td> </tr> <tr> <td data-bbox="520 1536 863 1570">-120 dBm&lt;, ≤-110 dBm</td> <td data-bbox="863 1503 1137 1570">±0.5 dB</td> <td data-bbox="1137 1503 1414 1570">±0.7 dB</td> </tr> <tr> <td data-bbox="520 1570 863 1603">-127 dBm&lt;, ≤-120 dBm</td> <td colspan="2" data-bbox="863 1570 1414 1603">±0.7 dB</td> </tr> <tr> <td data-bbox="520 1603 863 1621">-136 dBm&lt;, ≤-127 dBm</td> <td data-bbox="863 1603 1137 1621">±1.5 dB typ.</td> <td data-bbox="1137 1603 1414 1621">±1.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz	-2 dBm≤, ≤+10 dBm	±0.5 dB	±0.5 dB	-40 dBm<, <-2 dBm	±0.5 dB		-110 dBm<, ≤-40 dBm	±0.5 dB		-120 dBm<, ≤-110 dBm	±0.5 dB	±0.7 dB	-127 dBm<, ≤-120 dBm	±0.7 dB		-136 dBm<, ≤-127 dBm	±1.5 dB typ.	±1.5 dB typ.		
	Level	Frequency																											
		50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz																										
-2 dBm≤, ≤+10 dBm	±0.5 dB	±0.5 dB																											
-40 dBm<, <-2 dBm	±0.5 dB																												
-110 dBm<, ≤-40 dBm	±0.5 dB																												
-120 dBm<, ≤-110 dBm	±0.5 dB	±0.7 dB																											
-127 dBm<, ≤-120 dBm	±0.7 dB																												
-136 dBm<, ≤-127 dBm	±1.5 dB typ.	±1.5 dB typ.																											
<table border="1"> <thead> <tr> <th data-bbox="520 1659 863 1753">Level</th> <th colspan="2" data-bbox="863 1659 1414 1706">Frequency</th> </tr> <tr> <td data-bbox="520 1753 863 1800"></td> <td data-bbox="863 1706 1137 1753">3 GHz&lt;, ≤4 GHz</td> <td data-bbox="1137 1706 1414 1753">4 GHz&lt;, ≤5 GHz</td> </tr> </thead> <tbody> <tr> <td data-bbox="520 1800 863 1834">+8 dBm&lt;, ≤+10 dBm</td> <td data-bbox="863 1753 1137 1834">±0.7 dB</td> <td data-bbox="1137 1753 1414 1834">±0.8 dB</td> </tr> <tr> <td data-bbox="520 1834 863 1868">-2 dBm≤, ≤+8 dBm</td> <td colspan="2" data-bbox="863 1834 1414 1868">±0.7 dB</td> </tr> <tr> <td data-bbox="520 1868 863 1901">-40 dBm&lt;, &lt;-2 dBm</td> <td colspan="2" data-bbox="863 1868 1414 1901">±0.7 dB</td> </tr> <tr> <td data-bbox="520 1901 863 1935">-100 dBm&lt;, ≤-40 dBm</td> <td colspan="2" data-bbox="863 1901 1414 1935">±0.7 dB</td> </tr> <tr> <td data-bbox="520 1935 863 1968">-110 dBm&lt;, ≤-100 dBm</td> <td colspan="2" data-bbox="863 1935 1414 1968">±0.8 dB</td> </tr> <tr> <td data-bbox="520 1968 863 2002">-120 dBm&lt;, ≤-110 dBm</td> <td colspan="2" data-bbox="863 1968 1414 2002">±1.0 dB</td> </tr> <tr> <td data-bbox="520 2002 863 2029">-127 dBm&lt;, ≤-120 dBm</td> <td data-bbox="863 2002 1137 2029">±2.5 dB typ.</td> <td data-bbox="1137 2002 1414 2029">±2.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			3 GHz<, ≤4 GHz	4 GHz<, ≤5 GHz	+8 dBm<, ≤+10 dBm	±0.7 dB	±0.8 dB	-2 dBm≤, ≤+8 dBm	±0.7 dB		-40 dBm<, <-2 dBm	±0.7 dB		-100 dBm<, ≤-40 dBm	±0.7 dB		-110 dBm<, ≤-100 dBm	±0.8 dB		-120 dBm<, ≤-110 dBm	±1.0 dB		-127 dBm<, ≤-120 dBm	±2.5 dB typ.	±2.5 dB typ.
Level	Frequency																												
	3 GHz<, ≤4 GHz	4 GHz<, ≤5 GHz																											
+8 dBm<, ≤+10 dBm	±0.7 dB	±0.8 dB																											
-2 dBm≤, ≤+8 dBm	±0.7 dB																												
-40 dBm<, <-2 dBm	±0.7 dB																												
-100 dBm<, ≤-40 dBm	±0.7 dB																												
-110 dBm<, ≤-100 dBm	±0.8 dB																												
-120 dBm<, ≤-110 dBm	±1.0 dB																												
-127 dBm<, ≤-120 dBm	±2.5 dB typ.	±2.5 dB typ.																											

<Output level> Continued

Items	Specifications																										
Accuracy	<table border="1"> <thead> <tr> <th data-bbox="520 506 863 555">Level</th> <th colspan="2" data-bbox="863 506 1414 555">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 555 863 600"></td> <td colspan="2" data-bbox="863 555 1414 600">5 GHz&lt;, ≤6 GHz</td> </tr> <tr> <td data-bbox="520 600 863 645">-2 dBm≤, ≤+8 dBm</td> <td colspan="2" data-bbox="863 600 1414 645">±0.8 dB</td> </tr> <tr> <td data-bbox="520 645 863 689">-40 dBm&lt;, &lt;-2 dBm</td> <td colspan="2" data-bbox="863 645 1414 689">±0.8 dB</td> </tr> <tr> <td data-bbox="520 689 863 734">-100 dBm&lt;, ≤-40 dBm</td> <td colspan="2" data-bbox="863 689 1414 734">±0.8 dB</td> </tr> <tr> <td data-bbox="520 734 863 779">-110 dBm&lt;, ≤-100 dBm</td> <td colspan="2" data-bbox="863 734 1414 779">±0.8 dB</td> </tr> <tr> <td data-bbox="520 779 863 824">-120 dBm&lt;, ≤-110 dBm</td> <td colspan="2" data-bbox="863 779 1414 824">±1.0 dB</td> </tr> <tr> <td data-bbox="520 824 863 869">-127 dBm&lt;, ≤-120 dBm</td> <td colspan="2" data-bbox="863 824 1414 869">±2.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			5 GHz<, ≤6 GHz		-2 dBm≤, ≤+8 dBm	±0.8 dB		-40 dBm<, <-2 dBm	±0.8 dB		-100 dBm<, ≤-40 dBm	±0.8 dB		-110 dBm<, ≤-100 dBm	±0.8 dB		-120 dBm<, ≤-110 dBm	±1.0 dB		-127 dBm<, ≤-120 dBm	±2.5 dB typ.	
	Level	Frequency																									
		5 GHz<, ≤6 GHz																									
	-2 dBm≤, ≤+8 dBm	±0.8 dB																									
	-40 dBm<, <-2 dBm	±0.8 dB																									
	-100 dBm<, ≤-40 dBm	±0.8 dB																									
	-110 dBm<, ≤-100 dBm	±0.8 dB																									
	-120 dBm<, ≤-110 dBm	±1.0 dB																									
	-127 dBm<, ≤-120 dBm	±2.5 dB typ.																									
	1st SG: MG3710A/MG3740A-041/141/042/142 installed, 2nd SG: MG3710A/MG3740A-071/171/072/172 installed																										
	<table border="1"> <thead> <tr> <th data-bbox="520 947 863 992">Level</th> <th colspan="2" data-bbox="863 947 1414 992">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 992 863 1088">-100 dBm&lt;, ≤+2 dBm</td> <td colspan="2" data-bbox="863 992 1414 1088">100 kHz≤, &lt;1 MHz ±0.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency		-100 dBm<, ≤+2 dBm	100 kHz≤, <1 MHz ±0.5 dB typ.																			
	Level	Frequency																									
	-100 dBm<, ≤+2 dBm	100 kHz≤, <1 MHz ±0.5 dB typ.																									
<table border="1"> <thead> <tr> <th data-bbox="520 1122 863 1167">Level</th> <th colspan="2" data-bbox="863 1122 1414 1167">Frequency</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 1167 863 1211"></td> <td data-bbox="863 1167 1137 1211">1 MHz≤, &lt;10 MHz</td> <td data-bbox="1137 1167 1414 1211">10 MHz≤, &lt;50 MHz</td> </tr> <tr> <td data-bbox="520 1211 863 1256">+2 dBm&lt;, ≤+7 dBm</td> <td colspan="2" data-bbox="863 1211 1414 1256">±0.7 dB typ.</td> </tr> <tr> <td data-bbox="520 1256 863 1301">-120 dBm&lt;, ≤+2 dBm</td> <td data-bbox="863 1256 1137 1301">±0.5 dB typ.</td> <td data-bbox="1137 1256 1414 1301">±0.5 dB typ.</td> </tr> </tbody> </table>			Level	Frequency			1 MHz≤, <10 MHz	10 MHz≤, <50 MHz	+2 dBm<, ≤+7 dBm	±0.7 dB typ.		-120 dBm<, ≤+2 dBm	±0.5 dB typ.	±0.5 dB typ.													
Level	Frequency																										
	1 MHz≤, <10 MHz	10 MHz≤, <50 MHz																									
+2 dBm<, ≤+7 dBm	±0.7 dB typ.																										
-120 dBm<, ≤+2 dBm	±0.5 dB typ.	±0.5 dB typ.																									

<Output level> Continued

Items	Specifications		
Accuracy	<b>Frequency</b>		
	<b>Level</b>	<b>50 MHz≤, &lt;400 MHz</b>	<b>400 MHz≤, ≤3 GHz</b>
	+17 dBm<, ≤+20 dBm	/	±0.6 dB
	+10 dBm<, ≤+17 dBm	±0.6 dB	±0.6 dB
	-2 dBm≤, ≤+10 dBm	±0.6 dB	±0.5 dB
	-40 dBm<, <-2 dBm	±0.5 dB	±0.5 dB
	-110 dBm<, ≤-40 dBm	±0.5 dB	±0.5 dB
	-120 dBm<, ≤-110 dBm	±0.5 dB	±0.7 dB
	-127 dBm<, ≤-120 dBm	±0.7 dB	±1.0 dB
	-136 dBm<, ≤-127 dBm	±1.5 dB typ.	±1.5 dB typ.
	<b>Frequency</b>		
	<b>Level</b>	<b>3 GHz&lt;, ≤4 GHz</b>	<b>4 GHz&lt;, ≤5 GHz</b>
	+10 dBm<, ≤+17 dBm	±0.7 dB	/
	+8 dBm<, ≤+10 dBm	±0.7 dB	±0.8 dB
	-2 dBm≤, ≤+8 dBm	±0.7 dB	±0.8 dB
	-40 dBm<, <-2 dBm	±0.7 dB	±0.8 dB
	-100 dBm<, ≤-40 dBm	±0.7 dB	±0.8 dB
	-110 dBm<, ≤-100 dBm	±0.8 dB	±0.8 dB
	-120 dBm<, ≤-110 dBm	±1.0 dB	±1.0 dB
	-127 dBm<, ≤-120 dBm	±2.5 dB typ.	±2.5 dB typ.
	<b>Frequency</b>		
	<b>Level</b>	<b>5 GHz&lt;, ≤6 GHz</b>	/
	-2 dBm<, ≤+8 dBm	±0.8 dB	/
	-40 dBm<, ≤-2 dBm	±0.8 dB	/
-100 dBm<, ≤-40 dBm	±0.8 dB	/	
-110 dBm<, ≤-100 dBm	±0.8 dB	/	
-120 dBm<, ≤-110 dBm	±1.0 dB	/	
-127 dBm<, ≤-120 dBm	±2.5 dB typ.	/	

<Output level> Continued

Items	Specifications															
Linearity	CW, at 18 to 28°C															
	1st SG: MG3710A/MG3740A-043/143 not installed, 2nd SG: MG3710A/MG3740A-073/173 not installed															
	1st SG: MG3710A/MG3740A-041/141/042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171/072/172 not installed Reference: -7 dBm															
	<table border="1"> <thead> <tr> <th data-bbox="496 696 839 745">Level</th> <th colspan="2" data-bbox="839 696 1406 745">Frequency</th> </tr> <tr> <td data-bbox="496 745 839 790"></td> <th data-bbox="839 745 1114 790">50 MHz≤, &lt;400 MHz</th> <th data-bbox="1114 745 1406 790">400 MHz≤, ≤3 GHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="496 790 839 835">-40 dBm&lt;, ≤+2 dBm</td> <td data-bbox="839 790 1114 835">±0.2 dB typ.</td> <td data-bbox="1114 790 1406 835">±0.2 dB typ.</td> </tr> <tr> <td data-bbox="496 835 839 869">-110 dBm&lt;, ≤-40 dBm</td> <td data-bbox="839 835 1114 869">±0.2 dB typ.</td> <td data-bbox="1114 835 1406 869">±0.2 dB typ.</td> </tr> </tbody> </table>	Level	Frequency			50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz	-40 dBm<, ≤+2 dBm	±0.2 dB typ.	±0.2 dB typ.	-110 dBm<, ≤-40 dBm	±0.2 dB typ.	±0.2 dB typ.			
	Level	Frequency														
		50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz													
	-40 dBm<, ≤+2 dBm	±0.2 dB typ.	±0.2 dB typ.													
	-110 dBm<, ≤-40 dBm	±0.2 dB typ.	±0.2 dB typ.													
	<table border="1"> <thead> <tr> <th data-bbox="496 902 839 952">Level</th> <th colspan="2" data-bbox="839 902 1406 952">Frequency</th> </tr> <tr> <td data-bbox="496 952 839 996"></td> <th data-bbox="839 952 1114 996">3 GHz&lt;, ≤4 GHz</th> <th data-bbox="1114 952 1406 996">4 GHz&lt;, ≤6 GHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="496 996 839 1041">-40 dBm&lt;, ≤+2 dBm</td> <td data-bbox="839 996 1114 1041">±0.3 dB typ.</td> <td data-bbox="1114 996 1406 1041">±0.3 dB typ.</td> </tr> <tr> <td data-bbox="496 1041 839 1086">-100 dBm&lt;, ≤-40 dBm</td> <td data-bbox="839 1041 1114 1086">±0.3 dB typ.</td> <td data-bbox="1114 1041 1406 1086">±0.3 dB typ.</td> </tr> <tr> <td data-bbox="496 1086 839 1122">-110 dBm&lt;, ≤-100 dBm</td> <td data-bbox="839 1086 1114 1122">±0.3 dB typ.</td> <td data-bbox="1114 1086 1406 1122">±0.3 dB typ.</td> </tr> </tbody> </table>	Level	Frequency			3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz	-40 dBm<, ≤+2 dBm	±0.3 dB typ.	±0.3 dB typ.	-100 dBm<, ≤-40 dBm	±0.3 dB typ.	±0.3 dB typ.	-110 dBm<, ≤-100 dBm	±0.3 dB typ.	±0.3 dB typ.
	Level	Frequency														
	3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz														
-40 dBm<, ≤+2 dBm	±0.3 dB typ.	±0.3 dB typ.														
-100 dBm<, ≤-40 dBm	±0.3 dB typ.	±0.3 dB typ.														
-110 dBm<, ≤-100 dBm	±0.3 dB typ.	±0.3 dB typ.														
1st SG: MG3710A/MG3740A-041/141 installed, 042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171 installed, 072/172 not installed Reference: -7 dBm																
<table border="1"> <thead> <tr> <th data-bbox="496 1261 839 1310">Level</th> <th colspan="2" data-bbox="839 1261 1406 1310">Frequency</th> </tr> <tr> <td data-bbox="496 1310 839 1355"></td> <th data-bbox="839 1310 1114 1355">50 MHz≤, &lt;400 MHz</th> <th data-bbox="1114 1310 1406 1355">400 MHz≤, ≤3 GHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="496 1355 839 1400">-40 dBm&lt;, ≤+2 dBm</td> <td data-bbox="839 1355 1114 1400">±0.2 dB typ.</td> <td data-bbox="1114 1355 1406 1400">±0.2 dB typ.</td> </tr> <tr> <td data-bbox="496 1400 839 1440">-110 dBm&lt;, ≤-40 dBm</td> <td data-bbox="839 1400 1114 1440">±0.2 dB typ.</td> <td data-bbox="1114 1400 1406 1440">±0.2 dB typ.</td> </tr> </tbody> </table>	Level	Frequency			50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz	-40 dBm<, ≤+2 dBm	±0.2 dB typ.	±0.2 dB typ.	-110 dBm<, ≤-40 dBm	±0.2 dB typ.	±0.2 dB typ.				
Level	Frequency															
	50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz														
-40 dBm<, ≤+2 dBm	±0.2 dB typ.	±0.2 dB typ.														
-110 dBm<, ≤-40 dBm	±0.2 dB typ.	±0.2 dB typ.														
<table border="1"> <thead> <tr> <th data-bbox="496 1473 839 1523">Level</th> <th colspan="2" data-bbox="839 1473 1406 1523">Frequency</th> </tr> <tr> <td data-bbox="496 1523 839 1568"></td> <th data-bbox="839 1523 1114 1568">3 GHz&lt;, ≤4 GHz</th> <th data-bbox="1114 1523 1406 1568">4 GHz&lt;, ≤6 GHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="496 1568 839 1612">-40 dBm&lt;, ≤+2 dBm</td> <td data-bbox="839 1568 1114 1612">±0.3 dB typ.</td> <td data-bbox="1114 1568 1406 1612">±0.3 dB typ.</td> </tr> <tr> <td data-bbox="496 1612 839 1657">-100 dBm&lt;, ≤-40 dBm</td> <td data-bbox="839 1612 1114 1657">±0.3 dB typ.</td> <td data-bbox="1114 1612 1406 1657">±0.3 dB typ.</td> </tr> <tr> <td data-bbox="496 1657 839 1693">-110 dBm&lt;, ≤-100 dBm</td> <td data-bbox="839 1657 1114 1693">±0.3 dB typ.</td> <td data-bbox="1114 1657 1406 1693">±0.3 dB typ.</td> </tr> </tbody> </table>	Level	Frequency			3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz	-40 dBm<, ≤+2 dBm	±0.3 dB typ.	±0.3 dB typ.	-100 dBm<, ≤-40 dBm	±0.3 dB typ.	±0.3 dB typ.	-110 dBm<, ≤-100 dBm	±0.3 dB typ.	±0.3 dB typ.	
Level	Frequency															
	3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz														
-40 dBm<, ≤+2 dBm	±0.3 dB typ.	±0.3 dB typ.														
-100 dBm<, ≤-40 dBm	±0.3 dB typ.	±0.3 dB typ.														
-110 dBm<, ≤-100 dBm	±0.3 dB typ.	±0.3 dB typ.														

<Output level> Continued

Items	Specifications																															
Linearity	<p>1st SG: MG3710A/MG3740A-041/141 not installed, 042/142 installed,                      2nd SG: MG3710A/MG3740A-071/171 not installed, 072/172 installed                      Reference: -7 dBm</p> <table border="1" data-bbox="520 562 1415 779"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="2">Frequency</th> </tr> <tr> <th>50 MHz<math>\leq</math>, &lt;400 MHz</th> <th>400 MHz<math>\leq</math>, <math>\leq</math>3 GHz</th> </tr> </thead> <tbody> <tr> <td>-40 dBm&lt;, <math>\leq</math>+2 dBm</td> <td><math>\pm</math>0.2 dB typ.</td> <td><math>\pm</math>0.2 dB typ.</td> </tr> <tr> <td>-110 dBm&lt;, <math>\leq</math>-40 dBm</td> <td><math>\pm</math>0.2 dB typ.</td> <td><math>\pm</math>0.2 dB typ.</td> </tr> <tr> <td>-120 dBm&lt;, <math>\leq</math>-110 dBm</td> <td><math>\pm</math>0.2 dB typ.</td> <td><math>\pm</math>0.2 dB typ.</td> </tr> </tbody> </table> <table border="1" data-bbox="520 815 1415 1070"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="2">Frequency</th> </tr> <tr> <th>3 GHz&lt;, <math>\leq</math>4 GHz</th> <th>4 GHz&lt;, <math>\leq</math>6 GHz</th> </tr> </thead> <tbody> <tr> <td>-40 dBm&lt;, <math>\leq</math>+2 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td><math>\pm</math>0.3 dB typ.</td> </tr> <tr> <td>-100 dBm&lt;, <math>\leq</math>-40 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td><math>\pm</math>0.3 dB typ.</td> </tr> <tr> <td>-110 dBm&lt;, <math>\leq</math>-100 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td><math>\pm</math>0.3 dB typ.</td> </tr> <tr> <td>-120 dBm&lt;, <math>\leq</math>-110 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td></td> </tr> </tbody> </table>	Level	Frequency		50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz	-40 dBm<, $\leq$ +2 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.	-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.	-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.	Level	Frequency		3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 6 GHz	-40 dBm<, $\leq$ +2 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.	-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.	-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.	-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.3 dB typ.	
Level	Frequency																															
	50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz																														
-40 dBm<, $\leq$ +2 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.																														
-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.																														
-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.																														
Level	Frequency																															
	3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 6 GHz																														
-40 dBm<, $\leq$ +2 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.																														
-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.																														
-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.																														
-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.3 dB typ.																															
	<p>1st SG: MG3710A/MG3740A-041/141/042/142 installed,                      2nd SG: MG3710A/MG3740A-071/171/072/172 installed                      Reference: -7 dBm</p> <table border="1" data-bbox="520 1214 1415 1431"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="2">Frequency</th> </tr> <tr> <th>50 MHz<math>\leq</math>, &lt;400 MHz</th> <th>400 MHz<math>\leq</math>, <math>\leq</math>3 GHz</th> </tr> </thead> <tbody> <tr> <td>-40 dBm&lt;, <math>\leq</math>+2 dBm</td> <td><math>\pm</math>0.2 dB typ.</td> <td><math>\pm</math>0.2 dB typ.</td> </tr> <tr> <td>-110 dBm&lt;, <math>\leq</math>-40 dBm</td> <td><math>\pm</math>0.2 dB typ.</td> <td><math>\pm</math>0.2 dB typ.</td> </tr> <tr> <td>-120 dBm&lt;, <math>\leq</math>-110 dBm</td> <td><math>\pm</math>0.2 dB typ.</td> <td><math>\pm</math>0.2 dB typ.</td> </tr> </tbody> </table> <table border="1" data-bbox="520 1467 1415 1722"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="2">Frequency</th> </tr> <tr> <th>3 GHz&lt;, <math>\leq</math>4 GHz</th> <th>4 GHz&lt;, <math>\leq</math>6 GHz</th> </tr> </thead> <tbody> <tr> <td>-40 dBm&lt;, <math>\leq</math>+2 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td><math>\pm</math>0.3 dB typ.</td> </tr> <tr> <td>-100 dBm&lt;, <math>\leq</math>-40 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td><math>\pm</math>0.3 dB typ.</td> </tr> <tr> <td>-110 dBm&lt;, <math>\leq</math>-100 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td><math>\pm</math>0.3 dB typ.</td> </tr> <tr> <td>-120 dBm&lt;, <math>\leq</math>-110 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td></td> </tr> </tbody> </table>	Level	Frequency		50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz	-40 dBm<, $\leq$ +2 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.	-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.	-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.	Level	Frequency		3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 6 GHz	-40 dBm<, $\leq$ +2 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.	-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.	-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.	-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.3 dB typ.	
Level	Frequency																															
	50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz																														
-40 dBm<, $\leq$ +2 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.																														
-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.																														
-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.																														
Level	Frequency																															
	3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 6 GHz																														
-40 dBm<, $\leq$ +2 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.																														
-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.																														
-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.																														
-120 dBm<, $\leq$ -110 dBm	$\pm$ 0.3 dB typ.																															

<Output level> Continued

Items	Specifications														
Linearity	1st SG: MG3710A/MG3740A-043/143 installed, 2nd SG: MG3710A/MG3740A-073/173 installed														
	1st SG: MG3710A/MG3740A-041/141/042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171/072/172 not installed Reference: -10 dBm														
	<table border="1"> <thead> <tr> <th data-bbox="520 645 863 741" rowspan="2">Level</th> <th colspan="2" data-bbox="863 645 1414 689">Frequency</th> </tr> <tr> <th data-bbox="863 689 1139 741">50 MHz≤, &lt;400 MHz</th> <th data-bbox="1139 689 1414 741">400 MHz≤, ≤3 GHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 741 863 779">-40 dBm&lt;, ≤-1 dBm</td> <td data-bbox="863 741 1139 779">±0.2 dB typ.</td> <td data-bbox="1139 741 1414 779">±0.2 dB typ.</td> </tr> <tr> <td data-bbox="520 779 863 819">-110 dBm&lt;, ≤-40 dBm</td> <td data-bbox="863 779 1139 819">±0.2 dB typ.</td> <td data-bbox="1139 779 1414 819">±0.2 dB typ.</td> </tr> </tbody> </table>	Level	Frequency		50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz	-40 dBm<, ≤-1 dBm	±0.2 dB typ.	±0.2 dB typ.	-110 dBm<, ≤-40 dBm	±0.2 dB typ.	±0.2 dB typ.			
	Level		Frequency												
		50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz												
	-40 dBm<, ≤-1 dBm	±0.2 dB typ.	±0.2 dB typ.												
	-110 dBm<, ≤-40 dBm	±0.2 dB typ.	±0.2 dB typ.												
	<table border="1"> <thead> <tr> <th data-bbox="520 857 863 954" rowspan="2">Level</th> <th colspan="2" data-bbox="863 857 1414 902">Frequency</th> </tr> <tr> <th data-bbox="863 902 1139 954">3 GHz&lt;, ≤4 GHz</th> <th data-bbox="1139 902 1414 954">4 GHz&lt;, ≤6 GHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 954 863 992">-40 dBm&lt;, ≤-1 dBm</td> <td data-bbox="863 954 1139 992">±0.3 dB typ.</td> <td data-bbox="1139 954 1414 992">±0.3 dB typ.</td> </tr> <tr> <td data-bbox="520 992 863 1030">-100 dBm&lt;, ≤-40 dBm</td> <td data-bbox="863 992 1139 1030">±0.3 dB typ.</td> <td data-bbox="1139 992 1414 1030">±0.3 dB typ.</td> </tr> <tr> <td data-bbox="520 1030 863 1072">-110 dBm&lt;, ≤-100 dBm</td> <td data-bbox="863 1030 1139 1072">±0.4 dB typ.</td> <td data-bbox="1139 1030 1414 1072">±0.4 dB typ.</td> </tr> </tbody> </table>	Level	Frequency		3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz	-40 dBm<, ≤-1 dBm	±0.3 dB typ.	±0.3 dB typ.	-100 dBm<, ≤-40 dBm	±0.3 dB typ.	±0.3 dB typ.	-110 dBm<, ≤-100 dBm	±0.4 dB typ.	±0.4 dB typ.
	Level		Frequency												
		3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz												
	-40 dBm<, ≤-1 dBm	±0.3 dB typ.	±0.3 dB typ.												
	-100 dBm<, ≤-40 dBm	±0.3 dB typ.	±0.3 dB typ.												
-110 dBm<, ≤-100 dBm	±0.4 dB typ.	±0.4 dB typ.													
1st SG: MG3710A/MG3740A-041/141 installed, 042/142 not installed, 2nd SG: MG3710A/MG3740A-071/171 installed, 072/172 not installed Reference: -10 dBm															
<table border="1"> <thead> <tr> <th data-bbox="520 1223 863 1319" rowspan="2">Level</th> <th colspan="2" data-bbox="863 1223 1414 1267">Frequency</th> </tr> <tr> <th data-bbox="863 1267 1139 1319">50 MHz≤, &lt;400 MHz</th> <th data-bbox="1139 1267 1414 1319">400 MHz≤, ≤3 GHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 1319 863 1357">-40 dBm&lt;, ≤-1 dBm</td> <td data-bbox="863 1319 1139 1357">±0.2 dB typ.</td> <td data-bbox="1139 1319 1414 1357">±0.2 dB typ.</td> </tr> <tr> <td data-bbox="520 1357 863 1397">-110 dBm&lt;, ≤-40 dBm</td> <td data-bbox="863 1357 1139 1397">±0.2 dB typ.</td> <td data-bbox="1139 1357 1414 1397">±0.2 dB typ.</td> </tr> </tbody> </table>	Level	Frequency		50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz	-40 dBm<, ≤-1 dBm	±0.2 dB typ.	±0.2 dB typ.	-110 dBm<, ≤-40 dBm	±0.2 dB typ.	±0.2 dB typ.				
Level		Frequency													
	50 MHz≤, <400 MHz	400 MHz≤, ≤3 GHz													
-40 dBm<, ≤-1 dBm	±0.2 dB typ.	±0.2 dB typ.													
-110 dBm<, ≤-40 dBm	±0.2 dB typ.	±0.2 dB typ.													
<table border="1"> <thead> <tr> <th data-bbox="520 1435 863 1532" rowspan="2">Level</th> <th colspan="2" data-bbox="863 1435 1414 1480">Frequency</th> </tr> <tr> <th data-bbox="863 1480 1139 1532">3 GHz&lt;, ≤4 GHz</th> <th data-bbox="1139 1480 1414 1532">4 GHz&lt;, ≤6 GHz</th> </tr> </thead> <tbody> <tr> <td data-bbox="520 1532 863 1570">-40 dBm&lt;, ≤-1 dBm</td> <td data-bbox="863 1532 1139 1570">±0.3 dB typ.</td> <td data-bbox="1139 1532 1414 1570">±0.3 dB typ.</td> </tr> <tr> <td data-bbox="520 1570 863 1608">-100 dBm&lt;, ≤-40 dBm</td> <td data-bbox="863 1570 1139 1608">±0.3 dB typ.</td> <td data-bbox="1139 1570 1414 1608">±0.3 dB typ.</td> </tr> <tr> <td data-bbox="520 1608 863 1650">-110 dBm&lt;, ≤-100 dBm</td> <td data-bbox="863 1608 1139 1650">±0.4 dB typ.</td> <td data-bbox="1139 1608 1414 1650">±0.4 dB typ.</td> </tr> </tbody> </table>	Level	Frequency		3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz	-40 dBm<, ≤-1 dBm	±0.3 dB typ.	±0.3 dB typ.	-100 dBm<, ≤-40 dBm	±0.3 dB typ.	±0.3 dB typ.	-110 dBm<, ≤-100 dBm	±0.4 dB typ.	±0.4 dB typ.	
Level		Frequency													
	3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz													
-40 dBm<, ≤-1 dBm	±0.3 dB typ.	±0.3 dB typ.													
-100 dBm<, ≤-40 dBm	±0.3 dB typ.	±0.3 dB typ.													
-110 dBm<, ≤-100 dBm	±0.4 dB typ.	±0.4 dB typ.													

<Output level> Continued

Items	Specifications																									
Linearity	<p>1st SG: MG3710A/MG3740A-041/141 not installed, 042/142 installed, 2nd SG: MG3710A/MG3740A-071/171 not installed, 072/172 installed Reference: -10 dBm</p> <table border="1" data-bbox="513 562 1417 739"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="2">Frequency</th> </tr> <tr> <th>50 MHz<math>\leq</math>, &lt;400 MHz</th> <th>400 MHz<math>\leq</math>, <math>\leq</math>3 GHz</th> </tr> </thead> <tbody> <tr> <td>-40 dBm&lt;, <math>\leq</math>-1 dBm</td> <td><math>\pm</math>0.2 dB typ.</td> <td><math>\pm</math>0.2 dB typ.</td> </tr> <tr> <td>-110 dBm&lt;, <math>\leq</math>-40 dBm</td> <td><math>\pm</math>0.2 dB typ.</td> <td><math>\pm</math>0.2 dB typ.</td> </tr> </tbody> </table> <table border="1" data-bbox="513 777 1417 992"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="2">Frequency</th> </tr> <tr> <th>3 GHz&lt;, <math>\leq</math>4 GHz</th> <th>4 GHz&lt;, <math>\leq</math>6 GHz</th> </tr> </thead> <tbody> <tr> <td>-40 dBm&lt;, <math>\leq</math>-1 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td><math>\pm</math>0.3 dB typ.</td> </tr> <tr> <td>-100 dBm&lt;, <math>\leq</math>-40 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td><math>\pm</math>0.3 dB typ.</td> </tr> <tr> <td>-110 dBm&lt;, <math>\leq</math>-100 dBm</td> <td><math>\pm</math>0.4 dB typ.</td> <td><math>\pm</math>0.4 dB typ.</td> </tr> </tbody> </table>	Level	Frequency		50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz	-40 dBm<, $\leq$ -1 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.	-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.	Level	Frequency		3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 6 GHz	-40 dBm<, $\leq$ -1 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.	-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.	-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.4 dB typ.	$\pm$ 0.4 dB typ.
	Level		Frequency																							
		50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz																							
	-40 dBm<, $\leq$ -1 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.																							
	-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.																							
	Level	Frequency																								
		3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 6 GHz																							
	-40 dBm<, $\leq$ -1 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.																							
	-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.																							
	-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.4 dB typ.	$\pm$ 0.4 dB typ.																							
	<p>1st SG: MG3710A/MG3740A-041/141/042/142 installed, 2nd SG: MG3710A/MG3740A-071/171/072/172 installed Reference: -10 dBm</p> <table border="1" data-bbox="513 1137 1417 1314"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="2">Frequency</th> </tr> <tr> <th>50 MHz<math>\leq</math>, &lt;400 MHz</th> <th>400 MHz<math>\leq</math>, <math>\leq</math>3 GHz</th> </tr> </thead> <tbody> <tr> <td>-40 dBm&lt;, <math>\leq</math>-1 dBm</td> <td><math>\pm</math>0.2 dB typ.</td> <td><math>\pm</math>0.2 dB typ.</td> </tr> <tr> <td>-110 dBm&lt;, <math>\leq</math>-40 dBm</td> <td><math>\pm</math>0.2 dB typ.</td> <td><math>\pm</math>0.2 dB typ.</td> </tr> </tbody> </table> <table border="1" data-bbox="513 1352 1417 1568"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="2">Frequency</th> </tr> <tr> <th>3 GHz&lt;, <math>\leq</math>4 GHz</th> <th>4 GHz&lt;, <math>\leq</math>6 GHz</th> </tr> </thead> <tbody> <tr> <td>-40 dBm&lt;, <math>\leq</math>-1 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td><math>\pm</math>0.3 dB typ.</td> </tr> <tr> <td>-100 dBm&lt;, <math>\leq</math>-40 dBm</td> <td><math>\pm</math>0.3 dB typ.</td> <td><math>\pm</math>0.3 dB typ.</td> </tr> <tr> <td>-110 dBm&lt;, <math>\leq</math>-100 dBm</td> <td><math>\pm</math>0.4 dB typ.</td> <td><math>\pm</math>0.4 dB typ.</td> </tr> </tbody> </table>	Level	Frequency		50 MHz $\leq$ , <400 MHz	400 MHz $\leq$ , $\leq$ 3 GHz	-40 dBm<, $\leq$ -1 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.	-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.	Level	Frequency		3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 6 GHz	-40 dBm<, $\leq$ -1 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.	-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.	-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.4 dB typ.	$\pm$ 0.4 dB typ.
	Level		Frequency																							
50 MHz $\leq$ , <400 MHz		400 MHz $\leq$ , $\leq$ 3 GHz																								
-40 dBm<, $\leq$ -1 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.																								
-110 dBm<, $\leq$ -40 dBm	$\pm$ 0.2 dB typ.	$\pm$ 0.2 dB typ.																								
Level	Frequency																									
	3 GHz<, $\leq$ 4 GHz	4 GHz<, $\leq$ 6 GHz																								
-40 dBm<, $\leq$ -1 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.																								
-100 dBm<, $\leq$ -40 dBm	$\pm$ 0.3 dB typ.	$\pm$ 0.3 dB typ.																								
-110 dBm<, $\leq$ -100 dBm	$\pm$ 0.4 dB typ.	$\pm$ 0.4 dB typ.																								



<ATT Hold>

Items	Specifications
ATT Hold	With reference to the level when ATT Hold is turned on, level adjustment of continuous signal generation is available in 0.01 dB step between the range from -10 dB to +10 dB. However, each upper and lower limit of the adjustment range is restricted by the signal output range.

<Output connector>

Items	Specifications											
Connector	Front panel, RF Output, 2nd RF Output (Opt), N-J connector, 50 Ω											
VSWR	1st SG: MG3710A/MG3740A-043/143 not installed, 2nd SG: MG3710A/MG3740A-073/173 not installed											
	<table border="1"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="3">Frequency</th> </tr> <tr> <th>50 MHz≤, ≤3 GHz</th> <th>3 GHz&lt;, ≤4 GHz</th> <th>4 GHz&lt;, ≤6 GHz</th> </tr> </thead> <tbody> <tr> <td>≤-7 dBm</td> <td>1.45</td> <td>1.65</td> <td>1.9</td> </tr> </tbody> </table>	Level	Frequency			50 MHz≤, ≤3 GHz	3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz	≤-7 dBm	1.45	1.65	1.9
	Level		Frequency									
50 MHz≤, ≤3 GHz		3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz									
≤-7 dBm	1.45	1.65	1.9									
1st SG: MG3710A/MG3740A-043/143 installed, 2nd SG: MG3710A/MG3740A-073/173 installed												
	<table border="1"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="3">Frequency</th> </tr> <tr> <th>50 MHz≤, ≤3 GHz</th> <th>3 GHz&lt;, ≤4 GHz</th> <th>4 GHz&lt;, ≤6 GHz</th> </tr> </thead> <tbody> <tr> <td>≤-10 dBm</td> <td>1.45</td> <td>1.65</td> <td>1.9</td> </tr> </tbody> </table>	Level	Frequency			50 MHz≤, ≤3 GHz	3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz	≤-10 dBm	1.45	1.65	1.9
Level	Frequency											
	50 MHz≤, ≤3 GHz	3 GHz<, ≤4 GHz	4 GHz<, ≤6 GHz									
≤-10 dBm	1.45	1.65	1.9									

<Maximum reverse input>

Items	Specifications
Maximum reverse input	
Maximum reverse input voltage	±50 V DC Max Common to 1st and 2nd SG
Maximum reverse input power	1st SG: MG3710A/MG3740A-043/143 not installed, 2nd SG: MG3710A/MG3740A-073/173 not installed 2 W (Nominal) 1st SG: MG3710A/MG3740A-043/143 installed, 2nd SG: MG3710A/MG3740A-073/173 installed 20 W (Nominal) (1 MHz<Reverse input power frequency≤1 GHz) 20 W (Nominal) (1 GHz< Reverse input power frequency ≤2 GHz) 10 W (Nominal) (2 GHz< Reverse input power frequency ≤6 GHz)

<Signal purity>

Items	Specifications																														
Harmonic spurious	<p>At CW, Optimize S/N = Off</p> <p>1st SG: MG3710A/MG3740A-043/143 not installed, 2nd SG: MG3710A/MG3740A-073/173 not installed</p> <p>1st SG: MG3710A/MG3740A-041/141 not installed, 2nd SG: MG3710A/MG3740A-071/171 not installed</p> <table border="1" data-bbox="483 665 1398 804"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="3">Frequency</th> </tr> <tr> <th>10 MHz<math>\leq</math>, <math>\leq</math>3 GHz</th> <th>3 GHz<math>&lt;</math></th> <th></th> </tr> </thead> <tbody> <tr> <td><math>\leq</math>+4 dBm</td> <td><math>\leq</math>-30 dBc</td> <td><math>\leq</math>-30 dBc</td> <td></td> </tr> </tbody> </table> <p>1st SG: MG3710A/MG3740A-041/141 installed, 2nd SG: MG3710A/MG3740A-071/171 installed</p> <table border="1" data-bbox="483 911 1398 1128"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="3">Frequency</th> </tr> <tr> <th>10 MHz<math>\leq</math>, <math>&lt;</math>50 MHz</th> <th>50 MHz <math>\leq</math>, <math>\leq</math>3 GHz</th> <th>3 GHz<math>&lt;</math></th> </tr> </thead> <tbody> <tr> <td><math>\leq</math>+4 dBm</td> <td><math>\leq</math>-30 dBc</td> <td></td> <td></td> </tr> <tr> <td><math>\leq</math>+12 dBm</td> <td></td> <td><math>\leq</math>-30 dBc</td> <td></td> </tr> <tr> <td><math>\leq</math>+4 dBm</td> <td></td> <td></td> <td><math>\leq</math>-30 dBc</td> </tr> </tbody> </table>	Level	Frequency			10 MHz $\leq$ , $\leq$ 3 GHz	3 GHz $<$		$\leq$ +4 dBm	$\leq$ -30 dBc	$\leq$ -30 dBc		Level	Frequency			10 MHz $\leq$ , $<$ 50 MHz	50 MHz $\leq$ , $\leq$ 3 GHz	3 GHz $<$	$\leq$ +4 dBm	$\leq$ -30 dBc			$\leq$ +12 dBm		$\leq$ -30 dBc		$\leq$ +4 dBm			$\leq$ -30 dBc
Level	Frequency																														
	10 MHz $\leq$ , $\leq$ 3 GHz	3 GHz $<$																													
$\leq$ +4 dBm	$\leq$ -30 dBc	$\leq$ -30 dBc																													
Level	Frequency																														
	10 MHz $\leq$ , $<$ 50 MHz	50 MHz $\leq$ , $\leq$ 3 GHz	3 GHz $<$																												
$\leq$ +4 dBm	$\leq$ -30 dBc																														
$\leq$ +12 dBm		$\leq$ -30 dBc																													
$\leq$ +4 dBm			$\leq$ -30 dBc																												
	<p>CW, Optimize S/N = Off</p> <p>1st SG: MG3710A/MG3740A-043/143 installed, 2nd SG: MG3710A/MG3740A-073/173 installed</p> <p>1st SG: MG3710A/MG3740A-041/141 not installed, 2nd SG: MG3710A/MG3740A-071/171 not installed</p> <table border="1" data-bbox="483 1344 1398 1482"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="3">Frequency</th> </tr> <tr> <th>10 MHz<math>\leq</math>, <math>\leq</math>3 GHz</th> <th>3 GHz<math>&lt;</math></th> <th></th> </tr> </thead> <tbody> <tr> <td><math>\leq</math>+1 dBm</td> <td><math>\leq</math>-30 dBc</td> <td><math>\leq</math>-30 dBc</td> <td></td> </tr> </tbody> </table> <p>1st SG: MG3710A/MG3740A-041/141 installed, 2nd SG: MG3710A/MG3740A-071/171 installed</p> <table border="1" data-bbox="483 1588 1398 1805"> <thead> <tr> <th rowspan="2">Level</th> <th colspan="3">Frequency</th> </tr> <tr> <th>10 MHz<math>\leq</math>, <math>&lt;</math>50 MHz</th> <th>50 MHz<math>\leq</math>, <math>\leq</math>3 GHz</th> <th>3 GHz<math>&lt;</math></th> </tr> </thead> <tbody> <tr> <td><math>\leq</math>+1 dBm</td> <td><math>\leq</math>-30 dBc</td> <td></td> <td></td> </tr> <tr> <td><math>\leq</math>+9 dBm</td> <td></td> <td><math>\leq</math>-30 dBc</td> <td></td> </tr> <tr> <td><math>\leq</math>+4 dBm</td> <td></td> <td></td> <td><math>\leq</math>-30 dBc</td> </tr> </tbody> </table>	Level	Frequency			10 MHz $\leq$ , $\leq$ 3 GHz	3 GHz $<$		$\leq$ +1 dBm	$\leq$ -30 dBc	$\leq$ -30 dBc		Level	Frequency			10 MHz $\leq$ , $<$ 50 MHz	50 MHz $\leq$ , $\leq$ 3 GHz	3 GHz $<$	$\leq$ +1 dBm	$\leq$ -30 dBc			$\leq$ +9 dBm		$\leq$ -30 dBc		$\leq$ +4 dBm			$\leq$ -30 dBc
Level	Frequency																														
	10 MHz $\leq$ , $\leq$ 3 GHz	3 GHz $<$																													
$\leq$ +1 dBm	$\leq$ -30 dBc	$\leq$ -30 dBc																													
Level	Frequency																														
	10 MHz $\leq$ , $<$ 50 MHz	50 MHz $\leq$ , $\leq$ 3 GHz	3 GHz $<$																												
$\leq$ +1 dBm	$\leq$ -30 dBc																														
$\leq$ +9 dBm		$\leq$ -30 dBc																													
$\leq$ +4 dBm			$\leq$ -30 dBc																												

**<Signal purity> Continued**

Items	Specifications
Non-harmonic spurious	Under the conditions of $-30 \text{ dBm} \leq \text{output level} \leq +5 \text{ dBm}$ , CW generation, 10 kHz or more frequency offset from the output frequency. $<-62 \text{ dBc} (-70 \text{ dBc typ.}) \quad (100 \text{ kHz} \leq \text{frequency} \leq 187.5 \text{ MHz})$ $<-68 \text{ dBc} (-76 \text{ dBc typ.}) \quad (187.5 \text{ MHz} < \text{frequency} \leq 750 \text{ MHz})$ $<-62 \text{ dBc} (-76 \text{ dBc typ.}) \quad (750 \text{ MHz} < \text{frequency} \leq 1.5 \text{ GHz})$ $<-56 \text{ dBc} (-70 \text{ dBc typ.}) \quad (1.5 \text{ GHz} < \text{frequency} \leq 3 \text{ GHz})$ $<-50 \text{ dBc} (-64 \text{ dBc typ.}) \quad (3 \text{ GHz} < \text{frequency} \leq 6 \text{ GHz})$
SSB phase noise	At Phase Noise Opt.: $<200 \text{ kHz}$ , CW, 20 kHz offset: $<-140 \text{ dBc/Hz (Nominal)} (100 \text{ MHz})$ $<-131 \text{ dBc/Hz typ.} (1 \text{ GHz})$ $<-125 \text{ dBc/Hz typ.} (2 \text{ GHz})$

<Analog modulation/Pulse modulation>

Items	Specifications
Optimize Function	<ul style="list-style-type: none"> <li>• Spurious mode Mode to control spurious problem. Controls spurious generated by the modulator.</li> <li>• Distortion mode Mode to control distortion problem. Optimizes the setting automatically to avoid distortions. This mode can be used when the output frequency is 7 MHz or higher .</li> </ul>
Amplitude Modulation	Available only for internal modulation. Specified only for the modulation onto CW.
AM Depth Type	In MG3740A, Optimize Function is set to Distortion. <ul style="list-style-type: none"> <li>• Lin Displays the AM depth type in linear.</li> <li>• Exp Displays the AM depth type into the log format.</li> </ul>
AM Depth	Range: 0% to 100.0%, Resolution: 0.1%
AM Depth Error (MG3710A)	Under the conditions: peak level ≤ 4 dBm, 100 kHz ≤ frequency range < 98 MHz, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio m ≤ 90%. < (3% of the set value + 2%) (Nominal)
AM Depth Error (MG3740A)	Under the conditions: peak level ≤ 4 dBm, 98 MHz ≤ frequency range ≤ 2700 MHz, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio m ≤ 90%. < (2% of the set value + 1%) (Nominal)
AM Depth Error (MG3740A)	Under the conditions: peak level ≤ 4 dBm, 98 MHz ≤ frequency range ≤ 2700 MHz, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio m < 20%. < (2% of the set value + 1%) (Nominal) Under the conditions: peak level ≤ 4 dBm, 98 MHz ≤ frequency range ≤ 2700 MHz, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and 20% ≤ modulation ratio m ≤ 90%. < (2% of the set value + 1%)

<Analog modulation/Pulse modulation> Continued

Items	Specifications
<p>Amplitude Modulation (Cont'd)</p> <p>Distortion (MG3710A)</p>	<p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>100 \text{ kHz} \leq \text{frequency range} &lt; 98 \text{ MHz}</math>, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio <math>m = 30\%</math>. &lt; 2% (Nominal)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>100 \text{ kHz} \leq \text{frequency range} &lt; 98 \text{ MHz}</math>, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio <math>m = 90\%</math>. &lt; 2.5% (Nominal)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>98 \text{ MHz} \leq \text{frequency range} \leq 2700 \text{ MHz}</math>, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio <math>m = 30\%</math>. &lt; 0.5% (Nominal)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>98 \text{ MHz} \leq \text{frequency range} \leq 2700 \text{ MHz}</math>, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio <math>m = 90\%</math>. &lt; 0.5% (Nominal)</p>
<p>Distortion (MG3740A)</p>	<p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>100 \text{ kHz} \leq \text{frequency range} &lt; 7 \text{ MHz}</math>, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio <math>m = 30\%</math>. &lt; 2% (Nominal)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>100 \text{ kHz} \leq \text{frequency range} &lt; 7 \text{ MHz}</math>, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio <math>m = 90\%</math>. &lt; 2.5% (Nominal)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>7 \text{ MHz} \leq \text{frequency range} &lt; 98 \text{ MHz}</math>, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio <math>m = 30\%</math>. &lt; 2%</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>7 \text{ MHz} \leq \text{frequency range} &lt; 98 \text{ MHz}</math>, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio <math>m = 90\%</math>. &lt; 2.5%</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>98 \text{ MHz} \leq \text{frequency range} \leq 2700 \text{ MHz}</math>, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio <math>m = 30\%</math>. &lt; 1%</p>

<Analog modulation/Pulse modulation> Continued

Items	Specifications
<p>Amplitude Modulation (Cont'd)</p> <p>Distortion (MG3740A)</p> <p>Modulation Frequency Response (MG3710A)</p>	<p>Under the conditions: peak level <math>\leq 4</math> dBm, 98 MHz <math>\leq</math> frequency range <math>\leq 2700</math> MHz, AM Depth Type = Lin, after CAL execution, modulation rate = 1 kHz, AM Source = Sine, and modulation ratio <math>m = 90\%</math>. <math>&lt; 1\%</math></p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, 100 kHz <math>\leq</math> frequency range <math>&lt; 98</math> MHz, AM Depth Type = Lin, modulation ratio <math>m = 30\%</math>, after CAL execution, and bandwidth within <math>\pm 1.5</math> dB. 0.1 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, 100 kHz <math>\leq</math> frequency range <math>&lt; 98</math> MHz, AM Depth Type = Lin, modulation ratio <math>m = 90\%</math>, after CAL execution, and bandwidth within <math>\pm 1.5</math> dB. 0.1 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, 98 MHz <math>\leq</math> frequency range <math>\leq 2700</math> MHz, AM Depth Type = Lin, modulation ratio <math>m = 30\%</math>, after CAL execution, and bandwidth within <math>\pm 1</math> dB. 0.1 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, 98 MHz <math>\leq</math> frequency range <math>\leq 2700</math> MHz, AM Depth Type = Lin, modulation ratio <math>m = 90\%</math>, after CAL execution, and bandwidth within <math>\pm 1</math> dB. 0.1 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)</p>

<Analog modulation/Pulse modulation> Continued

Items	Specifications
<p>Amplitude Modulation (Cont'd)</p> <p>Modulation Frequency Response (MG3740A)</p>	<p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>100 \text{ kHz} \leq \text{frequency range} &lt; 98 \text{ MHz}</math>, AM Depth Type = Lin, modulation ratio <math>m = 30\%</math>, after CAL execution, and bandwidth within <math>\pm 1.5</math> dB. <math>0.1 \text{ Hz} \leq \text{modulation rate} \leq 20 \text{ kHz}</math> (nominal)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>100 \text{ kHz} \leq \text{frequency range} &lt; 98 \text{ MHz}</math>, AM Depth Type = Lin, modulation ratio <math>m = 90\%</math>, after CAL execution, and bandwidth within <math>\pm 1.5</math> dB. <math>0.1 \text{ Hz} \leq \text{modulation rate} \leq 20 \text{ kHz}</math> (nominal)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>98 \text{ MHz} \leq \text{frequency range} \leq 2700 \text{ MHz}</math>, AM Depth Type = Lin, modulation ratio <math>m = 30\%</math>, after CAL execution, and bandwidth within <math>\pm 1</math> dB. <math>0.1 \text{ Hz} \leq \text{modulation rate} &lt; 50 \text{ Hz}</math> (nominal) <math>50 \text{ Hz} \leq \text{modulation rate} \leq 100 \text{ kHz}</math> (typ.)</p> <p>Under the conditions: peak level <math>\leq 4</math> dBm, <math>98 \text{ MHz} \leq \text{frequency range} \leq 2700 \text{ MHz}</math>, AM Depth Type = Lin, modulation ratio <math>m = 90\%</math>, after CAL execution, and bandwidth within <math>\pm 1</math> dB. <math>0.1 \text{ Hz} \leq \text{modulation rate} &lt; 50 \text{ Hz}</math> (nominal) <math>50 \text{ Hz} \leq \text{modulation rate} \leq 100 \text{ kHz}</math> (typ.)</p>

<Analog modulation/Pulse modulation> Continued

Items	Specifications
Frequency Modulation	Available only for internal modulation. Specified only for the modulation onto CW.
FM Deviation	In MG3740A, Optimize Function is set to Distortion. Range: A value between 0 Hz and 40 MHz or the value of 50 MHz minus modulation rate, whichever is smaller.
Deviation Accuracy (MG3710A)	Resolution: 0.1 Hz Under the conditions: output level ≤ 4 dBm, $100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation}) \leq \text{frequency} \leq 2700 \text{ MHz}$ , after CAL execution, modulation rate = 1 kHz, FM Source = Sine, and $20 \text{ Hz} \leq \text{deviation} \leq 40 \text{ kHz}$ . < (2% of the set value + 20 Hz) (Nominal)
Deviation Accuracy (MG3740A)	Under the conditions: output level ≤ 4 dBm, $100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation}) \leq \text{frequency} \leq 2700 \text{ MHz}$ , after CAL execution, modulation rate = 1 kHz, FM Source = Sine, and $20 \text{ Hz} \leq \text{deviation} \leq 200 \text{ Hz}$ . < (2% of the set value + 20 Hz) (Nominal)



## &lt;Analog modulation/Pulse modulation&gt; Continued

Items	Specifications
Frequency Modulation (Cont'd)	
Deviation Accuracy (MG3740A)	<p>Under the conditions:  output level <math>\leq 4</math> dBm,  <math>250 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation}) \leq \text{frequency} \leq 2700 \text{ MHz}</math>,  after CAL execution, modulation rate = 1 kHz, FM Source = Sine,  and <math>200 \text{ Hz} \leq \text{deviation} \leq 40 \text{ kHz}</math>.</p> <p>(Deviation <math>\div</math> modulation rate) <math>&gt; 0.2</math>:  <math>&lt; (3\% \text{ of the set value} + 20 \text{ Hz})</math>  <math>&lt; (1.26\% \text{ of the set value} + 20 \text{ Hz})</math> (typ.)</p> <p>(Deviation <math>\div</math> modulation rate) <math>&gt; 1.2</math>:  <math>&lt; (3\% \text{ of the set value} + 20 \text{ Hz})</math>  <math>&lt; (1.84\% \text{ of the set value} + 20 \text{ Hz})</math> (typ.)</p>
Distortion (MG3710A)	<p>Under the conditions:  output level <math>\leq 4</math> dBm,  <math>100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation}) \leq \text{frequency} \leq 2700 \text{ MHz}</math>,  after CAL execution, modulation rate = 1 kHz, FM Source = Sine,  and deviation = 22.5 kHz.</p> <p><math>&lt; 0.5\%</math> (Nominal)</p>
Distortion (MG3740A)	<p>Under the conditions:  output level <math>\leq 4</math> dBm,  <math>100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation}) \leq \text{frequency} \leq 2700 \text{ MHz}</math>,  after CAL execution, modulation rate = 1 kHz, FM Source = Sine,  and deviation = 3.5 kHz.</p> <p><math>&lt; 1\%</math> (Nominal)</p>
Distortion (MG3740A)	<p>Under the conditions:  output level <math>\leq 4</math> dBm,  <math>100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation}) \leq \text{frequency} &lt; 1 \text{ MHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation})</math>,  after CAL execution, modulation rate = 1 kHz, FM Source = Sine,  and deviation = 22.5 kHz.</p> <p><math>&lt; 0.5\%</math> (Nominal)</p>
Distortion (MG3740A)	<p>Under the conditions:  output level <math>\leq 4</math> dBm,  <math>1 \text{ MHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation}) \leq \text{frequency} \leq 2700 \text{ MHz}</math>,  after CAL execution, modulation rate = 1 kHz, FM Source = Sine,  and deviation = 22.5 kHz.</p> <p><math>&lt; 0.4\%</math></p>
Distortion (MG3740A)	<p>Under the conditions:  output level <math>\leq 4</math> dBm,  <math>100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation}) \leq \text{frequency} &lt; 1 \text{ MHz}</math>,  after CAL execution, modulation rate = 1 kHz, FM Source = Sine,  and deviation = 3.5 kHz.</p> <p><math>&lt; 1\%</math> (Nominal)</p>

<Analog modulation/Pulse modulation> Continued

Items	Specifications
<p>Frequency Modulation (Cont'd)</p> <p>Distortion (MG3740A)</p> <p>Modulation Frequency Response (MG3710A)</p> <p>Modulation Frequency Response (MG3740A)</p>	<p>Under the conditions: output level ≤ 4 dBm, 1 MHz + 2 ×(modulation rate + 2 × deviation) ≤ frequency ≤ 2700 MHz, after CAL execution, modulation rate = 1 kHz, FM Source = Sine, and deviation = 3.5 kHz. &lt; 0.5%</p> <p>Under the conditions: output level ≤ 4 dBm, 100 kHz + 2 ×(modulation rate + 2 × deviation) ≤ frequency ≤ 2700 MHz, deviation = 40 kHz, after CAL execution, and bandwidth within ±1 dB. 20 Hz ≤ modulation rate ≤ 20 kHz (nominal)</p> <p>Under the conditions: output level ≤ 4 dBm, 100 kHz + 2 ×(modulation rate + 2 × deviation) ≤ frequency &lt; 10 MHz, deviation = 40 kHz, after CAL execution, and bandwidth within ±1 dB. 20 Hz ≤ modulation rate ≤ 20 kHz (nominal)</p> <p>Under the conditions: Output level ≤ 4 dBm, 10 MHz ≤ frequency ≤ 2700 MHz, deviation = 40 kHz, after CAL execution, and bandwidth within ±1 dB. 20 Hz ≤ modulation rate ≤ 20 kHz (nominal)</p>

## &lt;Analog modulation/Pulse modulation&gt; Continued

Items	Specifications
Phase Modulation	Available only for internal modulation. Specified only for the modulation onto CW.
PM Deviation	In MG3740A, Optimize Function is set to Distortion. Range: A value between 0 rad and 160 rad or the value of 40 MHz divided by the modulation rate, whichever is smaller.
Deviation Accuracy (MG3710A)	Resolution: 0.001 rad Under the conditions: output level $\leq 4$ dBm, $100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation} \times \text{modulation rate}) \leq \text{frequency} \leq 2700 \text{ MHz}$ , after CAL execution, modulation rate = 1 kHz, $\phi\text{M Source} = \text{Sine}$ , and deviation $\leq 20$ rad. < (2% of the set value + 0.02 rad) (Nominal)
Deviation Accuracy (MG3740A)	Under the conditions: output level $\leq 4$ dBm, $100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation} \times \text{modulation rate}) \leq \text{frequency} \leq 2700 \text{ MHz}$ , after CAL execution, modulation rate = 1 kHz, $\phi\text{M Source} = \text{Sine}$ , and $0 < \text{deviation} \leq 0.7$ rad. < (2% of the set value + 0.02 rad) (Nominal)
	Under the conditions: output level $\leq 4$ dBm, $100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation} \times \text{modulation rate}) \leq \text{frequency} \leq 2700 \text{ MHz}$ , after CAL execution, modulation rate = 1 kHz, $\phi\text{M Source} = \text{Sine}$ , and $0.7 < \text{deviation} \leq 20$ rad. < (3% of the set value + 0.02 rad) < (1.84% of the set value + 0.02 rad) (typ.)
Distortion	Under the conditions: output level $\leq 4$ dBm, $100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation} \times \text{modulation rate}) \leq \text{frequency} \leq 2700 \text{ MHz}$ , after CAL execution, modulation rate = 1 kHz, $\phi\text{M Source} = \text{Sine}$ , and deviation = 20 rad. MG3710A: <0.2% (Nominal) MG3740A: <0.2% (typ.)
Modulation Frequency Response (MG3710A)	Under the conditions: output level $\leq 4$ dBm, $100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation} \times \text{modulation rate}) \leq \text{frequency} \leq 2700 \text{ MHz}$ , deviation = 2 rad, after CAL execution, and bandwidth within $\pm 1$ dB. $20 \text{ Hz} \leq \text{modulation rate} \leq 20 \text{ kHz}$ (nominal)
Modulation Frequency Response (MG3740A)	Under the conditions: output level $\leq 4$ dBm, $100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation} \times \text{modulation rate}) \leq \text{frequency} \leq 2700 \text{ MHz}$ , deviation = 2 rad, after CAL execution, and bandwidth within $\pm 1$ dB. $20 \text{ Hz} \leq \text{modulation rate} \leq 20 \text{ kHz}$ (nominal)

<Analog modulation/Pulse modulation> Continued

Items	Specifications
Pulse Modulation On/Off ratio  Minimum pulse width Rising/Falling time Pulse repetition frequency External pulse modulation signal input	>70 dB (50 MHz ≤ Output frequency ≤ 3 GHz) >60 dB (3 GHz < Output frequency ≤ 6 GHz) 1 μs (Nominal) ≤50 ns (10 to 90%) (Nominal) DC to 1 MHz (Duty 50%) Rear panel AUX connector, TTL  H = signal output/L = signal off
Internal modulation signal Waveform  Modulation rate  Frequency resolution Phase Phase resolution	Sine wave, Triangular wave, Square wave, Ramp wave (Positive or Negative) Sine wave: 0.01 Hz to 40 MHz or (50 MHz – FMDeviation) Triangular wave, Square wave, Ramp wave: 0.01 Hz to 4 MHz or (5 MHz - FMDeviation) 0.1 Hz -180 deg to 180 deg 0.1 deg
External modulation signal  Modulation type Input Impedance Coupling Input level Input Frequency  Simultaneous modulation	When MG3710A/MG3740A-050/150/080/180 is installed and for 1st SG and 2nd SG respectively Specified only for the modulation onto CW. In MG3740A, Optimize Function is set to Distortion. AM, FM, φM 50 Ω/600 Ω/Hi-Z (100 kΩ/70 pF) (nominal) DC or AC is alternatively selectable. For set value, 2 Vp-p (nominal) DC coupling: DC to 1 MHz (nominal) AC coupling: 20 Hz (typ.) to 1 MHz (nominal) AM + FM AM + φM Internal 1 + Internal 2 Internal + External FM and φM cannot enabled simultaneously.

<Analog modulation/Pulse modulation> Continued

Items	Specifications
<p>External modulation signal (Cont'd)</p> <p>Amplitude Modulation Frequency Response (MG3710A)</p>	<p>Under the conditions:            peak level <math>\leq 4</math> dBm, <math>100 \text{ kHz} \leq \text{frequency range} &lt; 98 \text{ MHz}</math>,            AM Depth Type = Lin, modulation ratio <math>m = 30\%</math>, after CAL execution,            and bandwidth within <math>\pm 1.5</math> dB.                DC coupling: <math>\text{DC} \leq \text{modulation rate} \leq 20 \text{ kHz}</math> (nominal)                AC coupling: <math>20 \text{ Hz} \leq \text{modulation rate} \leq 20 \text{ kHz}</math> (nominal)</p> <p>Under the conditions:            peak level <math>\leq 4</math> dBm, <math>100 \text{ kHz} \leq \text{frequency range} &lt; 98 \text{ MHz}</math>,            AM Depth Type = Lin, modulation ratio <math>m = 90\%</math>, after CAL execution,            and bandwidth within <math>\pm 1.5</math> dB.                DC coupling: <math>\text{DC} \leq \text{modulation rate} \leq 20 \text{ kHz}</math> (nominal)                AC coupling: <math>20 \text{ Hz} \leq \text{modulation rate} \leq 20 \text{ kHz}</math> (nominal)</p> <p>Under the conditions:            peak level <math>\leq 4</math> dBm, <math>98 \text{ MHz} \leq \text{frequency range} \leq 2700 \text{ MHz}</math>,            AM Depth Type = Lin, modulation ratio <math>m = 30\%</math>, after CAL execution,            and bandwidth within <math>\pm 1</math> dB.                DC coupling: <math>\text{DC} \leq \text{modulation rate} &lt; 20 \text{ kHz}</math> (nominal)                AC coupling: <math>20 \text{ Hz} \leq \text{modulation rate} &lt; 20 \text{ kHz}</math> (nominal)</p> <p>Under the conditions:            peak level <math>\leq 4</math> dBm, <math>98 \text{ MHz} \leq \text{frequency range} \leq 2700 \text{ MHz}</math>,            AM Depth Type = Lin, modulation ratio <math>m = 90\%</math>, after CAL execution,            and bandwidth within <math>\pm 1</math> dB.                DC coupling: <math>\text{DC} \leq \text{modulation rate} &lt; 20 \text{ kHz}</math> (nominal)                AC coupling: <math>20 \text{ Hz} \leq \text{modulation rate} &lt; 20 \text{ kHz}</math> (nominal)</p>

<Analog modulation/Pulse modulation> Continued

Items	Specifications
<p>External modulation signal (Cont'd)</p> <p>Amplitude Modulation Frequency Response (MG3740A)</p>	<p>Under the conditions:                      peak level <math>\leq 4</math> dBm, 100 kHz <math>\leq</math> frequency range <math>&lt; 98</math> MHz,                      AM Depth Type = Lin, modulation ratio <math>m = 30\%</math>, after CAL execution,                      and bandwidth within <math>\pm 1.5</math> dB.</p> <p>DC coupling: DC <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)                      AC coupling: 20 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)</p> <p>Under the conditions:                      peak level <math>\leq 4</math> dBm, 100 kHz <math>\leq</math> frequency range <math>&lt; 98</math> MHz,                      AM Depth Type = Lin, modulation ratio <math>m = 90\%</math>, after CAL execution,                      and bandwidth within <math>\pm 1.5</math> dB.</p> <p>DC coupling: DC <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)                      AC coupling: 20 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)</p> <p>Under the conditions:                      peak level <math>\leq 4</math> dBm, 98 MHz <math>\leq</math> frequency range <math>\leq 2700</math> MHz,                      AM Depth Type = Lin, modulation ratio <math>m = 30\%</math>, after CAL execution,                      and bandwidth within <math>\pm 1</math> dB.</p> <p>DC coupling: DC <math>\leq</math> modulation rate <math>&lt; 50</math> Hz (nominal)                      50 Hz <math>\leq</math> modulation rate <math>\leq 100</math> kHz (typ.)                      AC coupling: 20 Hz <math>\leq</math> modulation rate <math>&lt; 50</math> Hz (nominal)                      50 Hz <math>\leq</math> modulation rate <math>\leq 100</math> kHz (typ.)</p> <p>Under the conditions:                      peak level <math>\leq 4</math> dBm, 98 MHz <math>\leq</math> frequency range <math>\leq 2700</math> MHz,                      AM Depth Type = Lin, modulation ratio <math>m = 90\%</math>, after CAL execution,                      and bandwidth within <math>\pm 1</math> dB.</p> <p>DC coupling: DC <math>\leq</math> modulation rate <math>&lt; 50</math> Hz (nominal)                      50 Hz <math>\leq</math> modulation rate <math>\leq 100</math> kHz (typ.)                      AC coupling: 20 Hz <math>\leq</math> modulation rate <math>&lt; 50</math> Hz (nominal)                      50 Hz <math>\leq</math> modulation rate <math>\leq 100</math> kHz (typ.)</p>

## &lt;Analog modulation/Pulse modulation&gt; Continued

Items	Specifications
External modulation signal (Cont'd)	
Frequency Modulation Frequency Response (MG3710A)	<p>Under the conditions:  output level <math>\leq 4</math> dBm,  <math>100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation}) \leq \text{frequency} \leq 2700 \text{ MHz}</math>,  deviation = 40 kHz, after CAL execution, and bandwidth within <math>\pm 1</math> dB.</p> <p>DC coupling: DC <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)  AC coupling: 20 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)</p>
Frequency Modulation Frequency Response (MG3740A)	<p>Under the conditions:  output level <math>\leq 4</math> dBm,  <math>100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation}) \leq \text{frequency} &lt; 10 \text{ MHz}</math>,  deviation = 40 kHz, after CAL execution, and bandwidth within <math>\pm 1</math> dB.</p> <p>DC coupling: DC <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)  AC coupling: 20 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)</p> <p>Under the conditions:  output level <math>\leq 4</math> dBm,  <math>10 \text{ MHz} \leq \text{frequency} \leq 2700 \text{ MHz}</math>, deviation = 40 kHz,  after CAL execution, and bandwidth within <math>\pm 1</math> dB.</p> <p>DC coupling: DC <math>\leq</math> modulation rate <math>&lt; 50</math> Hz (nominal)  50 Hz <math>\leq</math> modulation rate <math>\leq 200</math> kHz (typ.)  AC coupling: 20 Hz <math>\leq</math> modulation rate <math>&lt; 50</math> Hz (nominal)  50 Hz <math>\leq</math> modulation rate <math>\leq 200</math> kHz (typ.)</p>
Phase Modulation Frequency Response (MG3710A)	<p>Under the conditions:  output level <math>\leq 4</math> dBm, <math>100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation} \times \text{modulation rate}) \leq \text{frequency} \leq 2700 \text{ MHz}</math>, deviation = 2 rad, after CAL execution, and bandwidth within <math>\pm 1</math> dB.</p> <p>DC coupling: DC <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)  AC coupling: 20 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (nominal)</p>
Phase Modulation Frequency Response (MG3740A)	<p>Under the conditions:  output level <math>\leq 4</math> dBm, <math>100 \text{ kHz} + 2 \times (\text{modulation rate} + 2 \times \text{deviation} \times \text{modulation rate}) \leq \text{frequency} \leq 2700 \text{ MHz}</math>, deviation = 2 rad, after CAL execution, and bandwidth within <math>\pm 1</math> dB.</p> <p>DC coupling: DC <math>\leq</math> modulation rate <math>&lt; 200</math> Hz (nominal)  200 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (typ.)  AC coupling: 20 Hz <math>\leq</math> modulation rate <math>&lt; 200</math> Hz (nominal)  200 Hz <math>\leq</math> modulation rate <math>\leq 20</math> kHz (typ.)</p>

<Vector modulation>

Items	Specifications
Modulation Frequency Response 1st SG (MG3710A)	When MG3710A-043/143 is not installed: Internal Channel Correction = On, Random signal of Bandwidth 160 MHz, Crest Factor 11 dB. Output level = -7 dBm At output frequency: 850 MHz/1.8 GHz/1.9 GHz/2.2 GHz, ±0.6 dB (At Center Frequency ±10 MHz) ±1.3 dB (At Center Frequency ±50 MHz) At output frequency: 3.5 GHz/5.8 GHz, ±0.6 dB (At Center Frequency ±10 MHz) ±1.9 dB (At Center Frequency ±50 MHz) When MG3710A-043/143 is installed: Internal Channel Correction = On, Random signal of Bandwidth 160 MHz, Crest Factor 11 dB. Output level = -10 dBm At output frequency: 850 MHz/1.8 GHz/1.9 GHz/2.2 GHz, ±0.6 dB (At Center Frequency ±10 MHz) ±1.8 dB (At Center Frequency ±50 MHz) At output frequency: 3.5 GHz/5.8 GHz, ±0.6 dB (At Center Frequency ±10 MHz) ±2.4 dB (At Center Frequency ±50 MHz)
Modulation Frequency Response 2nd SG (MG3710A)	Same as 1st SG (MG3710A)



<Vector modulation> Continued

Items	Specifications
<p>Vector accuracy 1st SG (MG3710A)</p>	<p>After CAL execution</p> <p>When MG3710A-043/143 is not installed:</p> <p>When W-CDMA (Test Model 4) is modulated:            Output frequency: 800 MHz to 900 MHz, 1800 MHz to 2200 MHz,            Output level <math>\leq +7</math> dBm (When MG3710A-041/141 is not installed),            Output level <math>\leq +13</math> dBm (When MG3710A-041/141 is installed),  <math>\leq 0.62\%</math> (rms) (0.6% (rms) typ.)</p> <p>When GSM is modulated:            Output frequency: 800 MHz to 900 MHz, 1800 MHz to 1900 MHz,            Output level <math>\leq +7</math> dBm (When MG3710A-041/141 is not installed),            Output level <math>\leq +13</math> dBm (When MG3710A-041/141 is installed),  <math>\leq 0.84^\circ</math> (rms) (0.8° (rms) typ.)</p> <p>When EDGE is modulated:            Output frequency: 800 MHz to 900 MHz, 1800 MHz to 1900 MHz,            Output level <math>\leq +7</math> dBm (When MG3710A-041/141 is not installed),            Output level <math>\leq +13</math> dBm (When MG3710A-041/141 is installed),  <math>\leq 0.84\%</math> (rms) (0.8% (rms) typ.)</p> <p>When LTE (20MHz Test Model 3.1) is modulated:            Output frequency: 600 MHz to 2700 MHz,            Output level <math>\leq +7</math> dBm (When MG3710A-041/141 is not installed),            Output level <math>\leq +13</math> dBm (When MG3710A-041/141 is installed),  <math>\leq 0.82\%</math> (rms) (0.8% (rms) typ.)</p> <p>Output frequency: 3400 MHz to 3800 MHz,            Output level <math>\leq +4</math> dBm (When MG3710A-041/141 is not installed),            Output level <math>\leq +10</math> dBm (When MG3710A-041/141 is installed),  <math>\leq 0.82\%</math> (rms) (0.8% (rms) typ.)</p>

<Vector modulation> Continued

Items	Specifications
Vector accuracy 1st SG (MG3710A)	<p>When MG3710A-043/143 is installed:</p> <p>When W-CDMA (Test Model 4) is modulated:                      Output frequency: 800 MHz to 900 MHz, 1800 MHz to 2200 MHz,                      Output level <math>\leq +4</math> dBm (When MG3710A-041/141 is not installed),                      Output level <math>\leq +10</math> dBm (When MG3710A-041/141 is installed),  <math>\leq 0.62\%</math> (rms) (0.6% (rms) typ.)</p> <p>When GSM is modulated:                      Output frequency: 800 MHz to 900 MHz, 1800 MHz to 1900 MHz,                      Output level <math>\leq +4</math> dBm (When MG3710A-041/141 is not installed),                      Output level <math>\leq +10</math> dBm (When MG3710A-041/141 is installed),  <math>\leq 0.84^\circ</math> (rms) (0.8° (rms) typ.)</p> <p>When EDGE is modulated:                      Output frequency: 800 MHz to 900 MHz, 1800 MHz to 2200 MHz,                      Output level <math>\leq +4</math> dBm (When MG3710A-041/141 is not installed),                      Output level <math>\leq +10</math> dBm (When MG3710A-041/141 is installed),  <math>\leq 0.84\%</math> (rms) (0.8% (rms) typ.)</p> <p>When LTE (20MHz Test Model 3.1) is modulated:                      Output frequency: 600 MHz to 2700 MHz,                      Output level <math>\leq +4</math> dBm (When MG3710A-041/141 is not installed),                      Output level <math>\leq +10</math> dBm (When MG3710A-041/141 is installed),  <math>\leq 0.82\%</math> (rms) (0.8% (rms) typ.)</p> <p>Output frequency: 3400 MHz to 3800 MHz,                      Output level <math>\leq +1</math> dBm (When MG3710A-041/141 is not installed),                      Output level <math>\leq +7</math> dBm (When MG3710A-041/141 is installed),  <math>\leq 0.82\%</math> (rms) (0.8% (rms) typ.)</p>
Vector accuracy 2nd SG (MG3710A)	<p>When MG3710A-073/173 is not installed:</p> <p>When W-CDMA (Test Model 4) is modulated:                      Output frequency: 800 MHz to 900 MHz, 1800 MHz to 2200 MHz,                      Output level <math>\leq +7</math> dBm (When MG3710A-071/171 is not installed),                      Output level <math>\leq +13</math> dBm (When MG3710A-071/171 is installed),  <math>\leq 0.62\%</math> (rms) (0.6% (rms) typ.)</p> <p>When GSM is modulated:                      Output frequency: 800 MHz to 900 MHz, 1800 MHz to 1900 MHz,                      Output level <math>\leq +7</math> dBm (When MG3710A-071/171 is not installed),                      Output level <math>\leq +13</math> dBm (When MG3710A-071/171 is installed),  <math>\leq 0.84^\circ</math> (rms) (0.8° (rms) typ.)</p> <p>When EDGE is modulated:                      Output frequency: 800 MHz to 900 MHz, 1800 MHz to 1900 MHz,                      Output level <math>\leq +7</math> dBm (When MG3710A-071/171 is not installed),                      Output level <math>\leq +13</math> dBm (When MG3710A-071/171 is installed),  <math>\leq 0.84\%</math> (rms) (0.8% (rms) typ.)</p>

## &lt;Vector modulation&gt; Continued

Items	Specifications
Vector accuracy 2nd SG (MG3710A)	<p>When LTE (20MHz Test Model 3.1) is modulated:  Output frequency: 600 MHz to 2700 MHz,  Output level <math>\leq +7</math> dBm (When MG3710A-071/171 is not installed),  Output level <math>\leq +13</math> dBm (When MG3710A-071/171 is installed),  <math>\leq 0.82\%</math> (rms) (0.8% (rms) typ.)  Output frequency: 3400 MHz to 3800 MHz,  Output level <math>\leq +4</math> dBm (When MG3710A-071/171 is not installed),  Output level <math>\leq +10</math> dBm (When MG3710A-071/171 is installed),  <math>\leq 0.82\%</math> (rms) (0.8% (rms) typ.)</p> <p>When MG3710A-073/173 is installed:  When W-CDMA (Test Model 4) is modulated:  Output frequency: 800 MHz to 900 MHz, 1800 MHz to 2200 MHz,  Output level <math>\leq +4</math> dBm (When MG3710A-071/171 is not installed),  Output level <math>\leq +10</math> dBm (When MG3710A-071/171 is installed),  <math>\leq 0.62\%</math> (rms) (0.6% (rms) typ.)</p> <p>When GSM is modulated:  Output frequency: 800 MHz to 900 MHz, 1800 MHz to 1900 MHz,  Output level <math>\leq +4</math> dBm (When MG3710A-071/171 is not installed),  Output level <math>\leq +10</math> dBm (When MG3710A-071/171 is installed),  <math>\leq 0.84^\circ</math> (rms) (0.8° (rms) typ.)</p> <p>When EDGE is modulated:  Output frequency: 800 MHz to 900 MHz, 1800 MHz to 1900 MHz,  Output level <math>\leq +4</math> dBm (When MG3710A-071/171 is not installed),  Output level <math>\leq +10</math> dBm (When MG3710A-071/171 is installed),  <math>\leq 0.84\%</math> (rms) (0.8% (rms) typ.)</p> <p>When LTE (20MHz Test Model 3.1) is modulated:  Output frequency: 600 MHz to 2700 MHz,  Output level <math>\leq +4</math> dBm (When MG3710A-071/171 is not installed),  Output level <math>\leq +10</math> dBm (When MG3710A-071/171 is installed),  <math>\leq 0.82\%</math> (rms) (0.8% (rms) typ.)  Output frequency: 3400 MHz to 3800 MHz,  Output level <math>\leq +1</math> dBm (When MG3710A-071/171 is not installed),  Output level <math>\leq +7</math> dBm (When MG3710A-071/171 is installed),  <math>\leq 0.82\%</math> (rms) (0.8% (rms) typ.)</p>
Carrier leak	MG3710A or MG3740A with MG3740A-020/120 installed Under the conditions of the temperature range between 18°C and 28°C, RMS Value = 0 dB, and after CAL execution. $\leq -55$ dBc (100 MHz $\leq$ frequency < 4 GHz) $\leq -45$ dBc (4 GHz $\leq$ frequency)
Image rejection	In MG3710A, under the conditions of the temperature range between 18°C and 28°C, RMS Value = 0 dB, after CAL execution, and complex CW at 10MHz or less. $\leq -50$ dBc (200 MHz $\leq$ frequency < 4 GHz) $\leq -43$ dBc (4 GHz $\leq$ frequency)

<Vector modulation> Continued

Items	Specifications
Image rejection	<p>MG3740A with MG3740A-020/120 installed</p> <p>Under the conditions of the temperature range between 18°C and 28°C, RMS Value = 0 dB, after CAL execution, and complex CW at 1 MHz or less.</p> <p><math>\leq -50</math> dBc (200 MHz <math>\leq</math> frequency <math>&lt;</math> 4 GHz)</p> <p><math>\leq -43</math> dBc (4 GHz <math>\leq</math> frequency)</p>
ACLR	<p>Under the conditions of the temperature between 18°C and 28°C and W-CDMA (Test Model 1 64DPCH) signal generation.</p>
1st SG (MG3710A)	<p>When MG3710A-043/143 is not installed:</p> <p>300 MHz <math>\leq</math> Output frequency <math>&lt;</math> 800 MHz,            Output level <math>\leq -2</math> dBm (When MG3710A-041/141 is not installed),            Output level <math>\leq +5</math> dBm (When MG3710A-041/041 is installed),            5 MHz offset: <math>\leq -68</math> dBc/3.84 MHz            10 MHz offset: <math>\leq -70</math> dBc/3.84 MHz</p> <p>800 MHz <math>\leq</math> Output frequency <math>&lt;</math> 1 GHz,            Output level <math>\leq -2</math> dBm (When MG3710A-041/141 is not installed),            Output level <math>\leq +5</math> dBm (When MG3710A-041/041 is installed),            5 MHz offset: <math>\leq -71</math> dBc/3.84 MHz            10 MHz offset: <math>\leq -71</math> dBc/3.84 MHz</p> <p>1 GHz <math>\leq</math> Output frequency <math>&lt;</math> 1.8 GHz,            Output level <math>\leq -2</math> dBm (When MG3710A-041/141 is not installed),            Output level <math>\leq +5</math> dBm (When MG3710A-041/041 is installed),            5 MHz offset: <math>\leq -70</math> dBc/3.84 MHz            10 MHz offset: <math>\leq -71</math> dBc/3.84 MHz</p> <p>1.8 GHz <math>\leq</math> Output frequency <math>&lt;</math> 2.2 GHz,            Output level <math>\leq -2</math> dBm (When MG3710A-041/141 is not installed),            Output level <math>\leq +5</math> dBm (When MG3710A-041/041 is installed),            5 MHz offset: <math>\leq -71</math> dBc/3.84 MHz            10 MHz offset: <math>\leq -71</math> dBc/3.84 MHz</p> <p>2.2 GHz <math>\leq</math> Output frequency <math>\leq</math> 3.0 GHz,            Output level <math>\leq -2</math> dBm (When MG3710A-041/141 is not installed),            Output level <math>\leq +5</math> dBm (When MG3710A-041/041 is installed),            5 MHz offset: <math>\leq -69</math> dBc/3.84 MHz            10 MHz offset: <math>\leq -71</math> dBc/3.84 MHz</p> <p>3.0 GHz <math>&lt;</math> Output frequency <math>\leq</math> 3.8 GHz,            Output level <math>\leq -2</math> dBm            5 MHz offset: <math>\leq -67</math> dBc/3.84 MHz            10 MHz offset: <math>\leq -67</math> dBc/3.84 MHz</p>

<Vector modulation> Continued

Items	Specifications
ACLR 1st SG (MG3710A)	When MG3710A-043/143 is installed: 300 MHz≤Output frequency<800 MHz, Output level≤-5 dBm (When MG3710A-041/141 is not installed), Output level≤+2 dBm (When MG3710A-041/041 is installed), 5 MHz offset: ≤-68 dBc/3.84 MHz 10 MHz offset: ≤-70 dBc/3.84 MHz 800 MHz≤Output frequency<1 GHz, Output level≤-5 dBm (When MG3710A-041/141 is not installed), Output level≤+2 dBm (When MG3710A-041/041 is installed), 5 MHz offset: ≤-71 dBc/3.84 MHz 10 MHz offset: ≤-71 dBc/3.84 MHz 1 GHz≤Output frequency<1.8 GHz, Output level≤-5 dBm (When MG3710A-041/141 is not installed), Output level≤+2 dBm (When MG3710A-041/041 is installed), 5 MHz offset: ≤-70 dBc/3.84 MHz 10 MHz offset: ≤-71 dBc/3.84 MHz 1.8 GHz≤Output frequency<2.2 GHz, Output level≤-5 dBm (When MG3710A-041/141 is not installed), Output level≤+2 dBm (When MG3710A-041/041 is installed), 5 MHz offset: ≤-71 dBc/3.84 MHz 10 MHz offset: ≤-71 dBc/3.84 MHz 2.2 GHz≤Output frequency≤3.0 GHz, Output level≤-5 dBm (When MG3710A-041/141 is not installed), Output level≤+2 dBm (When MG3710A-041/041 is installed), 5 MHz offset: ≤-69 dBc/3.84 MHz 10 MHz offset: ≤-71 dBc/3.84 MHz 3.0 GHz<Output frequency≤3.8 GHz, Output level≤-5 dBm 5 MHz offset: ≤-67 dBc/3.84 MHz 10 MHz offset: ≤-67 dBc/3.84 MHz

<Vector modulation> Continued

Items	Specifications
ACLR 2nd SG (MG3710A)	When MG3710A-073/173 is not installed:  300 MHz ≤ Output frequency < 800 MHz, Output level ≤ -2 dBm (When MG3710A-071/171 is not installed), Output level ≤ +5 dBm (When MG3710A-071/071 is installed), 5 MHz offset: ≤ -68 dBc/3.84 MHz 10 MHz offset: ≤ -70 dBc/3.84 MHz 800 MHz ≤ Output frequency < 1 GHz, Output level ≤ -2 dBm (When MG3710A-071/171 is not installed), Output level ≤ +5 dBm (When MG3710A-071/071 is installed), 5 MHz offset: ≤ -71 dBc/3.84 MHz 10 MHz offset: ≤ -71 dBc/3.84 MHz 1 GHz ≤ Output frequency < 1.8 GHz, Output level ≤ -2 dBm (When MG3710A-071/171 is not installed), Output level ≤ +5 dBm (When MG3710A-071/071 is installed), 5 MHz offset: ≤ -70 dBc/3.84 MHz 10 MHz offset: ≤ -71 dBc/3.84 MHz 1.8 GHz ≤ Output frequency < 2.2 GHz, Output level ≤ -2 dBm (When MG3710A-071/171 is not installed), Output level ≤ +5 dBm (When MG3710A-071/071 is installed), 5 MHz offset: ≤ -71 dBc/3.84 MHz 10 MHz offset: ≤ -71 dBc/3.84 MHz 2.2 GHz ≤ Output frequency ≤ 3.0 GHz, Output level ≤ -2 dBm (When MG3710A-071/171 is not installed), Output level ≤ +5 dBm (When MG3710A-071/071 is installed), 5 MHz offset: ≤ -69 dBc/3.84 MHz 10 MHz offset: ≤ -71 dBc/3.84 MHz 3.0 GHz < Output frequency ≤ 3.8 GHz, Output level ≤ -2 dBm 5 MHz offset: ≤ -67 dBc/3.84 MHz 10 MHz offset: ≤ -67 dBc/3.84 MHz

## &lt;Vector modulation&gt; Continued

Items	Specifications
ACLR 2nd SG (MG3710A)	When MG3710A-073/173 is installed:  300 MHz ≤ Output frequency < 800 MHz, Output level ≤ -5 dBm (When MG3710A-071/171 is not installed), Output level ≤ +2 dBm (When MG3710A-071/071 is installed), 5 MHz offset: ≤ -68 dBc/3.84 MHz 10 MHz offset: ≤ -70 dBc/3.84 MHz 800 MHz ≤ Output frequency < 1 GHz, Output level ≤ -5 dBm (When MG3710A-071/171 is not installed), Output level ≤ +2 dBm (When MG3710A-071/071 is installed), 5 MHz offset: ≤ -71 dBc/3.84 MHz 10 MHz offset: ≤ -71 dBc/3.84 MHz 1 GHz ≤ Output frequency < 1.8 GHz, Output level ≤ -5 dBm (When MG3710A-071/171 is not installed), Output level ≤ +2 dBm (When MG3710A-071/071 is installed), 5 MHz offset: ≤ -70 dBc/3.84 MHz 10 MHz offset: ≤ -71 dBc/3.84 MHz 1.8 GHz ≤ Output frequency < 2.2 GHz Output level ≤ -5 dBm (When MG3710A-071/171 is not installed), Output level ≤ +2 dBm (When MG3710A-071/071 is installed), 5 MHz offset: ≤ -71 dBc/3.84 MHz 10 MHz offset: ≤ -71 dBc/3.84 MHz 2.2 GHz ≤ Output frequency ≤ 3.0 GHz, Output level ≤ -5 dBm (When MG3710A-071/171 is not installed), Output level ≤ +2 dBm (When MG3710A-071/071 is installed), 5 MHz offset: ≤ -69 dBc/3.84 MHz 10 MHz offset: ≤ -71 dBc/3.84 MHz 3.0 GHz < Output frequency ≤ 3.8 GHz, Output level ≤ -5 dBm 5 MHz offset: ≤ -67 dBc/3.84 MHz 10 MHz offset: ≤ -67 dBc/3.84 MHz

<Vector modulation> Continued

Items	Specifications
<p>Level error from CW during vector modulation</p> <p>1st SG (MG3710A)</p>	<p>Under the conditions of the temperature between 18°C and 28°C and AWGN signal of bandwidth = 5 MHz.</p> <p>When MG3710A-043/143 is not installed:</p> <p>Output level &lt;-5 dBm: ±0.3 dB (50 MHz≤Output frequency&lt;98 MHz)</p> <p>Output level&lt;+1 dBm: ±0.2 dB (98 MHz≤Output frequency≤3 GHz)</p> <p>±0.2 dB (3 GHz&lt;Output frequency≤6 GHz)</p> <p>When MG3710A-043/143 is installed:</p> <p>Output level &lt;-5 dBm: ±0.3 dB (50 MHz≤Output frequency&lt;98 MHz)</p> <p>Output level&lt;-2 dBm ±0.2 dB (98 MHz≤Output frequency≤3 GHz)</p> <p>±0.2 dB (3 GHz&lt;Output frequency≤6 GHz)</p>
<p>2nd SG (MG3710A)</p>	<p>When MG3710A-073/173 is not installed:</p> <p>Output level &lt;-5 dBm: ±0.3 dB (50 MHz≤Output frequency&lt;98 MHz)</p> <p>Output level&lt;+1 dBm: ±0.2 dB (98 MHz≤Output frequency≤3 GHz)</p> <p>±0.2 dB (3 GHz&lt;Output frequency≤6 GHz)</p> <p>When MG3710A-073/173 is installed:</p> <p>Output level &lt;-5 dBm: ±0.3 dB (50 MHz≤Output frequency&lt;98 MHz)</p> <p>Output level&lt;-2 dBm ±0.2 dB (98 MHz≤Output frequency≤3 GHz)</p> <p>±0.2 dB (3 GHz&lt;Output frequency≤6 GHz)</p>



<Vector modulation> Continued

Items	Specifications
IQ input/output Base band IQ adjustment	MG3710A or MG3740A with MG3740A-020/120 installed
DC offset function	Range: -20.000% to +20.000% Resolution: 0.025%
Gain balancing function	Range: -1.000 dB to +1.000 dB  Resolution: 0.001 dB
IQ adjustment function	Range: -10.00 deg to +10.00 deg  Resolution: 0.01 deg
IQ Phase adjustment function	Range: -360.00 deg to +360.00 deg  Resolution: 0.01 deg
IQ Skew adjustment function	Range: -800.000 ns to +800.000 ns  Resolution: 1 ps
IQ Delay adjustment function	Range: -400.000 ns to +400.000 ns  Resolution: 1 ps
IQ input	When MG3710A-018/118 is installed:
Modulation bandwidth	Base band 80 MHz (Nominal)  RF 160 MHz (Nominal) ±200 MHz At 3.8 GHz
Input level	$\sqrt{I^2+Q^2} = 85 \text{ mV (rms)}$ (optimum value of level accuracy)
DC offset function	Range: -100 mV to 100 mV  Resolution: 1 mV
Input connector	Connector: Front panel, BNC-J connector (I Input, Q Input) Maximum input level: -1 V (peak)≤I, Q≤+1 V (peak) Impedance: 50 Ω (Nominal)

<Vector modulation> Continued

Items	Specifications
IQ output Output voltage range DC offset function  IQ adjustment function Output connector	When MG3710A-018/118 is installed: Under open circuit output conditions, with output voltage amplitude +DC offset: -2.5 V to +5 V Under an open circuited output conditions Inphase DC offset Range: -2.5 V to 5 V Resolution: 2 mV Differential DC offset Range: -50 mV to 50 mV Resolution: 0.1 mV  Uses Baseband IQ adjustment function  Connector: Rear panel, BNC-J connector (I Output/ $\bar{I}$ Output, Q Output/ $\bar{Q}$ Output)  Impedance: 50 $\Omega$ (Nominal)

<Arbitrary waveform generator>

Items	Specifications
Waveform resolution	In MG3710A or MG3740A with MG3740A-020/120 installed I/Q is 14, 15, or 16 bits
Modulation bandwidth	In MG3710A or MG3740A with MG3740A-020/120 installed MG3710A: 160 MHz Bandwidth MG3740A: 2 MHz Bandwidth (Over sampling rate = 4, the maximum number of Sampling rate = 8 MHz)
Reconstruction filter	In MG3710A or MG3740A with MG3740A-020/120 installed 80 MHz
Base band level adjustment	In MG3710A or MG3740A with MG3740A-020/120 installed Input level adjustment capability of the quadrature modulator. (RMS Value Tuning) Decreasing a level leads to less distortion. Increasing a level leads to less floor noise. Adjustable range $\pm 8$ dB Resolution 0.01 dB
Marker output	In MG3710A or MG3740A with MG3740A-020/120 installed In case of 14 bit resolution Three signals among waveform patterns or three signals generated in real-time. In case of 15 bit resolution One signal among waveform patterns or three signals generated in real-time. In case of 16 bit resolution Three signals generated in real-time. Toggling between positive logic pulse output and negative logic pulse output is available.

## &lt;Arbitrary waveform generator&gt; Continued

Items	Specifications																														
Internal Baseband Reference clock signal Range Resolution	In MG3710A or MG3740A with MG3740A-020/120 installed  20 kHz to 200 MHz 0.001 Hz																														
External Baseband Reference clock signal Range Divisional and multiplication function Input connector Input level Others	When MG3710A-017/117 is installed:  20 kHz to 50 MHz A clock that is generated internally by multiplying the input frequency by 1, 2, 4, 8, 16, 1/2, 1/4, 1/8, and 1/16 can be used as the DAC sampling clock. Rear panel, BNC-J connector (BB REF CLK Input) $\geq 0.2$ V <sub>p-p</sub> /50 $\Omega$ (AC coupling) (Nominal) Function of External Input or MIMO connection (BB Ref Sync) is selectable.																														
Waveform memory  Memory capacity: 1st SG  Memory capacity: 2nd SG  Number of loadable files  Memory synthesizing function 1st SG  2nd SG	When the Memory synthesizing function is installed, both 1 ch and 2 ch must have the same capacity. A combination of different capacities is not available. <table border="1"> <thead> <tr> <th>MG3710A/MG3740A -045/145</th> <th>MG3710A-046/146</th> <th>Memory capacity</th> </tr> </thead> <tbody> <tr> <td>Not installed</td> <td>Not installed</td> <td>64 Msamples</td> </tr> <tr> <td>Installed</td> <td>Not installed</td> <td>256 Msamples</td> </tr> <tr> <td>Not installed</td> <td>Installed</td> <td>1024 Msamples</td> </tr> <tr> <td>Installed</td> <td>Installed</td> <td>1024 Msamples</td> </tr> </tbody> </table> <table border="1"> <thead> <tr> <th>MG3710A/MG3740A -075/175</th> <th>MG3710A-076/176</th> <th>Memory capacity</th> </tr> </thead> <tbody> <tr> <td>Not installed</td> <td>Not installed</td> <td>64 Msamples</td> </tr> <tr> <td>Installed</td> <td>Not installed</td> <td>256 Msamples</td> </tr> <tr> <td>Not installed</td> <td>Installed</td> <td>1024 Msamples</td> </tr> <tr> <td>Installed</td> <td>Installed</td> <td>1024 Msamples</td> </tr> </tbody> </table> The following numbers of waveform patterns are available per wave memory: 4096 packages/wave memory 4096 patterns/package The maximum number of patterns in total: 4096/wave memory The minimum number of samples per pattern: 128  When MG3710A/MG3740A-048/148 is installed, this function synthesizes the contents of two channel memories to generate a baseband waveform.  When MG3710A/MG3740A-078/178 is installed, this function synthesizes the contents of two channel memories to generate a baseband waveform.	MG3710A/MG3740A -045/145	MG3710A-046/146	Memory capacity	Not installed	Not installed	64 Msamples	Installed	Not installed	256 Msamples	Not installed	Installed	1024 Msamples	Installed	Installed	1024 Msamples	MG3710A/MG3740A -075/175	MG3710A-076/176	Memory capacity	Not installed	Not installed	64 Msamples	Installed	Not installed	256 Msamples	Not installed	Installed	1024 Msamples	Installed	Installed	1024 Msamples
MG3710A/MG3740A -045/145	MG3710A-046/146	Memory capacity																													
Not installed	Not installed	64 Msamples																													
Installed	Not installed	256 Msamples																													
Not installed	Installed	1024 Msamples																													
Installed	Installed	1024 Msamples																													
MG3710A/MG3740A -075/175	MG3710A-076/176	Memory capacity																													
Not installed	Not installed	64 Msamples																													
Installed	Not installed	256 Msamples																													
Not installed	Installed	1024 Msamples																													
Installed	Installed	1024 Msamples																													

<Arbitrary waveform generator> Continued

Items	Specifications
Frequency offset	In MG3710A: $\pm ((200 \text{ MHz} \times 0.8 - \text{Wave form data bandwidth})/2)$ at the maximum When MG3740A-020/120 is installed: $\pm ((8 \text{ MHz} \times 0.8 - \text{Wave form data bandwidth})/2)$ at the maximum
Sequence function          Pattern trigger  Input connector	In MG3710A or MG3740A with MG3740A-020/120 installed The following functions can be executed by selecting combination files. <ul style="list-style-type: none"> <li>• Selecting a pattern switching method (manual or auto)</li> <li>• Selecting a pattern switching position (the termination of a frame or the termination of a pattern)</li> <li>• When the switching method is set to manual, the pattern can be switched upon the receipt of an external trigger signal.</li> <li>• Sequence restart function.</li> <li>• Maximum number of elements: 200</li> <li>• Minimum number of points per pattern: 1000</li> </ul> Level ratio setting range    level difference between two signals <80 dB or OFF Level setting resolution    0.01 dB Frequency offset Frequency setting resolution    1 Hz
Trigger Input   Start trigger Frame trigger  Trigger event  Input connector	In MG3710A or MG3740A with MG3740A-020/120 installed Starts outputting waveform pattern in sync with trigger signal. Start trigger or frame trigger is alternatively selectable.
	Used to start a waveform generation.
	In the burst waveform generation mode, this function is used to determine the timing of burst signal generation.
	The following trigger events can be detected. No Retrigger/Buffered Trigger/Restart on Trigger
	Function switching:                          Start trigger or frame trigger can be selected at the connector.
	Connector:                          Either of BNC-J connector (Start Frame TRIG Input, Pattern TRIG1 Input) or AUX connector can be used.
	Input level:                          TTL
	Logic:                          The polarity of rising or falling edge can be selected.

<AWGN generating function>

Items	Specifications
AWGN generating function 1st SG  2nd SG  Band restriction filter	When MG3710A-049/149 is installed: Absolute value of CN ratio: $\leq 40$ dB  When MG3710A-079/179 is installed: Absolute value of CN ratio $\leq 40$ dB  When MG3710A-049/079/149/179 is installed: The band restriction of AWGN can be set in the following range. From 20% to 80% of waveform sampling rate

<Sweep/List function>

Items	Specifications
Sweep function List function	Frequency and level sweep can be set at 1000-point resolution. Sweeping points of both frequency and level can be set individually at 500-point resolution.

<BER measurement function>

Items	Specifications
Connector	When MG3710A/MG3740A-021/121 is installed: Connector: Rear panel, AUX Connector
Input signal	Input level: TTL
Input bit rate	Data, Clock, Enable
Measurable patterns	100 bps to 40 Mbps
Synchronization	PN,9, PN,1, PN,5, PN,0, PN,3, AL,0, AL,1, Repeat of "01"
establishing condition	PN9fix, PN11fix, PN15fix, PN20fix, PN23fix, User Define
PN signal	PN order × 2 bits error free
PNfix signal	Establish the synchronization with PN signal by PN order × 2 bits error free, and then establish the synchronization with PNfix signal from the start bit of PNfix signal by PN order error free.
ALLO, ALL1,	10 bit error free
repetition of 01	8 to 1024 bit (variable) error free
UserDefine	A start bit to be used for detection of synchronization can also be selected.
Re-synchronization	x/y: y = number of measurement bit: selectable among
judgment	500, 5000 and 50000
Measurable bit	x = number of error bits among y bits: selectable in the
Number of measurable	range from 1 to y/2
error bits	$\leq 2^{32}-1$ bit
Measurement end	$\leq 2^{32}-1$ bit
condition	Number of measurement bits, number of measurement error bits
Automatic	Can be toggled on and off.
re-synchronization	Can be selected Count Clear or Count Keep.
function	Single, Endless, Continuous
Operation of	Status, Error, Error Rate, Error Count, SyncLoss Count, number of
re-synchronization	measurement bits
Measurement mode	Polarity of Data, Clock and/or Enable can be alternatively switched.
Display	This function can start the measurement from 0 by clearing the
Alternating polarity	measurement values while keeping synchronization during the BER
function	measurement.
Measurement result	
clearing function	

<Connector>

Items	Specifications
Output connector (RF Output)	Refer to <Output connector> for details.
Output connector (2nd RF Output)	When MG3710A/MG3740A-062/064/066/162/164/166 is installed: Refer to <Output connector> for details.
Analog IQ input (I Input) (Q Input)	When MG3710A-018/118 is installed: Refer to <Vector modulation>, IQ input for details.
Analog IQ output (I Input/I Input) (Q Input/Q Input)	When MG3710A/MG3740A-062/064/066/162/164/166 is installed: Refer to <Vector modulation>, IQ output for details.
External reference input (REF Input)	
Connector	Rear panel, BNC-J, 50 Ω (Nominal)
Frequency	5 MHz/10 MHz/13 MHz
Operating range	±1 ppm
Input level	-15 dBm ≤ level ≤ +20 dBm, (AC coupling)
Reference signal output (Buffer Output)	
Connector	Rear panel, BNC-J, 50 Ω (Nominal)
Frequency	10 MHz
Output level	≥ 0 dBm (AC coupling)
Start Frame TRIG Input	In MG3710A or MG3740A with MG3740A-020/120 installed
Connector	Rear panel, BNC-J connector
Output level	TTL
Marker1 Output	In MG3710A or MG3740A with MG3740A-020/120 installed
Connector	Rear panel, BNC-J connector
Output level	TTL
Pattern TRIG1 Input	In MG3710A or MG3740A with MG3740A-020/120 installed
Connector	Rear panel, BNC-J connector
Input level	TTL
BB REF CLK Input	When MG3710A-017/117 is installed:
Connector	Rear panel, BNC-J, 50 Ω (Nominal)
Frequency	20 kHz to 50 MHz (for External Baseband Reference clock) 560 MHz to 800 MHz (for BB Ref Sync)
Input level	≥ 0.2 Vp-p, (Nominal) (AC coupling)
BB REF CLK Output	When MG3710A-017/117 is installed:
Connector	Rear panel, BNC-J, 50 Ω (Nominal)
Frequency	560 MHz to 800 MHz
Output level	0.8 Vp-p, (Nominal) (AC coupling)

<Connector> Continued

Items	Specifications
Sweep Output Connector Output level	When MG3710A/MG3740A-017/117 is installed: BNC-J at < 1 Ω (driving capability of up to 2 kΩ) on the rear panel 0 to 10 V (while 10V level sweep is being executed), 0 to 5 V (when Sweep Status is selected)
LO Input Connector Frequency Input level	When MG3710A-017/117 is installed: Rear panel, SMA-J, 50 Ω (Nominal) 98 MHz to 6 GHz -10 dBm ≤ level ≤ +1 dBm (Nominal) (AC coupling)
LO Output Connector Frequency Output level	When MG3710A-017/117 is installed Rear panel, SMA-J, 50 Ω (Nominal) 98 MHz to 6 GHz ≤ +1 dBm (Nominal) (AC coupling) (Internal Lo output)
Additional Analog Modulation Input Connector Input impedance Input level	When MG3710A/MG3740A-050/080/150/180 is installed: Rear panel, BNC-J 50 Ω, 600 Ω, or Hi-Z (100 kΩ/70 pF) (Nominal) For set value, 2 Vp-p (Nominal) Absolute maximum ratings: ±5 V
Remote control	Remote control functions from an external controller (excluding the power supply)
LAN Connector	Ethernet (10/100/1000 Base-T) Rear panel, RJ-45
GPIB Connector Interface function	Compatible with IEEE488.2 IEEE488 bus connector on the rear panel SH1, AH1, T6, L4, SR1, RL1, PP0, DC1, DT0, C0, E2
USB (B) Connector	Compatible with USB2.0 Rear panel. USB-B Connector
USB Connector	Compatible with USB2.0 Waveform hardcopy and parameter saving of this equipment onto USB compatible external devices are available. Two ports of USB-A Connector on each of front panel and rear panel.
Monitor Output Connector	VGA compatible mini D-SUB 15 pin on the rear panel
AUX Connector	Used for input/output of an auxiliary device when MG3710A/MG3740A-017/117/021/121 is installed. Rear panel, 50 pins (DX10A-50S equivalent part) An AUX-BNC conversion cable is attached when MG3710A/MG3740A-017/117/021/121 is installed.
Input/Output level	TTL



<Display>

Display	XGA color LCD (resolution 1024 × 768) 8.4 inches (213 mm)
---------	--

<General specification>

Items	Specifications
Dimensions and mass	
Dimensions	177 mm (h) × 426 mm (w) × 390 mm (d) (excluding protrusions)
Mass	≤13.7 kg (with MS3710A/MG3740A-032,034 or 036 installed; excludes all other options) ≤17 kg (with all options installed; MG3710A-001, -002, -011, -017, -018, -021, -036, -041, -042, -043, -046, -048, -049, -050, -066, -071, -072, -073, -076, -078, -079, or MG3740A-001, -002, -011, -017, -020, -021, -036, -041, -042, -043, -045, -048, -050, -066, -071, -072, -073, -075, -078, -080)
Power supply	
Rated power voltage	AC 100 V to 120 V or 200 V to 240 V *
Rated frequency	50 to 60 Hz
Power consumption	≤350 VA (Including all options) 180VA (Nominal) (Including the following options but excluding other options: MG3710A/MG3740A-032, 034 or 036, and 041 ) 260VA (Nominal) (Including the following options but excluding other options: MG3710A/MG3740A-032, 034 or 036, 041, and 042; and MG3710A/MG3740A-062, 064 or 066, 071, and 072) 280VA (Nominal) (Including the following options but excluding other options: MG3710A/MG3740A-032, 034 or 036, 041, and 042; MG3710A-062/MG3740A, 064 or 066, 071, and 072; and 001, 021)
Temperature	
Operating temperature	5 to 45°C
Storage temperature	-20 to 60°C

\*: Operating voltage: within the range of +10% to -15% from the rated voltage

**<Environment performance>**

<b>Items</b>	<b>Specifications</b>
Conducted interference	Conforms to EN 61326-1: 2006
Radiated interference	Conforms to EN 61326-1: 2006
Harmonic current emission	Conforms to EN 61000-3-2: 2006 +A1:2009 A2:2009
Electrostatic Discharge	Conforms to EN 61326-1: 2006
Electromagnetic immunity	Conforms to EN 61326-1: 2006
First transient/burst	Conforms to EN 61326-1: 2006
Surge	Conforms to EN 61326-1: 2006
RF Conductive Immunity	Conforms to EN 61326-1: 2006
Power Frequency Magnetic Field Immunity	Conforms to EN 61326-1: 2006
Voltage drop / power supply interruption	Conforms to EN 61326-1: 2006

## A.2 Options

### <Option 001 Rubidium Reference Oscillator /

#### Option 101 Rubidium Reference Oscillator Retrofit >

Items	Specifications
Model/Symbol	MG3710A-001, MG3740A-001 Rubidium Reference Oscillator MG3710A-101, MG3740A-101 Rubidium Reference Oscillator Retrofit
Intended Use	This option generates 10 MHz reference signal to enhance frequency stability. Refer to <Frequency>, Internal Rubidium Reference Oscillator for details.

### <Option 002 High Stability Reference Oscillator /

#### Option 102 High Stability Reference Oscillator Retrofit>

Items	Specifications
Model/Symbol	MG3710A-002, MG3740A-002 High Stability Reference Oscillator MG3710A-102, MG3740A-102 High Stability Reference Oscillator Retrofit
Intended Use	This option generates 10 MHz reference signal to enhance frequency stability. Refer to <Frequency>, Internal Rubidium Reference Oscillator for details.

### <Option 011 2ndary HDD /Option 111 2ndary HDD Retrofit >

Items	Specifications
Model/Symbol	MG3710A-011, MG3740A-011 2ndary HDD MG3710A-111, MG3740A-111 2ndary HDD Retrofit
Intended Use	Adds a removable HDD for storage of user data.

**<Option 017 Universal Input/Output /Option 117 Universal Input/Output Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-017, MG3740A-017 Universal Input/Output MG3710A-117, MG3740A-117 Universal Input/Output Retrofit
Intended Use	Supplies the following interfaces. MG3710A: The interface for local signal synchronization to realize MIMO function Sweep Out signal AUX-BNC conversion cable. MG3740A: Sweep Out signal AUX-BNC conversion cable.

**<Option 018 Analog IQ Input/Output /Option 118 Analog IQ Input/Output Retrofit >**

**Note:**

This option cannot be installed in MG3740A.

Items	Specifications
Model/Symbol	MG3710A-018 Analog IQ Input/Output MG3710A-118 Analog IQ Input/Output Retrofit
Intended Use	Adds the analog I/Q input/output function. Refer to <IQ Input/Output>, IQ input, IQ output for details.

**<Option 020 Digital Modulation /Option 120 Digital Modulation Retrofit >**

**Note:**

This option cannot be installed in MG3710A.

Items	Specifications
Model/Symbol	MG3740A-020 Digital Modulation MG3740A-120 Digital Modulation Retrofit
Intended Use	Adds the digital modulation function to the analog signal generator. Refer to <Vector modulation> for details.

**<Option 021 BER Test Function /Option 121 BER Test Function Retrofit >**

Items	Specifications
Model/Symbol	MG3710A-021, MG3740A-021 BER Test Function MG3710A-121, MG3740A-121 BER Test Function Retrofit
Intended Use	Adds the BER measurement function. Refer to <BER measurement function> for details.

**<Option 029 OS Upgrade to Windows 7>**

Items	Specifications
Model/Symbol	MG3710A-029, MG3740A-029 OS Upgrade to Windows 7
Intended Use	Upgrades OS to Windows 7. According to the license restriction, this product is available only as a factory option.

**<Option 032 1st RF 100 kHz to 2.7 GHz>**

Items	Specifications
Model/Symbol	MG3710A-032, MG3740A-032 1st RF 100kHz to 2.7GHz This option cannot be retrofitted.
Intended Use	Supplies a specific 1st RF frequency range. Refer to <Frequency> for details.

**<Option 034 1st RF 100 kHz to 4 GHz>**

Items	Specifications
Model/Symbol	MG3710A-034, MG3740A-034 1st RF 100kHz to 4GHz This option cannot be retrofitted.
Intended Use	Supplies a specific 1st RF frequency range. Refer to <Frequency> for details.

**<Option 036 1st RF 100 kHz to 6 GHz>**

Items	Specifications
Model/Symbol	MG3710A-036, MG3740A-036 1st RF 100kHz to 6GHz This option cannot be retrofitted.
Intended Use	Supplies a specific 1st RF frequency range. Refer to <Frequency> for details.

**<Option 041 High Power Extension for 1st RF /**

**Option 141 High Power Extension for 1st RF Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-041, MG3740A-041 High Power Extension for 1st RF MG3710A-141, MG3740A-141 High Power Extension for 1st RF Retrofit
Intended Use	Extends the maximum 1st RF output level. Refer to <Output level> for details.

**<Option 042 Low Power Extension for 1st RF /**

**Option 142 Low Power Extension for 1st RF Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-042, MG3740A-042 Low Power Extension for 1st RF MG3710A-142, MG3740A-142 Low Power Extension for 1st RF Retrofit
Intended Use	Extends the minimum 1st RF output level. Refer to <Output level> for details.

**<Option 043 Reverse Power Protection for 1st RF /**

**Option 143 Reverse Power Protection for 1st RF Retrofit >**

Items	Specifications
Model/Symbol	MG3710A-043, MG3740A-043 Reverse Power Protection for 1st RF MG3710A-143, MG3740A-143 Reverse Power Protection for 1st RF Retrofit
Intended Use	Protects 1st RF from damage due to reverse power input. Refer to <Maximum reverse input> for details.

**<Option 045 ARB Memory Upgrade 256 Msample for 1st RF /**

**Option 145 ARB Memory Upgrade 256 Msample for 1st RF Retrofit >**

Items	Specifications
Model/Symbol	MG3710A-045, MG3740A-045 ARB Memory Upgrade 256 Msample for 1st RF MG3710A-145, MG3740A-145 ARB Memory Upgrade 256 Msample for 1st RF Retrofit
Intended Use	Expands the ARB memory capacity of 1st RF to 256 M. Refer to <Arbitrary waveform generator>, Waveform memory for details.

**<Option 046 ARB Memory Upgrade 1024 Msample for 1st RF /**

**Option 146 ARB Memory Upgrade 1024 Msample for 1st RF Retrofit >**

**Note:**

This option cannot be installed in MG3740A.

Items	Specifications
Model/Symbol	MG3710A-046 ARB Memory Upgrade 1024 Msample for 1st RF MG3710A-146 ARB Memory Upgrade 1024 Msample for 1st RF Retrofit
Intended Use	Expands the ARB memory capacity of 1st RF to 1024 M. Refer to <Arbitrary waveform generator>, Waveform memory for details.

**<Option 048 Combination of Baseband Signal for 1st RF /**

**Option 148 Combination of Baseband Signal for 1st RF Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-048, MG3740A-048 Combination of Baseband Signal for 1st RF MG3710A-148, MG3740A-148 Combination of Baseband Signal for 1st RF Retrofit
Intended Use	Adds the memory synthesizing function for synthesizing signals in the 1st RF baseband. Refer to <Arbitrary waveform generator>, Waveform memory for details.

**<Option 049 AWGN for 1st RF /Option 149 AWGN for 1st RF Retrofit>**

**Note:**

This option cannot be installed in MG3740A.

Items	Specifications
Model/Symbol	MG3710A-049 AWGN for 1st RF MG3710A-149 AWGN for 1st RF Retrofit
Intended Use	Adds the AWGN function to the 1st RF. Refer to <AWGN generating function> for details.

**<Option 050 Additional Analog Modulation Input for 1st RF /**

**Option 150 Additional Analog Modulation Input for 1st RF Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-050, MG3740A-050 Additional Analog Modulation Input for 1st RF MG3710A-150, MG3740A-150 Additional Analog Modulation Input for 1st RF Retrofit
Intended Use	Adds the additional analog modulation function for 1st RF. Refer to <Analog modulation>, External modulation signal for details.

**<Option 062 2nd RF 100kHz to 2.7GHz /**

**Option 162 2nd RF 100kHz to 2.7GHz Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-062, MG3740A-062 2nd RF 100kHz to 2.7GHz MG3710A-162, MG3740A-162 2nd RF 100kHz to 2.7GHz Retrofit This option can be retrofitted only when 2nd RF is not installed.
Intended Use	Supplies a specific 2nd RF frequency range. Refer to <Frequency> for details.

**<Option 064 2nd RF 100kHz to 4GHz /Option 164 2nd RF 100kHz to 4GHz Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-064, MG3740A-064 2nd RF 100kHz to 4GHz MG3710A-164, MG3740A-164 2nd RF 100kHz to 4GHz Retrofit This option can be retrofitted only when 2nd RF is not installed.
Intended Use	Supplies a specific 2nd RF frequency range. Refer to <Frequency> for details.

**<Option 066 2nd RF 100kHz to 6GHz /Option 166 2nd RF 100kHz to 6GHz Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-066, MG3740A-066 2nd RF 100kHz to 6GHz MG3710A-166, MG3740A-166 2nd RF 100kHz to 6GHz Retrofit This option can be retrofitted only when 2nd RF is not installed.
Intended Use	Supplies a specific 2nd RF frequency range. Refer to <Frequency> for details.



**<Option 071 High Power Extension for 2nd RF /**

**Option 171 High Power Extension for 2nd RF Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-071, MG3740A-071 High Power Extension for 2nd RF MG3710A-171, MG3740A-171 High Power Extension for 2nd RF Retrofit
Intended Use	Extends the maximum 2nd RF output level. Refer to <Output level> for details.

**<Option 072 Low Power Extension for 2nd RF /**

**Option 172 Low Power Extension for 2nd RF Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-072, MG3740A-072 Low Power Extension for 2nd RF MG3710A-172, MG3740A-172 Low Power Extension for 2nd RF Retrofit
Intended Use	Extends the minimum 2nd RF output level. Refer to <Output level> for details.

**<Option 073 Reverse Power Protection for 2nd RF /**

**Option 173 Reverse Power Protection for 2nd RF Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-073, MG3740A-073 Reverse Power Protection for 2nd RF MG3710A-173, MG3740A-173 Reverse Power Protection for 2nd RF Retrofit
Intended Use	Protects 2nd RF from damage due to reverse power input. Refer to <Maximum reverse input> for details.

**<Option 075 ARB Memory Upgrade 256 Msample for 2nd RF /**

**Option 175 ARB Memory Upgrade 256 Msample for 2nd RF Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-075, MG3740A-075 ARB Memory Upgrade 256 Msample for 2nd RF MG3710A-175, MG3740A-175 ARB Memory Upgrade 256 Msample for 2nd RF Retrofit
Intended Use	Expands the ARB memory capacity of 2nd RF to 256 M. Refer to <Arbitrary waveform generator>, Waveform memory for details.

**<Option 076 ARB Memory Upgrade 1024 Msample for 2nd RF /  
Option 176 ARB Memory Upgrade 1024 Msample for 2nd RF Retrofit>**

**Note:**

This option cannot be installed in MG3740A.

Items	Specifications
Model/Symbol	MG3710A-076 ARB Memory Upgrade 1024 Msample for 2nd RF MG3710A-176 ARB Memory Upgrade 1024 Msample for 2nd RF Retrofit
Intended Use	Expands the ARB memory capacity of 2nd RF to 1024 M. Refer to <Arbitrary waveform generator>, Waveform memory for details.

**<Option 078 Combination of Baseband Signal for 2nd RF /  
Option 178 Combination of Baseband Signal for 2nd RF Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-078, MG3740A-078 Combination of Baseband Signal for 2nd RF MG3710A-178, MG3740A-178 Combination of Baseband Signal for 2nd RF Retrofit
Intended Use	Adds the memory synthesizing function for synthesizing signals in the 2nd RF baseband. Refer to <Arbitrary waveform generator>, Waveform memory for details.

**<Option 079 AWGN for 2nd RF /Option 179 AWGN for 2nd RF Retrofit>**

**Note:**

This option cannot be installed in MG3740A.

Items	Specifications
Model/Symbol	MG3710A-079 AWGN for 2nd RF MG3710A-179 AWGN for 2nd RF Retrofit
Intended Use	Adds the AWGN function to the 2nd RF. Refer to <AWGN generating function> for details.

**<Option 080 Additional Analog Modulation Input for 2nd RF /**

**Option 180 Additional Analog Modulation Input for 2nd RF Retrofit>**

Items	Specifications
Model/Symbol	MG3710A-080, MG3740A-080 Additional Analog Modulation Input for 2nd RF MG3710A-180, MG3740A-180 Additional Analog Modulation Input for 2nd RF Retrofit
Intended Use	Adds the additional analog modulation function for 2nd RF. Refer to <Analog modulation>, External modulation signal for details.

**<Option 313 Removable HDD>**

Items	Specifications
Model/Symbol	MG3710A-313, MG3740A-313 Removable HDD
Intended Use	A HDD as an additional main storage medium (including OS) Users should attach or detach their HDD by themselves.



## *Appendix B Error Messages*

---

B.1	Error Messages List.....	B-2
-----	--------------------------	-----

## B.1 Error Messages List

ID	Message	Description
-1	Operation is canceled	—
-100	Command error	Failed to analyze command syntax.
-108	Parameter not allowed	Received more-than-required number of parameters for header.
-109	Missing parameter	Received less-than-required number of parameters for header.
-113	Undefined header	Undefined program header.
-120	Numeric data error	Failed to analyze numeric data syntax.
-120	Character data error	Failed to analyze character data syntax.
-130	Suffix error	Failed to analyze suffix syntax.
-150	String data error	Failed to analyze string data syntax.
-160	Block data error	Failed to analyze block data syntax.
-200	Execution error	Aborted execution due to file access failure.
-200	Execution error	Failed to save. Number of files to be saved reached upper limit.
-200	Execution error	No selectable waveform pattern in waveform memory.
-200	Execution error	License error
-200	Execution error	License Version error
-200	Execution error	Waveform Pattern File not found.
-200	Execution error	Operation disabled because Long pattern is included.
-200	Execution error	Long pattern cannot be used for the current option configuration.
-200	Execution error	Operation disabled when Pattern Combination is Edit.
-200	Execution error	I/Q Calibration failed.
-200	Execution error	Cannot load waveform.
-200	Execution error	Only supported when Sweep or List function is being executed.
-200	Execution error	The number of waveform on memory A reached upper limit.
-200	Execution error	The number of waveform on memory B reached upper limit.
-200	Execution error	The number of Long pattern on memory reached upper limit.
-200	Execution error	There is insufficient space on memory A.
-200	Execution error	There is insufficient space on memory B.

ID	Message	Description
-200	Execution error	There is insufficient space on memory to load Long pattern.
-200	Execution error	The waveform already exists on memory A.
-200	Execution error	The waveform already exists on memory B.
-200	Execution error	The same Long pattern already exists on memory.
-200	Execution error	Cannot load with current condition.
-200	Execution error	Operation forbidden as long as the current function is being executed.
-200	Execution error	Option composition of parameter file is not the same.
-221	Settings conflict	Setting not supported for 1st SG.
-221	Settings conflict	Setting not supported for 2nd SG.
-221	Settings conflict	Operation disabled when SG type is Analog.
-221	Settings conflict	Operation disabled when I/Q Output is Analog I/Q Out.
-221	Settings conflict	Operation disabled when I/Q Source is Digital I/Q In.
-221	Settings conflict	Operation disabled when Modulation Source is Ext.
-221	Settings conflict	Operation disabled when Modulation Source is Int.
-221	Settings conflict	Operation disabled when Output Frequency is under 7MHz.
-221	Settings conflict	Operation disabled when Sequence Mode is being executed.
-221	Settings conflict	Operation disabled when Sweep/List is being executed.
-221	Settings conflict	Operation disabled with current level setting. Increase level to turn on this function.
-221	Settings conflict	Operation disabled when Channel A is Off.
-221	Settings conflict	Operation disabled when Channel B is Off.
-221	Settings conflict	Operation disabled when SyncWithSG is Off.
-221	Settings conflict	Operation disabled when no channel group is loaded to channel table.
-221	Settings conflict	Operation disabled when Frequency Type differs between SG1 and SG2.
-221	Settings conflict	Operation disabled when FreqType is Channel.
-221	Settings conflict	Operation disabled when AttHold is On.
-221	Settings conflict	Operation disabled when SyncWithSG is On.
-221	Settings conflict	Operation disabled when LO Source is not Internal.
-221	Settings conflict	Operation disabled when SG2 LO Source is Sync.

ID	Message	Description
-221	Settings conflict	Operation restricted by Multi SG Sync.
-221	Settings conflict	Operation disabled when Pattern Combination is Edit.
-221	Settings conflict	Operation disabled when Digital Modulation (Opt-020) not installed.
-221	Settings conflict	Parameter out of range or invalid: [Parameter]
-221	Settings conflict	Parameter out of range or invalid: [Header]Product Name
-221	Settings conflict	Parameter out of range or invalid: [Header]Soft Type
-221	Settings conflict	Parameter out of range or invalid: [Wave Info]Data Width
-221	Settings conflict	Operation disabled when Combination Pattern File or Alias Pattern File not selected.
-221	Settings conflict	Operation disabled when Pattern B is not selected.
-221	Settings conflict	Operation disabled when Pattern A is not selected.
-221	Settings conflict	Operation disabled when both Pattern A and B is not selected.
-221	Settings conflict	Operation disabled when Off not set for Sync Type.
-221	Settings conflict	Operation disabled when Sync Type is Slave.
-221	Settings conflict	Operation disabled when External not set for Baseband Reference Clock Source.
-221	Settings conflict	Operation disabled when Marker1 Edit Mode A is Off.
-221	Settings conflict	Operation disabled when Marker2 Edit Mode A is Off.
-221	Settings conflict	Operation disabled when Marker3 Edit Mode A is Off.
-221	Settings conflict	Operation disabled when On not set for Marker1 Edit Mode A.
-221	Settings conflict	Operation disabled when On not set for Marker2 Edit Mode A.
-221	Settings conflict	Operation disabled when On not set for Marker3 Edit Mode A.
-221	Settings conflict	Operation disabled when RF Gate Edit Mode is Off.
-221	Settings conflict	Operation disabled when On not set for RF Gate Edit Mode.
-221	Settings conflict	Operation disabled when Play Mode is Auto for Sequence Mode.
-221	Settings conflict	Operation disabled when Sequence Mode is not being executed.
-221	Settings conflict	Operation disabled because Master or Slave not set for Sync Type.
-221	Settings conflict	Operation disabled when Slave not set for Sync Type.
-221	Settings conflict	Operation disabled when Sync Type is Off.
-221	Settings conflict	Operation disabled when Waveform Pattern is not included in output signal.



ID	Message	Description
-221	Settings conflict	Operation disabled when Sequence Pattern File is selected.
-221	Settings conflict	Operation disabled when Carrier is not included in output signal.
-221	Settings conflict	Operation disabled when Carrier is included in output signal.
-221	Settings conflict	Operation disabled when Marker1 Edit Mode B is Off.
-221	Settings conflict	Operation disabled when Marker2 Edit Mode B is Off.
-221	Settings conflict	Operation disabled when Marker3 Edit Mode B is Off.
-221	Settings conflict	Operation disabled when On not set for Marker1 Edit Mode B.
-221	Settings conflict	Operation disabled when On not set for Marker2 Edit Mode B.
-221	Settings conflict	Operation disabled when On not set for Marker3 Edit Mode B.
-221	Settings conflict	Operation disabled when Pattern A and B is not included in output signal.
-221	Settings conflict	Operation disabled with currently selected Waveform Pattern File.
-221	Settings conflict	Operation disabled when Combination Pattern File or Alias Pattern File not selected.
-221	Settings conflict	Operation disabled when Waveform of List function is On when List function in use.
-221	Settings conflict	Operation disabled when Rate Matching is used.
-221	Settings conflict	Operation disabled when RfGateType is Single.
-221	Settings conflict	Operation disabled when Start/Frame Trigger is Off.
-221	Settings conflict	Operation disabled when Start/Frame Trigger Mode is Start.
-221	Settings conflict	Operation disabled when 3Trigger not set for Pattern Trigger Mode.
-221	Settings conflict	Operation disabled when Pattern Trigger Mode is 3Status.
-221	Settings conflict	Operation disabled when outputting Pattern A and B addition signal or Multiplex signal.
-221	Settings conflict	Operation disabled when Center Signal is Baseband DC.
-221	Settings conflict	Operation disabled when Baseband DC not set for Center Signal.
-221	Settings conflict	Operation disabled when Long pattern is loaded.
-221	Settings conflict	Operation disabled when Mod is On.
-221	Settings conflict	Operation disabled when SG1 output signal is CW.
-221	Settings conflict	Operation disabled when SG2 output signal is CW.
-221	Settings conflict	Invalid waveform type
-221	Settings conflict	Invalid waveform file information
-221	Settings conflict	Same combination file has been loaded.

ID	Message	Description
-221	Settings conflict	Cannot find waveform A specified with combination.
-221	Settings conflict	Cannot find waveform B specified with combination.
-221	Settings conflict	Invalid waveform A file information
-221	Settings conflict	Invalid waveform B file information
-221	Settings conflict	The number of combination file reached upper limit.
-221	Settings conflict	Cannot load new waveform when Long waveform is already loaded.
-221	Settings conflict	Cannot load new Long waveform when more than one waveform is already loaded.
-221	Settings conflict	Operation disabled when AM Type is Exp.
-221	Settings conflict	Operation disabled when AM Type is Lin.
-221	Settings conflict	Operation disabled when Square not set for Pulse Source.
-221	Settings conflict	Operation disabled when Freerun or Gated not set for Pulse Source.
-221	Settings conflict	Operation disabled when Pulse Source is Square or Ext Pulse.
-221	Settings conflict	Operation disabled when Pulse Source is Square, Freerun, Gated, or Ext Pulse.
-221	Settings conflict	Operation disabled when Adjustable Doublet not set for Pulse Source.
-221	Settings conflict	Operation disabled when I/Q Source is Analog I/Q In.
-221	Settings conflict	Operation disabled when SG output signals are not modulated.
-221	Settings conflict	Operation disabled when Sequence Pattern File is selected.
-221	Settings conflict	Operation disabled in Manual Mode.
-221	Settings conflict	Operation disabled when using 2nd SG and in Sweep mode.
-221	Settings conflict	Specified function not supported at current state.

<b>ID</b>	<b>Message</b>	<b>Description</b>
-222	Data out of range	Setting value out of range
-240	Hardware error	Failed to communicate with Power Sensor.
-241	Hardware missing	Operation disabled when both Option 018 and Option 019 not installed.
-241	Hardware missing	Operation disabled when Digital BB I/Q Unit (Opt-019) not installed.
-241	Hardware missing	Operation disabled when 2nd SG (Opt-062, 064, 066) not installed.
-241	Hardware missing	Operation disabled when Reverse Power Protection for 1st RF (Opt-043) not installed.
-241	Hardware missing	Operation disabled when Reverse Power Protection for 2nd RF (Opt-073) not installed.
-241	Hardware missing	Operation disabled when Option 048 not installed.
-241	Hardware missing	Operation disabled when Option 078 not installed.
-241	Hardware missing	Operation disabled when Universal Input/Output (Opt-017) not installed.
-241	Hardware missing	Operation disabled when AWGN (Opt-049) not installed.
-241	Hardware missing	Operation disabled when AWGN (Opt-079) not installed.
-241	Hardware missing	Operation disabled when 2nd HDD (Opt-011) not installed.
-241	Hardware missing	Operation disabled when Analog I/Q Input/Output (Opt-018) not installed.
-241	Hardware missing	Operation disabled when 1st SG (Opt-050) not installed.
-241	Hardware missing	Operation disabled when 2nd SG (Opt-080) not installed.
-256	File name not found	Unable to execute; specified file name not found in media.
-257	File name error	An invalid filename was encountered.
-350	Queue overflow	Remote control error queue overflowed.



## Appendix C Default Value List

---

The default values are common to SG Port 1 and 2, if not specified.

### <System>

Item	Default
SG Port	SG1

### <Frequency Functions>

Item	Default
Frequency setting	
Frequency	1 GHz
Frequency relative display On/Off	Off
Frequency relative display	0 Hz
Frequency offset On/Off	Off
Frequency offset	0 Hz
Frequency offset multiplier On/Off	Off
Frequency offset multiplier	1
Frequency step	100.00000 kHz
Channel setting	
Frequency/Channel display	Freq
Frequency display On/Off	Off
Channel group	No Group
Channel selection	0
Function	
Frequency synchronization On/Off	Off
Frequency synchronization mode	Parallel
Phase noise optimization	Offset < 200 kHz
RF spectrum	Normal
Signal source	
Reference frequency source	Auto
Reference frequency	10 MHz
Local signal source	Int
Local signal output	Off
Local signal phase	0.00 deg

**<Output Level Main Function>**

Item	Default
Output	
RF output On/Off	Off
Output level	-144.00 dBm
Display unit	dBm
Output level relative display On/Off	Off
Output level relative value	0 dB
Output level offset On/Off	Off
Output level offset	0.00 dB
Output level step	0.10 dB
Limit level On/Off	Off
Limit level	Maximum level of installed options
Function	
ATT Hold On/Off	Off
Output level synchronization On/Off	Off
User correction On/Off	Off
S/N optimization On/Off	Off
User correction setting	
Com Port	2
Model	MA24106A
Start Freq	1.00000000000 GHz
Stop Freq	1.00000000000 GHz
Level Offset On/Off	Off
Level Offset	0.00 dB
Correction Points	2
Averaging On/Off	Off
Averaging Count	10

<Sweep/List Function>

Item	Default
Sweep	
Sweep/List Freq On/Off	Off
Sweep/List Level On/Off	Off
Sweep/List Type	Sweep
Sweep repeat	Continuous
Sweep Direction	Up
Manual Mode On/Off	Off
Manual Point	1
Output setting	
Sweep Out setting	Sweep Status
Trigger Out Polarity	Positive
Sweep function setting	
Sweep start frequency	1.00000000000 GHz
Sweep stop frequency	1.00000000000 GHz
Sweep center frequency	1 GHz
Sweep span frequency	0 Hz
Sweep start level	-144.00 dBm
Sweep stop level	-144.00 dBm
Sweep point	101
Sweep dwell time	2.000 ms
Sweep type	Saw Tooth
List function setting	
List SG setting	SG1
List frequency setting	1 GHz
List level setting	-144.00 dBm
Dwell time selection	List
Point trigger	
Point trigger On/Off	Off
Point trigger mode	Start
Point trigger source	External
Point trigger delay	0.00000000 s
Point trigger edge	Rise
Point trigger timer	1.000 ms

<Modulation Function>

Item	Default
Modulation	
Modulation On/Off	Off
Analog/Pulse modulation	
AM Modulation On/Off	Off
AM Depth scale	Linear
AM Depth (Lin)	0.1%
AM Depth (Log)	3.00 dB
AM modulation frequency	400.0 Hz
Switching AM Source	Int
AM Waveform	Sine
AM Phase Adjust	0 deg
FM Modulation On/Off	Off
FM frequency deviation	1.0000 kHz (SG1) 0 Hz (SG2)
FM modulation frequency	400.0 Hz
Switching FM Source	Int
FM Waveform	Sine
FM Phase Adjust	0 deg
$\phi$ M Modulation On/Off	Off
$\phi$ M deviation angle	0.000 rad
$\phi$ M modulation frequency	400.0 Hz
Switching $\phi$ M Source	Int
$\phi$ M Waveform	Sine
$\phi$ M Phase Adjust	0 deg
Pulse Modulation On/Off	Off
Pulse modulation source	Freerun
Pulse modulation frequency	400.0 Hz
Pulse modulation period	4.00 $\mu$ s
Pulse modulation delay	0.00000000 s
Pulse modulation width	2.00 $\mu$ s
Pulse 2 delay	0.00000000 s
Pulse 2 width	2.00 $\mu$ s
Pulse Sync/Pulse Video output signal polarity	Positive
Pulse Mod input signal polarity	Positive
External Modulation Signal	
Coupling	DC
Impedance	600 $\Omega$



Item	Default
Optimize function for the analog modulation	
Optimize	Spurious (MG3710A) Distortion (MG3740A)
Digital modulation	
ARB On/Off	On
RMS adjustment	0.00 dB
Pattern generation mode	Defined
ARB Setup	
Pattern A On/Off	On
Pattern B On/Off	Off
Pattern A output level	-144.00 dBm
Pattern B output level	-144.00 dBm
Object of level change	A&B
Level ratio setting	0.00 dB
Sampling rate A	20.000000 kHz
Sampling rate B	20.000000 kHz
Frequency offset	0 Hz
Frequency offset A	0 Hz
Frequency offset B	0 Hz
Reference frequency	Baseband DC
Start offset	0
Spectrum reverse A	Normal
Spectrum reverse B	Normal
Waveform load	
Waveform load list focus	Package
Sub item	Status
Waveform load target memory	A
Waveform selection	
Waveform selection list focus	Package
Waveform selection target memory	A
Waveform copy	
Waveform copy list focus	Package
Waveform copy target drive	C:

*Appendix C Default Value List*

---

<b>Item</b>	<b>Default</b>
RF Gate	
RF Gate On/Off	On
RF Gate edit On/Off	Off
RF Gate line	Single
RF Gate offset 1	0.00
RF Gate width 1	1.00
RF Gate offset 2	0.00
RF Gate width 2	1.00
RF Gate frequency	1.00
Start/Frame Trigger	
Start/Frame Trigger On/Off	Off
Start/Frame Trigger Mode	Start
Start/Frame Trigger Source	Ext
Start/Frame Trigger Delay	0.00
Start/Frame Trigger Edge	Rise
Start/Frame Trigger Event	No Retrigger
Baseband Clock	
Baseband Reference Clock Source	Int
Baseband Reference Clock Division	1/4
Baseband Reference Clock Out	Off
Marker Setup	
Marker1 Edit Mode A On/Off	Off
Marker1 Offset A	0.00
Marker1 Width A	1.00
Marker1 Cycle A	1.00
Marker1 Polarity A	Positive
Marker1 Edit Mode B On/Off	Off
Marker1 Offset B	0.00
Marker1 Width B	1.00
Marker1 Cycle B	1.00
Marker1 Polarity B	Positive
Marker2 Edit Mode A On/Off	Off
Marker2 Offset A	0.00
Marker2 Width A	1.00
Marker2 Cycle A	1.00
Marker2 Polarity A	Positive
Marker2 Edit Mode B On/Off	Off
Marker2 Offset B	0.00
Marker2 Width B	1.00
Marker2 Cycle B	1.00

Item	Default
Marker2 Polarity B	Positive
Marker3 Edit Mode A On/Off	Off
Marker3 Offset A	0.00
Marker3 Width A	1.00
Marker3 Cycle A	1.00
Marker3 Polarity A	Positive
Marker3 Edit Mode B On/Off	Off
Marker3 Offset B	0.00
Marker3 Width B	1.00
Marker3 Cycle B	1.00
Marker3 Polarity B	Positive
Sequence Mode	
Sequence Play Mode	Auto
Sequence Repeat Mode	Continuous
Sequence Element Repeat Count	1
Sequence Element Number	1
Pattern Trigger On/Off	Off
Pattern Trigger 1 On/Off	Off
Pattern Trigger 1 Source	Ext
Pattern Trigger 1 Edge	Rise
Pattern Trigger 2 On/Off	Off
Pattern Trigger 2 Source	Ext
Pattern Trigger 2 Edge	Rise
Pattern Trigger 3 On/Off	Off
Pattern Trigger 3 Source	Ext
Pattern Trigger 3 Edge	Rise
Pattern Trigger Switching Point	Pattern
Sync Multi SG	
Sync Type	Off
Number of Slaves	1
Slave Position	1
LO Sync	Off
I/Q Phase	0.00 deg
I/Q Delay	0.000000000000 s

<Route Connectors>

Item	Default
Route Input Connectors	
S/F Trigger	SG1 S/F Trigger (MG3710A, MG3740A-020/120) OFF (When MG3740A-020/120 is not installed)
Pattern Trigger 1	Pattern Trigger 1 (MG3710A, MG3740A-020/120) OFF (When MG3740A-020/120 is not installed)
Pattern Trigger 2	Pattern Trigger 2
Pattern Trigger 3	Pattern Trigger 3
Pattern Status 1	Pattern Status 1
Pulse Mod	SG1 Pulse Mod
Pattern Trigger Type	<u>Shared</u>
Route Output Connectors	
Marker1	SG1 Marker1 A (MG3710A, MG3740A-020/120) Point Trigger Out (When MG3740A-020/120 is not installed)
Marker2	SG1 Marker2 A
Marker3	SG1 Marker3 A
Pulse Video	SG1 Pulse Video
Pulse Sync	SG1 Pulse Sync
Sync Trig Out	Sync Trigger Out

<AWGN>

Item	Default
AWGN	
AWGN On/Off	Off
Noise Bandwidth	16.000 kHz
Carrier Level	-110.00 dBm
Noise Level	-20.00 dBm
C/N Ratio	40.00 dB
C/N Set Signal	Constant

<I/Q Modulation>

Item	Default
I/Q	
I/Q Source	Internal
I/Q Output	RF
Internal Channel Correction	Off
I/Q Calibration	
Cal Type	DC
Wideband	Off
Analog I/Q Input Adjustments	
I Offset	0.000 V
Q Offset	0.000 V
Analog I/Q Output Adjustments	
I Level Trimming	100.0%
Q Level Trimming	100.0%
I/Q Common Offset	0.0000 V
I Diff Offset	0.0000 V
Q Diff Offset	0.0000 V
Internal Baseband Adjust	
I Offset	0.000%
Q Offset	0.000%
Gain Balance	0.000 dB
Quad. Angle	0.00 deg
I/Q Phase	0.00 deg
I/Q Skew	0.000000000000 s
I/Q Delay	0.000000000000 s

**<BER Measurement Functions>**

Item	Default
BER	
Measure Mode	Continuous
Data Type	PN9
Count Mode	
Count Mode	Data
Data	1000
Error	1
Resync Condition	
Auto Resync	On
Threshold X	200
Threshold Y	500 bits
at SyncLoss	Clear
BER Interface	
Clock Edge	Rise
Data Polarity	Positive
Enable Active	Disable
PN Fix Pattern	
PN Fix9 Pattern Initial	1FF
PN Fix11 Pattern Initial	7FF
PN Fix15 Pattern Initial	7FFF
PN Fix20 Pattern Initial	FFFFFF
PN Fix23 Pattern Initial	7FFFFFFF
PN Fix Pattern Length	96
User Defined Pattern	
Pattern Length	1024
Sync Start	1
Sync Length	32
Auto Restart	
Auto Restart	Off

<Power Meter>

Item	Default
Channel A On/Off	Off
Channel B On/Off	Off
Connection Settings	
Channel A Com Port	2
Channel A Model	MA24106A
Channel B Com Port	2
Channel B Model	MA24106A
Channel Settings	
Channel A Freq	1.000000000000 GHz
Channel A Offset On/Off	Off
Channel A Offset	0.00 dB
Channel A Averaging On/Off	Off
Channel A Averaging Count	1024
Channel A Measurement Units	dBm
Channel B Freq	1.000000000000 GHz
Channel B Offset On/Off	Off
Channel B Offset	0.00 dB
Channel B Averaging On/Off	Off
Channel B Averaging Count	1024
Channel B Measurement Units	dBm

<Utility>

Item	Default
Interface Settings	
GPIB Address	3
Terminator	CR
Language	SCPI
Raw Socket Port Number	49158
System Settings	
Beep Sound	On
Power On	Last

**<Other Functions>**

<b>Item</b>	<b>Default</b>
Copy	
File Type	PNG
Color	Normal
Others	
Screen display On/Off	On
Knob hold On/Off	Off

**<Save/Read Function>**

<b>Item</b>	<b>Default</b>
Saving/reading media	C



# *Appendix D Performance Test Report Form*

---

## **Performance Test Result Form**

Test  
Location

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Report No.

\_\_\_\_\_

Date

\_\_\_\_\_

Test person  
in charge

\_\_\_\_\_

Equipment Name: MG3710A Vector Signal Generator / MG3740A Analog Signal Generator

Serial No.

\_\_\_\_\_

Ambient  
temperature

°C

\_\_\_\_\_

Power  
frequency

\_\_\_\_\_

Relative  
humidity

%

\_\_\_\_\_

Remarks:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

### Output Frequency (Section 10.2.1)

1st RF

Setting	Results	
0.009 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
100 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
300 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
600 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
1000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
1500 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
2000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
2500 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
2700 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
3000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
3500 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
4000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
4500 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
5000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
5500 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
6000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG

\*: 3000 to 4000 MHz are available only when the Upper frequency limit 4 GHz, 6 GHz option is installed.  
4500 to 6000 MHz are available only when the Upper frequency limit 6 GHz option is installed.

2nd RF

Setting	Results	
0.009 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
100 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
300 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
600 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
1000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
1500 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
2000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
2500 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
2700 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
3000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
3500 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
4000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
4500 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
5000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
5500 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG
6000 MHz	<input type="checkbox"/> OK	<input type="checkbox"/> NG

\*: 3000 to 4000 MHz are available only when the Upper frequency limit 4 GHz, 6 GHz option is installed.  
 4500 to 6000 MHz are available only when the Upper frequency limit 6 GHz option is installed.

### Output Level Frequency Characteristics (Section 10.3.1)

1st RF, without Option 043/143

Setting		Minimum Rating	Results	Maximum Rating	Uncertainty
Frequency	Output level				
50 MHz 97 MHz	-5 dBm	-5.5 dBm	_____	-4.5 dBm	±0.27 dB
98 MHz 100 MHz 399 MHz 400 MHz	-7 dBm	-7.5 dBm	_____ _____ _____ _____	-6.5 dBm	±0.27 dB
500 MHz 1000 MHz 1500 MHz 2000 MHz 2500 MHz 2700 MHz 3000 MHz		-7.5 dBm	_____ _____ _____ _____ _____ _____	-6.5 dBm	±0.25 dB
3001 MHz 3500 MHz 4000 MHz		-7.7 dBm	_____ _____ _____	-6.3 dBm	±0.34 dB
4500 MHz 5000 MHz		-7.8 dBm	_____ _____	-6.2 dBm	±0.34 dB
5500 MHz 6000 MHz		-7.8 dBm	_____ _____	-6.2 dBm	±0.34 dB

\*: 3000 to 4000 MHz are available only when the Upper frequency limit 4 GHz, 6 GHz option is installed.  
 4500 to 6000 MHz are available only when the Upper frequency limit 6 GHz option is installed.

2nd RF, without Option 073/173

Setting		Minimum Rating	Results	Maximum Rating	Uncertainty
Frequency	Output level				
50 MHz 97 MHz	-5 dBm	-5.5 dBm	_____	-4.5 dBm	±0.27 dB
98 MHz 100 MHz 399 MHz 400 MHz	-7 dBm	-7.5 dBm	_____	-6.5 dBm	±0.27 dB
500 MHz 1000 MHz 1500 MHz 2000 MHz 2500 MHz 2700 MHz 3000 MHz		-7.5 dBm	_____	-6.5 dBm	±0.25 dB
3001 MHz 3500 MHz 4000 MHz		-7.7 dBm	_____	-6.3 dBm	±0.34 dB
4500 MHz 5000 MHz		-7.8 dBm	_____	-6.2 dBm	±0.34 dB
5500 MHz 6000 MHz		-7.8 dBm	_____	-6.2 dBm	±0.34 dB

\*: 3000 to 4000 MHz are available only when the Upper frequency limit 4 GHz, 6 GHz option is installed.  
 4500 to 6000 MHz are available only when the Upper frequency limit 6 GHz option is installed.

*Appendix D Performance Test Report Form*

---

1st RF, with Option 043/143

Setting		Minimum Rating	Results	Maximum Rating	Uncertainty
Frequency	Output level				
50 MHz 97 MHz	-8 dBm	-8.5 dBm	_____	-7.5 dBm	±0.27 dB
98 MHz 100 MHz 399 MHz 400 MHz	-10 dBm	-10.5 dBm	_____	-9.5 dBm	±0.27 dB
500 MHz 1000 MHz 1500 MHz 2000 MHz 2500 MHz 2700 MHz 3000 MHz		-10.5 dBm	_____	-9.5 dBm	±0.25 dB
3001 MHz 3500 MHz 4000 MHz		-10.7 dBm	_____	-9.3 dBm	±0.34 dB
4500 MHz 5000 MHz		-10.8 dBm	_____	-9.2 dBm	±0.34 dB
5500 MHz 6000 MHz		-10.8 dBm	_____	-9.2 dBm	±0.34 dB

\*: 3000 to 4000 MHz are available only when the Upper frequency limit 4 GHz, 6 GHz option is installed.  
 4500 to 6000 MHz are available only when the Upper frequency limit 6 GHz option is installed.

2nd RF, with Option 073/173

Setting		Minimum Rating	Results	Maximum Rating	Uncertainty
Frequency	Output level				
50 MHz 97 MHz	-8 dBm	-8.5 dBm	_____	-7.5 dBm	±0.27 dB
98 MHz 100 MHz 399 MHz 400 MHz	-10 dBm	-10.5 dBm	_____	-9.5 dBm	±0.27 dB
500 MHz 1000 MHz 1500 MHz 2000 MHz 2500 MHz 2700 MHz 3000 MHz		-10.5 dBm	_____	-9.5 dBm	±0.25 dB
3001 MHz 3500 MHz 4000 MHz		-10.7 dBm	_____	-9.3 dBm	±0.34 dB
4500 MHz 5000 MHz		-10.8 dBm	_____	-9.2 dBm	±0.34 dB
5500 MHz 6000 MHz		-10.8 dBm	_____	-9.2 dBm	±0.34 dB

\*: 3000 to 4000 MHz are available only when the Upper frequency limit 4 GHz, 6 GHz option is installed.  
 4500 to 6000 MHz are available only when the Upper frequency limit 6 GHz option is installed.

### Vector Accuracy (Section 10.4.1)

Note:

Waveform patterns are not included in the MG3740A; therefore the vector modulation performance test is not required.

1st RF

Setting			Results	Maximum Rating	Uncertainty			
System	Frequency	Output level						
W-CDMA (Test Model 4)	800 MHz	<input type="checkbox"/> (1) +7 dBm <input type="checkbox"/> (2) +13 dBm <input type="checkbox"/> (3) +4 dBm <input type="checkbox"/> (4) +10 dBm	_____	0.62% (rms)	0.02% (rms)			
	900 MHz		_____					
	1800 MHz		_____					
	1900 MHz		_____					
GSM	800 MHz		<input type="checkbox"/> (1) +7 dBm <input type="checkbox"/> (2) +13 dBm <input type="checkbox"/> (3) +4 dBm <input type="checkbox"/> (4) +10 dBm	_____	0.84° (rms)	0.04° (rms)		
	900 MHz			_____				
	1800 MHz			_____				
	1900 MHz			_____				
EDGE	800 MHz			<input type="checkbox"/> (1) +7 dBm <input type="checkbox"/> (2) +13 dBm <input type="checkbox"/> (3) +4 dBm <input type="checkbox"/> (4) +10 dBm	_____	0.84% (rms)	0.04% (rms)	
	900 MHz				_____			
	1800 MHz				_____			
	1900 MHz				_____			
LTE (20 MHz TestModel 3.1)	600 MHz				<input type="checkbox"/> (1) +7 dBm <input type="checkbox"/> (2) +13 dBm <input type="checkbox"/> (3) +4 dBm <input type="checkbox"/> (4) +10 dBm	_____	0.82% (rms)	0.02% (rms)
	800 MHz					_____		
	1500 MHz					_____		
	2000 MHz					_____		
	2400 MHz	_____						
LTE (20 MHz TestModel 3.1)	2700 MHz	<input type="checkbox"/> (1) +7 dBm <input type="checkbox"/> (2) +13 dBm <input type="checkbox"/> (3) +4 dBm <input type="checkbox"/> (4) +10 dBm				_____	0.82% (rms)	0.02% (rms)
	3400 MHz					_____		
	3500 MHz					_____		
	3600 MHz		_____					
	3700 MHz		_____					
3800 MHz	_____							

\*: Refer to the table below for output level.

Output level	1st RF : 043/143 2nd RF : 073/173	1st RF : 041/141 2nd RF : 071/171
(1)	Not installed	Not installed
(2)	Not installed	Installed
(3)	Installed	Not installed
(4)	Installed	Installed



2nd RF

Setting			Results	Maximum Rating	Uncertainty			
System	Frequency	Output level						
W-CDMA (Test Model 4)	800 MHz	<input type="checkbox"/> (1) +7 dBm <input type="checkbox"/> (2) +13 dBm <input type="checkbox"/> (3) +4 dBm <input type="checkbox"/> (4) +10 dBm	_____	0.62% (rms)	0.02% (rms)			
	900 MHz		_____					
	1800 MHz		_____					
	1900 MHz		_____					
GSM	800 MHz		<input type="checkbox"/> (1) +7 dBm <input type="checkbox"/> (2) +13 dBm <input type="checkbox"/> (3) +4 dBm <input type="checkbox"/> (4) +10 dBm	_____	0.84° (rms)	0.04° (rms)		
	900 MHz			_____				
	1800 MHz			_____				
	1900 MHz			_____				
EDGE	800 MHz			<input type="checkbox"/> (1) +7 dBm <input type="checkbox"/> (2) +13 dBm <input type="checkbox"/> (3) +4 dBm <input type="checkbox"/> (4) +10 dBm	_____	0.84% (rms)	0.04% (rms)	
	900 MHz				_____			
	1800 MHz				_____			
	1900 MHz				_____			
LTE (20 MHz TestModel 3.1)	600 MHz				<input type="checkbox"/> (1) +7 dBm <input type="checkbox"/> (2) +13 dBm <input type="checkbox"/> (3) +4 dBm <input type="checkbox"/> (4) +10 dBm	_____	0.82% (rms)	0.02% (rms)
	800 MHz					_____		
	1500 MHz					_____		
	2000 MHz					_____		
	2400 MHz	_____						
LTE (20 MHz TestModel 3.1)	2700 MHz	<input type="checkbox"/> (1) +7 dBm <input type="checkbox"/> (2) +13 dBm <input type="checkbox"/> (3) +4 dBm <input type="checkbox"/> (4) +10 dBm				_____	0.82% (rms)	0.02% (rms)
	3400 MHz					_____		
	3500 MHz					_____		
	3600 MHz		_____					
	3700 MHz		_____					
LTE (20 MHz TestModel 3.1)	3800 MHz		<input type="checkbox"/> (1) +4 dBm <input type="checkbox"/> (2) +10 dBm <input type="checkbox"/> (3) +1 dBm <input type="checkbox"/> (4) +7 dBm			_____	0.82% (rms)	0.02% (rms)
	3800 MHz					_____		

\*: Refer to the table below for output level.

Output level	1st RF : 043/143 2nd RF : 073/173	1st RF : 041/141 2nd RF : 071/171
(1)	Not installed	Not installed
(2)	Not installed	Installed
(3)	Installed	Not installed
(4)	Installed	Installed



# Appendix E Remote Control

---

This chapter provides an overview of the remote control operation of the MG3710A/MG3740A.

E.1	Overview .....	E-3
E.2	Connection .....	E-4
	E.2.1 GPIB connection .....	E-5
	E.2.2 Ethernet connection .....	E-6
	E.2.3 USB connection .....	E-7
E.3	Interface Settings .....	E-8
	E.3.1 GPIB interface settings .....	E-8
	E.3.2 Ethernet interface settings .....	E-9
	E.3.3 USB interface settings .....	E-15
E.4	Interface Selection/Changing .....	E-16
E.5	Initialization .....	E-17
E.6	Language Mode .....	E-18
	E.6.1 Language mode switching .....	E-18
E.7	SCPI Device Message Details .....	E-19
	E.7.1 SCPI Program message formats .....	E-19
	E.7.2 SCPI Response message formats .....	E-28
	E.7.3 Structure of SCPI command .....	E-31
	E.7.4 Command definition method .....	E-32
	E.7.5 Composition of commands .....	E-33
	E.7.6 Selecting SG1/2 .....	E-33
E.8	Native Device Message Details .....	E-35
	E.8.1 Native Program message formats .....	E-35
	E.8.2 Native Response message formats .....	E-42
	E.8.3 Selecting SG1/2 .....	E-45
E.9	Status Structure .....	E-46
	E.9.1 IEEE488.2 standard status model .....	E-46
	E.9.2 Status Byte (STB) register .....	E-48
	E.9.3 SCPI Device-dependent summary messages .....	E-49
	E.9.4 Native Device-dependent summary messages .....	E-50
	E.9.5 Reading and clearing STB register .....	E-51
	E.9.6 Service Request (SRQ) enable operation .....	E-52
	E.9.7 Standard Event Status register model .....	E-54
	E.9.8 Standard Event Status register operation .....	E-55
	E.9.9 SCPI Specification Status register .....	E-55
	E.9.10 SCPI specification status register operation .....	E-57
	E.9.11 Extended Event Status register .....	E-59
	E.9.12 Extended Error Event Status register .....	

	(Main Application).....	E-60
E.9.13	Extended End Event Status register (Main Application).....	E-61
E.9.14	Extended Error Event Status register (Sub Application) .....	E-62
E.9.15	Extended End Event Status register (Sub Application) .....	E-63
E.9.16	Extended Event Status register operation.....	E-64
E.10	Synchronization .....	E-66
E.11	IEEE488.2 Common Device Messages .....	E-69
E.11.1	IEEE488.2 Common Device Messages List.....	E-69
E.11.2	IEEE488.2 Common Device Messages Details .....	E-71
E.12	SCPI Device Message.....	E-82
E.12.1	OPERation status register.....	E-82
E.12.2	SCPI device message details.....	E-84

## E.1 Overview

Automatic measurement can be performed in combination with an external controller (PC). The MG3710A/MG3740A is equipped with GPIB, Ethernet and USB interfaces as standard. The following functions are supported via these interfaces:

- Control of all functions, except for the power switch
- Reading of all the status and settings
- Interrupts and serial polls

An overview of each interface is shown below:

(1) GPIB

The GPIB interface of the MG3710A/MG3740A conforms to the IEEE488.1/IEEE488.2 standard. The interface functions shown below are supported:

- SH1, AH1, T6, L4, SR1, RL1, PP0, DC1, DT0, C0, E2

(2) Ethernet (1000BASE-T)

The Ethernet interface of the MG3710A/MG3740A can be used as a remote control interface conforming to the VXI-11 protocol using TCP/IP. Control programs can be described using VISA software supporting the VXI-11 protocol. The interface functions shown below are supported:

- SH1, AH1, T6, L4, SR1, RL1, PP0, DC1, DT0, C0

In addition, the Ethernet interface can be controlled by a Raw Socket connection using TCP/IP. Control programs can be described by using the VISA software or a Telnet client supporting Raw Socket connections. Interrupt functions and serial port operation are not supported at Raw Socket connection.

(3) USB

The USB interface of the MG3710A/MG3740A can be used as a remote control interface conforming to the USBTMC-USB488 protocol. Control programs can be described using VISA software supporting the USBTMC-USB488 protocol. The interface functions shown below are supported:

- SH1, AH1, T6, L4, SR1, RL1, PP0, DC1, DT0, C0

## E.2 Connection

Connect the MG3710A/MG3740A and an external controller (PC) to be used for remote control using the dedicated connector for the applicable interface on the rear panel. Connection cables are provided as additional parts with the MG3710A/MG3740A.




Figure E.2-1 Connection port connecting to external controller (PC)

### E.2.1 GPIB connection

Connect the GPIB connector on the rear panel of the MS2690A/MS2691A /MS2692A and an external device using a GPIB cable.

**Note:**

Be sure to connect the GPIB cable before turning power on to the MG3710A/MG3740A. Connecting it while the power is on may damage internal circuits.

Up to 15 devices, including the external controller (PC), can be connected into one MG3710A/MG3740A. Be sure to abide by the conditions shown below when connecting devices.




Figure E.2.1-1 GPIB cable connection

## E.2.2 Ethernet connection

Connect the Ethernet connector on the rear panel and external devices using LAN cables.

**Note:**

Check the network settings before LAN connection. The destination LAN may be affected depending on settings.

Use a LAN crossover cable to connect the MG3710A/MG3740A and an external device. Use a network hub when connecting to multiple external devices.




Figure E.2.2-1 Sample connection with one external device




Figure E.2.2-2 Sample connection with multiple external devices

**Note:**

External devices may experience difficulty in communicating with the MG3710A/MG3740A, depending on the status of communications between them. A LAN crossover-cable connection is recommended to ensure communication stability.



### E.2.3 USB connection

Connect the USB (Remote) connector on the rear panel and external devices using USB cables. The external controller (PC) can be connected to multiple devices via a USB hub, etc.

External controller (PC)




Figure E.2.3-1 Sample connection with one external device




Figure E.2.3-2 Sample connection with multiple external devices

## **E.3 Interface Settings**

This section describes setting methods for the MG3710A/MG3740A and the external controller (PC) for remote control. Connecting a mouse or keyboard may be required to perform settings.

### **E.3.1 GPIB interface settings**

1. Sets the GPIB Address  
Refer to 9.4.1 “Interface Setting” for the setting procedure.  
The Resource Name used during control program description by VISA is as shown below:  
When the GPIB primary address is 1:  
`GPIB0::1::INSTR`
2. Sets the terminator (a terminator code).  
Refer to 9.4.1 “Interface Setting” for how to set it.

### **E.3.2 Ethernet interface settings**

1. Sets the terminator (a terminator code).  
Refer to 9.4.1 “Interface Setting” for how to set it.
2. Sets the Raw Socket Port Number.  
Refer to 9.4.1 “Interface Setting” for how to set it.
3. Confirms and configures the network settings of the MG3710A/MG3740A.

Confirm the IP address, subnet mask, and host name of the Ethernet settings by referring to <How to confirm and set IP address and subnet mask on Windows.> described on the next page.


In case of using Windows VISTA to remotely control MG3710A/MG3740A, the resource name should be described as follows;

When IP Address = 172.168.0.1:  
TCPIP::172.168.0.1::INSTR


<How to confirm and set IP address and subnet mask>

For Windows Embedded

1. Connect a keyboard. Press the Windows key to open the Start menu and then click **Control Panel**. (Or connect a mouse and move the pointer to the bottom of the screen by using it to open the Start menu.) The **Control Panel** window is displayed.




2. On the **Control Panel** window, click **Network Connections** to display the **Network Connections** window. Then click **Local Area Connection** on the **Network Connections** window to display the **Local Area Connection Properties** window.




3. On the **Local Area Connection Properties** window, click **Internet Protocol (TCP/IP)** to display the **Internet Protocol (TCP/IP) Properties** window.

Change the settings according to the connection conditions.




For Windows 7

1. Press the Windows key on the connected keyboard, and click the **Control Panel** from the Start menu. The Start menu is also displayed by moving the pointer of the connected mouse to the bottom of the screen. The **Control Panel** window is displayed.




2. Click **Network and Sharing Center** in the **Control Panel** window to display the **Network and Sharing Center** window. Click **Change adapter settings** on the upper left to display the **Network Connections** window.

Right-click the **Local Area Connection** icon and click **Properties** to display the **Local Area Connection Properties** window.



3. Select the **Internet Protocol Version 4 (TCP/IPv4)** and click **Properties** to display the **Internet Protocol Version 4 (TCP/IPv4) Properties** window. Change the setting to meet the conditions of connection.





### **E.3.3 USB interface settings**

 or **Top** >  > **Utility**


1. Sets the terminator (a terminator code).  
Refer to 9.4.1 “Interface Setting” for how to set it.
2. Check Vendor ID, Product ID, and Serial Number displayed in the USB(B) Settings field.  
Refer to 9.4.3 “Instrument Info” for the setting confirmation procedure.  
The Resource Name used during control program description by VISA is as shown below:


When Vendor ID = 0x0B5B, Product ID = 0x0006, Serial Number = 123456789:

USB0::0x0B5B::0x0006::123456789::INSTR

## **E.4 Interface Selection/Changing**

The MG3710A/MG3740A supports GPIB, Ethernet and USB as remote control interfaces. Only one of these can be used at once.

The interface to be used is determined automatically according to the communication start command received from the external controller (PC) while in Local status. It enters Remote status when the interface is determined.  on the front panel goes off in Local status and lights up in Remote status.

To change the interface, the MG3710A/MG3740A must enter Local status again. Press  on the front panel to enter Local status, then send a command via the desired interface.

## E.5 Initialization

Initialization types and targets for the MG3710A/MG3740A are shown in the table below.

**Table E.5-1 Initialization level**

Item	IFC	DCL/SDC	Power On	*RST	*CLS
Interface bus initialization	√	—	√	—	—
Message exchange initialization • Input buffer and output queue • Message processing and status	—	√	√	—	—
OPC status initialization	—	√	√	√	√
Event status initialization	—	—	—	—	√
Protected settings initialization (Calibration values, Correction values, OS settings, application load/execution status, etc.)	—	—	—	—	—
Initialization of settings saved at power-off	—	—	*	√	—
Initialization of settings not saved at power-off (window status, measurement results, etc.)	—	—	√	√	—

\*: Restores the settings from the last power-off.

- (1) IFC (Interface Clear)
  - Reception of control command IFC from external controller (PC) (GPIB)
  - create\_link request from external controller (PC) (Ethernet)
  - Establishment of USB2.0 link (USB)
  - Pressing of [Local] key
- (2) DCL (Device Clear)/SDC (Selectable Device Clear)
  - Reception of control command, DCL or SDC, from external controller (PC) (GPIB)
  - device\_clear request from external controller (PC) (Ethernet)
  - Reception of INITIATE\_CLEAR from external controller (PC) (USB)
- (3) Power On
  - Power-on of the MG3710A/MG3740A
- (4) \*RST
  - Reception of \*RST command (GPIB/Ethernet/USB)
- (5) \*CLS
  - Reception of \*CLS command (GPIB/Ethernet/USB)

## E.6 Language Mode

As a command to remotely control the MG3710A/MG3740A, you can select SCPI mode, which is a command format defined by the SCPI Consortium, or compatible modes, in which you can use commands for Anritsu's measuring instruments MG3700A, MG364x, MS269xA, and MS2830A.

- **SCPI Mode**  
This is a command format defined by the SCPI Consortium and enables control of instruments offered by various manufacturers following a common rule.
- **MS269xA Mode**  
The commands for the MS269xA Signal Generator application can be used for controlling.
- **MS2830A Mode**  
The commands for the MS2830A Signal Generator application can be used for controlling.
- **MG3700A Mode**  
The commands for the MG3700A Vector Signal Generator can be used for controlling.
- **MG364x Mode**  
The commands for the MG364xA Synthesized Signal Generator can be used for controlling.

Refer to the following descriptions corresponding to your language mode:

SCPI, MS269xA, and MS2830A Modes:

E.7 “SCPI Device Message Details”

MG3700A, MG364x Modes:

E.8 “Native Device Message Details”

Follow the procedure shown below to initialize the language mode to the SCPI mode.

- **Preset All**  
Refer to 9.5.1 “Preset”.
- **Factory Preset**  
Refer to 9.4.4 “Install”.
- **System Recovery Functions**  
Refer to 9.7.6 “System Recovery Functions”.

### E.6.1 Language mode switching

 or **Top** >  > **Utility**


Refer to 9.4.1 “Interface Setting” for language switch.

## E.7 SCPI Device Message Details

### E.7.1 SCPI Program message formats

Among all device messages, those that are transmitted from the external controller (PC) to the MG3710A/MG3740A are called “program messages”. Program messages fall into two groups: program commands, which set or specify instrument parameters, and program queries, which request parameters and measurement results.

An example of transmitting a program message from the external controller (PC) program to the MG3710A/MG3740A with a PRINT or any other statement is shown below.




PRINT @1;“MEAS:ACP?”

↑ Program message


A program message, when transmitted from the external controller (PC) to this unit, is terminated by a specified terminator.

Program Message Terminator



CR (Carriage Return) is ignored without being processed as a terminator.


Program message




<Example>  
PRINT @1; "CONF:ACP;READ:ACP?"

Multiple commands can be transmitted separately by separating them with semicolons (";").


Program message unit



Program header




Control header




Short Form data corresponds to the short form of SCPI. Long Form data corresponds to the long form of SCPI. Refer to the character program data for each specification. The numeric data is specified as a single ASCII code byte indicating any value within the range of numeric data, from 0 to 9.0.

Common command header



The common command header is denoted by an asterisk (\*) before the character program data.

Program data




Character program data

Defined strings of data are composed of any of the lowercase and uppercase alphanumeric characters A to Z and 0 to 9, and the underscore (“\_”).

Numeric program data

Numeric program data is grouped into four types: integral (NR1), fixed-point decimal (NR2), floating-point decimal (NR3), and hexadecimal formats.


Integral (NR1)



- Integral data can have leading zeros (e.g., 005, +005, -20).
- No space is allowed between a sign (+ or -) and the numeric value that follows it.
- The plus (“+”) sign can be omitted (e.g., 005, +005, -20).




Fixed-point decimal (NR2)



- An integer is represented in the integral part.
- No space is allowed between a digit and the decimal point that follows it.
- The plus (“+”) sign can be omitted.
- The digit 0 in the integral part may be omitted.
- Any number of zeros, including none, may precede the numeric value in the integral part (e.g., -0.5, +00204, -5).

Floating-point decimal (NR3)




- E denotes the power of 10, or the exponent.
- Spaces are allowed both before and after, only before or only after E/e.
- A numeric value is required in the mantissa.
- Alternatively selectable numeric values (ex. 1|2) and character strings are unavailable.
- The plus (“+”) sign can be omitted (from both the mantissa and the exponent).

<Examples>


$$-22.34E+6 \rightarrow -22.34 \times 10^6 (= -22,340,000)$$

$$5.3e-4 \rightarrow 5.3 \times 10^{-4} (= 0.00053)$$

Hexadecimal data



Binary data



Suffix data

The table below lists the suffix data that is used in the MG3710A/MG3740A.


The suffix codes available vary depending on the function.

**Table E.7.1-1 Suffix codes**

<b>Category</b>	<b>Suffix Code</b>	<b>Unit</b>
Frequency	GHZ or GZ	GHz
	MHZ or MZ	MHz
	KHZ or KZ	kHz
	HZ	Hz
Level	DB	dB
	DBM or DM	dBm
	DBUV	dB $\mu$ V
	DBUVE	dB $\mu$ V (emf)
	V MV UV	V mV $\mu$ V
Time	S	s
	MS	ms
	US	$\mu$ s
	NS	ns
	PS	ps
Angle	DEG	degree
Percent	PCT	%

String program data

An arbitrary character string is enclosed by one pair of double quotation marks (“ ”) or single quotation marks (‘ ’). The characters that can be used vary depending on their function.




Logic program data


Logical program data indicates a logical value by the program data specified in SCPI. On/off of character program data and 1/0 of numeric program data are defined as values corresponding to true/false.

### E.7.2 SCPI Response message formats

The formats in which the external controller (PC) transmits response messages from the MG3710A/MG3740A by way of INPUT and other statements are described below.




Response message




A response message is composed of one or more response message units to one or more program queries issued with one PRINT statement.

Response Message Terminator




Use a  
' :SYSTem:COMMunicate:GPIB[1] [:SELF]:DELimiter'  
command to specify the terminator format.

Response Unit



Response unit has no header and only returns the data of the measurement data.


Response data



Character response data

Defined strings of data are composed of any of the lowercase and uppercase alphanumeric characters A to Z and the digits 0 to 9, and the underscore (“\_”).

Numeric response data  
Integer (NR1)




- The leading digit must be non-zero.

<Examples>

123, -1234

Fixed-point decimal (NR2)




- The leading digit must be non-zero.
- A fixed-point decimal number having a value of 0 in its decimal place is output as an integer.


<Examples>

12.34, -12.345


Hexadecimal data



Binary data




String response data





### E.7.3 Structure of SCPI command

The SCPI commands are based on a layered structure. The commands are grouped according to their related functions, and each of them has a layer structure called a “sub-system”.



Example of SCPI command tree

Although the same header may be in the commands, it corresponds to each function, according to the position of the header. Therefore, the commands need to be described with all the headers available on the full path.

## E.7.4 Command definition method

```
:SENSe:FREQUency:CENTer <freq>  
:SENSe:FREQUency:CENTer?  
:SENSe:FREQUency:SPAN <freq>  
:SENSe:FREQUency:SPAN?
```

Example of SCPI command

The command tree in the previous page comprises the SCPI commands listed above. Overviews of the SCPI command definitions are shown below.

### <Command Format>

The command starts with a colon (“:”), and the commands are configured by consolidating a header with a header by a colon (“:”).

### <Omission format of header>

The headers have both a short and a long form, the short form being an abbreviated version of the long form. The commands are interpreted as being the same, regardless of whether the short or long form is used (both can be used at the same time). Uppercase and lower case alphabetic characters are used in this manual to distinguish between the short and long forms. (Uppercase letters denote the short form.) It should be noted that the headers are not case sensitive.

Example:

```
long form           > :SENSe:FREQUency:CENTer 1000000  
short form          > :SENS:FREQ:CENT 1000000  
long + short form   > :SENSe:FREQ:CENTer 1000000
```

### <Option Node>

[ ] indicates an Option Node.

A header enclosed by square brackets (“[ ]”) may be omitted, and is treated as the same command whether omitted or not.

Example:

```
:STATus:OPERation:[EVENT]?  
When the header is not omitted > :STATus:OPERation:EVENT?  
When the header is omitted     > :STATus:OPERation?
```

**<Header Separator>**

There must be at least one space between a command and a parameter. Furthermore, if there is more than one parameter, they need to be separated by commas.

**E.7.5 Composition of commands**

As in the following examples, commands can be combined by a semi-colon (“;”). The second command is referred to as the same level as the bottom layer of the first command. Thus, the second command can be described as in Example 1, or can be described without the upper header over FREQUENCY, as in Example 2.

Example 1:                    >:SENSE:FREQUENCY:CENTer 1000000  
                                  :SENSe:FREQUENCY:SPAN 500000

Example 2:                    >:SENSE:FREQUENCY:CENTer 1000000;SPAN  
                                  500000

**E.7.6 Selecting SG1/2**

Two SGs can be installed on the MG3710A/MG3740A. When the language mode is SCPI, the target SG can be selected with the beginning node of commands for controlling individual functions.

To specify the target SG:

Specify the beginning node of command

```
":SOURce[1]|2",":MMEMemory[1]|2",":OUTPut[1]|2,"
```

```
":UNIT[1]|2",":INITiate[1]|2",":CALibration[1]|2"
```

as shown below.

To select SG1:

```
":SOURce1",":MMEMemory1",":OUTPut1",":INITiate1",":UNIT1",  
":CALibration1" or
```

```
":SOURce",":MMEMemory",":OUTPut",":INITiate",":UNIT",":CAL  
ibration"
```

To select SG2:

```
:SOURce2, :MMEMemory2, :OUTPut2, :INITiate2, :UNIT2, :CALibratio  
n2
```

To control active SG:

Omit (if possible)

To activate SG, use the following command:

```
[ :SOURce ] :PORT 1|2
```

The commands for specifying frequencies are provided examples.

```
[ :SOURce[1]|2]:FREQuency[:CW|:FIXed] <freq>
```

**Example 1:** To select 1 GHz for the frequency of SG1

```
SOUR1:FREQ:CW 1GHZ, or SOUR:FREQ:CW 1GHZ
```

**Example 2:** To select 2 GHz for the frequency of SG2

```
SOUR2:FREQ:CW 2GHZ
```

**Example 3:** To activate SG2 and select 3 GHz for the frequency of SG2

```
PORT 2
```


```
FREQ:CW 3GHZ
```

## E.8 Native Device Message Details

### E.8.1 Native Program message formats

Among all device messages, those that are transmitted from the external controller (PC) to the MG3710A/MG3740A are called “program messages”. Program messages fall into two groups: program commands, which set or specify instrument parameters, and program queries, which request parameters and measurement results.

An example of transmitting a program message from the external controller (PC) program to the MG3710A/MG3740A with a PRINT or any other statement is shown below.




PRINT @1;"CNF 1GHZ"

↑ Program message


A program message, when transmitted from the external controller (PC) to this unit, is terminated by a specified terminator.

Program message terminator



CR (Carriage Return) is ignored without being processed as a terminator.


Program message



<Example>  
PRINT @1;"CNF 1GHZ;RLV 0DBM"


Multiple commands can be transmitted separately by separating them with semicolons (;).

Program message unit



The program header of each IEEE488.2 common command begins with an asterisk (\*). The program header of each program query (query) generally ends with a question mark (?).

Program data



Character program data

Defined strings of data are composed of any of the alphabetical lower-case and upper-case characters A to Z, the digits 0 through 9, and the underscore (\_).

<Examples>

LOAD SIGANA

Loads the Signal Analyzer.


SOUND OFF

Sets sound to Off.

Numeric program data


Numeric program data is grouped into four types: integral (NR1), fixed-point decimal (NR2), floating-point decimal (NR3), and hexadecimal.

Integral (NR1)




- Integral data can have leading zeros (e.g., 005, +005).
- No space is allowed between a sign (+ or -) and the numeric value that follows it.
- The “+” sign can be omitted (e.g., 005, +005).

Fixed-point decimal (NR2)



- An integer is represented in the integral part.
- No space is allowed between a digit and the decimal point that follows it.
- The “+” sign can be omitted.
- The digit 0 in the integral part may be omitted.
- Any number of zeros may precede the numeric value in the integral part (e.g., -0.5, +00204, -5).

Floating-point decimal (NR3)



- E denotes the power of 10, or the exponent.
- Spaces are allowed both before and after, only before or only after E/e.
- A numeric value is required in the mantissa.
- Alternatively selectable numeric values (ex. 1|2) and character strings are unavailable.
- The “+” sign can be omitted (from both the mantissa and exponent).


<Examples>

$$-22.34E+6 \rightarrow -22.34 \times 10^6 (= -22,340,000)$$


$$5.3e-4 \rightarrow 5.3 \times 10^{-4} (= 0.00053)$$



Hexadecimal data



Binary data



Suffix data


The table below lists the suffix data that is used.  
 The suffix codes available vary depending on the function.

**Table E.8.1-1 Suffix codes**

Category	Suffix Code	Unit
Frequency	GHZ or GZ	GHz
	MHZ or MZ	MHz
	KHZ or KZ	kHz
	HZ	Hz
Level	DB	dB
	DBM or DM	dBm
	DBUV	dB $\mu$ V
	DBUVEMF	dB $\mu$ V (emf)
	V	V
	MV	mV
	UV	$\mu$ V
	DBUV	dB $\mu$ V
	DBUVE	dB $\mu$ V (emf)
	V	V
	MV	mV
	UV	$\mu$ V
Time	S	s
	MS	ms
	US	$\mu$ s
	NS	ns
Angle	DEG	degree
Percent	PCT	%


String program data

Arbitrary character string enclosed by one pair of “” (double quotation marks) or ‘ ’ (single quotation marks). The characters that can be used vary depending on the function.




### E.8.2 Native Response message formats

The formats in which the external controller (PC) transmits response messages from the MG3710A/MG3740A by way of INPUT and other statements are described below.




Response message




A response message is composed of one or more response message units to one or more program queries issued with one PRINT statement.

Response message terminator



Use a TRM command to specify the terminator format.

Response data




Character response data

Defined strings of data are composed of any of the alphabetical lower case and upper case characters A to Z, the digits 0 through 9, and the underscore (\_).

Numeric response data

Integer (NR1)




- The leading digit must be non-zero.

<Examples>

123, -1234

Fixed-point decimal (NR2)




- The leading digit must be non-zero.
- A fixed-point decimal number having a value of 0 in its decimal place is output as an integer.


<Examples>

12.34, -12.345


Hexadecimal data



Binary data



String response data



### **E.8.3 Selecting SG1/2**

Two SGs can be installed on the MG3710A/MG3740A. When the language mode is Native, individual functions of active SG are controlled.

To activate SG, use the following command:

```
SELECTSG 1|2
```

Refer to Appendix F.1.1 “Functions Device Messages Common to Measurement Equipment”.

**Example:** To select 1 GHz for the frequency of SG1

```
SELECTSG 1  
FREQ 1GHZ
```

## E.9 Status Structure

The Status Byte (STB) that is transmitted to the external controller (PC) complies with the IEEE488.1 standard. Its bit string, called a “status summary message,” provides summary information about the current data placed in a register or queue.

### E.9.1 IEEE488.2 standard status model

The standard model of the status structure defined by IEEE488.2 is shown below.




Figure E.9.1-1 IEEE488.2 standard status model



In the status model, an IEEE488.1 status byte is used as the lowest-level status, which consists of seven summary message bits that are supplied from an upper status structure. The status data structure is organized into a register model and a queue model to generate these summary message bits.

**Table E.9.1-1 Register model and queue model**

Register model	Queue model
A set of registers used to keep a record of the events and conditions that have been encountered in the device. Its structure is built of an Event Status register and an Event Status Enable register. If their AND operation results in non-zero, the corresponding bit of the status byte is set to 1; otherwise, it is set to 0. If their OR operation results in 1, the corresponding summary bit is set to 1; otherwise, it is set to 0.	A queue used to keep a sequential record of status or information. In the queue structure, a bit is set to 1 only if data exists at the corresponding position in the queue; otherwise, a bit is 0.

On the basis of the register model and the queue model thus described, the standard model in the IEEE488.2 status data structure is assembled of two kinds of register models and one queue model.

- <1> Standard Event Status register and Event Status Enable register
- <2> Status Byte register and Standard Event Enable register
- <3> Output queue

**Table E.9.1-2 Register models and queue model of IEEE488.2 standard status**

Standard Event Status Register	Status Byte Register	Output Queue
The Standard Event Status register is structured in the register model described above. Among all the events that the device may encounter, this register holds bits that represent eight kinds of standard events: <1> power-on, <2> user request, <3> command error, <4> execution error, <5> device-dependent error, <6> query error, <7> bus control request, and <8> operation complete. Bit6 (DIO6) of the Status Byte Register works as an OR output bit to report an Event Summary Bit (ESB) summary message.	The Status Byte register holds an RQS bit seven summary message bits from the status data structure. Bit6 (DIO7) of the Service Request Enable register is system-reserved as an RQS bit to report a service request to the external controller. The mechanism of this SRQ conforms to the specifications of IEEE488.1.	The Output Queue is structured in the queue model described above. Bit4 (DIO5) of the Status Byte Register works as a Message Available (MAV) summary message to report the availability of data in the output buffer.

## **E.9.2 Status Byte (STB) register**

The STB register consists of an STB device and an RQS (or MSS) message.

### (1) ESB and MAV summary messages

The ESB and MAV summary messages are described below.

#### **ESB summary message**

The ESB (Event Summary Bit) summary message is a message defined by IEEE488.2. It is reported by STB register bit5. The ESB summary message is set to 1 when any one of the bits registered in the Standard Event Status register is set to 1 where event occurrence is enabled. The ESB summary bit is, in turn, set to 0 when none of the events registered in the Status Event Status register occur where event occurrence is enabled.

#### **MAV summary message**

The MAV (Message Available) summary message is a message defined by IEEE488.2. It is reported by STB register bit4. This bit indicates whether the output queue is empty. It is used by the device to synchronize message exchanges with the external controller (PC). For example, the external controller (PC) might transmit a query command to the device and wait for MAV to be set to 1. If reading from the output queue is begun without first checking MAV, all system bus actions are deferred until the device responds.

### E.9.3 SCPI Device-dependent summary messages

The structure of the status byte register is as shown below when the SCPI mode is selected.




Figure E.9.3-1 Status byte register in SCPI mode

### E.9.4 Native Device-dependent summary messages

When language mode is Native, in addition to the Status Bite Register defined by IEEE488.2, Extended Event Status Bits (EESB) are defined individually. EESB 0 to 3 are used as summary bits for application-specific Extended Event Status registers.

Both LEESB3 and EESB2 correspond to the event status expansion of main application (SG1) of the MG3710A/MG3740A, and also both EESB1 and EESB0 correspond to that of the sub-application (SG2) of the MG3710A/MG3740A.




Figure E.9.4-1 Status byte register in Native mode

### **E.9.5 Reading and clearing STB register**

The STB register is read by serial polling or by using an \*STB? query. Either way, an STB message as defined by IEEE488.1 is read, but the value that is transmitted to bit6 (position) varies with each method used. The STB register can be cleared using the \*CLS command.

#### **Use Serial Polling to read STB register**

If serial polling is implemented under IEEE488.1, a 7-bit status byte and an RQS message bit based on IEEE488.1 are returned. Serial polling does not alter the value of the status byte. The device will set the RQS message bit to 0 immediately on polling.

#### **Use an \*STB Common Query to read STB register**

Issuing an \*STB common query causes the device to transmit a response message, in the integer format, comprising the MSS (Master Summary Status) message in the STB register. Hence, a response to \*STB? matches one to serial polling, except that an MSS summary message appears at the bit6 position, instead of an RQS message.

#### **Define \*MSS (Master Summary Status)**

The MSS message indicates that the device has at least one service request condition. The MSS message appears at the bit6 position as a device response to an \*STB query, but not as a response to serial polling. It must not be viewed as part of the IEEE488.1 status byte. MSS consists of total OR which is the combination of the bits of the STB register and the SRQ Enable (SRE) register with one another.

#### **Use the \*CLS Common Command to clear STB register**

The \*CLS common command clears the entire status structure and also summary messages responding to it. The execution of \*CLS does not affect the settings of the enable registers.

### E.9.6 Service Request (SRQ) enable operation

Bits 0 to 7 of the Service Request Enable (SRE) register control whether the corresponding bits of the STB register will generate an SRQ. The SRB register bits are associated with the STB register bits. If the STB register bit associated with a SRE register bit that is 1 is set to 1, the device sets the RQS bit to 1, issuing a service request to the external controller (PC).




Table E.9.6-1 Service Request (SRQ) Enable Operation (SCPI Mode)




Table E.9.6-2 Service Request (SRQ) Enable Operation (Native Mode)

Read from SRE register

The SRE register is read using an `*SRE?` common query. A response message to this query is given as an integer between 0 and 255, equaling the sum of the values of the SRE register bits.

Update SRE register

The SRE register is written to using an `*SRE` common command with an integer between 0 and 255 as a parameter and with the SRE register bits being set to 0 or 1. The value of bit6 is ignored.

### E.9.7 Standard Event Status register model

Bit definitions of Standard Event Status register

The operations of the Standard Event Status register are shown below.




Figure E.9.7-1 Standard event status register

The Standard Event Status Enable (ESE) register specifies which bit of the Event Status register will cause a summary message to become true when it is set.

Table E.9.7-1 Bit events

bit	Event name	Description
7	Power on (PON)	Power transition from Off to On
6	User Request	Transition from Remote to Local
5	Command error (CME)	Device message with illegal header received
4	Execution error (EXE)	Device message with illegal parameter received or the executed function has not completed normally
3	Device-dependent error (DDE)	Error caused by a condition other than CME, EXE, and QYE
2	Query error (QYE)	Attempt to read data from the output queue when it is empty or queued data lost before it is read
1	Not used	—
0	Operation complete (OPC)	Set to 1 when the MG3710A/MG3740A has processed the *OPC command.



### E.9.8 Standard Event Status register operation

The operation methods for the Standard Event Status registers and Standard Event Status Enable registers are shown in the table below.

**Table E.9.8-1 Standard Event Status register operation**

Register	Operation	
Standard Event Status register	Read	This register is read using an *ESR? common query.
	Write	This register cannot be written externally.
	Clear	This register is cleared when: <1> The *CLS command is received. <2> The power is turned on (bit7 is turned on, with all other bits being cleared to 0). <3> An event is read in response to an *ESR? query command.
Standard Event Status Enable register	Read	This register is read using an *ESE? common query.
	Write	This register is written to using an *ESE common command.
	Clear	This register is cleared when: <1> An *ESE command with a data value of 0 is received. <2> The power is turned on.

### E.9.9 SCPI Specification Status register

The following registers are available, in addition to the status register specified in IEEE488.2 by the specification of SCPI in the SCPI mode.

**Table E.9.9-1 SCPI Specification Status registers**

Register-Filter	Operation
QUEStionable Status register	Reports the status of signals such as measurement results. It is used to require service to external controller when an error occurs. It is not used in MG3710A/MG3740A.
OPERation Status register	Reports some of the statuses of MG3710A/MG3740A.

The SCPI specification status register has the following configuration.




Figure E.9.9-1 Configuration of SCPI Specification Status Register

Table E.9.9-2 SCPI Specification Status register configurations

Register-Filter	Operation
Condition Register	Monitors device status and changes depending on the device status. Therefore, this register does not store the status.
Transition Filter	Sets the contents of the condition register to the event register. The transition filter has the three types shown below, according to what change of the condition register is measured. <ol style="list-style-type: none"> <li>(1) Positive direction change The event becomes true only when the corresponding condition changes false into true.</li> <li>(2) Negative direction change The event becomes true only when the corresponding condition changes from true into false.</li> <li>(3) Both direction change The event becomes true when a change in either the positive or negative direction is present.</li> </ol>
Event Register	Stores the output of transition filter.
Event Enable Register	Selects which bit of the corresponding event register is used to set the summary message to true when set to 1.

### E.9.10 SCPI specification status register operation

How to operate the SCPI specification status register and error/event queue is shown below.

**Table E.9.10-1 SCPI Status register operation**

Register	Operation	
SCPI event register (Main Application)	Read	:STATus:...:EVENT? This register is read using a query.
	Write	This register cannot be written externally.
	Clear	This register is cleared when: (1) *CLS command is received. (2) The power is On. (3) An event is read in response to :STATus:...:EVENT? Query command. (4) A language mode is switched.
SCPI enable register (Main Application)	Read	:STATus:...:ENABLE? This register is read by using an query.
	Write	:STATus:...:ENABLE This register is written by using a command.
	Clear	This register is cleared when: (1) :STATus:PRESet command is received. (2) The power is On. (3) :STATus:...:ENABLE 0 command is received. (4) A language mode is switched.

**Table E.9.10-1 SCPI Status register operation (Cont'd)**

Register	Operation	
SCPI Transition Filter (Main Application)	Read	:STATus:...:PTRansition? :STATus:...:NTRansition? This register is read using a query.
	Write	:STATus:...:PTRansition :STATus:...:NTRansition This register is written using a command.
	Clear	This register is cleared when. (1) :STATus:PRESet command is received. (2) The power is on. (3) :STATus:...:PTRansition 0 command is received. (4) A language mode is switched.
Error/Event Queue (Main Application)	Read	:SYSTem:ERRor? This register is read using a query.
	Write	This register cannot be written externally.
	Clear	This register is cleared when: (1) *CLS command is received. (2) The power is on. (3) An event is read in response to :SYSTem:ERRor? Query command. (4) A language mode is switched.

The values after the register and filter influenced by :STATus:PRESet have been reset are shown in the following table.

**Table E.9.10-2 Values after the register and filter influenced by :STATus:PRESet have been reset.**

Register	Enable Filter	Reset Value
OPERational Status Register	Enable Register	All 0
QUEStionable Status Register	PTRansition Filter	All 1
	NTRansition Filter	All 0

### E.9.11 Extended Event Status register

When the language mode is Native, the application running on the MG3710A/MG3740A has a specific extended event status register and an enable register.

The extended event status register transmits a summary message to EESB0 to EESB3 bits of the status byte register. This allows you to detect events of two applications running on the MG3710A/MG3740A using service requests.

In general, the applications are categorized into Main Application (1st SG) and Sub Application (2nd SG).

Summary messages of the extended event status register of Main Application are transmitted to EESB3 and EESB2 of the status byte register.

Summary messages of the extended event status register of Sub Application are transmitted to EESB1 and EESB0 of the status byte register.




Figure E.9.11-1 Extended event status register model

### E.9.12 Extended Error Event Status register (Main Application)

The operation model of the Extended Error Event Status registers for the Main Applications is shown below.

Main Application indicates 1st SG. The target of the status register and the enable register is 1st SG.




Figure E.9.12-1 Extended Error Event Status register (Main Application)

The Extended Error Event Status Enable register (on the left of the figure above) specifies which bit of the Event Status register will cause a summary message to become true when it is set.

For specifications of the event status register on the right side of the above figure, refer to Appendix F.1 “Native Device Messages”.

The summary message of this register is transmitted to EESB 3 of the Status Byte register.

<Program example>

To generate a service request when the error event 0 of 1st SG occurs

```
*SRE 8 ; Enables bit3 of the Service Request Enable register.
ESE3 1 ; Enables bit0 of the Extended Error Event Status Enable register of the main application.
```

### E.9.13 Extended End Event Status register (Main Application)

The operation model of the Extended End Event Status registers of Main Applications is shown below.

Main Application indicates 1st SG. The target of the status register and the enable register is 1st SG.




Figure E.9.13-1 Extended End Event Status register (Main Application)

The Extended End Event Status Enable register (on the left of the figure above) specifies which bit of the Event Status register will cause a summary message to become true when it is set.

For specifications of the event status register on the right side of the above figure, refer to Appendix F.1 “Native Device Messages”.

The summary message of this register is transmitted to EESB 2 of the Status Byte register.

<Program example>

To generate a service request when the end event 0 of 1st SG occurs

```
*SRE 4           ; Enables bit2 of the Service Request
                  Enable register.
ESE2 1           ; Enables bit0 of the Extended End Event
                  Status Enable register of the main
                  application.
```

### E.9.14 Extended Error Event Status register (Sub Application)

The operation model of the Extended Error Event Status registers for Sub Applications (an example with Application a) is shown below.

Sub Application indicates 2nd SG. The target of the status register and the enable register is 2nd SG.




Figure E.9.14-1 Extended Error Event Status Register (Sub Application)

The Extended Error Event Status Enable register (on the left of the figure above) specifies which bit of the Event Status register will cause a summary message to become true when it is set.

For specifications of the event status register on the right side of the above figure, refer to Appendix F.1 “Native Device Messages”.

The summary message of this register is transmitted to EESB 1 of the Status Byte register.

<Program example>

To generate a service request when the error event 0 of 2nd SG occurs

- \*SRE 2 ; Enables bit1 of the Service Request Enable register.
- ESE1 1 ; Enables bit0 of the extended error event status enable register of Sub Application.



### E.9.15 Extended End Event Status register (Sub Application)

The operation model of the Extended End Event Status registers of Sub Applications (an example with Application a) is shown below.

Sub Application indicates 2nd SG. The target of the status register and the enable register is 2nd SG.




Figure E.9.15-1 Extended End Event Status Register (Sub Application)

The Extended End Event Status Enable register (on the left of the figure above) specifies which bit of the Event Status register will cause a summary message to become true when it is set.

For specifications of the event status register on the right side of the above figure, refer to Appendix F.1 “Native Device Messages”.

The summary message of this register is transmitted to EESB 0 of the Status Byte register.

<Program example>

To generate a service request when the end event 0 of 2nd SG occurs

- \*SRE 1 ; Enables bit0 of the Service Request Enable register.
- ESE0 1 ; Enables bit0 of the extended end event status enable register of Sub Application.

### E.9.16 Extended Event Status register operation

The operation methods for the Extended Event Status registers and Extended Event Status Enable registers are shown in the table below.

**Table E.9.16-1 Extended Event Status Register Operation**

Register	Operation	
Extended Error Event Status Register (Main Application)	Read	This register is read using an ESR3? query.
	Write	This register cannot be written externally.
	Clear	This register is cleared when: <1> The *CLS command is received. <2> The power is turned on. <3> An event is read in response to an ESR3? query command. <4> When the language mode has been switched.
Extended Error Event Status Enable Register (Main Application)	Read	This register is read using an ESE3? query.
	Write	This register is written to using an ESE3 command.
	Clear	This register is cleared when: <1> An ESE3 command with a data value of 0 (i.e., ESE3 0) is received. <2> The power is turned on. <3> When the language mode has been switched.
Extended End Event Status Register (Main Application)	Read	This register is read using an ESR2? query.
	Write	This register cannot be written externally.
	Clear	This register is cleared when: <1> The *CLS command is received. <2> The power is turned on. <3> An event is read in response to an ESR2? query command. <4> When the language mode has been switched.
Extended End Event Status Enable Register (Main Application)	Read	This register is read using an ESE2? query.
	Write	This register is written to using an ESE2 command.
	Clear	This register is cleared when: <1> An ESE2 command with a data value of 0 (i.e., ESE2 0) is received. <2> The power is turned on. <3> When the language mode has been switched.

Table E.9.16-1 Extended Event Status Register Operation (Cont'd)

Register	Operation	
Extended Error Event Status Register (Sub Application)	Read	This register is read using an ESR1? query.
	Write	This register cannot be written externally.
	Clear	This register is cleared when: <1> The *CLS command is received. <2> The power is turned on. <3> An event is read in response to an ESR1? query command. <4> When the language mode has been switched.
Extended Error Event Status Enable Register (Sub Application)	Read	This register is read using an ESE1? query.
	Write	This register is written to using an ESE1 command.
	Clear	This register is cleared when: <1> An ESE1 command with a data value of 0 (i.e., ESE1 0) is received. <2> The power is turned on. <3> When the language mode has been switched.
Extended End Event Status Register (Sub Application)	Read	This register is read using an ESR0? query.
	Write	This register cannot be written externally.
	Clear	This register is cleared when: <1> The *CLS command is received. <2> The power is turned on. <3> An event is read in response to an ESR0? query command. <4> When the language mode has been switched.
Extended End Event Status Enable Register (Sub Application)	Read	This register is read using an ESE0? query.
	Write	This register is written to using an ESE0 command.
	Clear	This register is cleared when: <1> An ESE0 command with a data value of 0 (i.e., ESE0 0) is received. <2> The power is turned on. <3> When the language mode has been switched.

## E.10 Synchronization

This section describes synchronized control of the MG3710A/MG3740A (completing processing of a command message before proceeding to the next one).

The following methods can be used for controlling synchronization:

- (1) Using the \*WAI command
- (2) Using the \*OPC command
- (3) Using the \*OPC? query

(1) Using the \*WAI command

The \*WAI (Wait to Continue) command prevents from starting the subsequent operations before the transmitted commands completes their operations. This is an effective method when an overlap command is used.

<Program example>

To select a waveform pattern after loading of a waveform pattern completes

This example uses the following overlap command:

```
:MMEMory[1]|2:LOAD:WAVEform:WMA|WMB|LONG|COMBination  
<string1>,<string2>[,<device>]
```

```
MMEM:LOAD:WAV:WMA           ; Loads a waveform  
"PackageName","PatternName" ; pattern.  
*WAI                         ; Waits until loading  
                             ; completes.  
RAD:ARB:WMA:WAV             ; Selects a waveform  
"PackageName","PatternName" ; pattern.
```

(2) Using the \*OPC

This method transmits \*OPC (Operation Complete), which is the IEEE488.2 common command, to wait until bit0 (OPC) of the standard event status register is enabled, indicating the operation completes. To wait an event, query a standard event status register directly or use a service request.

<Program example>

To select a waveform pattern after loading of a waveform pattern completes

This example uses the following overlap command:

```
:MMEMory[1] | 2:LOAD:WAVEform:WMA|WMB|LONG|COMBination  
<string1>,<string2>[,<device>]
```

```
*CLS ; Clears the OPC status.  
MMEM:LOAD:WAV:WMA ; Loads a waveform  
"PackageName","PatternName" pattern.  
*OPC ; Switches to the  
operation completion  
waiting status.  
*ESR? ; Queries the standard  
event status register  
directly.  
>0 ; No event occurred.  
*ESR? ; Queries the standard  
event status register  
directly.  
>1 ; An event occurred.  
RAD:ARB:WMA:WAV ; Selects a waveform  
"PackageName","PatternName" pattern.
```

(3) Using the \*OPC?

This method queries a response of \*OPC? (Operation Complete Query), which is the IEEE488.2 common command.

<Program example>

To select a waveform pattern after loading of a waveform pattern completes

This example uses the following overlap command:

```
:MMEMory[1]|2:LOAD:WAVEform:WMA|WMB|LONG|COMBination  
<string1>,<string2>[,<device>]
```

MMEM:LOAD:WAV:WMA	; Loads a waveform
"PackageName", "PatternName"	pattern.
*OPC?	; Switches to the
	operation completion
	waiting status.
>1	; Returns 1 if lading
	completes.
RAD:ARB:WMA:WAV	; Selects a waveform
"PackageName", "PatternName"	pattern.

## E.11 IEEE488.2 Common Device Messages

Described below are the IEEE488.2 Common Device Messages intended to execute the functions of the MG3710A/MG3740A.

### E.11.1 IEEE488.2 Common Device Messages List

Table E.11-1 IEEE488.2 Common Device Messages

Function	Command	Query	Response	Remarks
Identification Query	---	*IDN?	company, model, serial number, firmware	model: Main unit model name serial: Main unit serial number version: Software package version
Self Test Query	---	*TST?	n	n = bit7 : ALC Alarm bit6 : Internal Baseband Reference Clock Unlock bit5 : Not used bit4 : Internal Reference Frequency Unlock bit3 : RPP generation bit2 : Not used bit1 : Not used bit0 : Not used
Operation Complete	*OPC	*OPC?	1	
Preset All	*RST	---	---	
Wait to Continue Command	*WAI	---	---	
Clear Status Command	*CLS	---	---	
Standard Event Status Enable Register Command/Query	*ESE n	*ESE?	n	n = bit7 : Power On bit6 : User request
Standard Event Status Register Query	---	*ESR?	n	bit5 : Command error bit4 : Execution error bit3 : Device error bit2 : Query error bit1 : Not used bit0 : Operation complete

Table E.11-1 IEEE488.2 Common Device Messages (Continued)

Function	Command	Query	Response	Remarks
Service Request Enable Register Command/Query	*SRE n	*SRE?	n	n = SCPI mode bit7 : OPER bit6 : MSS/RQS bit5 : ESB bit4 : MAV bit3 : QUES bit2 : QUE bit1 : Not used bit0 : Not used Native mode bit7 : Not used bit6 : MSS/RQS bit5 : ESB bit4 : MAV bit3 : EESB3 bit2 : EESB2 bit1 : EESB1 bit0 : EESB0
Read Status Byte Query	---	*STB?	n	n = SCPI mode bit7 : OPER bit6 : MSS/RQS bit5 : ESB bit4 : MAV bit3 : QUES bit2 : QUE bit1 : Not used bit0 : Not used Native mode bit7 : Not used bit6 : MSS/RQS bit5 : ESB bit4 : MAV bit3 : EESB3 bit2 : EESB2 bit1 : EESB1 bit0 : EESB0
Trigger Control	*TRG	---	---	



## **E.11.2 IEEE488.2 Common Device Messages Details**

This section describes detailed specifications on IEEE488.2 common device message remote control commands for executing MG3710A/MG3740A functions in alphabetical order.

### **\*CLS**

Clear Status Command

Function

Clears the status byte register, standard event status register, extended event status register and output queue data, and disables the wait for operation completion set by \*OPC/\*OPC?. This is a common IEEE488.2 command.

Command

\*CLS

Example of Use

To clear status

## \*ESE/\*ESE?

Standard Event Status Enable Command/Query

### Function

Sets the standard event status enable register. The standard event status enable register value is returned for the query. This is a common IEEE488.2 command/query.

### Command

\*ESE n

### Query

\*ESE?

### Response

n

### Parameter

n Standard event status enable register  
Value = bit0 + bit1 + bit2 + bit3 + bit4 + bit5 + bit6 + bit7  
bit0 : 2<sup>0</sup> = 1      Operation completion  
bit1 : 2<sup>1</sup> = 2      Request control (not used)  
bit2 : 2<sup>2</sup> = 4      Query error  
bit3 : 2<sup>3</sup> = 8      Device error  
bit4 : 2<sup>4</sup> = 16     Execution error  
bit5 : 2<sup>5</sup> = 32     Command error  
bit6 : 2<sup>6</sup> = 64     User request  
bit7 : 2<sup>7</sup> = 128    Power ON  
Range 0 to 255  
Default 0

### Details

This is not initialized by the System Reset (Preset) command.  
This is initialized by Power On.

### Example of Use

To enable execution error and command error  
\*ESE 48  
\*ESE?  
>48

**\*ESR?**

Standard Event Status Register Query

Function

Returns the standard event status register value. If this is queried, the standard event status register is cleared. This is a common IEEE488.2 query.

Query

\*ESR?

Response

n

Parameter

n      Standard event status register  
Value = bit0 + bit1 + bit2 + bit3 + bit4 + bit5 + bit6 + bit7  
bit0 : 2<sup>0</sup> = 1      Operation completion  
bit1 : 2<sup>1</sup> = 2      Request control (not used)  
bit2 : 2<sup>2</sup> = 4      Query error  
bit3 : 2<sup>3</sup> = 8      Device error  
bit4 : 2<sup>4</sup> = 16     Execution error  
bit5 : 2<sup>5</sup> = 32     Command error  
bit6 : 2<sup>6</sup> = 64     User request  
bit7 : 2<sup>7</sup> = 128    Power ON  
Range 0 to 255

Example of Use

To query the standard event status register value (when an execution error and command error have occurred)

\*ESR?  
>48

**\*IDN?**

Identification Query

Function

This command queries the device information. This is a common IEEE488.2 query.

Query

\*IDN?

Response

company,model,serialnumber,firmware

Parameter

company	Manufacturer (ANRITSU)
model	Product model (7-character alphanumeric)
serialnumber	Serial number (10-digit number)
firmware	Version number of this application

Example of Use

To query the device information:

\*IDN?

>ANRITSU, MG3710A, 6100000000, 1.0.0.0

## \*OPC/\*OPC?

Operation Complete Command/Query

### Function

\*OPC/\*OPC? is a command/query to synchronize between the device and the external controller (PC). This is a common IEEE488.2 command/query.

If a \*OPC command is received, the operation completion bit (bit 0) is set to 1 once all active processes are complete.

If a \*OPC? query is received, 1 is returned once all active processes are complete.

### Command

\*OPC

### Query

\*OPC?

### Response

1

### Details

The wait for operation completion set by \*OPC/\*OPC? is disabled after the following events:

- Power ON
- Reception of DCL or SCL on the IEEE488.1 interface
- Reception of the \*CLS command
- Reception of \*RST command
- Completion of all active processing

### Example of Use

To wait for completion of measurement with \*OPC

```
*CLS           Clears the event status.
*SRE 32       Enables the ESB service request.
*ESE 1        Enables the operation completion bit.
MMEM:LOAD:WAV:WMA "PackageName", "PatternName"
              Loads a waveform pattern.
*OPC?        Switches to the operation completion waiting
              status.
>1           Returns 1 if lading completes.
RAD:ARB:WMA:WAV "PackageName", "PatternName"
              Selects a waveform pattern.
```

**\*RST**

Reset Command

Function

Initializes the device. This is a common IEEE488.2 command.

Command

\*RST

Details

Initializes the settings and status of all loaded applications.

Example of Use

To initialize the device

\*RST

**\*SRE/\*SRE?**

Service Request Enable Command/Query

Function

Sets the service request enable register. The service request enable register value is returned for the query. This is a common IEEE488.2 command/query.

Command

\*SRE n

Query

\*SRE?

Response

n

Parameter

n Service request enable register  
 Value = bit0 + bit1 + bit2 + bit3 + bit4 + bit5 + bit6 + bit7

SCPI mode

bit0 : 2 <sup>0</sup> = 1	Not used
bit1 : 2 <sup>1</sup> = 2	Not used
bit2 : 2 <sup>2</sup> = 4	QUE
bit3 : 2 <sup>3</sup> = 8	QUES
bit4 : 2 <sup>4</sup> = 16	MAV
bit5 : 2 <sup>5</sup> = 32	ESB
bit6 : 2 <sup>6</sup> = 64	MSS/RQS
bit7 : 2 <sup>7</sup> = 128	OPER

Native mode

bit0 : 2 <sup>0</sup> = 1	Extended event status 2nd SG (EESB0)
bit1 : 2 <sup>1</sup> = 2	Extended event status 2nd SG (EESB1)
bit2 : 2 <sup>2</sup> = 4	Extended event status 1st SG (EESB2)
bit3 : 2 <sup>3</sup> = 8	Extended event status 1st SG (EESB3)
bit4 : 2 <sup>4</sup> = 16	MAV
bit5 : 2 <sup>5</sup> = 32	ESB
bit6 : 2 <sup>6</sup> = 64	MSS/RQS
bit7 : 2 <sup>7</sup> = 128	Not used

Range 0 to 255  
 Default 0

Details

This is not initialized by the System Reset (Preset) command.  
This is initialized by Power On.

Example of Use

Enables the ESB service request.

```
*SRE 32
```

```
*SRE?
```

```
>32
```



**\*STB?**

Status Byte Register Query

Function

Returns the status byte register value. This is a common IEEE488.2 query.

Query

\*STB?

Response

n

Parameter

n      Status byte register  
 Value = bit0 + bit1 + bit2 + bit3 + bit4 + bit5 + bit6 + bit7

SCPI mode

- bit0 : 2<sup>0</sup> = 1      Not used
- bit1 : 2<sup>1</sup> = 2      Not used
- bit2 : 2<sup>2</sup> = 4      QUE
- bit3 : 2<sup>3</sup> = 8      QUES
- bit4 : 2<sup>4</sup> = 16     MAV
- bit5 : 2<sup>5</sup> = 32     ESB
- bit6 : 2<sup>6</sup> = 64     MSS/RQS
- bit7 : 2<sup>7</sup> = 128    OPER

Native mode

- bit0 : 2<sup>0</sup> = 1      Extended event status 2nd SG (EESB0)
- bit1 : 2<sup>1</sup> = 2      Extended event status 2nd SG (EESB1)
- bit2 : 2<sup>2</sup> = 4      Extended event status 1st SG (EESB2)
- bit3 : 2<sup>3</sup> = 8      Extended event status 1st SG (EESB3)
- bit4 : 2<sup>4</sup> = 16     MAV
- bit5 : 2<sup>5</sup> = 32     ESB
- bit6 : 2<sup>6</sup> = 64     MSS/RQS
- bit7 : 2<sup>7</sup> = 128    Not used

Range    0 to 255

Example of Use

To query the status byte register value (when the ESB bit is 1)

\*STB?

>32

**\*TRG**

Trigger Control

Function

This command requests the trigger execution.

Command message

\*TRG

Explanation

This command executes processing related to trigger input.

Example of Use

To execute trigger.

\*TRG Controller → MG3710A/MG3740A

### \*TST?

Self-Test Query  
Function

Returns the result of the self test. This is a common IEEE488.2 query.

Query

\*TST?

Response

n

Parameter

n	Status byte register
Value	= bit0 + bit1 + bit2 + bit3 + bit4 + bit5 + bit6 + bit7
	bit0 : 2 <sup>0</sup> = 1      Not used
	bit1 : 2 <sup>1</sup> = 2      Not used
	bit2 : 2 <sup>2</sup> = 4      Not used
	bit3 : 2 <sup>3</sup> = 8      RPP generation
	bit4 : 2 <sup>4</sup> = 16     Internal Reference Frequency Unlock
	bit5 : 2 <sup>5</sup> = 32     Not used
	bit6 : 2 <sup>6</sup> = 64     Internal Baseband Reference Clock Unlock
	bit7 : 2 <sup>7</sup> = 128    ALC Alarm
Range	0 to 255

Example of Use

To query the self test result  
\*TST?  
>0

### \*WAI

Wait-to-Continue Command

Function

Waits until all active processes are complete before executing the next command. This is a common IEEE488.2 command.

Command

\*WAI

Example of Use

To wait for completion of measurement with \*WAI

```
MMEM:LOAD:WAV:WMA "PackageName", "PatternName"
```

Loads a waveform pattern.

```
*WAI
```

Waits until loading completes.

```
RAD:ARB:WMA:WAV "PackageName", "PatternName"
```

Selects a waveform pattern.

## E.12 SCPI Device Message

This section describes SCPI device messages for status registers.

### E.12.1 OPERation status register

The following table and figure show the layer structure of the OPERation Status Register.




Figure E.12-1 OPERation Status Register

Table E.12-1 OPERation Status Register

Bit Definition of OPERation Status Register	
DB3	Executing Sweep
DB4	BERT measurement in progress
DB11	Calibrating 1st SG
DB12	Calibrating 2nd SG
DB13	Executing 1st SG sequence mode
DB14	Executing 2nd SG sequence mode
DB15	Fix to 0.

Table E.12-2 lists device messages for the OPERation Status Register.

**Table E.12-2 Device Messages Related to OPERation Status Register**

<b>Function</b>	<b>Device Message</b>
Operation Status Register Event	:STATus:OPERation[:EVENT]?
Operation Status Register Condition	:STATus:OPERation:CONDition?
Operation Status Register Enable	:STATus:OPERation:ENABle <integer>
	:STATus:OPERation:ENABle?
Operation Status Register Negative Transition	:STATus:OPERation:NTRansition <integer>
	:STATus:OPERation:NTRansition?
Operation Status Register Positive Transition	:STATus:OPERation:PTRansition <integer>
	:STATus:OPERation:PTRansition?
Status Preset	:STATus:PRESet

## E.12.2 SCPI device message details

This section describes SCPI device messages for the OPERATION status register.

### :STATus:OPERation[:EVENT]?

Operation Status Register Event

#### Function

This command queries the event register of the OPERATION Status Register.

#### Query

:STATus:OPERation[:EVENT]?

#### Response

<integer>

#### Parameter

<integer>	Bit sum of event register
Resolution	1
Range	0 to 65535

#### Details

This command is available only in SCPI mode.

#### Example of Use

To query the event register contents of the OPERATION Status Register.  
STAT:OPER?  
> 0

## :STATus:OPERation:CONDition?

Operation Status Register Condition

### Function

This command queries the content of the condition register of the OPERation status register.

### Query

:STATus:OPERation:CONDition?

### Response

<integer>

### Parameter

<integer>	Bit sum of condition register
Resolution	1
Range	0 to 65535

### Details

This command is available only in SCPI mode.

### Example of Use

To query the content of the condition register of the OPERation status register.

```
STAT:OPER:COND?
```

```
> 0
```

## :STATus:OPERation:ENABLE <integer>

Operation Status Register Enable

### Function

This command sets the event enable register of the OPERATION Status Register.

### Command

```
:STATus:OPERation:ENABLE <integer>
```

### Parameter

<integer>	Bit sum of event enable register
Resolution	1
Range	0 to 65535

### Details

This command is available only in SCPI mode.

### Example of Use

To set the event enable register of the OPERATION status register to 16.  
STAT:OPER:ENAB 16

## :STATus:OPERation:ENABLE?

Operation Status Register Enable Query

### Function

This command queries the event enable register of the OPERATION Status Register.

### Query

```
:STATus:OPERation:ENABLE?
```

### Response

```
<integer>
```

### Parameter

<integer>	Bit sum of event enable register
Resolution	1
Range	0 to 65535

### Example of Use

To query the event enable register of the OPERATION Status Register.  
STAT:OPER:ENAB?  
> 16



## :STATus:OPERation:NTRansition <integer>

Operation Status Register Negative Transition

### Function

This command sets the transition filter (negative transition) of the OPERation status register.

### Command

```
:STATus:OPERation:NTRansition <integer>
```

### Parameter

<integer>	Bit sum of transition filter (negative transition)
Resolution	1
Range	0 to 65535

### Details

This command is available only in SCPI mode.

### Example of Use

To set the transition filter (negative transition) of the OPERation status register to 16.

```
STAT:OPER:NTR 16
```

## :STATus:OPERation:NTRansition?

Operation Status Register Negative Transition Query

### Function

This command queries the transition filter (negative transition) of the OPERation status register.

### Query

```
:STATus:OPERation:NTRansition?
```

### Response

```
<integer>
```

### Parameter

<integer>	Bit sum of transition filter (negative transition)
Resolution	1
Range	0 to 65535

### Example of Use

To query the transition filter (negative transition) of the OPERation status register.

```
STAT:OPER:NTR?
```

```
> 16
```

## **:STATus:OPERation:PTRansition <integer>**

Operation Status Register Positive Transition

### Function

This command sets the transition filter (positive transition) of the OPERation status register.

### Command

```
:STATus:OPERation:PTRansition <integer>
```

### Parameter

<integer>	Bit sum of transition filter (positive transition)
Resolution	1
Range	0 to 65535

### Details

This command is available only in SCPI mode.

### Example of Use

To set the transition filter (positive transition) of the OPERation status register to 16.

```
STAT:OPER:PTR 16
```

### :STATus:OPERation:PTRansition?

Operation Status Register Positive Transition Query

Function

This command queries the transition filter (positive transition) of the OPERation status register.

Query

:STATus:OPERation:PTRansition?

Response

<integer>

Parameter

<integer>	Bit sum of transition filter (positive transition)
Resolution	1
Range	0 to 65535

Example of Use

To query the transition filter (positive transition) of the OPERation status register.

```
STAT:OPER:PTR?  
> 16
```

### :STATus:PRESet

Status Preset

Function

This command presets all of the transition filters, enable registers, errors and event queue enable registers.

Command

:STATus:PRESet

Parameter

None

Details

This command is available only in SCPI mode.

Example of Use

To preset all of the transition filters, enable registers, errors and event queue enable registers.

```
STAT:PRES
```



# *Appendix F Native Device Message Details*

---

This chapter describes the compatible commands for controlling the MG3710A/MG3740A with the remote-control commands of the MG3700A. For the detailed specifications of each command, refer to MG3700A Vector Signal Generator Operational Manual (Mainframe) and “F.1 Native Device Message” of this manual.

F.1	Native Device Messages .....	F-2
	F.1.1 Functions Device Messages Common to Measurement Equipment .....	F-4
F.2	MG3710A-MG3700A Common Functions .....	F-14
	F.2.1 MG3710A-MG3700A Common Functions .....	F-14
F.3	Frequency & Channel Function .....	F-18
	F.3.1 Frequency & Channel function .....	F-18
F.4	Level Function.....	F-23
	F.4.1. Level function .....	F-23
F.5	Modulation Functions.....	F-27
	F.5.1 Common to modulation functions.....	F-27
	F.5.2 Modulation .....	F-28
	F.5.3 Load pattern .....	F-35
	F.5.4 Ext I/O Setup .....	F-43
	F.5.5 I/Q tuning .....	F-47
	F.5.6 Edit HDD.....	F-50
	F.5.7 Sequence Progress .....	F-51
F.6	Utility Function .....	F-52
	F.6.1 Common to utility functions .....	F-52
	F.6.2 Save/Recall .....	F-53
	F.6.3 BER Measurement .....	F-55
	F.6.4 BER Measurement (Data Type Detail Setup) .....	F-61
	F.6.5 Alarm Monitor .....	F-64
	F.6.6 Interface Setup .....	F-66
	F.6.7 Network Setup .....	F-67
	F.6.8 Common Setup.....	F-70
	F.6.9 Maintenance Check.....	F-72
	F.6.10 Hardware Check.....	F-73
	F.6.11 Install .....	F-76
F.7	IEEE488.2 Common Commands.....	F-77
	F.7.1 Common to IEEE488.2.....	F-77

## F.1 Native Device Messages

Described below are the commands that do not exist on the MG3700A when controlling the MG3710A/MG3740A using the MG3700A compatible commands.

**Table F.1-1 MG3710A-MG3740A-MG3700A Common Device Messages**

Function	Command	Query	Response	Remarks
Extended End Event Status Enable Register	ESE0 n	ESE0?	n	n = bit7 : Memory optimization check complete bit6 : Memory optimization complete bit5 : Not used bit4 : Waveform pattern loaded bit3 : Measurement complete bit2 : Level setting complete bit1 : Not used bit0 : Frequency setting complete
Extended End Event Status Register	---	ESR0?	n	bit5 : Not used bit4 : Waveform pattern loaded bit3 : Measurement complete bit2 : Level setting complete bit1 : Not used bit0 : Frequency setting complete
Extended Error Event Status Enable Register	ESE1 n	ESE1?	n	n = bit7 : Memory optimization check error bit6 : Memory optimization error bit5 : Not used bit4 : Waveform pattern load error bit3 : Measurement error bit2 : Level setting error bit1 : Not used bit0 : Frequency setting error
Extended Error Event Status Register	---	ESR1?	n	bit5 : Not used bit4 : Waveform pattern load error bit3 : Measurement error bit2 : Level setting error bit1 : Not used bit0 : Frequency setting error
Extended End Event Status Enable Register	ESE2 n	ESE2?	n	n = bit7 : Memory optimization check complete bit6 : Memory optimization complete bit5 : Not used bit4 : Waveform pattern loaded bit3 : Measurement complete bit2 : Level setting complete bit1 : Not used bit0 : Frequency setting complete
Extended End Event Status Register	---	ESR2?	n	bit5 : Not used bit4 : Waveform pattern loaded bit3 : Measurement complete bit2 : Level setting complete bit1 : Not used bit0 : Frequency setting complete

Table F.1-1 MG3710A-MG3700A Common Device Messages (Cont'd)

Function	Command	Query	Response	Remarks
Extended Error Event Status Enable Register	ESE3 n	ESE3?	n	n = bit7 : Memory optimization check error bit6 : Memory optimization error bit5 : Not used bit4 : Waveform pattern load error bit3 : Measurement error bit2 : Level setting error bit1 : Not used bit0 : Frequency setting error
Extended Error Event Status Register	---	ESR3?	n	
Select SG	SELECTSG 1 2	SELECTSG?	n	n = SG No. 1 = SG1 2 = SG2

## F.1.1 Functions Device Messages Common to Measurement Equipment

### ESE0/ESE0?

Extended End Event Status Enable Register

#### Function

This command sets the extended end event status enable register of SG2. When an end event occurs, the end summary bit (ESB) value of the corresponding status byte register is set to 1 (true). The end event status enable register value of SG2 is returned for the query. This command does not exist on the MG3700A.

#### Command

ESE0 n

#### Query

ESE0?

#### Response

n

#### Parameter

n	Extended end event status enable register (2nd SG)
Value	= bit0 + bit1 + bit2 + bit3 + bit4 + bit5 + bit6 + bit7
	bit0 : 20 = 1      Frequency setting complete
	bit1 : 21 = 2      (Not used)
	bit2 : 22 = 4      Level setting complete
	bit3 : 23 = 8      Measurement complete
	bit4 : 24 = 16     Waveform pattern loaded
	bit5 : 25 = 32     (Not used)
	bit6 : 26 = 64     Memory optimization complete
	bit7 : 27 = 128   Memory optimization check complete
Range	0 to 255
Default	0

#### Details

This command is available only in native mode.



Example of Use

To enable the waveform pattern loaded and the level setting complete of 2nd SG.

```
ESE0 20
ESE0?
> 20
```

Related Command

ESR0?            Queries the extended end event status register of 2nd SG.

## ESE1/ESE1?

### Extended Error Event Status Enable Register

Function

This command sets the extended error event status enable register of 2nd SG. When an error event occurs, the error summary bit (ESB) value of the corresponding status byte register is set to 1 (true). The error event status enable register value of 2nd SG is returned for the query.

This command does not exist on the MG3700A.

Command

```
ESE1 n
```

Query

```
ESE1?
```

Response

```
n
```

Parameter

n            Extended error event status enable register (2nd SG)

Value      = bit0 + bit1 + bit2 + bit3 + bit + bit5 + bit6 + bit7

bit0 : 20 = 1      Frequency setting error

bit1 : 21 = 2      (Not used)

bit2 : 22 = 4      Level setting error

bit3 : 23 = 8      Measurement error

bit4 : 24 = 16     Waveform pattern load error

bit5 : 25 = 32     (Not used)

bit6 : 26 = 64     Memory optimization error

bit7 : 27 = 128   Memory optimization check error

Range      0 to 255

Default    0

## *Appendix F Native Device Message Details*

---

### Details

This command is available only in native mode.

### Example of Use

To enable the waveform pattern load error and the level setting error of 2nd SG.

```
ESE1 20
```

```
ESE1?
```

```
> 20
```

### Related Command

```
ESR1?
```

Queries the extended error event status register of 2nd SG.

## ESE2/ESE2?

Extended End Event Status Enable Register

### Function

This command sets the extended end event status enable register of 1st SG. When an end event occurs at 1st SG, the end summary bit (ESB) value of the corresponding status byte register is set to 1 (true). The end event status enable register value of 1st SG is returned for the query.

### Command

ESE2 n

### Query

ESE2?

### Response

n

### Parameter

n Extended end event status enable register of 1st SG  
 Value = bit0 + bit1 + bit2 + bit3 + bit + bit5 + bit6 + bit7  
 bit0 : 2<sup>0</sup> = 1 Frequency setting complete  
 bit1 : 2<sup>1</sup> = 2 Not used  
 bit2 : 2<sup>2</sup> = 4 Level setting complete  
 bit3 : 2<sup>3</sup> = 8 End of measurement  
 bit4 : 2<sup>4</sup> = 16 Waveform pattern loaded  
 bit5 : 2<sup>5</sup> = 32 Not used  
 bit6 : 2<sup>6</sup> = 64 Memory optimization complete  
 bit7 : 2<sup>7</sup> = 128 Memory optimization check complete  
 Range 0 to 255  
 Default 0

### Details

This command is available only in native mode.

### Example of Use

To enable the waveform pattern loaded and the level setting complete of 1st SG.  
 ESE2 20  
 ESE2?  
 > 20

### Related Command

ESR2? Queries the extended end event status register of 1st SG.

## ESE3/ESE3?

Extended Error Event Status Enable Register

### Function

This command sets the extended error event status enable register of 1st SG. When an error event occurs at 1st SG, the error summary bit (ESB) value of the corresponding status byte register is set to 1 (true). The error event status enable register value of 1st SG is returned for the query.

### Command

ESE3 n

### Query

ESE3?

### Response

n

### Parameter

n Extended error event status enable register of 1st SG.  
 Value = bit0 + bit1 + bit2 + bit3 + bit + bit5 + bit6 + bit7  
 bit0 :  $2^0 = 1$  Frequency setting error  
 bit1 :  $2^1 = 2$  Not used  
 bit2 :  $2^2 = 4$  Level setting error  
 bit3 :  $2^3 = 8$  Measurement error  
 bit4 :  $2^4 = 16$  Waveform pattern load error  
 bit5 :  $2^5 = 32$  Not used  
 bit6 :  $2^6 = 64$  Memory optimization error  
 bit7 :  $2^7 = 128$  Memory optimization check error  
 Range 0 to 255  
 Default 0

### Details

This command is available only in native mode.

### Example of Use

To enable the waveform pattern load error and the level setting error of 1st SG.

```
ESE3 20
ESE3?
> 20
```

### Related Command

ESR3? Queries the extended error event status register of 1st SG.

## ESR0?

### Extended End Event Status Register Query

#### Function

This command queries the extended end event status register of 2nd SG. After the query, this register is reset to 0. This command does not exist on the MG3700A.

#### Query

ESR0?

#### Response

n

#### Parameter

n Extended end event status register of 2nd SG  
 Value = bit0 + bit1 + bit2 + bit3 + bit + bit5 + bit6 + bit7  
 bit0 :  $2^0 = 1$       Frequency setting complete  
 bit1 :  $2^1 = 2$       Not used  
 bit2 :  $2^2 = 4$       Level setting complete  
 bit3 :  $2^3 = 8$       End of measurement  
 bit4 :  $2^4 = 16$      Waveform pattern loaded  
 bit5 :  $2^5 = 32$      Not used  
 bit6 :  $2^6 = 64$      Memory optimization complete  
 bit7 :  $2^7 = 128$     Memory optimization check complete  
 Range 0 to 255  
 Default 0

#### Details

This command is available only in native mode.

#### Example of Use

To query the extended end event status register of 2nd SG.

ESR0?

>1

Frequency setting complete

#### Related Command

ESE0?

Queries the extended end event status enable register of 2nd SG.

## ESR1?

### Extended Error Event Status Register Query

#### Function

This command queries the extended error event status register of 2nd SG. After the query, this register is reset to 0. This command does not exist on the MG3700A.

#### Query

ESR1?

#### Response

n

#### Parameter

n      Extended error event status register of 2nd SG  
Value = bit0 + bit1 + bit2 + bit3 + bit + bit5 + bit6 + bit7  
bit0 :  $2^0 = 1$       Frequency setting error  
bit1 :  $2^1 = 2$       Not used  
bit2 :  $2^2 = 4$       Level setting error  
bit3 :  $2^3 = 8$       Measurement error  
bit4 :  $2^4 = 16$       Waveform pattern load error  
bit5 :  $2^5 = 32$       Not used  
bit6 :  $2^6 = 64$       Memory optimization error  
bit7 :  $2^7 = 128$       Memory optimization check error  
Range 0 to 255  
Default 0

#### Details

This command is available only in native mode.

#### Example of Use

To query the extended error event status register of 2nd SG.

ESR1?

>1      Frequency setting error

#### Related Command

ESE1?      Queries the extended error event status enable register of 2nd SG.

## ESR2?

### Extended End Event Status Register Query

#### Function

This command queries the extended end event status register of 1st SG. After the query, this register is reset to 0.

#### Query

ESR2?

#### Response

n

#### Parameter

n Extended end event status register of 1st SG  
 Value = bit0 + bit1 + bit2 + bit3 + bit + bit5 + bit6 + bit7  
 bit0 :  $2^0 = 1$       Frequency setting complete  
 bit1 :  $2^1 = 2$       Not used  
 bit2 :  $2^2 = 4$       Level setting complete  
 bit3 :  $2^3 = 8$       End of measurement  
 bit4 :  $2^4 = 16$      Waveform pattern loaded  
 bit5 :  $2^5 = 32$      Not used  
 bit6 :  $2^6 = 64$      Memory optimization complete  
 bit7 :  $2^7 = 128$     Memory optimization check complete  
 Range 0 to 255  
 Default 0

#### Details

This command is available only in native mode.

#### Example of Use

To query the extended end event status register of 1st SG.  
 ESR2?  
 >1                                      Frequency setting complete

#### Related Command

ESE2?                                      Queries the extended end event status enable register of 1st SG.

## ESR3?

### Extended Error Event Status Register Query

#### Function

This command queries the extended error event status register of 1st SG. After the query, this register is reset to 0.

#### Query

ESR3?

#### Response

n

#### Parameter

n      Extended error event status register of 1st SG  
Value = bit0 + bit1 + bit2 + bit3 + bit + bit5 + bit6 + bit7  
bit0 :  $2^0 = 1$       Frequency setting error  
bit1 :  $2^1 = 2$       Not used  
bit2 :  $2^2 = 4$       Level setting error  
bit3 :  $2^3 = 8$       Measurement error  
bit4 :  $2^4 = 16$       Waveform pattern load error  
bit5 :  $2^5 = 32$       Not used  
bit6 :  $2^6 = 64$       Memory optimization error  
bit7 :  $2^7 = 128$       Memory optimization check error  
Range 0 to 255  
Default 0

#### Details

This command is available only in native mode.

#### Example of Use

To query the extended error event status register of 1st SG.

ESR3?

>1      Frequency setting error

#### Related Command

ESE3?      Queries the extended error event status enable register of 1st SG.



## SELECTSG/SELECTSG?

Select SG

Function

This command selects the corresponding SG to be operated with the remote command.

This command does not exist on the MG3700A. It is used to select SG of the MG3710A/MG3740A.

Setting a numeric value other than “1” and “2” causes an error. (Out of range)

Command

```
SELECTSG 1|2
```

Query

```
SELECTSG?
```

Response

```
n
```

Parameter

n	No. of SG
1	SG1
2	SG2
Default	1

Details

This command is available only in native mode.

Example of Use

```
To select SG2 to be controlled
SELECTSG 2
SELECTSG?
> 2
```

## F.2 MG3710A-MG3700A Common Functions

**Note:**

Column SG1/2 of the compatible list shows whether the behavior changes according to the SELECTSG command.

√: The SELECTSG command 1 is for SG1, and 2 is for SG2.

N/A: Command not related to SG1/2.

### F.2.1 MG3710A-MG3740A-MG3700A Common Functions

Given below is the compatible list of the functions device common to messages measurement equipment.

**Table F.2.1-1 Compatible List of Device Messages Common to Applications**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
DSPL ON OFF	√	DSPL ON OFF	N/A	Turns the display On/Off	:DisplayENABLE ON OFF 1 0
DSPL?	√	DSPL?	N/A	Turns the display On/Off	:DISPlay:ENABLE?
—	√	ESE0 <integer>	N/A	Sets the extended status enable register For notification of the end of SG2; Not existing on the MG3700A.	—
—	√	ESE0?	N/A	Reads the extended status enable register For notification of the end of SG2; Not existing on the MG3700A.	—
—	√	ESE1 <integer>	N/A	Sets the extended status enable register For notification of the error of SG2; Not existing on the MG3700A.	—

**Table F.2.1-1 Compatible List of Device Messages Common to Applications (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
—	√	ESE1?	N/A	Reads the extended status enable register For notification of the error of SG2; Not existing on the MG3700A.	—
ESE2 n	√	ESE2 <integer>	N/A	Sets the extended status enable register For notification of the end of SG1	—
ESE2?	√	ESE2?	N/A	Reads the extended status enable register For notification of the end of SG1.	—
ESE3 n	√	ESE3 <integer>	N/A	Sets the extended status enable register For notification of SG1 errors	—
ESE3?	√	ESE3?	N/A	Reads the extended status enable register For notification of SG1 errors	—
—	√	ESR0?	N/A	Sets the extended status register For notification of the end of SG2; Not existing on the MG3700A.	—
—	√	ESR1?	N/A	Sets the extended status register For notification of the error of SG2; Not existing on the MG3700A.	—
ESR2?	√	ESR2?	N/A	Sets the extended status register For notification of the end of SG1.	—
ESR3?	√	ESR3?	N/A	Sets the extended status register For notification of SG1 errors	—

Table F.2.1-1 Compatible List of Device Messages Common to Applications (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
HEAD ON OFF	√	HEAD ON OFF	N/A	Header of the response message When the Language Mode is MG3700A and this function is turned on, inserts in capital letters all character strings of the header section of the query input by the user. Adds no header section to the response of the IEEE488.2 common commands such as *IDN? even if the HEAD is on.	—
HEAD?	√	HEAD?	N/A	Header of the response message	—
KNOBHOLD ON OFF	√	KNOBHOLD ON OFF	N/A	Holds the rotary knob.	:SYSTem:KNOB:HOLD <boolean>
KNOBHOLD?	√	KNOBHOLD?	N/A	Holds the rotary knob	:SYSTem:KNOB:HOLD?
PRE	√	PRE	N/A	System Preset	:SYSTem:PRESet
SCOPY	√	SCOPY [<string>,[<device>]]	N/A	Copies the screen Device specified with SCRCPYMEDIA when <device> is omitted The formats to be used are those currently set with the following: :MMEMory:STORe:SCReen:MODE BMP PNG	:MMEMory:STORe:SCReen [<filename>[,<device>]]
ERRMSG?	√	ERRMSG?	N/A	Obtains error messages Obtains only the error occurred immediately before	:SYSTem:ERRor[:NEXT ]?

Table F.2.1-1 Compatible List of Device Messages Common to Applications (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN?	√	SCREEN?	N/A	Current screen Returns the options set immediately before with the SCREEN command The default is <code>FREQ_TOP</code> .	—
—	√	SELECTSG 1 2	N/A	Selects the corresponding SG to be operated with the remote command. A command that does not exist on the MG3700A. Used to select SG of the MG3710A/MG3740A. Setting a numeric value other than "1" and "2" causes an error. (Out of range)	[ :SOURce ] :PORT 1 2
—	√	SELECTSG?	N/A	Queries the corresponding SG to be operated with the remote command. Command that does not exist on the MG3700A Queries the selected status of SG of the MG3710A/MG3740A	[ :SOURce ] :PORT?

## F.3 Frequency & Channel Function

### F.3.1 Frequency & Channel function

Given below is the compatible list of the frequency & channel functions device messages.

**Table F.3.1-1 Compatible List of Frequency & Channel Functions Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN FREQ_TOP	√	SCREEN FREQ_TOP	N/A	Moves to the frequency screen This command is accepted but the screen is not moved.	—
FREQ f	√	FREQ <freq>	√	Sets frequency	[ :SOURce [1]   2 ] :FREQ uency [ :CW   :FIXed ] <freq>
FREQ?	√	FREQ?	√	Sets frequency	[ :SOURce [1]   2 ] :FREQ uency [ :CW   :FIXed ] ?
BPADISP FREQ CH	√	BPADISP FREQ CH	√	Switches between frequency and channel	[ :SOURce [1]   2 ] :FREQ uency :TYPE FREQuency   CHANnel
BPADISP?	√	BPADISP?	√	Switches between frequency and channel	[ :SOURce [1]   2 ] :FREQ uency :TYPE?
FRS UP   DN   DOWN	√	FRS UP   DN   DOWN	√	Steps up/down the frequency	[ :SOURce [1]   2 ] :FREQ uency [ :CW   :FIXed ] UP   DOWN
FIS f	√	FIS <freq>	√	Increments the step of the frequency	[ :SOURce [1]   2 ] :FREQ uency :STEP [ :INCReme nt ] <freq>

**Table F.3.1-1 Compatible List of Frequency & Channel Functions Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
FIS?	√	FIS?	√	Increments the step of the frequency	[ :SOURce[1]   2 ] :FREQuency:STEP[ :INCRement ]?
FREQSWSPEED NORMAL   FAST	N/A		N/A	Frequency switching speed	
FREQSWSPEED?	N/A		N/A	Frequency switching speed	
SPREV ON   REV   INV   OFF   NORMAL	√	SPREV ON   REV   INV   OFF   NORMAL	√	RF spectrum	[ :SOURce[1]   2 ] :DM:POLarity[ :ALL ] NORMal   INVert
SPREV?	√	SPREV?	√	RF spectrum	[ :SOURce[1]   2 ] :DM:POLarity[ :ALL ]?
REF?	√	REF?	N/A	Queries the frequency reference Response: INT, EXT	—
PLLCOND?	√	PLLCOND?	N/A	Queries the PLL Condition Response: NORMAL, OVENCOND, ALARM, CHKEXT	—
SCREEN FREQ_PHASE	√	SCREEN FREQ_PHASE	N/A	Moves to the RF output phase adjustment screen. This command is accepted but the screen is not moved	—
RFPHASE d	√	RFPHASE <phase>	√	RF output phase	[ :SOURce[1]   2 ] :PHASe[ :ADJust ] <ext_numeric>
RFPHASE?	√	RFPHASE?	√	RF output phase	[ :SOURce[1]   2 ] :PHASe[ :ADJust ]?
SCREEN CHAN_TOP	√	SCREEN CHAN_TOP	N/A	Moves to the channel screen This command is accepted but the screen is not moved.	—

Table F.3.1-1 Compatible List of Frequency &amp; Channel Functions Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN CHAN_EDIT	√	SCREEN CHAN_EDIT	N/A	Moves to the channel edit screen This command is accepted but the screen is not moved.	—
CH n	√	CH <ext_integer>	√	Sets the channel number.	[ :SOURce [1]   2 ] :FREQuency:CHANnels:NUMBER <ext_integer>
CH?	√	CH?	√	Sets the channel number.	[ :SOURce [1]   2 ] :FREQuency:CHANnels:NUMBER?
CHS UP DN DOWN	√	CHS UP DN DOWN	√	Up/Down of the step of the channel Increases by 1 or decreases by 1	
CHFDISP ON OFF	√	CHFDISP ON OFF	√	Frequency display	[ :SOURce [1]   2 ] :FREQuency:CHANnels:DISP lay <boolean>
CHFDISP?	√	CHFDISP?	√	Frequency display	[ :SOURce [1]   2 ] :FREQuency:CHANnels:DISP lay?
CHGRPSEL n	√	CHGRPSEL <ext_integer>	√	Sets the channel group Setting this when no channel group exists causes an error	[ :SOURce [1]   2 ] :FREQuency:CHANnels:GROu p <ext_integer>
CHGRPSEL?	√	CHGRPSEL?	√	Sets the channel group Querying when no group is selected causes an error	[ :SOURce [1]   2 ] :FREQuency:CHANnels:GROu p?



**Table F.3.1-1 Compatible List of Frequency & Channel Functions Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
CHTBLALLCLR	√	CHTBLALLCLR	√	Entirely clears the channel table	[ :SOURce[1]   2 ] :FREQuency:CHANnels:DELe te:ALL
CHTBL n1,s,n2,n3,f 1,f2	√	CHTBL <ext_integer1>,<strin g>,<ext_integer2>,<ex t_integer3>,<freq1>,< freq2>	√	Edits the channel table	[ :SOURce[1]   2 ] :FREQuency:CHANnels:EDIT <ext_integer1>,<str ing>,<ext_integer2> ,<ext_integer3>,<fr eq1>,<freq2>
CHTBL? n1	√	CHTBL? <ext_integer>	√	Edits the channel table	[ :SOURce[1]   2 ] :FREQuency:CHANnels:EDIT ?
CHTBLDEL n	√	CHTBLDEL <ext_integer>	√	Clears the channel table	[ :SOURce[1]   2 ] :FREQuency:CHANnels:DELe te <integer>
CHFILESAVE s	√	CHFILESAVE <string>[,<device>]	√	Stores the channel table Device specified by CHMEDIA when the device is omitted	:MMEMory<1 2>:STORE :FREQuency:CHANnels <string>[,<Device>]
CHFILERECALL s	√	CHFILERECALL <string>[,<device>]	√	Reads the channel table Device specified by CHMEDIA when the device is omitted	:MMEMory<1 2>:LOAD: FREQuency:CHANnels <string>[,<Device>]

Table F.3.1-1 Compatible List of Frequency &amp; Channel Functions Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
CHCURFILE?	√	CHCURFILE?	√	Obtains the name of the channel table file Returns the name of the current channel table file When the channel table file is saved/recalled, changes the name accordingly. Default: ChTable (tentative name)	—
CHMEDIA HDD CF	√	CHMEDIA HDD SHDD CF	√	Selects the media in which the channel table is to be stored/read C drive when HDD is selected D drive when SHDD is selected (enabled only when the 2nd HDD option is installed; otherwise causes an error). Devices other than HDD whose drive letter is the youngest when CF is selected Default: HDD	—
CHMEDIA?	√	CHMEDIA?	√	Selects the media to store/read the channel table Returns CF for drives other than C and 2nd HDD	—

## F.4 Level Function

### F.4.1 Level function

Given below is the compatible list of the level function device messages.

**Table F.4.1-1 Compatible List of Level Function Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN LVL_TOP	√	SCREEN LVL_TOP	N/A	Moves to the level screen This command is accepted but the screen is not moved	—
LVL ON OFF	√	LVL ON OFF	√	Turns the RF output On/Off	:OUTPut[1] 2[:STATE] <boolean>
LVL?	√	LVL?	√	Turns the RF output On/Off	:OUTPut[1] 2[:STATE] >?
OLVL 1	√	OLVL <ampl>	√	RF output level	[:SOURce[1] 2]:POWe r[:LEVel][:IMMediat e][:AMPLitude] <ampl>
OLVL? [DBM DBU]	√	OLVL? [DBM DBU]	√	RF output level Reads by specifying the unit Uses the unit specified by VDSPL, when DBU is selected	—
OLS UP DN DOWN	√	OLS UP DN DOWN	√	Increases/Decreases the step of the RF output level	[:SOURce[1] 2]:POWe r[:LEVel][:IMMediat e][:AMPLitude] UP DOWN

Table F.4.1-1 Compatible List of Level Functions Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
OLU DBM DBU	√	OLU DBM DBU	√	Switches the unit of the level Uses the unit specified by VDSPL, when DBU is selected Default: DBM	:UNIT[1] 2:POWer DBM DBUV DBUVEMF
OLU?	√	OLU?	√	Switches the unit of the level	:UNIT[1] 2:POWer?
VDSPL EMF TERM	√	VDSPL EMF TERM	√	Sets the voltage display Switches the unit of display to the one specified by VDSPL, where OLU is DBU Makes no switching but leaves the display as dBm, where OLU is DBM Default EMF	:UNIT[1] 2:POWer DBM DBUV DBUVEMF
VDSPL?	√	VDSPL?	√	Sets the voltage display	:UNIT[1] 2:POWer?
OOS 1	√	OOS <rel_ampl>	√	Sets the offset output level	[:SOURce[1] 2]:POWe r[:LEVel][:IMMediat e]:OFFSet <rel_ampl>
OOS?	√	OOS?	√	Sets the offset output level	[:SOURce[1] 2]:POWe r[:LEVel][:IMMediat e]:OFFSet?
OOF ON OFF	√	OOF ON OFF	√	Turns the offset on/off	[:SOURce[1] 2]:POWe r[:LEVel][:IMMediat e]:OFFSet:STATe <boolean>

**Table F.4.1-1 Compatible List of Level Functions Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
OOF?	√	OOF?	√	Turns the offset on/off	[ :SOURce[1] 2]:POWe r[:LEVel][:IMMediat e]:OFFSet:StAte?
ORL ON OFF	√	ORL ON OFF	√	Turns the relative level on/off	[ :SOURce[1] 2]:POWe r:REFEreNce:StAte <boolean>
ORL?	√	ORL?	√	Turns the relative level on/off	[ :SOURce[1] 2]:POWe r:REFEreNce:StAte?
OCNT ON OFF	√	OCNT ON OFF	√	Continuous mode (ATT Hold)	[ :SOURce[1] 2]:POWe r:ATTenuation:AUTO <boolean>
OCNT?	√	OCNT?	√	Continuous mode (ATT Hold)	[ :SOURce[1] 2]:POWe r:ATTenuation:AUTO?
OIS 1	√	OIS <rel_ampl>	√	Increments the step level	[ :SOURce[1] 2]:POWe r[:LEVel][:IMMediat e]:STEP[:INCRement] <rel_ampl>
OIS?	√	OIS?	√	Increments the step level	[ :SOURce[1] 2]:POWe r[:LEVel][:IMMediat e]:STEP[:INCRement] ?
CAL	√	CAL	√	Executes the level calibration	[ :SOURce[1] 2]:POWe r:ALC:SEARch [ONCE]

Table F.4.1-1 Compatible List of Level Functions Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
ORLR?	√	ORLR?	√	Relative reference level	[ :SOURce[1]   2 ] :POWe r:REFeRence?
ORLV 1	√	ORLV <rel_ampl>	√	Relative output level	[ :SOURce[1]   2 ] :POWe r:REFeRence:AMPLitu de <rel_ampl>
ORLV?	√	ORLV?	√	Relative output level	[ :SOURce[1]   2 ] :POWe r:REFeRence:AMPLitu de?
EXTALC ON OFF	N/A	—	—	Switches the external ALC mode Supported by the 2nd step and after	—
EXTALC?	N/A	—	—	Switches the external ALC mode Supported by the 2nd step and after	—
ALCSTT?	√	ALCSTT?	√	Obtains the ALC status	[ :SOURce[1]   2 ] :POWe r:ALC:ERRor?
LVLACCSTT?	√	LVLACCSTT?	√	Obtains the level accuracy status Regards as unlevelled, when the [ :SOURce[1]   2 ] :POWe r:UNLeveled:ERRor? is other than NORM.	[ :SOURce ] :UNLeveled :ERRor?
ATTCHKSTT?	√	ATTCHKSTT?	√	Obtains the attenuator wearing status	—
LVLSTTLST?	√	LVLSTTLST?	√	Level output status	—

## F.5 Modulation Functions

### F.5.1 Common to modulation functions

Given below is the compatible list of device messages common to modulation functions

**Table F.5.1-1 Compatible List of Device Messages Common to Modulation Functions**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN BB_TOP	√	SCREEN BB_TOP	N/A	Moves to the modulation function screen This command is accepted but the screen is not moved	—
BBREFCOND?	√	BBREFCOND?	√	BB Reference Clock Condition NORMAL :Int lock or Ext lock UNLOCK :Int unlock CHKEXT :Ext unlock	[ :SOURce[1]   2 ] :RADI o :ARB :CLOCK :REFeren ce :ERRor?

## F.5.2 Modulation

Given below is the compatible list of the modulation device messages.

**Table F.5.2-1 Compatible List of Modulation Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN BB_ADVANCE	√	SCREEN BB_ADVANCE	N/A	Moves to the Advanced Menu screen This command is accepted but the screen is not moved.	—
DLRES	√	DLRES	√	Waveform Restart	[ :SOURce[1]   2 ] :RADI o:ARB:WAVeform:REST art
LOADEDFILESEL WMA,s1,s2	√	LOADEDFILESEL WMA,<string1>,<string 2>	√	Selects waveform files	[ :SOURce[1]   2 ] :RADI o:ARB:WMA:WAVeform <string1>,<string2>
LOADEDFILESEL? WMA	√	LOADEDFILESEL? WMA	√	Selects waveform files	[ :SOURce[1]   2 ] :RADI o:ARB:WMA:WAVeform?
LOADEDFILESEL WMB,s1,s2	√	LOADEDFILESEL WMB,<string1>,<string 2>	√	Selects waveform files	[ :SOURce[1]   2 ] :RADI o:ARB:WMB:WAVeform <string1>,<string2>
LOADEDFILESEL? WMB	√	LOADEDFILESEL? WMB	√	Selects waveform files	[ :SOURce[1]   2 ] :RADI o:ARB:WMB:WAVeform?



**Table F.5.2-1 Compatible List of Modulation Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
LOADEDFILESEL LONG,s1,s2	√	LOADEDFILESEL LONG,<string1>,<string2>	√	Selects waveform files	[ :SOURce[1]   2 ] :RADI o:ARB:LONG:WAVEform <string1>,<string2>
LOADEDFILESEL? LONG	√	LOADEDFILESEL? LONG	√	Selects waveform files	[ :SOURce[1]   2 ] :RADI o:ARB:LONG:WAVEform ?
LOADEDFILESEL CONB,s1,s2	√	LOADEDFILESEL COMB,<string1>,<string2>	√	Selects waveform files	[ :SOURce[1]   2 ] :RADI o:ARB:COMBination:W AVEform <string1>,<string2>
LOADEDFILESEL? COMB	√	LOADEDFILESEL? COMB	√	Selects waveform files	[ :SOURce[1]   2 ] :RADI o:ARB:COMBination:W AVEform?
PAT a,s1,s2	√	PAT WMA WMB LONG COMB,<string1>,<string2>	√	Selects waveform files Operates similarly as the LOADEDFILESEL.....command	[ :SOURce[1]   2 ] :RADI o:ARB:WMA WMB:WAVEf orm <string1>,<string2> [ :SOURce[1]   2 ] :RADI o:ARB:WAVEform <string1>,<string2>

Table F.5.2-1 Compatible List of Modulation Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
PAT? a	√	PAT? WMA WMB LONG COMB	√	Selects waveform files Operates similarly as the LOADEDFILESEL.....command	[ :SOURce[1]   2] :RADI o:ARB:WMA WMB:WAVef orm? [ :SOURce[1]   2] :RADI o:ARB:WAVEform?
PATCOMBMODE EDIT DEFINED	√	PATCOMBMODE EDIT DEFINED	√	Pattern Addition	[ :SOURce[1]   2] :RADI o:ARB:PCOMbination EDIT DEFined
PATCOMBMODE?	√	PATCOMBMODE?	√	Pattern Addition	[ :SOURce[1]   2] :RADI o:ARB:PCOMbination?
PATSOF n	√	PATSOF <ext_integer>	√	Start Offset	[ :SOURce[1]   2] :RADI o:ARB:TIME:SOFFset <ext_integer>
PATSOF?	√	PATSOF?	√	Start Offset	[ :SOURce[1]   2] :RADI o:ARB:TIME:SOFFset?
PATWMALVL 1	√	PATWMALVL <ampl>	√	Pattern (WM(A)) Level	[ :SOURce[1]   2] :RADI o:ARB:WMA:POWer <ampl>
PATWMALVL?	√	PATWMALVL? [DBM DBU DBUT]	√	Pattern (WM(A)) Level Reads by specifying the unit DBM : dBm, DBU : dB $\mu$ V(EMF), DBUT : dB $\mu$ V(TERM)	[ :SOURce[1]   2] :RADI o:ARB:WMA:POWer?

**Table F.5.2-1 Compatible List of Modulation Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
PATWMBLVL 1	√	PATWMBLVL <ampl>	√	Pattern (WM(B)) Level Does not depend on the AWGN converted value.	[ :SOURce[1]   2 ] :RADI o :ARB :WMB :POWer <ampl>
PATWMBLVL?	√	PATWMBLVL? [DBM DBU DBUT]	√	Pattern (WM(B)) Level Reads by specifying the unit DBM : dBm, DBU : dBμV(EMF), DBUT : dBμV(TERM)	[ :SOURce[1]   2 ] :RADI o :ARB :WMB :POWer?
PATWMBDLVL 1	√	PATWMBDLVL <ampl>	√	Pattern (WM(B')) Level Does not depend on the AWGN converted value.	[ :SOURce[1]   2 ] :RADI o :ARB :WMB :POWer <ampl>
PATWMBDLVL?	√	PATWMBDLVL? [DBM DBU DBUT]	√	Pattern (WM(B')) Level Reads by specifying the unit DBM : dBm, DBU : dBμV (EMF), DBUT : dBμV (TERM)	[ :SOURce[1]   2 ] :RADI o :ARB :WMB :POWer?
PATWMOUT WMA   WMB   WMAB	√	PATWMOUT WMA   WMB   WMAB   OFF	√	Output WMA, WMB	[ :SOURce[1]   2 ] :RADI o :ARB :WMA   WMB :OUTPu t <boolean>
PATWMOUT?	√	PATWMOUT?	√	Output WMA, WMB	[ :SOURce[1]   2 ] :RADI o :ARB :WMA   WMB :OUTPu t?
POWRATIOTARGET WMA   WMB   CONSTANT	√	POWRATIOTARGET WMA   WMB   CONSTANT	√	For setting the A/B output ratio	[ :SOURce ] :ARB :POWer :RATio :TARGet A   B   AB
POWRATIOTARGET?	√	POWRATIOTARGET?	√	For setting the A/B output ratio	[ :SOURce[1]   2 ] :RADI o :ARB :POWer :RATio :T ARGet?

Table F.5.2-1 Compatible List of Modulation Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
PATWMPowRatio l	√	PATWMPowRatio <rel_ampl>	√	A/B output ratio	[ :SOURce[1]   2 ] :RADI o :ARB :POWer :RATio <rel_ampl>
PATWMPowRatio?	√	PATWMPowRatio?	√	A/B output ratio	[ :SOURce[1]   2 ] :RADI o :ARB :POWer :RATio?
PATWmFOF f	√	PATWmFOF <freq>	√	Frequency Offset Changes the frequency offset of side A	[ :SOURce[1]   2 ] :RADI o :ARB :FREQuency :OFF Set <freq>
PATWmFOF?	√	PATWmFOF?	√	Frequency Offset Changes the frequency offset of side A	[ :SOURce[1]   2 ] :RADI o :ARB :FREQuency :OFF Set?
PATWMAFOF f	√	PATWMAFOF <freq>	√	Frequency Offset Changes the frequency offset of side A	[ :SOURce[1]   2 ] :RADI o :ARB :FREQuency :OFF Set <freq>
PATWMAFOF?	√	PATWMAFOF?	√	Frequency Offset Changes the frequency offset of side A	[ :SOURce[1]   2 ] :RADI o :ARB :FREQuency :OFF Set?
PATRunSTT?	√	PATRunSTT?	√	Pattern regeneration status	[ :SOURce[1]   2 ] :RADI o :ARB :REGister [ :STA Tus ] ?
SAMPLINGCLK f	√	SAMPLINGCLK <freq>	√	Sampling Clock Changes the sampling rate of side A	[ :SOURce[1]   2 ] :RADI o :ARB :WMA :SCLock :RA TE <freq>
SAMPLINGCLK?	√	SAMPLINGCLK?	√	Sampling Clock Changes the sampling rate of side A	[ :SOURce[1]   2 ] :RADI o :ARB :WMA :SCLock :RA TE ?

**Table F.5.2-1 Compatible List of Modulation Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
LPF a	√	LPF AUTO THROUGH 100KHZ 3 00KHZ 1MHZ 3MHZ 10MHZ  30MHZ 70MHZ	√	Low Pass Filter Setting is accepted, but no operational effect occurs Default: AUTO	—
LPF?	√	LPF?	√	Low Pass Filter Setting is accepted, but no operational effect occurs.	—
RMSVAL 1	√	RMSVAL <rel_ampl>	√	RMS Value Tuning	[ :SOURce[1]   2 ] :RADI o:ARB:RMSTuning <rel_ampl>
RMSVAL?	√	RMSVAL?	√	RMS Value Tuning	[ :SOURce[1]   2 ] :RADI o:ARB:RMSTuning?
CENTERSIG WMA WMB	√	CENTERSIG WMA WMB BDC	√	Center Signal	[ :SOURce[1]   2 ] :RADI o:ARB:CSIGnal A B BDC
CENTERSIG?	√	CENTERSIG?	√	Center Signal	[ :SOURce[1]   2 ] :RADI o:ARB:CSIGnal?
DMOD ON OFF	√	DMOD ON OFF	√	Modulation On/Off	:OUTPut[1]   2 :MODula tion[:STATe] <boolean>
DMOD?	√	DMOD?	√	Modulation On/Off	:OUTPut[1]   2 :MODula tion[:STATe]?
IQSRC INT EXT	√	IQSRC INT EXT	√	IQ Source INT :Internal, EXT :Analog I/Q In	[ :SOURce[1]   2 ] :DM:S OURce INTernal AEXTernal

Table F.5.2-1 Compatible List of Modulation Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
IQSRC?	√	IQSRC?	√	IQ Source	[ :SOURce[1]   2 ] :DM:S OURce?
MODE INT EXT	√	MODE INT EXT	√	IQ Source	[ :SOURce[1]   2 ] :DM:S OURce INTernal AEXTernal
MODE?	√	MODE?	√	IQ Source	[ :SOURce[1]   2 ] :DM:S OURce?
IQOUT ON OFF	√	IQOUT ON OFF	√	IQ output ON: Analog I/Q Out, OFF :RF	[ :SOURce[1]   2 ] :DM:O UTPut RFOut AEXTernalRFA  RFD
IQOUT?	√	IQOUT?	√	IQ output ON: Analog I/Q Out, OFF :RF	[ :SOURce[1]   2 ] :DM:O UTPut?
SMPLCLKMATCH?	√	SMPLCLKMATCH?	√	Sampling Clock Warning of mismatch	[ :SOURce[1]   2 ] :RADI o:ARB:RMATching:ERR or?

## F.5.3 Load pattern

Given below is the compatible list of Load Pattern device messages.

**Table F.5.3-1 Compatible List of Load Pattern Device Messages**

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN BB_LOADPT	√	SCREEN BB_LOADPT	N/A	Moves to the Load Pattern to Memory screen This command is accepted but the screen is not moved.	—
LDFILE WMA, s1, s2	√	LDFILE WMA, <string1>, <string2>[, <device>]	√	Loads waveform files Asynchronous command C, when <device> is omitted	:MMEMory[1]   2:LOAD: WAVEform:WMA <string1>, <string2> [, <device>]
LDFILE? WMA	√	LDFILE? WMA, <string1>, <string2>[, <device>]	√	Loads waveform files C, when <device> is omitted	:MMEMory[1]   2:LOAD: WAVEform:WMA? <string1>, <string2> [, <device>]
LDFILE WMB, s1, s2	√	LDFILE WMB, <string1>, <string2>[, <device>]	√	Loads waveform files Asynchronous command C, when <device> is omitted	:MMEMory[1]   2:LOAD: WAVEform:WMB <string1>, <string2> [, <device>]
LDFILE? WMB	√	LDFILE? WMB, <string1>, <string2>[, <device>]	√	Loads waveform files C, when <device> is omitted	:MMEMory[1]   2:LOAD: WAVEform:WMB? <string1>, <string2> [, <device>]
LDFILE LONG, s1, s2	√	LDFILE LONG, <string1>, <string2>[, <device>]	√	Loads waveform files C, when <device> is omitted	:MMEMory[1]   2:LOAD: WAVEform:LONG <string1>, <string2> [, <device>]

Table F.5.3-1 Compatible List of Load Pattern Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
LDFILE? LONG	√	LDFILE? LONG, <string1>,<string2>[,<device>]	√	Lloads waveform files C, when <device> is omitted	:MMEMory[1] 2:LOAD: WAVEform:LONG? <string1>,<string2> [,<device>]
LDFILE COMB,s1,s2	√	LDFILE CONB, <string1>,<string2>[,<device>]	√	Lloads waveform files C, when <device> is omitted	:MMEMory[1] 2:LOAD: WAVEform:COMBinatio n <string1>,<string2> [,<device>]
LDFILE? COMB	√	LDFILE? CONB,<string1>,<string2 >[,<device>]	√	Lloads waveform files C, when <device> is omitted	:MMEMory[1] 2:LOAD: WAVEform:COMBinatio n? <string1>,<string2> [,<device>]
LDPAT a,s1,s2	√	LDPAT WMA WMB LONG COMB,<string1>,<string2>[,<device>]	√	Lloads waveform files C, when <device> is omitted Operates similarly as LOADEDFILESEL ... command	:MMEMory[1] 2:LOAD: WAVEform:WMA <string1>,<string2> [,<device>] :MMEMory[1] 2:LOAD: WAVEform:WMB <string1>,<string2> [,<device>] :MMEMory[1] 2:LOAD: WAVEform <string1>,<string2> [,<device>]



**Table F.5.3-1 Compatible List of Load Pattern Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
LDPAT?	√	LDPAT? WMA WMB LONG COMB,<string1>,<string2>[,<device>]	√	Loads waveform files C, when <device> is omitted Operates similarly as LOADEDFILESEL ... command	:MMEMory[1] 2:LOAD: WAVEform:WMA? <string1>,<string2> [,<device>] :MMEMory[1] 2:LOAD: WAVEform:WMB? <string1>,<string2> [,<device>] :MMEMory[1] 2:LOAD: WAVEform? <string1>,<string2> [,<device>]
SEQFILELDCHK s1, s2	√	SEQFILELDCHK <string1>,<string2>[,<device>]	√	Confirms whether or not loading of combination files for the sequence mode is enabled Synchronous command C, when <device> is omitted	—
SEQFILELDCHK?	√	SEQFILELDCHK?	√	Confirms whether or not loading of combination files for the sequence mode is enabled.	—
LDCANCEL	√	LDCANCEL	√	Cancels loading of the waveform file to the memory	:MMEMory[1] 2:LOAD: WAVEform:ABORT

Table F.5.3-1 Compatible List of Load Pattern Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
LOADEDFILENAME? WMA   WMB   LONG   CO MB, n	√	LOADEDFILENAME? WMA   WMB   LONG   COMB, <ext_integer>	√	Queries the name of the loaded waveform file	:MEMory[1]   2:WAVefo rm:WMA:NAME? <ext_integer> :MEMory[1]   2:WAVefo rm:WMB:NAME? <ext_integer> :MEMory[1]   2:WAVefo rm:NAME? <ext_integer>
PATNAME? WMA   WMB   LONG   CO MB, n	√	PATNAME? WMA   WMB   LONG   COMB, <ext_integer>	√	Queries the name of the loaded waveform file	:MEMory[1]   2:WAVefo rm:WMA:NAME? <ext_integer> :MEMory[1]   2:WAVefo rm:WMB:NAME? <ext_integer> :MEMory[1]   2:WAVefo rm:NAME? <ext_integer>
LOADEDFILENUM? WMA   WMB   LONG   CO MB	√	LOADEDFILENUM? WMA   WMB   LONG   COMB	√	Obtains the number of loaded files.	:MEMory[1]   2:WAVefo rm:WMA:COUNT? :MEMory[1]   2:WAVefo rm:WMB:COUNT? :MEMory[1]   2:WAVefo rm:COUNT?

**Table F.5.3-1 Compatible List of Load Pattern Device Messages (Cont'd)**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
PATNUM? WMA   WMB   LONG   COMB	√	PATNUM? WMA   WMB   LONG   COMB	√	Obtains the number of loaded files	:MEMory[1] 2:WAVefo rm:WMA:COUNT? :MEMory[1] 2:WAVefo rm:WMB:COUNT? :MEMory[1] 2:WAVefo rm:COUNT?
CFTOHDD s1,s2	√	CFTOHDD <string1> CFROOT,<string2>[,<device1>[,<device2>]]	N/A	Copies the waveform file from the external media to the hard disc string1: Name of the copy source package string2: Name of the copy source file device1: Device with the youngest drive letter connected via the one other than opt011=Off : Device with the youngest drive letter connected via the one other than C.  opt011=On : Device with the youngest drive letter connected via the one other than C and D device2: C, when the copy destination device is omitted.	:MEMory:COPY:WAVef orm <device1>[,<string>  ROOT,<string1>,<string2>[,<device2>]]

Table F.5.3-1 Compatible List of Load Pattern Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
DELFILEWM WMA   WMB   LONG   CO MB,s1,s2	√	DELFILEWM WMA   WMB   LONG   COMB, s1, s2	√	Deletes the waveform files on the selected memory	:MEMory[1]   2:DElete :WAVEform[:NAME] <string1>, <string2> :MEMory[1]   2:DElete :WAVEform:WMA[:NAME ] <string1>, <string2> :MEMory[1]   2:DElete :WAVEform:WMB[:NAME ] <string1>, <string2>
DELFILEWM ALL	√	DELFILEWM ALL	√	Deletes the waveform files on all memories	:MEMory[1]   2:DElete :WAVEform:ALL
DELPATWM WMA   WMB   LONG   CO MB,s1,s2	√	DELPATWM WMA   WMB   LONG   COMB, s1, s2	√	Deletes the waveform files on the selected memory	:MEMory[1]   2:DElete :WAVEform[:NAME] <string1>, <string2> :MEMory[1]   2:DElete :WAVEform:WMA[:NAME ] <string1>, <string2> :MEMory[1]   2:DElete :WAVEform:WMB[:NAME ] <string1>, <string2>
DELPATWM ALL	√	DELPATWM ALL	√	Deletes the waveform files on all memories	:MEMory[1]   2:DElete :WAVEform:ALL

**Table F.5.3-1 Compatible List of Load Pattern Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
WMSPC? WMA   WMB	√	WMSPC? WMA   WMB	√	Obtains the free space of the memory	:MEMory[1]   2:WAVefo rm:WMA:FREE? :MEMory[1]   2:WAVefo rm:WMB:FREE?
WMOPTIMIZE WMA   WMB	√	WMOPTIMIZE WMA   WMB	√	Optimizes the memory Command F is accepted but does not affect the MG3710A/MG3740A	—
WMOPTCHK WMA   WMB	√	WMOPTCHK WMA   WMB	√	Checks the optimization of the memory The command is accepted but does not affect the MG3710A/MG3740A	—
WMOPTCHK? WMA   WMB	√	WMOPTCHK? WMA   WMB	√	Checks the optimization of the memory The command is accepted but does not affect the MG3710A/MG3740A Response: Always NO_NEED_OPTIMIZE	—
WMOPTCANCEL	√	WMOPTCANCEL	√	Stops the optimization of the memory The command is accepted but does not affect the MG3710A/MG3740A	—
HDDSPC?	√	HDDSPC? [<device>]	N/A	Obtains the space information of the hard disk C, when <device> is omitted	:MMEMory:FREE[:ALL] ? [<device>]
COMBPAT? s1,s2,WMA   WMB	√	COMBPAT? <string1>,<string2>,WMA   WMB[,<device>]	N/A	Queries the pattern file name existing on HDD. C, when <device> is omitted Returns "NONE","NONE" when querying non existing files and sequence files	—

Table F.5.3-1 Compatible List of Load Pattern Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
COMBTOTALSIZE? s1,s2	√	COMBTOTALSIZE? <string1>,<string2>,[<de vice>]	N/A	Queries the total size of the pattern files used by the combination file C, when <device> is omitted Returns in Byte the total size of wvd of each WaveMemory In the case of a Sequence file, returns the total of the wvd files of the element as the size of WaveMemoryA (excluding the overlapped ones) Returns wvd of the AddMode as the size of WaveMemoryB	—
SEQELMNUM? s1,s2	√	SEQELMNUM? <string1>,<string2>[,<de vice>]	N/A	Queries the number of elements that belong to the combination file for the sequence mode existing on HDD C, when <device> is omitted	—
SEQELMNAME? s1,s2,n	√	SEQELMNAME? <string1>,<string2>,<ext _integer>[,<device>]	N/A	Queries the number of elements that belong to the combination file for the sequence mode existing on HDD C, when <device> is omitted	—
SEQCURRENTELM?	√	SEQCURRENTELM?	√	Obtains the element number of the pattern regenerated in the sequence	—
FILEVER? s1,s2	√	FILEVER? <string1>,<string2>[,<de vice>]	N/A	Queries the version number of the pattern file existing on HDD C, when <device> is omitted	—

## F.5.4 Ext I/O Setup

Given below is the compatible list of the Ext I/O Setup device messages:

**Table F.5.4-1 Compatible List of Ext I/O Setup Device Messages**

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN B_IOSETUP	√	SCREEN B_IOSETUP	N/A	Moves to the Ext I/O Setup screen This command is accepted but the screen is not moved	—
SFTRG ON OFF	√	SFTRG ON OFF	√	Start/Frame Trigger	[ :SOURce[1] 2]:RADi o:ARB:TRIGger[:STAT e] <boolean>
SFTRG?	√	SFTRG?	√	Start/Frame Trigger	[ :SOURce[1] 2]:RADi o:ARB:TRIGger[:STAT e]?
SFTRGMODE START FRAME	√	SFTRGMODE START FRAME	√	Start/Frame Trigger Mode	[ :SOURce[1] 2]:RADi o:ARB:TRIGger:TYPE START FRAME
SFTRGMODE?	√	SFTRGMODE?	√	Start/Frame Trigger Mode	[ :SOURce[1] 2]:RADi o:ARB:TRIGger:TYPE?
STGS INT EXTSTA EXT E XTFRM	√	STGS INT EXTSTA EXT EXTFRM	√	Start/Frame Trigger Source	—
STGS?	√	STGS?	√	Start/Frame Trigger Source Returns EXTSTA when Start Trigger is set	—

Table F.5.4-1 Compatible List of Ext I/O Setup Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
STDLY n	√	STDLY <ext_numeric>	√	Start/Frame Trigger Delay Setting unit: In sample point, Resolution: 0.01 The setting of STDLY is as same as that of STDLYSYM (a/OverSampling)	—
STDLY?	√	STDLY?	√	Start/Frame Trigger Delay	—
STDLYSYM n	√	STDLYSYM <ext_numeric>	√	Start/Frame Trigger Delay (to be specified in conversion unit) Resolution: 0.01	[ :SOURce ] :ARB:TRIGger:DELay <ext_numeric>
STDLYSYM?	√	STDLYSYM?	√	Start/Frame Trigger Delay (to be specified in conversion unit)	[ :SOURce [ 1 ]   2 ] :RADi o:ARB:TRIGger:DELay ?
EIST RISE FALL	√	EIST RISE FALL	√	Start/Frame Trigger Edge	[ :SOURce [ 1 ]   2 ] :RADi o:ARB:TRIGger:SLOPe POSitive NEGative
EIST?	√	EIST?	√	Start/Frame Trigger Edge	[ :SOURce [ 1 ]   2 ] :RADi o:ARB:TRIGger:SLOPe ?
REFCLKSRC INT EXT	√	REFCLKSRC INT EXT EXTS SYNC	√	BB Reference Clock Source INT :Internal, EXT:External EXTS :External(BB Ref Sync) SYNC :Sync with 1st SG	[ :SOURce [ 1 ]   2 ] :RADi o:ARB:CLOCK:REFeren ce [ :SOURce ] INTernal EXTernal E XTSync
REFCLKSRC?	√	REFCLKSRC?	√	BB Reference Clock Source	[ :SOURce [ 1 ]   2 ] :RADi o:ARB:CLOCK:REFeren ce [ :SOURce ] ?



Table F.5.4-1 Compatible List of Ext I/O Setup Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
PATTRG ON OFF	√	PATTRG ON OFF	√	Pattern Trigger On/Off	[ :SOURce[1]  2] :RADi o:ARB:SEQuence:TRIG ger[:STATe] <boolean>
PATTRG?	√	PATTRG?	√	Pattern Trigger On/Off	[ :SOURce[1]  2] :RADi o:ARB:SEQuence:TRIG ger[:STATe]?
PATTRGEDGE RISE FALL	√	PATTRGEDGE RISE FALL	√	Pattern Trigger Edge Valid only for Pattern Trigger 1	[ :SOURce[1]  2] :RADi o:ARB:SEQuence:TRIG ger1:SLOPe POSitive NEGative
PATTRGEDGE?	√	PATTRGEDGE?	√	Pattern Trigger Edge Valid only for Pattern Trigger 1	[ :SOURce[1]  2] :RADi o:ARB:SEQuence:TRIG ger1:SLOPe?
REFCLKVAL SIXTEENTH EIGHTH QUARTER HALF 1 2 4 8 16	√	[ :SOURce[1] ] :REFCLKVAL SIXTEENTH EIGHTH QUARTER HALF X1 X2 X4 X8 X16	N/A	BB Reference Clock	[ :SOURce[1] ] :RADi o:ARB:CLOCK:REFeRence :DIVision SIXTeenth EIGHth QU ARter HALF X1 X2 X4  X8 X16
REFCLKVAL?	√	[ :SOURce[1] ] :REFCLKVAL?	N/A	BB Reference Clock	[ :SOURce[1] ] :RADi o:ARB:CLOCK:REFeRence :DIVision?
MARKERPOL n,a	√	MARKERPOL <ext_integer>, POS NEG	√	Marker Polarity Valid only for WMA	[ :SOURce[1]  2] :RADi o:ARB:WMA:MARKer1 2  3:POLarity POSitive NEGative

Table F.5.4-1 Compatible List of Ext I/O Setup Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
MARKERPOL? n	√	MARKERPOL? <ext_integer>	√	Marker Polarity Valid only for WMA	[ :SOURce[1] 2]:RADi o:ARB:WMA:MARKer1 2  3:POLarity?
PMO INT EXT OFF	√	PMO INT EXT OFF	√	Pulse Modulation Source When setting INT: PulseModulatio=Off, RFGate=On When setting EXT: PulseModulation=On, PulseSource=Ext Pulse, RFGate=Off When setting OFF: PulseModulatio=Off, RFGate=On	—
PMO?	√	PMO?	√	Pulse Modulation Source When setting INT: When RFGate=On EXT: When PulseModulation=On, PulseSource=Ext Pulse, and RFGate=Off OFF: Other than the above:	—

## F.5.5 I/Q tuning

Given below is the compatible list of the I/Q Tuning device messages:

**Table F.5.5-1 Compatible List of I/Q Tuning Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN BB_IQTUNING	√	SCREEN BB_IQTUNING	N/A	Moves to the I/Q Tuning screen This command is accepted but the screen is not moved	—
IOLTR p	√	IOLTR <percent>	N/A	I Output Level Trimming	[ :SOURce[1]] :DM: IQA Djustment:EXTernal: ITrimming <percent>
IOLTR?	√	IOLTR?	N/A	I Output Level Trimming	[ :SOURce[1]] :DM: IQA Djustment:EXTernal: ITrimming?
QOLTR p	√	QOLTR <percent>	N/A	Q Output Level Trimming	[ :SOURce[1]] :DM: IQA Djustment:EXTernal: QTrimming <percent>
QOLTR?	√	QOLTR?	N/A	Q Output Level Trimming	[ :SOURce[1]] :DM: IQA Djustment:EXTernal: QTrimming?

Table F.5.5-1 Compatible List of I/Q Tuning Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
ICOMOS 1	√	ICOMOS <voltage>	N/A	I Common Offset While I-phase and Q-phase can be set and read separately on MG3700A, setting and reading either I-phase or Q-phase on the MG3710A/MG3740A refers to IQ Common Offset. (For example, if Q-phase is set after I-phase is set, the value of IQ Common Offset is the setting for Q-phase.)	[ :source :IQADjustment:EXTernal:COFFset <voltage>
ICOMOS?	√	ICOMOS?	N/A	I Common Offset While I-phase and Q-phase can be set and read separately on MG3700A, setting and reading either I-phase or Q-phase on the MG3710A/MG3740A refers to IQ Common Offset. (For example, if Q-phase is set after I-phase is set, the value of IQ Common Offset is the setting for Q-phase.)	[ :SOURce[1]] :DM:IQA Djustment:EXTernal: COFFset?
QCOMOS 1	√	QCOMOS <voltage>	N/A	Q Common Offset While I-phase and Q-phase can be set and read separately on MG3700A, setting and reading either I-phase or Q-phase on the MG3710A/MG3740A refers to IQ Common Offset. (For example, if Q-phase is set after I-phase is set, the value of IQ Common Offset is the setting for Q-phase.)	[ :source :IQADjustment:EXTernal:COFFset <voltage>

**Table F.5.5-1 Compatible List of I/Q Tuning Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
QCOMOS?	√	QCOMOS?	N/A	Q Common Offset While I-phase and Q-phase can be set and read separately on MG3700A, setting and reading either I-phase or Q-phase on the MG3710A/MG3740A refers to IQ, Common, Offset. (For example, if Q-phase is set after I-phase is set, the value of IQ, Common, Offset is the setting for Q-phase.)	[ :SOURce[1]] :DM:IQA Djustment:EXTernal: COFFset?
IDIFFOS 1	√	IDIFFOS <voltage>	N/A	I Differential Offset	[ :SOURce[1]] :DM:IQA Djustment:EXTernal: DIOffset <voltage>
IDIFFOS?	√	IDIFFOS?	N/A	I Differential Offset	[ :SOURce[1]] :DM:IQA Djustment:EXTernal: DIOffset?
QDIFFOS 1	√	QDIFFOS <voltage>	N/A	Q Differential Offset	[ :SOURce[1]] :DM:IQA Djustment:EXTernal: DQOOffset <voltage>
QDIFFOS?	√	QDIFFOS?	N/A	Q Differential Offset	[ :SOURce[1]] :DM:IQA Djustment:EXTernal: DQOOffset?

## F.5.6 Edit HDD

Given below is the compatible list of Edit HDD device messages.

**Table F.5.6-1 Compatible List of Edit HDD Device Messages**

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN BB_EDITHDD	√	SCREEN BB_EDITHDD	N/A	Moves to the Edit HDD screen This command is accepted but the screen is not moved	—
DELFILEHDD s1,s2	√	DELFILEHDD <string1>,<string2>[,<device>]	N/A	Deletes waveform files on the hard disk C, when <device> is omitted wvc is given preference where both wvc and wvi exist.	:MMEMory:DELeTe:WAV eform[:NAME] <string1>,<string2> , [<device>] :MMEMory:DELeTe:WAV eform:SINGLE[:NAME] <string1>,<string2> , [<device>]
DELPATHDD s1,s2	√	DELPATHDD <string1>,<string2>[,<device>]	N/A	Deletes waveform files on the hard disk. C, when <device> is omitted. wvc is given preference where both wvc and wvi exist.	:MMEMory:DELeTe:WAV eform[:NAME] <string1>,<string2> , [<device>] :MMEMory:DELeTe:WAV eform:SINGLE[:NAME] <string1>,<string2> , [<device>]

## F.5.7 Sequence Progress

Given below is the compatible list of Sequence Progress device messages.

**Table F.5.7-1 Compatible List of Sequence Progress Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN BB_PROGRESS	√	SCREEN BB_PROGRESS	N/A	Moves to the Sequence Progress screen This command is accepted but the screen is not moved.	—
SEQNEXTPAT	√	SEQNEXTPAT	√	Sequence Next Pattern	[ :SOURce[1]   2 ] :RADi o:ARB:SEQuence:NEXT
SEQRESTART	√	SEQRESTART	√	Sequence Restart	INITiate[1]   2 :ARB:S EQuence[:IMMediate]
SEQPLAYMODE AUTO   MANUAL	√	SEQPLAYMODE AUTO   MANUAL	√	Sequence Play Mode	[ :SOURce[1]   2 ] :RADi o:ARB:SEQuence:MODE AUTO   MANual
SEQPLAYMODE?	√	SEQPLAYMODE?	√	Sequence Play Mode	[ :SOURce[1]   2 ] :RADi o:ARB:SEQuence:MODE ?
SEQSWPOINT PAT_END   FRAME_END	√	SEQSWPOINT PAT_END   FRAME_END	√	Sequence Switching Point	[ :SOURce[1]   2 ] :RADi o:ARB:SEQuence:TRIG ger:SPOint PATTen   FRAMe
SEQSWPOINT?	√	PSEQSWPOINT?	√	Sequence Switching Point	[ :SOURce[1]   2 ] :RADi o:ARB:SEQuence:TRIG ger:SPOint?

## F.6 Utility Function

### F.6.1 Common to utility functions

Given below is the compatible list of device messages common to utility functions.

**Table F.6.1-1 Compatible List of Device Messages Common To Utility Functions**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_TOP	√	SCREEN UTIL_TOP	N/A	Moves to the utility function top screen This command is accepted but the screen is not moved.	—



## F.6.2 Save/Recall

Given below is the compatible list of Save/Recall device messages.

**Table F.6.2-1 Compatible List of Save/Recall Device Messages**

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_PARAMS	√	SCREEN UTIL_PARAMS	N/A	Moves to the Parameter Save/Recall screen This command is accepted but the screen is not moved.	—
PRMSAV s	√	PRMSAV <string>[, <device>]	N/A	Parameter Save The device specified by PRMMEDIA when <device> is omitted.	:MMEMory:STORe:STATe e [<filename>[, <device>]]
PRMREC s	√	PRMREC <string>[, <device>]	N/A	Parameter Recall The device specified by PRMMEDIA when <device> is omitted.	:MMEMory:LOAD:STATe <filename>[, <device>]
PRMDEL s	√	PRMDEL <string>[, <device>]	N/A	Parameter File Delete The device specified by PRMMEDIA when <device> is omitted.	:MMEMory:DELeTe:STATe Te <filename>[, <device>]
PRMLST?	√	PRMLST? [<device>]	N/A	Parameter File List The device specified by PRMMEDIA when <device> is omitted.	:MMEMory:CATalog:STATe? <device>

Table F.6.2-1 Compatible List of Save/Recall Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
PRMMEDIA HDD CF	√	PRMMEDIA HDD CF	N/A	Selects media for Save/Recall. C drive when HDD is selected. Devices other than HDD whose drive letter is the youngest, when CF is selected Default: HDD	—
PRMMEDIA?	√	PRMMEDIA?	N/A	Selects media for Save/Recall	—

### F.6.3 BER Measurement

Given below is the compatible list of the BER measurement device messages.

**Table F.6.3-1 Compatible List of BER Measurement Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_BERT	√	SCREEN UTIL_BERT	N/A	Moves to the BER measurement screen This command is accepted but the screen is not moved.	—
SCREEN UTIL_BER_IO	√	SCREEN UTIL_BER_IO	N/A	Moves to the BER measurement Interface Setup screen This command is accepted but the screen is not moved.	—
SCREEN UTIL_BER_RESYNC	√	SCREEN UTIL_BER_RESYNC	N/A	Moves to the BER measurement Resync Condition Setup screen This command is accepted but the screen is not moved.	—
BERSTART	√	BERSTART	N/A	Executes the BER measurement	:INITiate:BERT[:IMM ediate]
BERSTOP	√	BERSTOP	N/A	Stops the BER measurement	:ABORT:BERT
BERCOUNTCLR	√	BERCOUNTCLR	N/A	Clears the BER measurement bit	[:SENSe]:BERT[:BASE band]:COUNT:CLEar
BERDATA POS NEG	√	BERDATA POS NEG	N/A	Sets the Data polarity	:INPut:BERT[:BASEba nd]:DATA:POLarity POSitive NEGative

Table F.6.3-1 Compatible List of BER Measurement Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
BERDATA?	√	BERDATA?	N/A	Sets the Data polarity.	:INPut:BERT[:BASeba nd]:DATA:POLarity?
BERCLK RISE FALL	√	BERCLK RISE FALL	N/A	Sets the Clock polarity	:INPut:BERT[:BASeba nd]:CLOCK:POLarity POSitive NEGative
BERCLK?	√	BERCLK?	N/A	Sets the Clock polarity.	:INPut:BERT[:BASeba nd]:CLOCK:POLarity?
BERENBL POS NEG DISABLE	√	BERENBL POS NEG DISABLE	N/A	Sets the Enable polarity	:INPut:BERT[:BASeba nd]:CGATe:POLarity POSitive NEGative D ISable
BERENBL?	√	BERENBL?	N/A	Sets the Enable polarity	:INPut:BERT[:BASeba nd]:CGATe:POLarity?
BERDATATHLD 1	N/A	—	-	Data signal threshold level.	—
BERDATATHLD?	N/A	—	-	Data signal threshold level	—
BERCLKTHLD 1	N/A	—	-	Clock signal threshold level	—
BERCLKTHLD?	N/A	—	-	Clock signal threshold level	—
BERENBLTHLD 1	N/A	—	-	Enable level threshold level	—

Table F.6.3-1 Compatible List of BER Measurement Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
BERENBLTHLD?	N/A	—	-	Enable level threshold level	—
BERDATADELAY n	N/A	—	-	Sets Data Delay	—
BERDATADELAY?	N/A	—	-	Sets Data Delay	—
BERENBLDELAY n	N/A	—	-	Sets Enable Delay	—
BERENBLDELAY?	N/A	—	-	Sets Enable Delay	—
BERINZ HIZ 50	N/A	—	-	Input impedance	—
BERINZ?	N/A	—	-	Input impedance	—
BERMEDIA HDD CF	√	BERMEDIA HDD CF	N/A	Selects media for the BER measurement log. C drive when HDD is selected Devices other than HDD whose drive letter is the youngest, when CF is selected. Default: HDD	—
BERMEDIA?	√	BERMEDIA?	N/A	Selects media for the BER measurement log	—
BERAUTORES SYNC ON OFF	√	BERAUTORES SYNC ON OFF	N/A	Sets the automatic resynchronization	[ :SENSe ] :BERT [ :BASE band ] :RSYNc [ :STAtE ] <boolean>
BERAUTORES SYNC?	√	BERAUTORES SYNC?	N/A	Sets the automatic resynchronization	[ :SENSe ] :BERT [ :BASE band ] :RSYNc [ :STAtE ] ?
BERMODE SINGLE CONTINUOUS  ENDLESS	√	BERMODE SINGLE CONTINUOUS END LESS	N/A	Sets the measurement mode	[ :SENSe ] :BERT [ :BASE band ] :MODE SINGLe CONTInuous E NDLess

Table F.6.3-1 Compatible List of BER Measurement Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
BERMODE?	√	BERMODE?	N/A	Sets the measurement mode	[ :SENSe]:BERT[:BASE band]:MODE?
BERCOUNTMODE TIME DATABIT ERRO RBIT	√	BERCOUNTMODE DATABIT ERRORBIT	N/A	Measurement end condition TIME specification is not supported	[ :SENSe]:BERT[:BASE band]:STOP:CRITeria [:SElect] EBIT NONE
BERCOUNTMODE?	√	BERCOUNTMODE?	N/A	Measurement end condition	[ :SENSe]:BERT[:BASE band]:STOP:CRITeria [:SElect]?
BERTIME n	N/A	—	-	Measurement time	—
BERTIME?	N/A	—	-	Measurement time	—
BERBIT b	√	BERBIT <ext_integer>	N/A	Measurement bit count	[ :SENSe]:BERT[:BASE band]:TBITs <ext_integer>
BERBIT?	√	BERBIT?	N/A	Measurement bit count	[ :SENSe]:BERT[:BASE band]:TBITs?
BERERRORBIT b	√	BERERRORBIT <ext_integer>	N/A	Measurement error bit count	[ :SENSe]:BERT[:BASE band]:STOP:CRITeria :EBIT <ext_integer>
BERERRORBIT?	√	BERERRORBIT?	N/A	Measurement error bit count	[ :SENSe]:BERT[:BASE band]:STOP:CRITeria :EBIT?

**Table F.6.3-1 Compatible List of BER Measurement Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
BERLOG s	√	BERLOG <string>[,<device>]	N/A	Log output Device specified by BERMEDIA when <device> is omitted	:MMEMory:STORe:BERT :LOG <string>[,<device>]
BERLOGCLEAR	√	BERLOGCLEAR	N/A	Clears logs	[ :SENSe]:BERT[:BASE band]:LOG:CLear
BERLOGFILEDEL s	√	BERLOGFILEDEL <string>[,<device>]	N/A	Deletes Log files Device specified by BERMEDIA when <device> is omitted	:MMEMory:DELeTe:BER T:LOG <string>[,<device>]
BERTYPE PN9 PN11 PN15 PN2 0 PN23 ALL0 ALL1  ALT PN9FIX PN11FI X PN15FIX PN20FIX  PN23FIX USERPATT ERN	√	BERTYPE PN9 PN11 PN15 PN20 PN 23 ALL0 ALL1 ALT PN9F IX PN11FIX PN15FIX PN 20FIX PN23FIX USERPAT TERN	N/A	PN Type	[ :SENSe]:BERT[:BASE band]:PRBS[:DATA] PN9 PN11 PN15 PN20  PN23 ALL0 ALL1 ALT  FPN9 FPN11 FPN15 FP N20 FPN23 USER
BERTYPE?	√	BERTYPE?	N/A	PN Type	[ :SENSe]:BERT[:BASE band]:PRBS[:DATA]?
RCVBIT?	√	RCVBIT?	n/a	Receive Bit	FETCh:BERT:DATA:COU Nt?
BITERR?	√	BITERR?	N/A	Bit Error Count	FETCh:BERT:ERRor:CO UNt?

Table F.6.3-1 Compatible List of BER Measurement Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
BER? EP ER	√	BER? EP ER	N/A	Bit Error Rate	FEtCh:BERt:ERRor:RA TE?
BERSYNCLoss?	√	BERSYNCLoss?	N/A	Number of occurrences of Sync Loss.	[ :SENSe] :BERT [:BASE band] :SYNLoss:COUNT ?
BERSYNCLosSTHLD n, a	√	BERSYNCLosSTHLD <ext_integer>,500 500 0 50000	N/A	Threshold for detecting Sync Loss.	[ :SENSe] :BERT [:BASE band] :RSYNc:THResho ld <ext_integer>,500 5 000 50000
BERSYNCLosSTHLD?	√	BERSYNCLosSTHLD?	N/A	Threshold for detecting Sync Loss	[ :SENSe] :BERT [:BASE band] :RSYNc:THResho ld?
BERSYNCLosSACT COUNT_CLEAR COUNT_KEEP	√	BERSYNCLosSACT COUNT_CLEAR COUNT_KEEP	N/A	Count operation when Sync Loss is detected	[ :SENSe] :BERT [:BASE band] :RSYNc:COUNT:ACTion CLEAR KEEP
BERSYNCLosSACT?	√	BERSYNCLosSACT?	N/A	Count operation when Sync Loss is detected	[ :SENSe] :BERT [:BASE band] :RSYNc:COUNT:ACTion?
BERSTATUS?	√	BERSTATUS?	N/A	Obtain the measurement status	
BERERROR?	√	BERERROR?	N/A	Obtain the measurement error status	[ :SENSe] :BERT [:BASE band] :ERRor?
BERSTOPSTATUS?	√	BERSTOPSTATUS?	N/A	Obtain the measurement stop status	
BERRESULT? EP ER EP_WSYNCLoS S ER_WSYNCLoS S	√	BERRESULT? EP ER EP_WSYNCLoS S ER_WSYNCLoS S	N/A	Obtain the result and status of measurement	—



## F.6.4 BER Measurement (Data Type Detail Setup)

Given below is the compatible list of BER measurement (Data Type Detail Setup) device messages.

**Table F.6.4-1 Compatible List of BER Measurement (Data Type Detail Setup) Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_BER_DETAIL	√	SCREEN UTIL_BER_DETAIL	N/A	Moves to the BER measurement Data Type Detail screen This command is accepted but the screen is not moved.	—
BERPNINITIAL n	√	BERPNINITIAL <binary>	N/A	The default value of the PN pattern to be used for PN Fix. Attaches #B at the head of the argument.	[ :SENSe]:BERT[:BASE band]:PRBS:PNFix:IN ITial <binary>
BERPNINITIAL?	√	BERPNINITIAL?	N/A	The default value of the PN pattern to be used for PN Fix When the language mode is MS269xA, #B is not attached to the return value	[ :SENSe]:BERT[:BASE band]:PRBS:PNFix:IN ITial?
BERPNFIXLENG n	√	BERPNFIXLENG <ext_integer>	N/A	The length of one cycle of the pattern to be used for PN Fix	[ :SENSe]:BERT[:BASE band]:PRBS:PNFix:LE NGth <ext_integer>
BERPNFIXLENG?	√	BERPNFIXLENG?	N/A	The length of one cycle of the pattern to be used for PN Fix	[ :SENSe]:BERT[:BASE band]:PRBS:PNFix:LE NGth?
BERSYNCSTARTPOS n	√	BERSYNCSTARTPOS <ext_integer>	N/A	Specifies the position of the top bit of the portion in the user defined pattern to be used for synchronization judgment	[ :SENSe]:BERT[:BASE band]:PRBS:USER:SYN C:START <ext_integer>

Table F.6.4-1 Compatible List of BER Measurement (Data Type Detail Setup) Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
BERSYNCSTARTPOS?	√	BERSYNCSTARTPOS?	N/A	Specifies the position of the top bit of the portion in the user pattern to be used for synchronization judgment	[ :SENSe] :BERT [ :BASEband] :PRBS :USER :SYN C :START?
BERSYNCLENG n	√	BERSYNCLENG <ext_integer>	N/A	Length of the portion in the user defined pattern to be used for synchronization judgment	[ :SENSe] :BERT [ :BASEband] :PRBS :USER :SYN C :LENGth <ext_integer>
BERSYNCLENG?	√	BERSYNCLENG?	N/A	Length of the portion in the user defined pattern to be used for synchronization judgment	[ :SENSe] :BERT [ :BASEband] :PRBS :USER :SYN C :LENGth?
BERLOADMEDIA a	√	BERLOADMEDIA HDD CF	N/A	Loading source media of the user defined pattern C drive when HDD is selected Devices other than HDD whose drive letter is the youngest, when CF is selected Default: HDD	—
BERLOADMEDIA?	√	BERLOADMEDIA?	N/A	User defined pattern loading source media	—
BERUSERPATLST?	√	BERUSERPATLST? [<device>]	N/A	List of the user defined pattern files Device specified by BERLOADMEDIA when <device> is omitted	:MMEMory :LIST :BERT :PATtern? [<device>]
BERLOADUSERPAT s	√	BERLOADUSERPAT <string>[,<device>]	N/A	Loads the user defined patterns Device specified by BERLOADMEDIA when <device> is omitted	:MMEMory :LOAD :BERT :PATtern <string>[,<device>]

**Table F.6.4-1 Compatible List of BER Measurement (Data Type Detail Setup) Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
BERUSERPAT?	√	BERUSERPAT?	N/A	Current user defined pattern file	[ :SENSe] :BERT [ :BASE band] :PRBS:USER:PAT Tern?
BERUSERPATLENG?	√	BERUSERPATLENG?	N/A	Current user defined pattern bit length	[ :SENSe] :BERT [ :BASE band] :PRBS:USER:LEN Gth?

## F.6.5 Alarm Monitor

Given below is the compatible list of Alarm Monitor device messages.

**Table F.6.5-1 Compatible List of Alarm Monitor Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_ALARMMON	√	SCREEN UTIL_ALARMMON	N/A	Moves to the Alarm Monitor screen This command is accepted but the screen is not moved.	—
ALMMONITOR?	√	ALMMONITOR?	√	Alarm Monitor Response = bit0 + bit1 + bit2 + bit3 + bit4 + bit5 + bit6 + bit7 bit7 : Unused (fixed to 0) bit6 : Unused (fixed to 0) bit5 : Unused (fixed to 0) bit4 : RppStatus On bit3 : Unlock BB Int Clock bit2 : ALC Alarm bit1 : Unused (fixed to 0) bit0 : Int.Unlock	—
ALMLOG s	√	ALMLOG <string>[,<device>]	√	Alarm History output Device specified by ALMMEDIA when <device> is omitted	:MMEMory:STORe:ALAR m:LOG <string>[,<device>]

**Table F.6.5-1 Compatible List of Alarm Monitor Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
ALMMEDIA HDD CF	√	ALMMEDIA HDD CF	√	Selects media for Alarm History output C drive when HDD is selected Devices other than HDD whose drive letter is the youngest, when CF is selected Default: HDD	—
ALMMEDIA?	√	ALMMEDIA?	√	Selects media for Alarm History output	—

## F.6.6 Interface Setup

Given below is the compatible list of the Interface Setup device messages.

**Table F.6.6-1 Compatible List of Interface Setup Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_IFSET	√	SCREEN UTIL_IFSET	N/A	Moves to the Interface Setup Interface Setup screen This command is accepted but the screen is not moved.	—
TRM 0 1 LF CRLF	√	TRM 0 1 LF CRLF EOI	N/A	GPIB Terminator	:SYSTem:COMMunicate :GPIB:TERMinator LF CRLF EOI
TRM?	√	TRM?	N/A	GPIB Terminator Response: LF, CRLF, EOI	:SYSTem:COMMunicate :GPIB:TERMinator?

## F.6.7 Network Setup

Given below is the compatible list of the Network Setup device messages:

**Table F.6.7-1 Compatible List of Network Setup Device Messages**

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_NETSET	√	SCREEN UTIL_NETSET	N/A	Moves to the Network Setup Interface Setup screen This command is accepted but the screen is not moved.	—
HOSTNAME s	N/A	—	-	Host Name To be set on Windows	—
HOSTNAME?	N/A	—	-	Host Name To be set on Windows	—
DOMAINNAME s	N/A	—	-	Host Name To be set on Windows	—
DOMAINNAME?	N/A	—	-	Host Name To be set on Windows	—
DHCP ON OFF	N/A	—	-	DHCP To be set on Windows	—
DHCP?	N/A	—	-	DHCP To be set on Windows	—
IPAD n1,n2,n3,n4	N/A	—	-	IP Address To be set on Windows	—
IPAD?	N/A	—	-	IP Address To be set on Windows	—
SUBNET n1,n2,n3,n4	N/A	—	-	Subnet mask To be set on Windows	—

Table F.6.7-1 Compatible List of Network Setup Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SUBNET?	N/A	—	-	Subnet mask To be set on Windows	—
DNSAUTO ON OFF	N/A	—	-	DNS To be set on Windows	—
DNSAUTO?	N/A	—	-	DNS To be set on Windows	—
DNS1AD n1,n2,n3,n4	N/A	—	-	DNS Primary Address To be set on Windows	—
DNS1AD?	N/A	—	-	DNS Primary Address To be set on Windows	—
DNS2AD n1,n2,n3,n4	N/A	—	-	DNS Secondary Address To be set on Windows	—
DNS2AD?	N/A	—	-	DNS Secondary Address To be set on Windows	—
GATEWAY n1,n2,n3,n4	N/A	—	-	Default Gateway To be set on Windows	—
GATEWAY?	N/A	—	-	Default Gateway To be set on Windows	—
IQPROID s	N/A	—	-	IQproducer User ID To be set on Windows	—
IQPROID?	N/A	—	-	IQproducer User ID To be set on Windows	—
IQPROPASWD s	N/A	—	-	IQproducer Password To be set on Windows	—
IPRENEW	N/A	—	-	IP Address Renew To be set on Windows	—



**Table F.6.7-1 Compatible List of Network Setup Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
IPRELEASE	N/A	—	-	IP Address Release To be set on Windows	—
MACAD?	N/A	—	-	MAC Address To be set on Windows	—

## F.6.8 Common Setup

Given below is the compatible list of the Common Setup device messages:

**Table F.6.8-1 Compatible List of Common Setup Device Messages**

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_COMSET	√	SCREEN UTIL_COMSET	N/A	Moves to the Common Setup screen This command is accepted but the screen is not moved.	—
BUZ ON OFF	√	BUZ ON OFF	N/A	Buzzer	:SYSTem:BEEPer ON OFF 0 1
BUZ?	√	BUZ?	N/A	Buzzer	:SYSTem:BEEPer?
REMDISP NORMAL REMA	√	REMDISP NORMAL REMAIN REMA RE MAIN_LAST	N/A	Remote Error Message Mode NORMAL: Clears the error message when the next command is received REMAIN: Keeps the first error message displayed REMA: Same as REMAIN REMAIN_LAST: Keeps the last error message displayed.	:DisplayERRor:MODE NORMAl REMain LAST
REMDISP?	√	REMDISP?	N/A	Remote Error Message Mode	:DISPlay:ERRor:MODE ?
SCRCPYMEDIA HDD CF	√	SCRCPYMEDIA HDD CF	N/A	Screen Copy Media C drive when HDD is selected Devices other than HDD whose drive letter is the youngest, when CF is selected Default: HDD	—
SCRCPYMEDIA?	√	SCRCPYMEDIA?	N/A	Screen Copy Media	—

**Table F.6.8-1 Compatible List of Common Setup Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
BITMAPS COLOR GRAY	√	BITMAPS COLOR GRAY REV MREV	N/A	Bitmap Setup COLOR:Color, GRAY:Monochrome, REV:Reverse MREV:Monochrome&Reverse	:MMEMory:STORe:SCRe en:THEMe NORMAl REVerse MONO chrome MREVerse
BITMAPS?	√	BITMAPS?	N/A	Bitmap Setup	:MMEMory:STORe:SCRe en:THEMe?
TIMESSET n1,n2,n3,n4,n5,n6	N/A	—	-	Time Set To be set on Windows	—
TIMESSET?	N/A	—	-	Time Set To be set on Windows	—
ATTCHKDISP ON OFF	√	ATTCHKDISP ON OFF	N/A	Attenuator check Display Setting is acceptable but no display is made since no ATT error exists. Default: ON	—
ATTCHKDISP?	√	ATTCHKDISP?	N/A	Attenuator check Display	—

## F.6.9 Maintenance Check

Given below is the compatible list of Maintenance Check device messages:

**Table F.6.9-1 Compatible List of Maintenance Check Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_MNTCHK	√	SCREEN UTIL_MNTCHK	N/A	Moves to the Maintenance Check screen This command is accepted but the screen is not moved.	—
ATTT?	√	ATTT?	N/A	Attenuator Count Always returns 0	—
RUNT?	√	RUNT?	N/A	Running Time Unit: Time (H)	:SystemINformation: RTIME?

## F.6.10 Hardware Check

Given below is the compatible list of Hardware Check device messages.

**Table F.6.10-1 Compatible List of Hardware Check Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_HDCHK	√	SCREEN UTIL_HDCHK	N/A	Moves to the Hardware Check screen This command is accepted but the screen is not moved.	—
SCREEN UTIL_HDCHK_OPT	√	SCREEN UTIL_HDCHK_OPT	N/A	Moves to the Option Hardware Check screen This command is accepted but the screen is not moved.	—
HWC?	N/A	—	-	Hardware Check result This function is not supported, since the HW structure is different.	
HWCBER?	N/A	—	-	High-speed BER Hardware Check result This function is not supported, since the HW structure is different.	

Table F.6.10-1 Compatible List of Hardware Check Device Messages (Cont'd)

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SERNUMCPU?	N/A	<p>Not supported due to the different HW structure.</p> <p>To obtain the information about the hardware version, use the following:</p> <p>:SYSTem:FPGA:VERSion? &lt;hardware&gt;</p> <p>:SYSTem:FPGA:VERSion:CATalog?</p> <p>:SYSTem:HARDware:REVi sion? &lt;hardware&gt;</p> <p>:SYSTem:HARDware:REVi sion:CATalog?</p>	-	CPU port serial number	—
BOARDCPUVER?	N/A		-	CPU port version number	—
FPGACPUVER?	N/A		-	CPU FPGA version number	—
IPLVER?	N/A		-	IPL version number	—
SOFTCPUVER?	N/A		-	CPU Software version number	—
SERNUMIF?	N/A		-	IF port serial number	—
BOARDIFVER?	N/A		-	IF port version number	—
FPGADIGVER?	N/A		-	Baseband FPGA (Digital) version number	—
FPGAANAVER?	N/A		-	Baseband FPGA (Analog) version number	—
SERNUMRF?	N/A		-	RF port serial number	—
BOARDRFVER?	N/A		-	RF port version number	—
FPGARFVER?	N/A		-	RF FPGA version number	—
KEYENCVER?	N/A		-	Key Encoder version number	—
SERNUMBER?	N/A		-	High-speed BER serial number	—
BOARDBERVER?	N/A		-	High-speed BER port version number	—
FPGABERVER?	N/A		-	High-speed BER FPGA version number	—

**Table F.6.10-1 Compatible List of Hardware Check Device Messages (Cont'd)**

<b>MG3700A Commands</b>	<b>Com- patibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>SG 1/2</b>	<b>Remarks</b>	<b>MG3710A/MG3740A Original Commands</b>
SCREEN UTIL_PRDINF	√	SCREEN UTIL_PRDINF	N/A	Moves to the Product Information screen This command is accepted but the screen is not moved.	—
PType?	√	PType?	N/A	Product Type	:SYSTem:INFormation :TYPE?
PModel?	√	PModel?	N/A	Model Number	:SYSTem:INFormation :MODEl?
SERNum?	√	SERNum?	N/A	Serial Number	:SYSTem:INFormation :SERial?
OPT? N	√	OPT? <integer>	N/A	Confirms whether or not any Option exists Unavailable as it is as a compatible command, since the option structure differs from that of the MG3700A	—

## F.6.11 Install

Given below is the compatible list of Install device messages.

**Table F.6.11-1 Compatible List of Install Device Messages**

MG3700A Commands	Compatibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
SCREEN UTIL_INSTTOP	√	SCREEN UTIL_INSTTOP	N/A	Moves to the Install screen This command is accepted but the screen is not moved.	SCREEN UTIL_INSTTOP
SCREEN UTIL_INSTFRM	√	SCREEN UTIL_INSTFRM	N/A	Moves to the Firmware Install screen This command is accepted but the screen is not moved.	SCREEN UTIL_INSTFRM
SCREEN UTIL_INSTWV	√	SCREEN UTIL_INSTWV	N/A	Moves to the Waveform Data License Install screen This command is accepted but the screen is not moved.	SCREEN UTIL_INSTWV
FIRMINST s	N/A	—	N/A	Firmware Install	—
INSTMEDIA HDD CF	N/A	—	N/A	Install Source Media	—
INSTMEDIA?	N/A	—	N/A	Install Source Media	—
WVKEYNUM?	√	WVKEYNUM?	N/A	Waveform Data License Number	WVKEYNUM?
WVKEYNAME? n	√	WVKEYNAME? <integer>	N/A	Waveform Data License Name	WVKEYNAME? <integer>
WVKEYVER? s	√	WVKEYVER? <string>	N/A	Waveform Data License Version	WVKEYVER? <string>
WVINSTMEDIA HDD CF	√	WVINSTMEDIA HDD CF	N/A	Waveform Data license Install Source Media C drive, when HDD is selected Devices other than HDD whose drive letter is the youngest, when CF is selected Default: HDD	WVINSTMEDIA HDD CF
WVINSTMEDIA?	√	WVINSTMEDIA?	N/A	Waveform Data license Install Source Media	WVINSTMEDIA?



## F.7 IEEE488.2 Common Commands

### F.7.1 Common to IEEE488.2

Given below is the IEEE488.2 common command device messages available on the MG3710A/MG3740A

**Table F.7.1-1 IEEE488.2 Common Device Messages**

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
*CLS	√	*CLS	N/A	Clear Status Command	Same as the compatible command
*ESE	√	*ESE	N/A	Standard Event Status Enable Command	Same as the compatible command
*ESE?	√	*ESE?	N/A	Standard Event Status Enable Query	Same as the compatible command
*ESR?	√	*ESR?	N/A	Standard Event Status Register Query	Same as the compatible command
*IDN?	√	*IDN?	N/A	Identification Query	Same as the compatible command
*OPC	√	*OPC	N/A	Operation Complete Command	Same as the compatible command
*OPC?	√	*OPC?	N/A	Operation Complete Query	Same as the compatible command
*RST	√	*RST	N/A	Reset Command	Same as the compatible command
*SRE	√	*SRE	N/A	Service Request Enable Command	Same as the compatible command
*SRE?	√	*SRE?	N/A	Service Request Enable Query	Same as the compatible command

Table F.7.1-1 IEEE488.2 Common Device Messages (Cont'd)

MG3700A Commands	Com- patibility	MG3710A/MG3740A Compatible Command	SG 1/2	Remarks	MG3710A/MG3740A Original Commands
*STB	√	*STB	N/A	Read Status Byte Query	Same as the compatible command
*TRG	√	*TRG	N/A	Trigger Command	Same as the compatible command
*TST?	√	*TST?	N/A	Self Test Query	Same as the compatible command
*WAI	√	*WAI	N/A	Wait to Continue Command	Same as the compatible command

# *Appendix G SCPI Compatible Command*

---

This appendix describes SCPI commands for signal generators supported by the MG3710A/MG3740A.

Supported signal generators

Agilent            N5162A/N5182A

G.1	Basic Function Commands.....	G-2
G.1.1	Correction Subsystem .....	G-2
G.1.2	Digital Modulation Subsystem .....	G-4
G.1.3	Frequency Subsystem.....	G-10
G.1.4	List/Sweep Subsystem .....	G-13
G.1.5	Fast Subsystem.....	G-16
G.1.6	Marker Subsystem.....	G-17
G.1.7	Power Subsystem.....	G-19
G.2	System Commands .....	G-25
G.2.1	Calibration Subsystem.....	G-25
G.2.2	Communication Subsystem.....	G-27
G.2.3	Display Subsystem .....	G-30
G.2.4	IEEE 488.2 Common Commands .....	G-32
G.2.5	Memory Subsystem.....	G-34
G.2.6	Output Subsystem .....	G-39
G.2.7	Route Subsystem .....	G-40
G.2.8	Status Subsystem.....	G-41
G.2.9	System Subsystem.....	G-44
G.2.10	Trigger Subsystem .....	G-50
G.2.11	Unit Subsystem .....	G-51
G.3	Analog Modulation Commands.....	G-52
G.3.1	Amplitude Modulation Subsystem .....	G-52
G.3.2	Frequency Modulation Subsystem .....	G-54
G.3.3	Phase Modulation Subsystem .....	G-56
G.3.4	Pulse Modulation Subsystem .....	G-58
G.4	Arb Commands .....	G-61
G.4.1	All Subsystem .....	G-61
G.4.2	Dual ARB Subsystem .....	G-62
G.4.3	LARB Subsystem .....	G-71

## G.1 Basic Function Commands

### G.1.1 Correction Subsystem

Correction Subsystem device messages available in MG3710A/MG3740A are shown in Table G.1.1-1.

**Table G.1.1-1 Correction Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURCE]:CORREction:FLATness:FREQuency? <point>	√	[ :SOURCE[1] 2]:CORREction:FLATness:FREQuency? <ext_integer>	
[ :SOURCE]:CORREction:FLATness:INITialize:FSTep	N/A	Not supported.	
[ :SOURCE]:CORREction:FLATness:LOAD "<file name>"	√	[ :SOURCE[1] 2]:CORREction:FLATness:LOAD <string>[, <device>]	
[ :SOURCE]:CORREction:FLATness:PAIR <freq.>[<freq suffix>], <corr.>[<corr suffix>]	√	[ :SOURCE[1] 2]:CORREction:FLATness:PAIR <freq>, <rel_ampl>	
[ :SOURCE]:CORREction:FLATness:POINts?	√	[ :SOURCE[1] 2]:CORREction:FLATness:POINts?	
[ :SOURCE]:CORREction:FLATness:PRESet	√	[ :SOURCE[1] 2]:CORREction:FLATness:PRESet	
[ :SOURCE]:CORREction:FLATness:STEP:POINts <points>  MAXimum MINimum DEFAULT	N/A	Not supported.	
[ :SOURCE]:CORREction:FLATness:STEP:POINts?[MAXimum MINimum]	N/A	Not supported.	
[ :SOURCE]:CORREction:FLATness:STEP:STARt <freq><unit>  MAXimum MINimum DEFAULT	N/A	Not supported.	
[ :SOURCE]:CORREction:FLATness:STEP:STARt? [MAXimum MINimum]	N/A	Not supported.	
[ :SOURCE]:CORREction:FLATness:STEP:STOP <freq><unit>  MAXimum MINimum DEFAULT	N/A	Not supported.	

**Table G.1.1-1 Correction Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURCE]:CORREction:FLATness:STEP:STOP ? [MAXimum MINimum]	N/A	Not supported.	
[ :SOURCE]:CORREction:FLATness:STORE "<file name>"	√	[ :SOURCE[1] 2]:CORREction:FLATness:STO Re <string>[,<device>]	Folder fixed. Cannot use msus.
[ :SOURCE]:CORREction:PMETER:CHANnel A B	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:CHANnel?	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :LAN:DEvice <deviceName>	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :LAN:DEvice?	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :LAN:IP <ipAddress>	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :LAN:IP?	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :LAN:PORT <portNumber>	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :LAN:PORT?	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :TYPE SOCKets SOCKETS VXI11 USB	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :TYPE?	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :USB:DEvice <device>	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :USB:DEvice?	N/A	Not supported.	
[ :SOURCE]:CORREction:PMETER:COMMunicate :USB:LIST?	N/A	Not supported.	
[ :SOURCE]:CORREction[:STATE] ON OFF 1 0	√	[ :SOURCE[1] 2]:CORREction[:STATE] <boolean>	
[ :SOURCE]:CORREction[:STATE]?	√	[ :SOURCE[1] 2]:CORREction[:STATE]?	

## G.1.2 Digital Modulation Subsystem

Digital Modulation Subsystem device messages available in MG3710A/MG3740A are shown in Table G.1.2-1.

**Table G.1.2-1 Digital Modulation Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ]:BURSt:STATe ON OFF 1 0	N/A	Not supported.	
[ :SOURce ]:BURSt:STATe?	N/A	Not supported.	
[ :SOURce ]:DM:CORREction:OPTimizati on RFOut EXTernal	N/A	Not supported.	
[ :SOURce ]:DM:CORREction:OPTimizati on?	N/A	Not supported.	
[ :SOURce ]:DM:EXTernal:POLarity NORMal INVert INVerted	√	[ :SOURce[1] 2]:DM:EXTernal:POLarity NORMal INVert INVerted	
[ :SOURce ]:DM:EXTernal:POLarity?	√	[ :SOURce[1] 2]:DM:EXTernal:POLarity?	
[ :SOURce ]:DM:INTernal:CHANnel:CORR ection[:STATe] ON OFF 1 0	√	[ :SOURce[1] 2]:DM:INTernal:CHANnel:COR Rection[:STATe] <boolean>	
[ :SOURce ]:DM:INTernal:CHANnel:CORR ection[:STATe]?	√	[ :SOURce[1] 2]:DM:INTernal:CHANnel:COR Rection[:STATe]?	
[ :SOURce ]:DM:INTernal:CHANnel:OPTi mization EVM ACP	N/A	Not supported.	

**Table G.1.2-1 Digital Modulation Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce ]:DM:INTernal:CHANnel:OPTimization?	N/A	Not supported.	
[ :SOURce ]:DM:INTernal:EQUalization:FILTer:SElect "Filter"	N/A	Not supported.	
[ :SOURce ]:DM:INTernal:EQUalization:FILTer:SElect?	N/A	Not supported.	
[ :SOURce ]:DM:INTernal:EQUalization:FILTer:STate ON OFF 1 0	N/A	Not supported.	
[ :SOURce ]:DM:INTernal:EQUalization:FILTer:STate?	N/A	Not supported.	
[ :SOURce ]:DM:IQADjustment:DElay <value><unit>	√	[ :SOURce[1] 2 ]:DM:IQADjustment:DElay <time>	
[ :SOURce ]:DM:IQADjustment:DElay?	√	[ :SOURce[1] 2 ]:DM:IQADjustment:DElay?	
[ :SOURce ]:DM:IQADjustment:EXTernal:CMRange COARse FINE	N/A	Not supported.	

Table G.1.2-1 Digital Modulation Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ] :DM :IQADjustment :EXTernal :CMRange?	N/A	Not supported.	
[ :SOURce ] :DM :IQADjustment :EXTernal :COFFset <value>	√	[ :SOURce[1] ] :DM :IQADjustment :EXTernal :COFFset <voltage>	
[ :SOURce ] :DM :IQADjustment :EXTernal :COFFset?	√	[ :SOURce[1] ] :DM :IQADjustment :EXTernal :COFFset?	
[ :SOURce ] :DM :IQADjustment :EXTernal :DIOffset <value>	√	[ :SOURce[1] ] :DM :IQADjustment :EXTernal :DIOffset <voltage>	
[ :SOURce ] :DM :IQADjustment :EXTernal :DIOffset?	√	[ :SOURce[1] ] :DM :IQADjustment :EXTernal :DIOffset?	



**Table G.1.2-1 Digital Modulation Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce ] :DM:IQADjustment:EXTernal :DQOFFset <value>	√	[ :SOURce[1] ] :DM:IQADjustment:EXTernal :DQOFFset <voltage>	
[ :SOURce ] :DM:IQADjustment:EXTernal :DQOFFset?	√	[ :SOURce[1] ] :DM:IQADjustment:EXTernal :DQOFFset?	
[ :SOURce ] :DM:IQADjustment:EXTernal :IOFFset <value>	√	[ :SOURce[1]   2 ] :DM:IQADjustment:IOFFset <percent>	Value is input in % units.
[ :SOURce ] :DM:IQADjustment:EXTernal :IOFFset?	√	[ :SOURce[1]   2 ] :DM:IQADjustment:IOFFset ?	Value is output in % units.
[ :SOURce ] :DM:IQADjustment:EXTernal :QOFFset <value>	√	[ :SOURce[1]   2 ] :DM:IQADjustment:QOFFset <percent>	Value is input in % units.
[ :SOURce ] :DM:IQADjustment:EXTernal :QOFFset?	√	[ :SOURce[1]   2 ] :DM:IQADjustment:QOFFset ?	Value is output in % units.
[ :SOURce ] :DM:IQADjustment:EXTernal :QSKew <value>	N/A	Not supported.	

Table G.1.2-1 Digital Modulation Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURCE ] : DM : IQADjustment : EXTERNAL : QSKew?	N/A		
[ :SOURCE ] : DM : IQADjustment : GAIN <value><unit>	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : GAIN <rel_ampl>	
[ :SOURCE ] : DM : IQADjustment : GAIN?	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : GAIN?	
[ :SOURCE ] : DM : IQADjustment : IOFFset <value><unit>	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : IOFFset <percent>	
[ :SOURCE ] : DM : IQADjustment : IOFFset?	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : IOFFset ?	
[ :SOURCE ] : DM : IQADjustment : PHASE <value><unit>	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : PHASE <phase>	
[ :SOURCE ] : DM : IQADjustment : PHASE?	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : PHASE?	
[ :SOURCE ] : DM : IQADjustment : QOFFset	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : QOFFset <percent>	
[ :SOURCE ] : DM : IQADjustment : QOFFset?	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : QOFFset ?	
[ :SOURCE ] : DM : IQADjustment : QSKew <value>	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : QSKew <angle>	

**Table G.1.2-1 Digital Modulation Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURCE ] : DM : IQADjustment : QSKew?	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : QSKew?	
[ :SOURCE ] : DM : IQADjustment : SKEW <value>	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : SKEW <time>	
[ :SOURCE ] : DM : IQADjustment : SKEW?	√	[ :SOURCE[1]   2 ] : DM : IQADjustment : SKEW?	
[ :SOURCE ] : DM : IQADjustment [ :STATE ] ON   OFF   1   0	N/A	Not supported.	
[ :SOURCE ] : DM : IQADjustment [ :STATE ] ?	N/A	Not supported.	
[ :SOURCE ] : DM : POLarity [ :ALL ] NORMal   INVert	√	[ :SOURCE[1]   2 ] : DM : POLarity [ :ALL ] NORMal   INVert	
[ :SOURCE ] : DM : POLarity?	√	[ :SOURCE[1]   2 ] : DM : POLarity [ :ALL ] ?	
[ :SOURCE ] : DM : SOURCE EXTernal   INTernal   SUM	√	[ :SOURCE[1]   2 ] : DM : SOURCE EXTernal   INTernal	IQ signal source Cannot use SUM.
[ :SOURCE ] : DM : SOURCE?	√	[ :SOURCE[1]   2 ] : DM : SOURCE?	IQ signal source Cannot use SUM.
[ :SOURCE ] : DM : STATE ON   OFF   1   0	N/A	Not supported.	
[ :SOURCE ] : DM : STATE?	N/A	Not supported.	

## G.1.3 Frequency Subsystem

Frequency Subsystem device messages available in MG3710A/MG3740A are shown in Table G.1.3-1.

**Table G.1.3-1 Frequency Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ]:FREQuency:CENTer <num>[ <freq_suffix> ]   UP   DOWN	√	[ :SOURce[1] ]:FREQuency:CENTer <freq>	
[ :SOURce ]:FREQuency:CENTer? [ MAXimum   MINimum ]	√	[ :SOURce[1] ]:FREQuency:CENTer?	
[ :SOURce ]:FREQuency:CHANnels: BAND <band>	√	[ :SOURce[1]   2 ]:FREQuency:CHANnels: BAND <band>	
[ :SOURce ]:FREQuency:CHANnels: BAND?	√	[ :SOURce[1]   2 ]:FREQuency:CHANnels: BAND ?	
[ :SOURce ]:FREQuency:CHANnels: NUMBe r <number>	√	[ :SOURce[1]   2 ]:FREQuency:CHANnels: NUMB er <integer>	
[ :SOURce ]:FREQuency:CHANnels: NUMBe r?	√	[ :SOURce[1]   2 ]:FREQuency:CHANnels: NUMB er?	
[ :SOURce ]:FREQuency:CHANnels[ :STAT e] ON   OFF   1   0	√	[ :SOURce[1]   2 ]:FREQuency:CHANnels[ :STA Te] <boolean>	
[ :SOURce ]:FREQuency:CHANnels[ :STAT e]?	√	[ :SOURce[1]   2 ]:FREQuency:CHANnels[ :STA Te]?	
[ :SOURce ]:FREQuency[ :CW ] <value><unit>	√	[ :SOURce[1]   2 ]:FREQuency[ :CW   :FIXed ] <freq>	
[ :SOURce ]:FREQuency[ :CW ]?	√	[ :SOURce[1]   2 ]:FREQuency[ :CW   :FIXed ]?	
[ :SOURce ]:FREQuency:MODE CW   FIXed   LIST	√	[ :SOURce[1]   2 ]:FREQuency:MODE CW   FIXed   LIST	
[ :SOURce ]:FREQuency:MODE?	√	[ :SOURce[1]   2 ]:FREQuency:MODE?	

**Table G.1.3-1 Frequency Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURCE ]:FREQUENCY:MULTIPLIER <value>	√	[ :SOURCE[1] 2 ]:FREQUENCY:MULTIPLIER <ext_numeric>	
[ :SOURCE ]:FREQUENCY:MULTIPLIER?	√	[ :SOURCE[1] 2 ]:FREQUENCY:MULTIPLIER?	
[ :SOURCE ]:FREQUENCY:OFFSET <value><unit>	√	[ :SOURCE[1] 2 ]:FREQUENCY:OFFSET <freq>	
[ :SOURCE ]:FREQUENCY:OFFSET?	√	[ :SOURCE[1] 2 ]:FREQUENCY:OFFSET?	
[ :SOURCE ]:FREQUENCY:OFFSET:STATE ON OFF 1 0	√	[ :SOURCE[1] 2 ]:FREQUENCY:OFFSET:STATE <boolean>	
[ :SOURCE ]:FREQUENCY:OFFSET:STATE?	√	[ :SOURCE[1] 2 ]:FREQUENCY:OFFSET:STATE?	
[ :SOURCE ]:FREQUENCY:REFERENCE <value><unit>	N/A	Not supported.	
[ :SOURCE ]:FREQUENCY:REFERENCE?	N/A	Not supported.	
[ :SOURCE ]:FREQUENCY:REFERENCE:SET	N/A	Not supported.	
[ :SOURCE ]:FREQUENCY:REFERENCE:STATE ON OFF 1 0	√	[ :SOURCE[1] 2 ]:FREQUENCY:REFERENCE:STATE <boolean>	
[ :SOURCE ]:FREQUENCY:REFERENCE:STATE?	√	[ :SOURCE[1] 2 ]:FREQUENCY:REFERENCE:STATE?	
[ :SOURCE ]:FREQUENCY:SPAN <num>[ <freq_suffix> ] UP DOWN	√	[ :SOURCE[1] ]:FREQUENCY:SPAN <freq>	
[ :SOURCE ]:FREQUENCY:SPAN? [ MAXimum MINimum ]	√	[ :SOURCE[1] ]:FREQUENCY:SPAN?	
[ :SOURCE ]:FREQUENCY:START <value><unit>	√	[ :SOURCE[1] ]:FREQUENCY:START <freq>	
[ :SOURCE ]:FREQUENCY:START?	√	[ :SOURCE[1] ]:FREQUENCY:START?	
[ :SOURCE ]:FREQUENCY:STOP <value><unit>	√	[ :SOURCE[1] ]:FREQUENCY:STOP <freq>	

Table G.1.3-1 Frequency Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ] : FREQuency : STOP?	√	[ :SOURce[1] ] : FREQuency : STOP?	
[ :SOURce ] : PHASe : REFerence	N/A	Not supported.	
[ :SOURce ] : PHASe [ :ADJust ] <value><unit>	√	[ :SOURce[1]   2 ] : PHASe [ :ADJust ] <ext_numeric>	
[ :SOURce ] : PHASe [ :ADJust ]?	√	[ :SOURce[1]   2 ] : PHASe [ :ADJust ]?	
[ :SOURce ] : ROSCillator : BANDwidth : EX Ternal <value> [ <units> ]   NARRow   WIDE   MINimum   MAXimum   DEFault	N/A	Not supported.	
[ :SOURce ] : ROSCillator : BANDwidth : EX Ternal?   MINimum   MAXimum	N/A	Not supported.	
[ :SOURce ] : ROSCillator : FREQuency : EX Ternal <value>	√	[ :SOURce ] : ROSCillator : FREQuency : EX Ternal <freq>	
[ :SOURce ] : ROSCillator : FREQuency : EX Ternal?	√	[ :SOURce ] : ROSCillator : FREQuency : EX Ternal?	
[ :SOURce ] : ROSCillator : SOURce?	√	[ :SOURce ] : ROSCillator : SOURce?	
[ :SOURce ] : ROSCillator : SOURce : AUTO ON   OFF   1   0	√	[ :SOURce ] : ROSCillator : SOURce : AUTO <boolean>	
[ :SOURce ] : ROSCillator : SOURce : AUTO?	√	[ :SOURce ] : ROSCillator : SOURce : AUTO?	

## G.1.4 List/Sweep Subsystem

List/Sweep Subsystem device messages available in MG3710A/MG3740A are shown in Table G.1.4-1.

**Table G.1.4-1 List/Sweep Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURCE ] :LIST :CPOINT ?	√	[ :SOURCE ] :LIST :CPOINT ?	
[ :SOURCE ] :LIST :DIRection UP  DOWN	√	[ :SOURCE ] :LIST :DIRection UP  DOWN	
[ :SOURCE ] :LIST :DIRection ?	√	[ :SOURCE ] :LIST :DIRection ?	
[ :SOURCE ] :LIST :DWELL <value> { , <value> }	N/A	Not supported.	
[ :SOURCE ] :LIST :DWELL ?	N/A	Not supported.	
[ :SOURCE ] :LIST :DWELL :POINTs ?	√	[ :SOURCE ] :LIST :DWELL :POINTs ?	
[ :SOURCE ] :LIST :DWELL :TYPE LIST  STEP	√	[ :SOURCE ] :LIST :DWELL :TYPE LIST  STEP  SWEep	
[ :SOURCE ] :LIST :DWELL :TYPE ?	√	[ :SOURCE ] :LIST :DWELL :TYPE ?	
[ :SOURCE ] :LIST :FREQuency <value> { , <value> }	N/A	Not supported.	
[ :SOURCE ] :LIST :FREQuency ?	N/A	Not supported.	
[ :SOURCE ] :LIST :FREQuency :POINTs ?	√	[ :SOURCE ] :LIST :FREQuency :POINTs ?	
[ :SOURCE ] :LIST :MANual <value>  UP  DOWN	√	[ :SOURCE ] :LIST :MANual <value>  UP  DOWN	

Table G.1.4-1 List/Sweep Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ] :LIST :MANual ?	√	[ :SOURce ] :LIST :MANual ?	
[ :SOURce ] :LIST :MODE AUTO   MANual	√	[ :SOURce ] :LIST :MODE AUTO   MANual	
[ :SOURce ] :LIST :MODE ?	√	[ :SOURce ] :LIST :MODE ?	
[ :SOURce ] :LIST :OPTions <val> { , <val> }	N/A	Not supported.	
[ :SOURce ] :LIST :OPTions ?	N/A	Not supported.	
[ :SOURce ] :LIST :OPTions :POINTs ?	N/A	Not supported.	
[ :SOURce ] :LIST :POWER <value> { , <value> }	N/A	Not supported.	
[ :SOURce ] :LIST :POWER ?	N/A	Not supported.	
[ :SOURce ] :LIST :POWER :POINTs ?	√	[ :SOURce ] :LIST :POWER :POINTs ?	
[ :SOURce ] :LIST :RETRace ON   OFF   1   0	N/A	Not supported.	
[ :SOURce ] :LIST :RETRace ?	N/A	Not supported.	
[ :SOURce ] :LIST :TRIGger :SOURce BUS   IMMEDIATE   EXTERNAL   KEY   TIMER   MANua l	√	[ :SOURce ] :LIST :TRIGger :SOURce BUS   IMMEDIATE   EXTERNAL   KEY   TIMER   MANua l	
[ :SOURce ] :LIST :TRIGger :SOURce ?	√	[ :SOURce ] :LIST :TRIGger :SOURce ?	
[ :SOURce ] :LIST :TYPE LIST   STEP	√	[ :SOURce ] :LIST :TYPE LIST   STEP	
[ :SOURce ] :LIST :TYPE ?	√	[ :SOURce ] :LIST :TYPE ?	
[ :SOURce ] :LIST :TYPE :LIST :INITialize :FS Tep	N/A	Not supported.	
[ :SOURce ] :LIST :TYPE :LIST :INITialize :PR ESet	√	[ :SOURce ] :LIST :TYPE :LIST :INITialize :PR ESet	



**Table G.1.4-1 List/Sweep Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURCE ] :LIST :WAVEform <name> { , <name> }	N/A	Not supported.	
[ :SOURCE ] :LIST :WAVEform?	N/A	Not supported.	
[ :SOURCE ] :LIST :WAVEform :POINTs?	√	[ :SOURCE ] :LIST :WAVEform :POINTs?	
[ :SOURCE ] :SWEep :CPOINT?	√	[ :SOURCE ] :SWEep :CPOINT?	
[ :SOURCE ] :SWEep :DWELL <value>	√	[ :SOURCE [ 1 ]   2 ] :SWEep :DWELL <time>	
[ :SOURCE ] :SWEep :DWELL?	√	[ :SOURCE [ 1 ]   2 ] :SWEep :DWELL?	
[ :SOURCE ] :SWEep :POINTs <value>	√	[ :SOURCE [ 1 ]   2 ] :SWEep :POINTs <value>	
[ :SOURCE ] :SWEep :POINTs?	√	[ :SOURCE [ 1 ]   2 ] :SWEep :POINTs?	
[ :SOURCE ] :SWEep :SPACing LINear   LOGarithmic	N/A	Not supported.	
[ :SOURCE ] :SWEep :SPACing?	N/A	Not supported.	

## G.1.5 Fast Subsystem

Fast Subsystem device messages available in MG3710A/MG3740A are shown in Table G.1.5-1.

**Table G.1.5-1 Fast Subsystem Device Messages**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
:FAST:FP <Freq MHz>, <power mdB>	N/A	Not supported.	
:FAST:FREQuency <Freq MHz>	N/A	Not supported.	
:FAST:POWer <power mdB>	N/A	Not supported.	

## G.1.6 Marker Subsystem

Marker Subsystem device messages available in MG3710A/MG3740A are shown in Table G.1.6-1.

**Table G.1.6-1 Marker Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ] :MARKer :AMPLitude [ :STATE ] ON   OFF   1   0	N/A	Not supported.	
[ :SOURce ] :MARKer :AMPLitude [ :STATE ] ?	N/A	Not supported.	
[ :SOURce ] :MARKer :AMPLitude :VALue <num> [ DB ]	N/A	Not supported.	
[ :SOURce ] :MARKer :AMPLitude :VALue?	N/A	Not supported.	
[ :SOURce ] :MARKer :AOFF	N/A	Not supported.	
[ :SOURce ] :MARKer :DELTA? <num> , <num>	N/A	Not supported.	
[ :SOURce ] :MARKer [ 0 , 1 , 2 , 3 , 4 , 5 , 6 , 7 , 8 , 9 , 10 , 11 , 12 , 13 , 14 , 15 , 16 , 17 , 18 , 19 ] : FREQuency <val> <unit>	N/A	Not supported.	
[ :SOURce ] :MARKer [ 0 , 1 , 2 , 3 , 4 , 5 , 6 , 7 , 8 , 9 , 10 , 11 , 12 , 13 , 14 , 15 , 16 , 17 , 18 , 19 ] : FREQuency? MAXimum   MINimum	N/A	Not supported.	
[ :SOURce ] :MARKer :MODE FREQuency   DELTA	N/A	Not supported.	
[ :SOURce ] :MARKer :MODE?	N/A	Not supported.	
[ :SOURce ] :MARKer :REFerence <marker>	N/A	Not supported.	
[ :SOURce ] :MARKer :REFerence?	N/A	Not supported.	

Table G.1.6-1 Marker Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[:SOURCE]:MARKer[0,1,2,3,4,5,6,7,8,9,10,11,12,13,14,15,16,17,18,19][:STATE] ON OFF 1 0	N/A	Not supported.	
[:SOURCE]:MARKer[0,1,2,3,4,5,6,7,8,9,10,11,12,13,14,15,16,17,18,19][:STATE]?	N/A	Not supported.	

## G.1.7 Power Subsystem

Power Subsystem device messages available in MG3710A/MG3740A are shown in Table G.1.7-1.

**Table G.1.7-1 Power Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURCE ] :POWER:ALC:BANDwidth   BWIDth <num> {freq suffix}	N/A	Not supported.	
[ :SOURCE ] :POWER:ALC:BANDwidth   BWIDth?	N/A	Not supported.	
[ :SOURCE ] :POWER:ALC:BANDwidth   BWIDth:AUTO ON   OFF   1   0	N/A	Not supported.	
[ :SOURCE ] :POWER:ALC:BANDwidth   BWIDth:AUTO?	N/A	Not supported.	
[ :SOURCE ] :POWER:ALC:SEARCH AUTO   SPAN   ON   1   ONCE	√	[ :SOURCE[1]   2 ] :POWER:ALC:SEARCH [ONCE]	Only ONCE can be used.
[ :SOURCE ] :POWER:ALC:SEARCH?	√	[ :SOURCE[1]   2 ] :POWER:ALC:SEARCH?	ONCE returns.
[ :SOURCE ] :POWER:ALC:LEVEL <value> <unit>	N/A	Not supported.	
[ :SOURCE ] :POWER:ALC:LEVEL?	N/A	Not supported.	
[ :SOURCE ] :POWER:ALC:SEARCH:REFERENCE RMS   FIXEd   MANual   MODulated	N/A	Not supported.	
[ :SOURCE ] :POWER:ALC:SEARCH:REFERENCE?	N/A	Not supported.	

Table G.1.7-1 Power Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ] : POWer : ALC : SEARCh : REFerence : L EVEl <value>	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SEARCh : REFerence : L EVEl?	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SEARCh : SPAN : START <value><units>	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SEARCh : SPAN : START?	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SEARCh : SPAN : STOP <value><units>	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SEARCh : SPAN : STOP?	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SEARCh : SPAN : TYPE FULL   USER	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SEARCh : SPAN : TYPE?	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SEARCh : SPAN [ : STATe ] ON   OFF   1   0	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SEARCh : SPAN [ : STATe ] ?	N/A	Not supported.	

**Table G.1.7-1 Power Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce ] : POWer : ALC : SOURce INTernal   DIODE	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SOURce?	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SOURce : EXTernal : CO UPling <value>DB	N/A	Not supported.	
[ :SOURce ] : POWer : ALC : SOURce : EXTernal : CO UPling?	N/A	Not supported.	
[ :SOURce ] : POWer : ALC [ :STATe ] ON   OFF   1   0	N/A	Not supported.	
[ :SOURce ] : POWer : ALC [ :STATe ]?	N/A	Not supported.	
[ :SOURce ] : POWer : ATTenuation <value><unit>	N/A	Not supported.	
[ :SOURce ] : POWer : ATTenuation?	N/A	Not supported.	
[ :SOURce ] : POWer : ATTenuation : AUTO ON   OFF   1   0	√	[ :SOURce ] : POWer : ATTenuation : AUTO <boolean>	
[ :SOURce ] : POWer : ATTenuation : AUTO?	√	[ :SOURce ] : POWer : ATTenuation : AUTO?	

Table G.1.7-1 Power Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURCE ] : POWER : ATTenuation : BYPass ON   OFF   1   0	N/A	Not supported.	
[ :SOURCE ] : POWER : ATTenuation : BYPass?	N/A	Not supported.	
[ :SOURCE ] : POWER [ :LEVEL ] [ :IMMEDIATE ] : OF FSet <value><unit>	√	[ :SOURCE [ 1 ]   2 ] : POWER [ :LEVEL ] [ :IMMEDIATE ] : OFFSet <rel_ampl>	
[ :SOURCE ] : POWER [ :LEVEL ] [ :IMMEDIATE ] : OF FSet?	√	[ :SOURCE [ 1 ]   2 ] : POWER [ :LEVEL ] [ :IMMEDIATE ] : OFFSet?	
[ :SOURCE ] : POWER [ :LEVEL ] [ :IMMEDIATE ] [ :A MPLitude ] <value><unit>	√	[ :SOURCE [ 1 ]   2 ] : POWER [ :LEVEL ] [ :IMMEDIATE ] [ :AMPLitude ] <ampl>	
[ :SOURCE ] : POWER [ :LEVEL ] [ :IMMEDIATE ] [ :A MPLitude ]?	√	[ :SOURCE [ 1 ]   2 ] : POWER [ :LEVEL ] [ :IMMEDIATE ] [ :AMPLitude ]?	
[ :SOURCE ] : POWER : MINimum : LIMit LOW   HIGH	N/A	Not supported.	
[ :SOURCE ] : POWER : MINimum : LIMit?	N/A	Not supported.	
[ :SOURCE ] : POWER : MODE FIXed   LIST	√	[ :SOURCE [ 1 ]   2 ] : POWER : MODE FIXed   LIST	
[ :SOURCE ] : POWER : MODE?	√	[ :SOURCE [ 1 ]   2 ] : POWER : MODE?	



**Table G.1.7-1 Power Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce ] :POWer:NOISe :[ STATE ] ON   OFF   1   0	√	[ :SOURce[ 1 ]   2 ] :POWer:NOISe :[ STATE ] <boolean>	
[ :SOURce ] :POWer:NOISe :[ STATE ] ?	√	[ :SOURce[ 1 ]   2 ] :POWer:NOISe :[ STATE ] ?	
[ :SOURce ] :POWer:PROTection [ :STATE ] ON   OFF   1   0	N/A	Not supported.	
[ :SOURce ] :POWer:PROTection [ :STATE ] ?	N/A	Not supported.	
[ :SOURce ] :POWer:REFeRence <value><unit>	N/A	Not supported.	
[ :SOURce ] :POWer:REFeRence ?	√	[ :SOURce[ 1 ]   2 ] :POWer:REFeRence ?	
[ :SOURce ] :POWer:REFeRence :STATE ON   OFF   1   0	√	[ :SOURce[ 1 ]   2 ] :POWer:REFeRence :STATE <boolean>	
[ :SOURce ] :POWer:REFeRence :STATE ?	√	[ :SOURce[ 1 ]   2 ] :POWer:REFeRence :STATE ?	
[ :SOURce ] :POWer:STARt <value><unit>	√	[ :SOURce[ 1 ] ] :POWer:STARt <amp;pl>	
[ :SOURce ] :POWer:STARt ?	√	[ :SOURce[ 1 ] ] :POWer:STARt ?	

Table G.1.7-1 Power Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURCE ] : POWER : STOP <value><unit>	√	[ :SOURCE[1] ] : POWER : STOP <amp1>	
[ :SOURCE ] : POWER : STOP?	√	[ :SOURCE[1] ] : POWER : STOP?	
[ :SOURCE ] : POWER : USER : MAX <amp1>	√	[ :SOURCE[1]   2 ] : POWER : USER : MAX <amp1>	
[ :SOURCE ] : POWER : USER : MAX?	√	[ :SOURCE[1]   2 ] : POWER : USER : MAX?	
[ :SOURCE ] : POWER : USER : ENABLE <0 1>	√	[ :SOURCE[1]   2 ] : POWER : USER : ENABLE <boolean>	
[ :SOURCE ] : POWER : USER : ENABLE?	√	[ :SOURCE[1]   2 ] : POWER : USER : ENABLE?	

## G.2 System Commands

### G.2.1 Calibration Subsystem

Calibration Subsystem device messages available in MG3710A/MG3740A are shown in Table G.2.1-1.

**Table G.2.1-1 Calibration Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:CALibration:ALC:MODulator:BIAS		Not supported.	
:CALibration:BBG:CHANnel	√	:CALibration:BBG:CHANnel	
:CALibration:BBG:SKEW RFOut EXTernal, <value in pS>	N/A	Not supported.	
:CALibration:BBG:SKEW? RFOut EXTernal	N/A	Not supported.	
:CALibration:BBG:SKEW:RFOut	N/A	Not supported.	
:CALibration:DCFM	N/A	Not supported.	
:CALibration:IQ:DC	√	:CALibration[1 2]:IQ:DC	
:CALibration:IQ:DEFault	√	:CALibration[1 2]:IQ:DEFault	
:CALibration:IQ:FULL	√	:CALibration[1 2]:IQ:FULL	
:CALibration:IQ:START <value><unit>	N/A	Not supported.	
:CALibration:IQ:START?	N/A	Not supported.	
:CALibration:IQ:STOP <value><unit>	N/A	Not supported.	
:CALibration:IQ:STOP?	N/A	Not supported.	

Table G.2.1-1 Calibration Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:CALibration:IQ:TYPE DC USER FULL	√	:CALibration[1] 2]:IQ:TYPE DC USER	
:CALibration:IQ:TYPE?	√	:CALibration[1] 2]:IQ:TYPE?	
:CALibration:IQ[:USER]	N/A	Not supported.	

## G.2.2 Communication Subsystem

Communication Subsystem device messages available in MG3710A/MG3740A are shown in Table G.2.2-1.

**Table G.2.2-1 Communication Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:SYSTem:CAPability?	N/A	Not supported.	
:SYSTem:ERRor:CODe[:NEXT]?	√	:SYSTem:ERRor:CODe[:NEXT]?	
:SYSTem:ERRor[:NEXT]?	√	:SYSTem:ERRor[:NEXT]?	
:SYSTem:COMMunicate:GPIB:ADDRess <number>	√	:SYSTem:COMMunicate:GPIB:ADDRess <number>	
:SYSTem:COMMunicate:GPIB:ADDRess?	√	:SYSTem:COMMunicate:GPIB:ADDRess?	
:SYSTem:COMMunicate:GTLocal	√	:SYSTem:COMMunicate:GTLocal	
:SYSTem:COMMunicate:LAN:CONFig DHCP MANual AUTO AIP	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:CONFig?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DEFaults	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DESCRiption <string>	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DESCRiption?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DHCP:TIMEout {30} 60 90 120sec	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DHCP:TIMEout?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DOMain <string>	N/A	Not supported.	

Table G.2.2-1 Communication Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:SYSTem:COMMunicate:LAN:DOMain?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DNS:DYNamic ON OFF 1 0	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DNS:DYNamic?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DNS:OVERride ON OFF 1 0	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DNS:OVERride?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DNS[:SERVer] <ipstring>	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:DNS[:SERVer]?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:GATeway "<ipstring>"	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:GATeway?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:HOSTname "<string>"	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:HOSTname?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:IDENTify ON OFF 1 0	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:IP "<ipstring>"	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:IP?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:KEEP:TIMEout <value>	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:KEEP:TIMEout?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:KEEP[:STATE] ON OFF 1 0	N/A	Not supported.	

**Table G.2.2-1 Communication Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
:SYSTem:COMMunicate:LAN:KEEP[:STATe]?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:MDNS ON OFF 1 0	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:MDNS?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:MONitor ON OFF 1 0	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:MONitor?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:NBIOs ON OFF 1 0	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:NBIOs?	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:REStart	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:SUBNet "<ipstring>"	N/A	Not supported.	
:SYSTem:COMMunicate:LAN:SUBNet?	N/A	Not supported.	
:SYSTem:COMMunicate:PMETer:DEVIce <deviceName>	N/A	Not supported.	
:SYSTem:COMMunicate:PMETer:DEVIce?	N/A	Not supported.	
:SYSTem:COMMunicate:PMETer:IP <ipaddr>	N/A	Not supported.	
:SYSTem:COMMunicate:PMETer:IP?	N/A	Not supported.	
:SYSTem:COMMunicate:PMETer:PORT <portNum>	N/A	Not supported.	
:SYSTem:COMMunicate:PMETer:PORT?	N/A	Not supported.	
:SYSTem:COMMunicate:PMETer:TYPE SOCKets SOCKETS VXI11 USB	N/A	Not supported.	
:SYSTem:COMMunicate:PMETer:TYPE?	N/A	Not supported.	

## G.2.3 Display Subsystem

Display Subsystem device messages available in MG3710A/MG3740A are shown in Table G.2.3-1.

**Table G.2.3-1 Display Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:DISPlay:ANNotation:AMPLitude[:STATE] ON OFF 1 0	N/A	Not supported.	
:DISPlay:ANNotation:AMPLitude[:STATE]?	N/A	Not supported.	
:DISPlay:ANNotation:AMPLitude:UNIT DBM DBUV DBUVEMF V VEMF DB	√	:UNIT[1] 2:POWer DBM DBUV DBUVEMF	
:DISPlay:ANNotation:AMPLitude:UNIT?	√	:UNIT[1] 2:POWer?	
:DISPlay:ANNotation:FREQuency[:STATE] ON OFF 1 0	N/A	Not supported.	
:DISPlay:ANNotation:FREQuency[:STATE]?	N/A	Not supported.	
:DISPlay:ANNotation:CLOCK:DATE:FORMat MDY DMY	N/A	Not supported.	
:DISPlay:ANNotation:CLOCK:DATE:FORMat?	N/A	Not supported.	
:DISPlay:ANNotation:CLOCK[:STATE] ON OFF 1 0	N/A	Not supported.	
:DISPlay:ANNotation:CLOCK[:STATE]?	N/A	Not supported.	
:DISPlay:BRIGhtness <value>	N/A	Not supported.	
:DISPlay:BRIGhtness?	N/A	Not supported.	
:DISPlay:CAPTure	√	:MMEMory:STORe:SCReen [<filename>[,<device>]]	
:DISPlay:CMAP:DEFault [<palette:{BRIGht} DARK MONOchrome>]	N/A	Not supported.	



**Table G.2.3-1 Display Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
:DISPlay:CONTRast <value>	N/A	Not supported.	
:DISPlay:CONTRast?	N/A	Not supported.	
:DISPlay:REMote ON OFF 1 0	√	:DISPlay:ENABle ON OFF 1 0	
:DISPlay:REMote?	√	:DISPlay:ENABle?	
:DISPlay[:WINDow][:STATE] ON OFF 1 0	√	:DISPlay:ENABle ON OFF 1 0	
:DISPlay[:WINDow][:STATE]?	√	:DISPlay:ENABle?	

## G.2.4 IEEE 488.2 Common Commands

IEEE 488.2 Common Commands device messages available in MG3710A/MG3740A are shown in Table G.2.4-1.

Table G.2.4-1 IEEE 488.2 Common Commands Device Messages

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
*CLS	√	*CLS	
*ESE <data>	√	*ESE <integer>	
*ESE?	√	*ESE?	
*ESR?	√	*ESR?	
*IDN?	√	*IDN?	
*OPC	√	*OPC	
*OPC?	√	*OPC?	
*OPT?	N/A	Not supported.	
*PSC ON OFF 1 0	N/A	Not supported.	
*PSC?	N/A	Not supported.	
*RCL <reg>, <seq>	N/A	Not supported.	
*RST	√	*RST	
*SAV <reg>, <seq>	N/A	Not supported.	
*SRE <data>	√	*SRE <integer>	
*SRE?	√	*SRE?	

**Table G.2.4-1 IEEE 488.2 Common Commands Device Messages (Continued)**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
*STB?	√	*STB?	
*TRG	√	*TRG	
*TST?	√	*TST?	
*WAI	√	*WAI	

## G.2.5 Memory Subsystem

Memory Subsystem device messages available in MG3710A/MG3740A are shown in Table G.2.5-1.

**Table G.2.5-1 Memory Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:MEMory:CATalog:BINary?	N/A	Not supported.	
:MEMory:CATalog:DMOD?	N/A	Not supported.	
:MEMory:CATalog:FIR?	N/A	Not supported.	
:MEMory:CATalog:FSK?	N/A	Not supported.	
:MEMory:CATalog:IQ?	N/A	Not supported.	
:MEMory:CATalog:LIST?	N/A	Not supported.	
:MEMory:CATalog:MDMod?	N/A	Not supported.	
:MEMory:CATalog:MTONE?	N/A	Not supported.	
:MEMory:CATalog:PTRain?	N/A	Not supported.	
:MEMory:CATalog:SEQ?	N/A	Not supported.	
:MEMory:CATalog:STATe?	N/A	Not supported.	
:MEMory:CATalog:UFLT?	N/A	Not supported.	
:MEMory:CATalog[:ALL]?	N/A	Not supported.	
:MEMory:COpy[:NAME] "<file name>", "<file name>"	√	:MEMory[1] 2:COpy[:NAME] <string1>, <string2>	Only supports waveform pattern loading.
:MEMory:DATA "<file_name>", <data_block>	N/A	Not supported.	

**Table G.2.5-1 Memory Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
:MEMory:DATA? "<file_name>"	N/A	Not supported.	
:MEMory:DATA:APPend "<file_name>",<data_block>	N/A	Not supported.	
:MEMory:DATA:FIR "<file_name>",<REAL COMpLex>,<osr>,<coeffi cient>	N/A	Not supported.	
:MEMory:DATA:FIR? "<file_name>"	N/A	Not supported.	
:MEMory:DATA:FSK "<file_name>",<num_states>,<f0>,<f1>,... <f(n)>[,<diff_state>,<num_diff_states> <diff1>,...<diff(n)>]	N/A	Not supported.	
:MEMory:DATA:FSK? "<file_name>"	N/A	Not supported.	
:MEMory:DATA:IQ "<file_name>",<offsetQ>,<num_states>,<i 0>,<q0>,<i1>,<q1>,...<i(n)>,<q(n)>[,<di ff_state>,<num_diff_states>,<diff0>,<di ff1>,...<diff(n)>]	N/A	Not supported.	
:MEMory:DATA:IQ? "<file_name>"	N/A	Not supported.	
:MEMory:DELeTe:ALL	N/A	Not supported.	
:MEMory:DELeTe:BINary	N/A	Not supported.	
:MEMory:DELeTe:DMOD	N/A	Not supported.	
:MEMory:DELeTe:FIR	N/A	Not supported.	
:MEMory:DELeTe:LIST	N/A	Not supported.	
:MEMory:DELeTe:MMod	N/A	Not supported.	

Table G.2.5-1 Memory Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:MEMory:DELeTe:MTONE	N/A	Not supported.	
:MEMory:DELeTe:PTRain	N/A	Not supported.	
:MEMory:DELeTe:SEQ	N/A	Not supported.	
:MEMory:DELeTe:STATE	N/A	Not supported.	
:MEMory:DELeTe:UFLT	N/A	Not supported.	
:MEMory:DELeTe[:NAME] "<file name>"	N/A	Not supported.	
:MEMory:EXPort[:AScii]:PTRain <"filename">	N/A	Not supported.	
:MEMory:EXPort[:AScii]:SEParator:COLumn TAB SEmicolon COMMa SPACE	N/A	Not supported.	
:MEMory:EXPort[:AScii]:SEParator:COLumn ?	N/A	Not supported.	
:MEMory:EXPort[:AScii]:SEParator:DECima l DOT COMMa	N/A	Not supported.	
:MEMory:EXPort[:AScii]:SEParator:DECima l?	N/A	Not supported.	
:MEMory:FREE[:ALL]?	√	:MEMory[1] 2:FREE[:ALL]? [<device>]	
:MEMory:IMPort[:AScii]:PTRain <"filename">	N/A	Not supported.	
:MEMory:IMPort[:AScii]:SEParator:DECima l DOT COMMa	N/A	Not supported.	
:MEMory:IMPort[:AScii]:SEParator:DECima l?	N/A	Not supported.	
:MEMory:LOAD:LIST "<file name>"	√	:MEMory:LOAD:LIST <string>[,<device>]	
:MEMory:MOVE "<src_file>","<dest_file>"	N/A	Not supported.	

**Table G.2.5-1 Memory Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
:MEMory:SIZE? <"filename">	N/A	Not supported.	
:MEMory:STAtE:COMMeNt <reg_num>, <seq_num>, "<comment>"	N/A	Not supported.	
:MEMory:STAtE:COMMeNt? <reg_num>, <seq_num>	N/A	Not supported.	
:MEMory:STORe:LIST "<file name>"	√	:MMEMemory:STORe:LIST <string>[, <device>]	
:MMEMemory:CATALog? "<msus>"	N/A	Not supported.	
:MMEMemory:COpy "<file name>", "<file name>"	√	:MMEMemory[1]   2:COpy[:NAME] <string1>, <string2>	Only supports waveform pattern loading.
:MMEMemory:DATA "<file name>", <datablock>	N/A	Not supported.	
:MMEMemory:DATA? "<file name>"	N/A	Not supported.	
:MMEMemory:DELeTe:NVWFm	N/A	Not supported.	
:MMEMemory:DELeTe:WFM	N/A	Not supported.	
:MMEMemory:DELeTe[:NAME] "<file name>", ["<msus>"]	N/A	Not supported.	
:MMEMemory:HEADer:CLEAr "<file name>"	N/A	Not supported.	
:MMEMemory:HEADer:DESCription "<file name>", "<description>"	N/A	Not supported.	
:MMEMemory:HEADer:DESCription? "<file name>"	N/A	Not supported.	
:MMEMemory:HEADer:ID? "<file name>"	N/A	Not supported.	
:MMEMemory:LOAD:LIST "<file name>"	√	:MMEMemory:LOAD:LIST <string>[, <device>]	
:MMEMemory:LOAD:PTRain <"filename">	N/A	Not supported.	

Table G.2.5-1 Memory Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:MMEMory:LOAD:WFM:ALL	√	:MMEMory:LOAD:WFM:ALL [<device>]	
:MMEMory:MOVE "<src_file>","<dest_file>"	N/A	Not supported.	
:MMEMory:STORE:LIST "<file name>"	√	:MMEMory:STORE:LIST <string>[,<device>]	
:MMEMory:STORE:PTRain "<filename>"	N/A	Not supported.	
:MMEMory:STORE:WFM:ALL	N/A	Not supported.	
:SYSTem:SANalyzer:COMMunicate:LAN:DEVic e <deviceName>	N/A	Not supported.	
:SYSTem:SANalyzer:COMMunicate:LAN:DEVic e?	N/A	Not supported.	
:SYSTem:SANalyzer:COMMunicate:LAN:IP <ipAddr>	N/A	Not supported.	
:SYSTem:SANalyzer:COMMunicate:LAN:IP?	N/A	Not supported.	
:SYSTem:SANalyzer:COMMunicate:LAN:PORT <portNum>	N/A	Not supported.	
:SYSTem:SANalyzer:COMMunicate:LAN:PORT?	N/A	Not supported.	
:SYSTem:SANalyzer:COMMunicate:TYPE SOCKets SOCKETS VXI11	N/A	Not supported.	
:SYSTem:SANalyzer:COMMunicate:TYPE?	N/A	Not supported.	



## G.2.6 Output Subsystem

Output Subsystem device messages available in MG3710A/MG3740A are shown in Table G.2.6-1.

**Table G.2.6-1 Output Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:OUTPut:BLANking:AUTO ON OFF 1 0	N/A	Not supported.	
:OUTPut:BLANking:AUTO?	N/A	Not supported.	
:OUTPut:BLANking:STATe ON OFF 1 0	N/A	Not supported.	
:OUTPut:BLANking:STATe?	N/A	Not supported.	
:OUTPut:MODulation[:STATe] ON OFF 1 0	√	:OUTPut[1] 2:MODulation[:STATe] <boolean>	
:OUTPut:MODulation[:STATe]?	√	:OUTPut[1] 2:MODulation[:STATe]?	
:OUTPut:PROTection[:STATe] ON OFF 1 0	N/A	Not supported.	
:OUTPut:PROTection[:STATe]?	N/A	Not supported.	
:OUTPut[:STATe] ON OFF 1 0	√	:OUTPut[1] 2[:STATe] <boolean>	
:OUTPut[:STATe]?	√	:OUTPut[1] 2[:STATe]?	

## G.2.7 Route Subsystem

Route Subsystem device messages available in MG3710A/MG3740A are shown in Table G.2.7-1.

**Table G.2.7-1 Route Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:ROUte[:CONNectors]:EVENT1 M1 M2 M3 M4	√	:ROUte[:CONNectors]:EVENT1 2 3 M1 M2 M3 SF P1 P2 P3 PS10 PSYNc PVIDeo  M12 M22 M32 PSYNc2 PVIDeo2	Cannot use M4.
:ROUte[:CONNectors]:EVENT1?	√	:ROUte[:CONNectors]:EVENT1 2 3?	
:ROUte[:CONNectors]:SOUT SWEep SETTled PVIDeo SW8757	√	:ROUte[:CONNectors]:SOUT SWEep SETTled	Cannot use SW8757 and PVIDeo.
:ROUte:CONNectors:SOUT?	√	:ROUte[:CONNectors]:SOUT?	
:ROUte[:CONNectors]:TOUT SWEep SETTled PVIDeo PSYNc M1 M2 M3 M4	N/A	Not supported.	
:ROUte[:CONNectors]:TOUT?	N/A	Not supported.	

## G.2.8 Status Subsystem

Status Subsystem device messages available in MG3710A/MG3740A are shown in Table G.2.8-1.

**Table G.2.8-1 Status Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:STATus:OPERation:CONDition?	√	:STATus:OPERation:CONDition?	The layout of the register is that of the MG3710A/MG3740A.
:STATus:OPERation:ENABle <value>	√	:STATus:OPERation:ENABle <integer>	The layout of the register is that of the MG3710A/MG3740A.
:STATus:OPERation:ENABle?	√	:STATus:OPERation:ENABle?	The layout of the register is that of the MG3710A/MG3740A.
:STATus:OPERation:NTRansition <value>	√	:STATus:OPERation:NTRansition <integer>	The layout of the register is that of the MG3710A/MG3740A.
:STATus:OPERation:NTRansition?	√	:STATus:OPERation:NTRansition?	The layout of the register is that of the MG3710A/MG3740A.
:STATus:OPERation:PTRansition <value>	√	:STATus:OPERation:PTRansition <integer>	The layout of the register is that of the MG3710A/MG3740A.
:STATus:OPERation:PTRansition?	√	:STATus:OPERation:PTRansition?	The layout of the register is that of the MG3710A/MG3740A.
:STATus:OPERation:SUPPress 0 1 ON OFF	√	:STATus:OPERation:SUPPress 0 1 ON OFF	The layout of the register is that of the MG3710A/MG3740A.
:STATus:OPERation:SUPPress?	√	:STATus:OPERation:SUPPress?	The layout of the register is that of the MG3710A/MG3740A.
:STATus:OPERation[:EVENT]?	√	:STATus:OPERation[:EVENT]?	The layout of the register is that of the MG3710A/MG3740A.

Table G.2.8-1 Status Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:STATus:PRESet	√	:STATus:PRESet	
:STATus:QUESTionable:CALibration:CONDit ion?	N/A	Not supported.	
:STATus:QUESTionable:CALibration:ENABLe <value>	N/A	Not supported.	
:STATus:QUESTionable:CALibration:ENABLe ?	N/A	Not supported.	
:STATus:QUESTionable:CALibration:NTRans ition <value>	N/A	Not supported.	
:STATus:QUESTionable:CALibration:NTRans ition?	N/A	Not supported.	
:STATus:QUESTionable:CALibration:PTRans ition <value>	N/A	Not supported.	
:STATus:QUESTionable:CALibration:PTRans ition?	N/A	Not supported.	
:STATus:QUESTionable:CALibration[:EVENT ]?	N/A	Not supported.	
:STATus:QUESTionable:CONDition?	N/A	Not supported.	
:STATus:QUESTionable:ENABLe <value>	N/A	Not supported.	
:STATus:QUESTionable:ENABLe?	N/A	Not supported.	
:STATus:QUESTionable:FREQuency:CONDitio n?	N/A	Not supported.	
:STATus:QUESTionable:FREQuency:ENABLe <value>	N/A	Not supported.	
:STATus:QUESTionable:FREQuency:ENABLe?	N/A	Not supported.	
:STATus:QUESTionable:FREQuency:NTRansit ion <value>	N/A	Not supported.	
:STATus:QUESTionable:FREQuency:NTRansit ion?	N/A	Not supported.	

**Table G.2.8-1 Status Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
<code>:STATUS:QUESTIONABLE:FREQUENCY:PTRANSITION &lt;value&gt;</code>	N/A	Not supported.	
<code>:STATUS:QUESTIONABLE:FREQUENCY:PTRANSITION?</code>	N/A	Not supported.	
<code>:STATUS:QUESTIONABLE:FREQUENCY[:EVENT]?</code>	N/A	Not supported.	

## G.2.9 System Subsystem

System Subsystem device messages available in MG3710A/MG3740A are shown in Table G.2.9-1.

**Table G.2.9-1 System Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:SYSTem:DATE <year>,<month>,<day>	N/A	Not supported.	
:SYSTem:DATE?	N/A	Not supported.	
:SYSTem:ERRor:CODE[:NEXT]?	√	:SYSTem:ERRor:CODE[:NEXT]?	
:SYSTem:ERRor[:NEXT]?	√	:SYSTem:ERRor[:NEXT]?	
:SYSTem:ERRor:SCPI[:SYNTax] ON OFF 1 0	N/A	Not supported.	
:SYSTem:ERRor:SCPI[:SYNTax]?	N/A	Not supported.	
:SYSTem:FILEsystem:STORage:EXTErnal?	N/A	Not supported.	
:SYSTem:FILEsystem:STORage:EXTErnal:PATH <"USB media root path">	N/A	Not supported.	
:SYSTem:FILEsystem:STORage:EXTErnal:PATH?	N/A	Not supported.	
:SYSTem:FILEsystem:STORage:TYPE INTERNAL EXTERNAL	N/A	Not supported.	
:SYSTem:FILEsystem:STORage:TYPE?	N/A	Not supported.	
:SYSTem:FILEsystem:STORage:TYPE:AUTO ON OFF 1 0	N/A	Not supported.	
:SYSTem:FILEsystem:STORage:TYPE:AUTO?	N/A	Not supported.	
:SYSTem:IDN "string"	N/A	Not supported.	

**Table G.2.9-1 System Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
:SYSTem:LANGuage "SCPI"   "COMP"   "8648"   "E4428C"   "E4438C"   "E8257D"   "E8267D"   "E8663B"   "E8247C"   "E8 257C"   "E8267C"   "E8241A"   "E8244A"   "E8251 A"   "E8254A"   "E8247C"   "E8257C"   "E8267C"   "SMU200A"   "SMATE200A"   "SMJ100A"   "SMIQ"   "SML"   "SMV"   "3410"	√	:SYSTem:LANGuage "SCPI"   "MG3700A"	
:SYSTem:LANGuage?	√	:SYSTem:LANGuage?	
:SYSTem:LICense:AUS[:DATE]?	N/A	Not supported.	
:SYSTem:LICense:EXternal:LIST?	N/A	Not supported.	
:SYSTem:LICense:[FPack:]WAVeform:ADD "filename"	N/A	Not supported.	
:SYSTem:LICense[:FPack]:WAVeform:CLear <slot_number>	N/A	Not supported.	
:SYSTem:LICense[:FPack]:WAVeform:FREE?	N/A	Not supported.	
:SYSTem:LICense:[FPack]:WAVeform:IDLlist ?	N/A	Not supported.	
:SYSTem:LICense[:FPack]:WAVeform:LOCK slot_number	N/A	Not supported.	
:SYSTem:LICense[:FPack]:WAVeform:REPlac e slot_number, "filename"	N/A	Not supported.	
:SYSTem:LICense[:FPack]:WAVeform:STATUs ? slot_number	N/A	Not supported.	
:SYSTem:LICense:FPACK:WAVeform:USED?	N/A	Not supported.	
:SYSTem:LICense:INSTall <license_line> <block_of_license_lines>	N/A	Not supported.	
:SYSTem:LICense:LIST?	N/A	Not supported.	

Table G.2.9-1 System Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:SYSTem:LIcense:REMOve <license_line>	N/A	Not supported.	
:SYSTem:OPT "string"	N/A	Not supported.	
:SYSTem:PDOWn	√	:SYSTem:PDOWn	
:SYSTem:PMETer[1]   2:CHANnel A B	N/A	Not supported.	
:SYSTem:PMETer[1]   2:CHANnel?	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:LAN:DEV ice <deviceName>	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:LAN:DEV ice?	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:LAN:IP <ipAddress>	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:LAN:IP?	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:LAN:POR T <portNumber>	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:LAN:POR T?	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:TYPE SOCKETs SOCKETs VXI11 USB	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:TYPE?	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:USB:DEV ice <device>	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:USB:DEV ice?	N/A	Not supported.	
:SYSTem:PMETer[1]   2:COMMunicate:USB:LIS T?	N/A	Not supported.	



**Table G.2.9-1 System Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
:SYSTem:PMETer[1] 2:MEASure?	√	:SYSTem:PMETer[1] 2:MEASure?	
:SYSTem:PMETer[1] 2:SENSe:AVERage:COUNt<avgCount>	√	:SYSTem:PMETer[1] 2:SENSe:AVERage:COUNt <ext_integer>	
:SYSTem:PMETer[1] 2:SENSe:AVERage:COUNt?	√	:SYSTem:PMETer[1] 2:SENSe:AVERage:COUNt?	
:SYSTem:PMETer[1] 2:SENSe:AVERage:COUNt:AUTO ON OFF 1 0	N/A	Not supported.	
:SYSTem:PMETer[1] 2:SENSe:AVERage:COUNt:AUTO?	N/A	Not supported.	
:SYSTem:PMETer[1] 2:SENSe:AVERage[:STATe] ON OFF 1 0	√	:SYSTem:PMETer[1] 2:SENSe:AVERage[:STATe] <boolean>	
:SYSTem:PMETer[1] 2:SENSe:AVERage[:STATe]?	√	:SYSTem:PMETer[1] 2:SENSe:AVERage[:STATe]?	
:SYSTem:PMETer[1] 2:SENSe:FREQuency[:CW :FIXed] <freq><unit>	√	:SYSTem:PMETer[1] 2:SENSe:FREQuency[:CW :FIXed] <freq>	
:SYSTem:PMETer[1] 2:SENSe:FREQuency[:CW :FIXed]?	√	:SYSTem:PMETer[1] 2:SENSe:FREQuency[:CW :FIXed]?	
:SYSTem:PMETer[1] 2:UNIT:POWer DBM W	√	:SYSTem:PMETer[1] 2:UNIT:POWer DBM W	
:SYSTem:PMETer[1] 2:UNIT:POWer?	√	:SYSTem:PMETer[1] 2:UNIT:POWer?	
:SYSTem:PMETer[1] 2[:STATe] ON OFF 1 0	√	:SYSTem:PMETer[1] 2[:STATe] <boolean>	
:SYSTem:PMETer[1] 2[:STATe]?	√	:SYSTem:PMETer[1] 2[:STATe]?	
:SYSTem:PON:TYPE PRESet LAST USER	√	:SYSTem:PON:TYPE PRESet LAST	
:SYSTem:PON:TYPE?	√	:SYSTem:PON:TYPE?	
:SYSTem:PRESet	√	:SYSTem:PRESet	Executes preset

Table G.2.9-1 System Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:SYSTem:PRESet:ALL	N/A	Not supported.	
:SYSTem:PRESet:LANGuage "SCPI" "COMP" "8648" "E4428C" "E4438C" "E8257D" "E8267D" "E8663B" "E8247C" "E8257C" "E8267C" "E442XB" "E443XB" "E8241A" "E8244A" "E8251A" "E8254A" "E8247C" "E8257C" "E8267C" "SMU200A" "SMATE200A" "SMJ100A" "SMIQ" "SML" "SMV" "3410"	N/A	Not supported.	
:SYSTem:PRESet:LANGuage?	N/A	Not supported.	
:SYSTem:PRESet:PERSistent	N/A	Not supported.	
:SYSTem:PRESet:PN9 NORMAL QUICK	N/A	Not supported.	
:SYSTem:PRESet:PN9?	N/A	Not supported.	
:SYSTem:PRESet:TYPE NORMAL USER	N/A	Not supported.	
:SYSTem:PRESet:USER	N/A	Not supported.	
:SYSTem:PRESet[:USER]:SAVE	N/A	Not supported.	
:SYSTem:SECurity:DISPlay ON OFF 1 0	N/A	Not supported.	
:SYSTem:SECurity:DISPlay?	N/A	Not supported.	
:SYSTem:SECurity:DISPlay:RESTRicted ON OFF 1 0	N/A	Not supported.	
:SYSTem:SECurity:DISPlay:RESTRicted?	N/A	Not supported.	
:SYSTem:SECurity:ERASeall	N/A	Not supported.	
:SYSTem:SECurity:LEVel NONE ERASe OVERwrite SANitize	N/A	Not supported.	

**Table G.2.9-1 System Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
:SYSTem:SECurity:LEVel?	N/A	Not supported.	
:SYSTem:SECurity:LEVel:STATE ON OFF 1 0	N/A	Not supported.	
:SYSTem:SECurity:LEVel:STATE?	N/A	Not supported.	
:SYSTem:SECurity:OVERwrite	N/A	Not supported.	
:SYSTem:SECurity:SANitize	N/A	Not supported.	
:SYSTem:SSAVer:DELay <value>	N/A	Not supported.	
:SYSTem:SSAVer:DELay?	N/A	Not supported.	
:SYSTem:SSAVer:MODE LIGHT TEXT	N/A	Not supported.	
:SYSTem:SSAVer:MODE?	N/A	Not supported.	
:SYSTem:SSAVer:STATE ON OFF 1 0	N/A	Not supported.	
:SYSTem:SSAVer:STATE?	N/A	Not supported.	
:SYSTem:TIME <hour>,<minute>,<second>	N/A	Not supported.	
:SYSTem:TIME?	N/A	Not supported.	
:SYSTem:VERSion?	√	:SYSTem:VERSion?	

## G.2.10 Trigger Subsystem

Trigger Subsystem device messages available in MG3710A/MG3740A are shown in Table G.2.10-1.

**Table G.2.10-1 Trigger Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
:ABORT	N/A	Not supported.	
:INITiate:CONTinuous[:ALL] ON OFF 1 0	√	:INITiate:CONTinuous[:ALL] <boolean>	
:INITiate:CONTinuous[:ALL]?	√	:INITiate:CONTinuous[:ALL]?	
:INITiate[:IMMediate][:ALL]	√	:INITiate[:IMMediate][:ALL]	
:TRIGger:OUTPut:POLarity POSitive NEGative	N/A	Not supported.	
:TRIGger:OUTPut:POLarity?	N/A	Not supported.	
:TRIGger[:SEquence]:SLOPe POSitive NEGative	√	:TRIGger[1] 2[:SEquence]:SLOPe POSitive NEGative	
:TRIGger[:SEquence]:SLOPe?	√	:TRIGger[1] 2[:SEquence]:SLOPe?	
:TRIGger[:SEquence]:SOURce BUS IMMediate EXTernal KEY TIMER	√	:TRIGger[1] 2[:SEquence]:SOURce BUS IMMediate EXTernal KEY TIMER	TIMER cannot be selected. Turns Trigger off in selecting IMMEDIATE
:TRIGger[:SEquence]:SOURce?	√	:TRIGger[1] 2[:SEquence]:SOURce?	Returns IMM when Trigger is off in selecting IMMEDIATE
:TRIGger[:SEquence]:TIMER <period>	√	:TRIGger[:SEquence]:TIMER <time>	
:TRIGger[:SEquence]:TIMER?	√	:TRIGger[:SEquence]:TIMER?	
:TRIGger[:SEquence][:IMMediate]	√	:TRIGger[:SEquence][:IMMediate]	
[:SOURce]:TSweep	√	[:SOURce]:TSweep	

## G.2.11 Unit Subsystem

Unit Subsystem device messages available in MG3710A/MG3740A are shown in Table G.2.11-1.

**Table G.2.11-1 Unit Subsystem Device Messages**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
:UNIT:POWer DBM DBUV DBUVEMF V VEMF DB	√	:UNIT[1] 2:POWer DBM DBUV DBUVEMF	V, VEMF, and DB cannot be selected.
:UNIT:POWer?	√	:UNIT[1] 2:POWer?	
:UNIT:VOLT:TYPE PD EMF	N/A	Not supported.	
:UNIT:VOLT:TYPE?	N/A	Not supported.	

## G.3 Analog Modulation Commands

### G.3.1 Amplitude Modulation Subsystem

Amplitude Modulation Subsystem device messages available in MG3710A/MG3740A are shown in Table G.3.1-1.

**Table G.3.1-1 Amplitude Modulation Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
A[:SOURCE]:AM:EXTERNAL:COUPLing AC DC	√	[:SOURCE[1] 2]:AM:EXTERNAL:COUPLing AC DC	
[:SOURCE]:AM:EXTERNAL:COUPLing?	√	[:SOURCE[1] 2]:AM:EXTERNAL:COUPLing?	
[:SOURCE]:AM:INTERNAL:FREQUENCY <value><unit> UP DOWN	√	[:SOURCE[1] 2]:AM[:AM[1] 2]:INTERNAL:FREQUENCY <freq>	
[:SOURCE]:AM:INTERNAL:FREQUENCY?	√	[:SOURCE[1] 2]:AM[:AM[1] 2]:INTERNAL:FREQUENCY?	
[:SOURCE]:AM:INTERNAL:FREQUENCY:STEP[:INCREMENT] <num>	√	[:SOURCE[1] 2]:AM:INTERNAL:FREQUENCY:STEP[:INCREMENT] <freq>	
[:SOURCE]:AM:INTERNAL:FREQUENCY:STEP[:INCREMENT]?	√	[:SOURCE[1] 2]:AM:INTERNAL:FREQUENCY:STEP[:INCREMENT]?	
[:SOURCE]:AM:INTERNAL:FUNCTION:SHAPE SINE	√	[:SOURCE[1] 2]:AM[1] 2:INTERNAL:FUNCTION:SHAPE SINE TRIangle SQUare RAMP	
[:SOURCE]:AM:INTERNAL:FUNCTION:SHAPE?	√	[:SOURCE[1] 2]:AM[1] 2:INTERNAL:FUNCTION:SHAPE?	
[:SOURCE]:AM:MODE DEEP NORMAL	N/A	Not supported.	
[:SOURCE]:AM:MODE?	N/A	Not supported.	
[:SOURCE]:AM:SOURCE INT EXT	√	[:SOURCE[1] 2]:AM[1] 2:SOURCE INT EXT	
[:SOURCE]:AM:SOURCE?	√	[:SOURCE[1] 2]:AM[1] 2:SOURCE?	

**Table G.3.1-1 Amplitude Modulation Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce]:AM:STATE ON OFF 1 0	√	[ :SOURce[1] 2]:AM[1] 2:STATE <boolean>	
[ :SOURce]:AM:STATE?	√	[ :SOURce[1] 2]:AM[1] 2:STATE?	
[ :SOURce]:AM:TYPE LINear EXponential	√	[ :SOURce[1] 2]:AM:TYPE LINear EXponential	
[ :SOURce]:AM:TYPE?	√	[ :SOURce[1] 2]:AM:TYPE?	
[ :SOURce]:AM[:DEPTh]:EXponential <value>	√	[ :SOURce[1] 2]:AM[1] 2[:DEPTh]:EXponen tial <rel_ampl>	
[ :SOURce]:AM[:DEPTh]:EXponential?	√	[ :SOURce[1] 2]:AM[1] 2[:DEPTh]:EXponen tial?	
[ :SOURce]:AM[:DEPTh]:STEP[:INCRement] <value><unit>	N/A	Not supported.	
[ :SOURce]:AM[:DEPTh]:STEP[:INCRement]?	N/A	Not supported.	
[ :SOURce]:AM[:DEPTh][:LINear] <value><unit> UP DOWN	√	[ :SOURce[1] 2]:AM[1] 2[:DEPTh][:LINear] ] <percent>	
[ :SOURce]:AM[:DEPTh][:LINear]?	√	[ :SOURce[1] 2]:AM[1] 2[:DEPTh][:LINear] ]?	

## G.3.2 Frequency Modulation Subsystem

Frequency Modulation Subsystem device messages available in MG3710A/MG3740A are shown in Table G.3.2-1.

**Table G.3.2-1 Frequency Modulation Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce]:FM:EXTErnal:COUPling AC DC	√	[ :SOURce[1] 2]:FM:EXTErnal:COUPling AC DC	
[ :SOURce]:FM:EXTErnal:COUPling?	√	[ :SOURce[1] 2]:FM:EXTErnal:COUPling?	
[ :SOURce]:FM:INTernAl:FREQuency <value><unit> UP DOWN	√	[ :SOURce[1] 2]:FM[1] 2:INTernAl:FREQuency <freq>	
[ :SOURce]:FM:INTernAl:FREQuency?	√	[ :SOURce[1] 2]:FM[1] 2:INTernAl:FREQuency?	
[ :SOURce]:FM:INTernAl:FREQuency:STEP[:INCRement] <num>	√	[ :SOURce[1] 2]:FM:INTernAl:FREQuency:STEP[:INCRement] <freq>	
[ :SOURce]:FM:INTernAl:FREQuency:STEP[:INCRement]?	√	[ :SOURce[1] 2]:FM:INTernAl:FREQuency:STEP[:INCRement]?	
[ :SOURce]:FM:INTernAl:FUNCTion:SHAPE SINE	√	[ :SOURce[1] 2]:FM[1] 2:INTernAl:FUNCTion:SHAPE SINE SQUare RAMP PULSe	
[ :SOURce]:FM:INTernAl:FUNCTion:SHAPE?	√	[ :SOURce[1] 2]:FM[1] 2:INTernAl:FUNCTion:SHAPE?	
[ :SOURce]:FM:SOURce INT EXT	√	[ :SOURce[1] 2]:FM[1] 2:SOURce INT EXT	
[ :SOURce]:FM:SOURce?	√	[ :SOURce[1] 2]:FM[1] 2:SOURce?	
[ :SOURce]:FM:STATe ON OFF 1 0	√	[ :SOURce[1] 2]:FM[1] 2:STATe <boolean>	
[ :SOURce]:FM:STATe?	√	[ :SOURce[1] 2]:FM[1] 2:STATe?	
[ :SOURce]:FM[:DEViation] <value><unit>	√	[ :SOURce[1] 2]:FM[1] 2[:DEViation] <freq>	
[ :SOURce]:FM[:DEViation]?	√	[ :SOURce[1] 2]:FM[1] 2[:DEViation]?	



**Table G.3.2-1 Frequency Modulation Subsystem Device Messages (Continued)**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[:SOURCE]:FM[:DEVIation]:STEP[:INCRement] <value><unit> GHz MHz kHz Hz	√	[:SOURCE[1] 2]:FM[:DEVIation]:STEP[:INCRement] <freq>[,<sg>]	
[:SOURCE]:FM[:DEVIation]:STEP[:INCRement]?	√	[:SOURCE[1] 2]:FM[:DEVIation]:STEP[:INCRement]? [<sg>]	

### G.3.3 Phase Modulation Subsystem

Phase Modulation Subsystem device messages available in MG3710A/MG3740A are shown in Table G.3.3-1.

**Table G.3.3-1 Phase Modulation Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ] : PM : BANDwidth   BWIDth NORMal   HIGH	N/A	Not supported.	
[ :SOURce ] : PM : BANDwidth   BWIDth?	N/A	Not supported.	
[ :SOURce ] : PM : EXTernal : COUPling AC   DC	√	[ :SOURce[1]   2 ] : PM : EXTernal : COUPling AC   DC	
[ :SOURce ] : PM : EXTernal : COUPling?	√	[ :SOURce[1]   2 ] : PM : EXTernal : COUPling?	
[ :SOURce ] : PM : INTernal : FREQuency <value><unit>   UP   DOWN	√	[ :SOURce[1]   2 ] : PM[1]   2 : INTernal : FREQue ncy <freq>	
[ :SOURce ] : PM : INTernal : FREQuency?	√	[ :SOURce[1]   2 ] : PM[1]   2 : INTernal : FREQue ncy?	
[ :SOURce ] : PM : INTernal : FREQuency : STEP[ : I NCRement ] <num>	√	[ :SOURce[1]   2 ] : PM : INTernal : FREQuency : S TEP[ : INCRement ] <freq>	
[ :SOURce ] : PM : INTernal : FREQuency : STEP[ : I NCRement ]?	√	[ :SOURce[1]   2 ] : PM : INTernal : FREQuency : S TEP[ : INCRement ]?	
[ :SOURce ] : PM : INTernal : FUNCTion : SHAPE SINE	√	[ :SOURce[1]   2 ] : PM[1]   2 : INTernal : FUNCTi on : SHAPE SINE   SQUare   TRIangle   RAMP   PULSe	
[ :SOURce ] : PM : INTernal : FUNCTion : SHAPE?	√	[ :SOURce[1]   2 ] : PM[1]   2 : INTernal : FUNCTi on : SHAPE?	
[ :SOURce ] : PM : SOURce INT   EXT	√	[ :SOURce[1]   2 ] : PM : [ PM[1]   2 ] : SOURce INT1   INT2   EXT	
[ :SOURce ] : PM : SOURce?	√	[ :SOURce[1]   2 ] : PM : [ PM[1]   2 ] : SOURce?	
[ :SOURce ] : PM : STATE ON   OFF   1   0	√	[ :SOURce[1]   2 ] : PM : [ : PM[1]   2 ] : STATE <boolean>	
[ :SOURce ] : PM : STATE?	√	[ :SOURce[1]   2 ] : PM : [ : PM[1]   2 ] : STATE?	

**Table G.3.3-1 Phase Modulation Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURCE]:PM[:DEVIation] <value><unit> UP DOWN	√	[ :SOURCE[1] 2]:PM[:DEVIation] <ext_numeric>	
[ :SOURCE]:PM[:DEVIation]?	√	[ :SOURCE[1] 2]:PM[:DEVIation]?	
[ :SOURCE]:PM[:DEVIation]:STEP[:INCREment] <value><unit>	√	[ :SOURCE]:PM[:DEVIation]:STEP[:INCREment] <value><unit>	
[ :SOURCE]:PM[:DEVIation]:STEP[:INCREment]?	√	[ :SOURCE]:PM[:DEVIation]:STEP[:INCREment]?	

## G.3.4 Pulse Modulation Subsystem

Pulse Modulation Subsystem device messages available in MG3710A/MG3740A are shown in Table G.3.4-1.

**Table G.3.4-1 Phase Modulation Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ] :PULM :EXTernal :POLarity NORMal   INVerted	√	[ :SOURce ] :PULM :EXTernal :POLarity NORMal   INVerted	
[ :SOURce ] :PULM :EXTernal :POLarity?	√	[ :SOURce ] :PULM :EXTernal :POLarity?	
[ :SOURce ] :PULM :INTernal :DELay :STEP <num><time_suffix>	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :DELay :STEP?	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :DELay [ 1 ] [ 2 ] <num><time_suffix>   UP   DOWN	√	[ :SOURce [ 1 ]   2 ] :PULM :INTernal :DELay [ 1 ]   2 <time>	
[ :SOURce ] :PULM :INTernal :DELay [ 1 ] [ 2 ]	√	[ :SOURce [ 1 ]   2 ] :PULM :INTernal :DELay [ 1 ]   2	
[ :SOURce ] :PULM :INTernal :FREQuency <frequency>   MAXimum   MINimum   UP   DOWN	√	[ :SOURce [ 1 ]   2 ] :PULM :INTernal :FREQuency <freq>	
[ :SOURce ] :PULM :INTernal :FREQuency?	√	[ :SOURce [ 1 ]   2 ] :PULM :INTernal :FREQuency ?	
[ :SOURce ] :PULM :INTernal :FREQuency :STEP [ :INCRement ] <freq>   MAXimum   MINimum   DEFault	√	[ :SOURce [ 1 ]   2 ] :PULM :INTernal :FREQuency :STEP [ :INCRement ] <freq>	
[ :SOURce ] :PULM :INTernal :FREQuency :STEP [ :INCRement ]?	√	[ :SOURce [ 1 ]   2 ] :PULM :INTernal :FREQuency :STEP [ :INCRement ]?	
[ :SOURce ] :PULM :INTernal :PERiod <period>   MAXimum   MINimum   UP   DOWN	√	[ :SOURce [ 1 ]   2 ] :PULM :INTernal :PERiod <time>	
[ :SOURce ] :PULM :INTernal :PERiod?	√	[ :SOURce [ 1 ]   2 ] :PULM :INTernal :PERiod?	

**Table G.3.4-1 Pulse Modulation Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce ] :PULM :INTernal :PERiod :STEP [ :INCRement ] <step>  UP  DOWN	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :PERiod :STEP [ :INCRement ] ?	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :PWIDth :STEP <num> <time_suffix>  MAXimum  MINimum  DEFa ult	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :PWIDth :STEP ?	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :PWIDth [ 1 ]   2 <num> <time_suffix>  UP  DOWN	√	[ :SOURce [ 1 ]   2 ] :PULM :INTernal :PWIDth [ 1 ]   2 <time>	
[ :SOURce ] :PULM :INTernal :PWIDth [ 1 ]   2 ?	√	[ :SOURce [ 1 ]   2 ] :PULM :INTernal :PWIDth [ 1 ]   2 ?	
[ :SOURce ] :PULM :INTernal :TRain :LIST :PRES et	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :TRain :OFFTime <value> { , <value> }	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :TRain :OFFTime ?	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :TRain :ONTime <value> { , <value> }	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :TRain :ONTime ?	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :TRain :REPetitio n <value> { , <value> }	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal :TRain :REPetitio n ?	N/A	Not supported.	
[ :SOURce ] :PULM :INTernal [ 1 ] :VIDeo :POLari ty NORMal   INVerted	√	[ :SOURce ] :PULM :INTernal [ 1 ] :VIDeo :POLar ity NORMal   INVerted	
[ :SOURce ] :PULM :INTernal [ 1 ] :VIDeo :POLari ty ?	√	[ :SOURce ] :PULM :INTernal [ 1 ] :VIDeo :POLar ity ?	
[ :SOURce ] :PULM :SOURce INTernal   EXTernal	√	[ :SOURce [ 1 ]   2 ] :PULM :SOURce INTernal   EXTernal	

Table G.3.4-1 Pulse Modulation Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ] :PULM :SOURce?	√	[ :SOURce[1]   2 ] :PULM :SOURce?	
[ :SOURce ] :PULM :SOURce :INTernal SQUare   FRUN   TRIGgered   ADoublet   DOUBlet   GATED   PTRain	√	[ :SOURce[1]   2 ] :PULM :SOURce :INTernal SQUare   FRUN   TRIGgered   ADoublet   DOUBlet   GATED	
[ :SOURce ] :PULM :SOURce :INTernal?	√	[ :SOURce[1]   2 ] :PULM :SOURce :INTernal?	
[ :SOURce ] :PULM :STATE ON   OFF   1   0	√	[ :SOURce[1]   2 ] :PULM :STATE <boolean>	
[ :SOURce ] :PULM :STATE?	√	[ :SOURce[1]   2 ] :PULM :STATE?	

## G.4 Arb Commands

### G.4.1 All Subsystem

All subsystem device messages available in MG3710A/MG3740A are shown in Table G.4.1-1.

**Table G.4.1-1 All Subsystem Device Messages**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce]:RADio:ALL:OFF	√	[ :SOURce[1] 2]:RADio:ALL:OFF	ARB is turned off during execution.

## G.4.2 Dual ARB Subsystem

Dual ARB subsystem device messages available in MG3710A/MG3740A are shown in Table G.4.2-1.

**Table G.4.2-1 Dual ARB Subsystem Device Messages**

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce]:RADio:ARB:BASEband:FREQuency:OFFSet <value><unit>	√	[ :SOURce[1] 2]:RADio:ARB:BASEband:FREQuency:OFFSet <value><unit>	Corresponds to the Offset A.
[ :SOURce]:RADio:ARB:BASEband:FREQuency:OFFSet?	√	[ :SOURce[1] 2]:RADio:ARB:BASEband:FREQuency:OFFSet?	Corresponds to the Offset A.
[ :SOURce]:RADio:ARB:BASEband:FREQuency:OFFSet:PHASe:RESet	N/A	Not supported.	
[ :SOURce]:RADio:ARB:CLIPping "<file name>", IJQ  IORQ, <value>[ , <value>]	N/A	Not supported.	
[ :SOURce]:RADio:ARB:DOPProtection ON OFF 1 0	N/A	Not supported.	
[ :SOURce]:RADio:ARB:DOPProtection?	N/A	Not supported.	
[ :SOURce]:RADio[1]:ARB:FILTer:ALPha <value>	N/A	Not supported.	
[ :SOURce]:RADio[1]:ARB:FILTer:ALPha?	N/A	Not supported.	
[ :SOURce]:RADio[1]:ARB:FILTer:BBT <value>	N/A	Not supported.	
[ :SOURce]:RADio[1]:ARB:FILTer:BBT?	N/A	Not supported.	
[ :SOURce]:RADio[1]:ARB:FILTer:CHANnel EVM ACP	N/A	Not supported.	
[ :SOURce]:RADio[1]:ARB:FILTer:CHANnel?	N/A	Not supported.	



**Table G.4.2-1 Dual ARB Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce]:RADio:ARB:FILTer:TYPE RNYQuist NYQuist GAUSSian RECTangle  IS95 IS95_EQ IS95_MOD IS95_MOD_EQ  EDGE EWIDE EHSR WCDMa AC4Fm  "<user FIR>"	N/A	Not supported.	
[ :SOURce]:RADio:ARB:FILTer:TYPE?	N/A	Not supported.	
[ :SOURce]:RADio[1]:ARB:FILTer[:STATE]ON  {OFF} 1 0	N/A	Not supported.	
[ :SOURce]:RADio:ARB:GENerate:SINE ["<file_name>"][,<osr>],[<scale>],[I Q  IQ][<phasedeg>]	N/A	Not supported.	
[ :SOURce]:RADio:ARB:GENerate:TEST:WAVEf orms	N/A	Not supported.	
[ :SOURce]:RADio:ARB:HEADer:CLEAr	N/A	Not supported.	
[ :SOURce]:RADio:ARB:HEADer:NOISe:RMS:OV ERride "<file_name>",<value> UNSPecified	N/A	Not supported.	
[ :SOURce]:RADio:ARB:HEADer:NOISe:RMS:OV ERride? "<file_name>"	N/A	Not supported.	
[ :SOURce]:RADio:ARB:HEADer:RMS "<file_name>",<value> UNSPecified	N/A	Not supported.	
[ :SOURce]:RADio:ARB:HEADer:RMS? "<file_name>"	N/A	Not supported.	
[ :SOURce]:RADio:ARB:HEADer:SAVE	N/A	Not supported.	
[ :SOURce]:RADio:ARB:IQ:MODulation:ATTen <value>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:IQ:MODulation:ATTen ?	N/A	Not supported.	

Table G.4.2-1 Dual ARB Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce]:RADio:ARB:IQ:MODulation:ATTen:AUTO ON OFF 1 0	N/A	Not supported.	
[ :SOURce]:RADio:ARB:IQ:MODulation:ATTen:AUTO?	N/A	Not supported.	
[ :SOURce]:RADio:ARB:MARKer:CLEar "<file_name>", <marker>, <first_point>, <last_point>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:MARKer:CLEar:ALL "<file_name>", <marker>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:MARKer:ROTate "<file_name>", <rotate_count>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:MARKer[:SET] "<file_name>", <marker>, <first_point>, <last_point>, <skip_count>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:MBSync OFF MASTER SLAVE	√	[ :SOURce]:RADio:ARB:MBSync OFF SG12 MASTER SLAVE	
[ :SOURce]:RADio:ARB:MBSync?	√	[ :SOURce]:RADio:ARB:MBSync?	
[ :SOURce]:RADio:ARB:MBSync:NSLaves <value>	√	[ :SOURce]:RADio:ARB:MBSync:NSLaves <ext_integer>	
[ :SOURce]:RADio:ARB:MBSync:NSLaves?	√	[ :SOURce]:RADio:ARB:MBSync:NSLaves?	
[ :SOURce]:RADio:ARB:MBSync:SLISTen	√	[ :SOURce]:RADio:ARB:MBSync:SLISTen	
[ :SOURce]:RADio:ARB:MBSync:SREFerence <value>	√	[ :SOURce]:RADio:ARB:MBSync:SREFerence <ext_integer>	
[ :SOURce]:RADio:ARB:MBSync:SREFerence?	√	[ :SOURce]:RADio:ARB:MBSync:SREFerence?	
[ :SOURce]:RADio:ARB:MBSync:SSLaves	√	[ :SOURce]:RADio:ARB:MBSync:SSLaves	

**Table G.4.2-1 Dual ARB Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce]:RADio:ARB:MDEStination:ALCHold NONE   M1   M2   M3   M4	N/A	Not supported.	
[ :SOURce]:RADio:ARB:MDEStination:ALCHold?	N/A	Not supported.	
[ :SOURce]:RADio:ARB:MDEStination:PULSe NONE   M1   M2   M3   M4	N/A	Not supported.	
[ :SOURce]:RADio:ARB:MDEStination:PULSe?	N/A	Not supported.	
[ :SOURce]:RADio:ARB:MPOLarity:MARKer1   2   3   4 NEGative   POSitive	√	[ :SOURce]:RADio:ARB:MPOLarity:MARKer1   2   3 NEGative   POSitive	MARKer4 is not supported
[ :SOURce]:RADio:ARB:MPOLarity:MARKer1   2   3   4?	√	[ :SOURce]:RADio:ARB:MPOLarity:MARKer1   2   3?	MARKer4 is not supported
[ :SOURce]:RADio:ARB:NOISe:BANDwidth <value><unit>	√	[ :SOURce[1]   2]:RADio:ARB:NOISe:BANDwidth <freq>	
[ :SOURce]:RADio:ARB:NOISe:BANDwidth?	√	[ :SOURce[1]   2]:RADio:ARB:NOISe:BANDwidth?	
[ :SOURce]:RADio:ARB:NOISe:CBRate <lbps - 999Mbps>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:NOISe:CBRate?	N/A	Not supported.	
[ :SOURce]:RADio:ARB:NOISe:CBWidth <value><unit>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:NOISe:CBWidth?	N/A	Not supported.	
[ :SOURce]:RADio:ARB:NOISe:CN <value><unit>	√	[ :SOURce[1]   2]:RADio:ARB:NOISe:CN <rel_ampl>	
[ :SOURce]:RADio:ARB:NOISe:CN?	√	[ :SOURce[1]   2]:RADio:ARB:NOISe:CN?	
[ :SOURce]:RADio:ARB:NOISe:CNFormat CN   EBNO	N/A	Not supported.	

Table G.4.2-1 Dual ARB Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ]:RADio:ARB:NOISe:CNFormat?	N/A	Not supported.	
[ :SOURce ]:RADio:ARB:NOISe:EBNO <ebno in dB>	N/A	Not supported.	
[ :SOURce ]:RADio:ARB:NOISe:EBNO?	N/A	Not supported.	
[ :SOURce ]:RADio[1]:ARB:NOISe:MUX SUM CARRier NOISe	N/A	Not supported.	
[ :SOURce ]:RADio[1]:ARB:NOISe:MUX?	N/A	Not supported.	
[ :SOURce ]:RADio:ARB:NOISe:POWer:CARRier <carrierPower>	√	[ :SOURce[1] 2]:RADio:ARB:NOISe:POWer:CARRier <ampl>	
[ :SOURce ]:RADio:ARB:NOISe:POWer:CARRier?	√	[ :SOURce[1] 2]:RADio:ARB:NOISe:POWer:CARRier?	
[ :SOURce ]:RADio:ARB:NOISe:POWer:CONTRol [ :MODE ]{TOTal} CARRier NOISe	√	[ :SOURce[1] 2]:RADio:ARB:NOISe:POWer:CONTRol [ :MODE ] TOTal CARRier NOISe	
[ :SOURce ]:RADio:ARB:NOISe:POWer:CONTRol [ :MODE ]?	√	[ :SOURce[1] 2]:RADio:ARB:NOISe:POWer:CONTRol [ :MODE ]?	
[ :SOURce ]:RADio:ARB:NOISe:POWer:NOISe:CHANnel?	√	[ :SOURce[1] 2]:RADio:ARB:NOISe:POWer:NOISe:CHANnel?	
[ :SOURce ]:RADio:ARB:NOISe:POWer:NOISe:TOTal <totalNoisePowerInDbm>	N/A	Not supported.	
[ :SOURce ]:RADio:ARB:NOISe:POWer:NOISe:TOTal?	N/A	Not supported.	
[ :SOURce ]:RADio:ARB:NOISe [ :STATE ] ON OFF 1 0	√	[ :SOURce[1] 2]:RADio:ARB:NOISe [ :STATE ] <boolean>	
[ :SOURce ]:RADio:ARB:NOISe [ :STATE ]?	√	[ :SOURce[1] 2]:RADio:ARB:NOISe [ :STATE ]?	
[ :SOURce ]:RADio:ARB:PHASe:NOISe:F1 <value><unit>	N/A	Not supported.	

**Table G.4.2-1 Dual ARB Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce]:RADio:ARB:PHASe:NOISe:F1?	N/A	Not supported.	
[ :SOURce]:RADio:ARB:PHASe:NOISe:F2 <value><unit>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:PHASe:NOISe:F2?	N/A	Not supported.	
[ :SOURce]:RADio:ARB:PHASe:NOISe:LMID <value>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:PHASe:NOISe:LMID?	N/A	Not supported.	
[ :SOURce]:RADio:ARB:PHASe:NOISe[:STATe] ON OFF 1 0	N/A	Not supported.	
[ :SOURce]:RADio:ARB:PHASe:NOISe[:STATe] ?	N/A	Not supported.	
[ :SOURce]:RADio:ARB:REGister[:STATus]?	√	[ :SOURce[1] 2]:RADio:ARB:REGister[:STA Tus]?	
[ :SOURce]:RADio:ARB:RETRigger ON OFF 1 0 IMMediate	√	[ :SOURce[1] 2]:RADio:ARB:RETRigger ON OFF 1 0 IMMediate	
[ :SOURce]:RADio:ARB:RETRigger?	√	[ :SOURce[1] 2]:RADio:ARB:RETRigger?	
[ :SOURce]:RADio:ARB:RSCaling <value>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:RSCaling?	N/A	Not supported.	
[ :SOURce]:RADio:ARB:SCALing "<file_name>", <value>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:SCLock:RATE <value>	N/A	Not supported.	
[ :SOURce]:RADio:ARB:SCLock:RATE?	√	[ :SOURce[1] 2]:RADio:ARB:SCLock:RATE?	

Table G.4.2-1 Dual ARB Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce ] :RADio:ARB:SEQuence[ :MWAVEform <filename> , <waveform1> , <reps> , NONE   M1   M2   M3   M4   M1M2   M1M3   M1M4   M2M3   M2M4   M3M4   M1M2M3   M1M2M4   M1M3M4   M2M3M4   M1M2M3M4   ALL , { , <waveform2> , <reps> , NONE   M1   M2   M3   M4   M1M2   M1M3   M1M4   M2M3   M2M4   M3M4   M1M2M3   M1M2M4   M1M3M4   M2M3M4   M1M2M3M4   ALL , }	N/A	Not supported.	
[ :SOURce ] :RADio:ARB:SEQuence[ :MWAVEform ]? <filename>	N/A	Not supported.	
[ :SOURce ] :RADio:ARB:TRIGger:TYPE CONTinuous   SINGLE   GATE   SADVance	√	[ :SOURce[1]   2 ] :RADio:ARB:TRIGger:TYPE CONTinuous   SINGLE	CONTinuous: MG3710A/MG3740A is set to Off. SINGLE: MG3710A/MG3740A is set to On. GATE   SADVance cannot be used.
[ :SOURce ] :RADio:ARB:TRIGger:TYPE?	√	[ :SOURce[1]   2 ] :RADio:ARB:TRIGger:TYPE?	CONTinuous: MG3710A/MG3740A is set to Off. SINGLE: MG3710A/MG3740A is set to On. GATE   SADVance cannot be used.
[ :SOURce ] :RADio:ARB:TRIGger:TYPE:CONTinuous[ :TYPE ] FREE   TRIGger   RESet	N/A	Not supported.	
[ :SOURce ] :RADio:ARB:TRIGger:TYPE:CONTinuous[ :TYPE ]?	N/A	Not supported.	
[ :SOURce ] :RADio:ARB:TRIGger:TYPE:GATE LOW   HIGH	N/A	Not supported.	

**Table G.4.2-1 Dual ARB Subsystem Device Messages (Continued)**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURCE ] :RADio:ARB:TRIGger:TYPE:GATE?	N/A	Not supported.	
[ :SOURCE ] :RADio:ARB:TRIGger:TYPE:SADVan ce[ :TYPE ] SINGLE CONTInuous	N/A	Not supported.	
[ :SOURCE ] :RADio:ARB:TRIGger:TYPE:SADVan ce[ :TYPE ]?	N/A	Not supported.	
[ :SOURCE ] :RADio:ARB:TRIGger[ :SOURCE ] KEY EXT BUS	√	[ :SOURCE[1] 2 ] :RADio:ARB:TRIGger:S OURCE KEY EXT BUS	
[ :SOURCE ] :RADio:ARB:TRIGger[ :SOURCE ]?	√	[ :SOURCE[1] 2 ] :RADio:ARB:TRIGger:SOURc e?	
[ :SOURCE ] :RADio:ARB:TRIGger[ :SOURCE ] :EX Ternal:DElay <value>	√	[ :SOURCE[1] 2 ] :RADio:ARB:TRIGger[ :SOUR ce ] :EXternal:DElay <time>	The argument is <time> in the MG3710A/MG3740A Compatible Command.
[ :SOURCE ] :RADio:ARB:TRIGger[ :SOURCE ] :EX Ternal:DElay?	√	[ :SOURCE[1] 2 ] :RADio:ARB:TRIGger[ :SOUR ce ] :EXternal:DElay?	The argument is <time> in the MG3710A/MG3740A Compatible Command.
[ :SOURCE ] :RADio:ARB:TRIGger[ :SOURCE ] :EX Ternal:DElay:STATE ON OFF 1 0	N/A	Not supported.	
[ :SOURCE ] :RADio:ARB:TRIGger[ :SOURCE ] :EX Ternal:DElay:STATE?	N/A	Not supported.	
[ :SOURCE ] :RADio:ARB:TRIGger[ :SOURCE ] :EX Ternal:SLOPe POSitive NEGative	√	[ :SOURCE[1] 2 ] :RADio:ARB:TRIGger[ :SOUR ce ] :EXternal:SLOPe POSitive NEGative	
[ :SOURCE ] :RADio:ARB:TRIGger[ :SOURCE ] :EX Ternal:SLOPe?	√	[ :SOURCE[1] 2 ] :RADio:ARB:TRIGger[ :SOUR ce ] :EXternal:SLOPe?	
[ :SOURCE ] :RADio:ARB:TRIGger[ :SOURCE ] :EX Ternal[ :SOURCE ] EPT1 EPT2 EPTRIGGER1 EPTRIGGER2	N/A	Not supported.	
[ :SOURCE ] :RADio:ARB:TRIGger[ :SOURCE ] :EX Ternal[ :SOURCE ]?	N/A	Not supported.	

Table G.4.2-1 Dual ARB Subsystem Device Messages (Continued)

N5162A/N5182A Commands	Compatibility	MG3710A/MG3740A Compatible Command	Remarks
[ :SOURce]:RADio:ARB:WAVeform "WFM1:file_name" "SEQ:file_name"	√	[ :SOURce[1] 2]:RADio:ARB:WAVeform <string>	
[ :SOURce]:RADio:ARB:WAVeform?	√	[ :SOURce[1] 2]:RADio:ARB:WAVeform?	
[ :SOURce]:RADio:ARB:WAVeform:NHEaders "WFM1:file_name" "SEQ:filename"	√	[ :SOURce[1] 2]:RADio:ARB:WAVeform:NHEa ders <string>	
[ :SOURce]:RADio:ARB:WAVeform:NHEade rs?	√	[ :SOURce[1] 2]:RADio:ARB:WAVeform: NHEaders?	
[ :SOURce]:RADio:ARB[:STATe] ON OFF 1 0	√	[ :SOURce[1] 2]:RADio:ARB[:STATe] <boolean>	
[ :SOURce]:RADio:ARB[:STATe]?	√	[ :SOURce[1] 2]:RADio:ARB[:STATe]?	



### G.4.3 LARB Subsystem

LARB subsystem device messages available in MG3710A/MG3740A are shown in Table G.4.3-1.

**Table G.4.3-1 LARB Subsystem Device Messages**

<b>N5162A/N5182A Commands</b>	<b>Compatibility</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>Remarks</b>
[ :SOURce]:RADio:LARB[:STATE] ON OFF 1 0	√	[ :SOURce]:RADio:LARB[:STATE] <boolean>	
[ :SOURce]:RADio:LARB[:STATE]?	√	[ :SOURce]:RADio:LARB[:STATE]?	



## *Appendix H Panel Keys and Keyboard Operations*

**Table H-1 Correspondences Between Panel Keys and Keyboard Operations**































































Panel Key	USB Keyboard
 Preset	Ctrl+Shift+R
 Local	Ctrl+Shift+O
 Cal	Ctrl+Shift+9
 Save	Ctrl+S
 Recall	Ctrl+O
 Copy	Ctrl+Shift+8
 Top	Ctrl+Shift+ ↑
 F1	F1
 F2	F2
 F3	F3
 F4	F4
 F5	F5
 F6	F6
 F7	F7
 F8	F8
 More	Ctrl+Shift+→
 Back	Ctrl+Shift+←
 SG1	Ctrl+Shift+U
 SG2	Ctrl+Shift+I
 IQpro	Ctrl+Shift+P
 Frequency	Ctrl+Shift+Y
 Sweep/List	Ctrl+Shift+6
 AM	Ctrl+Shift+1
 I/Q	Ctrl+Alt+X
 Level	Ctrl+Shift+L
 Mode	Ctrl+Alt+V
 FM/φM	Ctrl+Shift+5
 AUX Fctn	Ctrl+Shift+3
 Load	Ctrl+Shift+F1
 Select	Ctrl+Shift+F2
 Pulse	Ctrl+Shift+4
 Utility	Ctrl+Alt+B










Table H-1 Correspondences Between Panel Keys and Keyboard Operations (Continued)

Panel Key	USB Keyboard
 0	0
 1	1
 2	2
 3	3
 4	4
 5	5
 6	6
 7	7
 8	8
 9	9
 A	A
 B	B
 C	C
 D	D
 E	E
 F	F
 .	.
 -/+	—
 Tab	Tab
 Shift	Shift
 BS	Back Space
 Ctrl	Ctrl
 Alt	Alt
 Alt Tab	Alt+Tab
 Cancel	Esc
 Help	Ctrl+Shift+H
 Enter	Enter
 Incr Set	Ctrl+Shift+7
 Context	Application, Right-click of a mouse
 Windows	Windows

**Note:**

The figure in Ctrl+Shift+“figure” cannot be entered by the numeric keypad.

Table H-1 Correspondences Between Panel Keys and Keyboard Operations (Continued)

Panel Key		USB Keyboard
	↑	↑
	→	→
	↓	↓
	←	←
	Rotary knob, clockwise	Mouse wheel up
	Rotary knob, counter-clockwise	Mouse wheel down
 Mod On/Off	RF Output Mod On/Off	Ctrl+Shift+Q
 On/Off	RF Output On/Off	Ctrl+Shift+G
 Mod On/Off	2nd RF Output Mod On/Off	Ctrl+Shift+E
 On/Off	2nd RF Output On/Off	Ctrl+Shift+S



# *Appendix I Scanning for Virus*

---

For the MG3710A/MG3740A, we recommend not installing virus scanning software to ensure the best possible performance of the equipment. In some user operating environments, however, the MG3710A/MG3740A might not be completely protected from virus infection, and periodic virus scans might be required.

This chapter provides a procedure to use to check for viruses and the related cautions. The following shows an overview of the virus scanning procedure, in which the MG3710A/MG3740A drives are mounted (assigned) to network drives on an external PC, and then viruses are checked for using antivirus software installed in that computer:

I.1	For Windows XP Embedded.....	I-3
I.1.1	Connecting external PC to MG3710A/MG3740A .....	I-3
I.1.2	Checking IP address of MG3710A/MG3740A ...	I-3
I.1.3	Configuring shared settings.....	I-5
I.1.4	Changing user account for MG3710A/MG3740A .....	I-6
I.1.5	Shared settings for MG3710A/MG3740A .....	I-9
I.1.6	Mounting MG3710A/MG3740A drives to external PC drives .....	I-11
I.1.7	Scanning for virus.....	I-12
I.1.8	Dismounting MG3710A/MG3740A drives from external PC drives .....	I-12
I.1.9	Making MG3710A/MG3740A drives unshared.....	I-12
I.1.10	Restoring previous user account setting for MG3710A/MG3740A .....	I-12
I.1.11	Enabling Simple File Sharing .....	I-13
I.2	For Windows 7 .....	I-14
I.2.1	Connecting external PC to MG3710A/MG3740A .....	I-14
I.2.2	Checking IP address of MG3710A/MG3740A.	I-14
I.2.3	Configuring shared settings.....	I-16
I.2.4	Changing user account for MG3710A/MG3740A .....	I-18
I.2.5	Shared settings for MG3710A/MG3740A .....	I-21
I.2.6	Mounting MG3710A/MG3740A drives to external PC drives .....	I-23
I.2.7	Scanning for virus.....	I-25
I.2.8	Dismounting MG3710A/MG3740A drives from external PC drives .....	I-25

I.2.9	Making MG3710A/MG3740A drives unshared .....	I-25
I.2.10	Restoring previous user account setting for MG3710A/MG3740A .....	I-25
I.2.11	Enabling Sharing Settings .....	I-26

**Note:**

1. Be sure to follow the procedure described in this document. If this procedure is not followed, not only will it not be possible to check for viruses, but the MG3710A/MG3740A might become unusable.

If the MG3710A/MG3740A runs abnormally after removing viruses, execute system recovery to restore all drives to the factory default settings. For the procedures, refer to 9.7.6 “System Recovery Functions”.

After performing system recovery, the firmware might have to be upgraded to the latest version depending on when the MG3710A/MG3740A was released.

2. Before using antivirus software, be sure to check its usage and the license scope.



## I.1 For Windows XP Embedded

### I.1.1 Connecting external PC to MG3710A/MG3740A

Connect MG3710A/MG3740A and the external PC with a LAN cable.

For details about how to set up the network for the MG3710A/MG3740A, refer to Appendix E “Remote Control”.

### I.1.2 Checking IP address of MG3710A/MG3740A

If the IP address is automatically assigned upon establishing a DHCP connection, check the IP address by using the following procedure:

1. Display the MG3710A/MG3740A desktop.  
To display the desktop, right-click anywhere on the screen and select **Show the Desktop**.
2. Display the MS-DOS Prompt. On the MG3710A/MG3740A, select **Start – All Programs – Accessories – Command Prompt**.



3. Enter the following:  
`ipconfig`  
The assigned IP address displays as shown.

```
ca Command Prompt
Microsoft Windows XP [Version 5.1.2600]
(C) Copyright 1985-2001 Microsoft Corp.
C:\Documents and Settings\ANRITSU>ipconfig

Windows IP Configuration

Ethernet adapter Local Area Connection:


    Connection-specific DNS Suffix  . : 
    IP Address . . . . . : 192.168.0.1
    Subnet Mask . . . . . : 255.255.255.0
    Default Gateway . . . . . : 192.168.0.2

C:\Documents and Settings\ANRITSU>_
```

### I.1.3 Configuring shared settings

Simple File Sharing is enabled for the MG3710A/MG3740A by default. If authentication is performed by way of a network while Simple File Sharing is enabled, the accessing user is regarded as having a Guest account and cannot access important folders and files such as the Windows folder. To avoid this, use the following procedure to temporarily disable Simple File Sharing:

1. On the MG3710A/MG3740A, click the **Start** button and then click **My Computer**.
2. In the **Tool** menu, click **Folder Options**, and click the **View** tab.
3. From the **Advanced Settings** list, make sure that the **Use simple file sharing (Recommended)** check box is NOT selected.




4. Click **OK**.


### I.1.4 Changing user account for MG3710A/MG3740A

This section describes how to change the user account used when the MG3710A/MG3740A drives are mounted to network drives.


1. From the Start menu, select **Control Panel**.
2. Select **Administrative Tools** from the Control Panel.




3. In Administrative Tools, select **Computer Management**.




4. In the Computer Management tree, select **Users** under **Local Users and Groups**.



5. Right-click the user account “ANRITSU” to use, and select the **Set Password...** menu.



6. When the message below is shown during the password setting, select **Proceed**.




7. Type "ANRITSU" for the password.



8. After setting the password, click **OK** in the dialog for confirmation.

### I.1.5 Shared settings for MG3710A/MG3740A


1. From the Start menu, select **My Computer**.
2. Right-click the C drive.
3. Select **Sharing and Security**.
4. Select the **Sharing** tab.



5. To disable the default sharing setting, select **Do not share this folder**.
6. Click the **Apply** button.




7. A dialog appears. Select **Yes**.




8. Select **Share this folder**.

9. Click the **Permissions** button.



10. Select the **Allow** check box for **Full control**.



11. Click **OK** to close two dialogs displayed.



12. Repeat steps 3 to 11 to the D drive.


### I.1.6 Mounting MG3710A/MG3740A drives to external PC drives

1. On the PC connected by way of the network (which is used to run the virus scanning software), mount (assign) all the shared drives of the MG3710A/MG3740A as network drives.
2. On the PC, right-click **My Network Places**, and select **Map Network Drive**.
3. Enter “The IP address of MG3710A/MG3740A + drive name” for the folder name.


**Example** When the IP address of the MG3710A/MG3740A is 192.168.0.1:

To mount the C drive, specify Y for Drive and \\192.168.0.1\c for Folder.

To mount the D drive, specify Z for Drive and \\192.168.0.1\d for Folder.



4. Click **Connect using a different user name**.
5. Enter ANRITSU for the User name, and also ANRITSU for the Password (as specified in Section I.1.4, Step 7).



6. Click **OK – Finish** to complete mounting the network drive.
7. Repeat steps 2 to 6 to the D drive.

### **I.1.7 Scanning for virus**

Scan the network drives mounted on the external PC for viruses.

Even if network drives cannot be scanned using your software, scanning might be possible by dragging and dropping a network drive onto the virus software icon in Windows Explorer.

### **I.1.8 Dismounting MG3710A/MG3740A drives from external PC drives**

Right-click **My Network Places** on the external PC, and select **Disconnect Network Drive**.

Dismount the two mapped drives.

### **I.1.9 Making MG3710A/MG3740A drives unshared**

1. From the **Start** menu, select **My Computer**.
2. Right-click the C drive.
3. Select **Sharing and Security**.
4. Select the **Sharing** tab.
5. Select the **Do not share this folder** button.
6. Repeat steps 2 to 5 to the D drive.


### **I.1.10 Restoring previous user account setting for MG3710A/MG3740A**

The user password has been changed in Section I.1.4 “Changing the user account for the MG3710A/MG3740A” for mounting the MG3710A/MG3740A drives to network drives of the external computer. Restore the password before change in the same way as it was changed. Note that no password is specified by default.

### I.1.11 Enabling Simple File Sharing

Simple File Sharing has been disabled in Section I.1.3 “Configuring shared settings” for sharing drives. To restore the original settings, enable Simple File Sharing by using the following procedure:

1. On the MG3710A/MG3740A, click the **Start** button and then click **My Computer**.
2. In the **Tool** menu, click **Folder Options**, and click the **View** tab.
3. From the **Advanced Settings** list, make sure that the **Use simple file sharing (Recommended)** check box is selected.



4. Click **OK**.

## I.2 For Windows 7

### I.2.1 Connecting external PC to MG3710A/MG3740A

Connect MG3710A/MG3740A and the external PC with a LAN cable.

For details about how to set up the network for the MG3710A/MG3740A, refer to Appendix E “Remote Control”.


### I.2.2 Checking IP address of MG3710A/MG3740A

If the IP address is automatically assigned upon establishing a DHCP connection, check the IP address by using the following procedure:

1. Display the MG3710A/MG3740A desktop.  
To display the desktop, right-click anywhere on the screen and select **Show the Desktop**.
2. Display the MS-DOS Prompt. On the MG3710A/MG3740A, select **Start – All Programs – Accessories – Command Prompt**.



3. Enter the following:  
`ipconfig`  
The assigned IP address displays as shown.



```
Administrator: Command Prompt
Microsoft Windows [Version 6.1.7601]
Copyright (c) 2009 Microsoft Corporation. All rights reserved.

C:\Users\ANRITSU>ipconfig

Windows IP Configuration

Ethernet adapter Local Area Connection:

    Connection-specific DNS Suffix . . . . . : 
    IP Address. . . . . : 192.168.0.1
    Subnet Mask . . . . . : 255.255.255.0
    Default Gateway . . . . . : 192.168.0.2  >:

C:\Users\ANRITSU>_
```


### 1.2.3 Configuring shared settings

Sharing Settings is enabled for the MG3710A/MG3740A by default. If authentication is performed by way of a network while Sharing Settings is enabled, the accessing user is regarded as having a Guest account and cannot access important folders and files such as the Windows folder. To avoid this, use the following procedure to temporarily disable Sharing Settings:


1. On the MG3710A/MG3740A, click the **Start** button and then click **Control Panel**.
2. From the **Control Panel** menu, click **View network status and tasks**.



3. From the **Network and sharing Center** menu, click **Change advanced sharing settings**.



4. In the **Advanced sharing settings** dialog box, click **Turn off network discovery**, **Turn off file and printer sharing**, and **Turn on Password protected sharing**.



5. Click **Save changes**.


## 1.2.4 Changing user account for MG3710A/MG3740A

This section describes how to change the user account used when the MG3710A/MG3740A drives are mounted to network drives.

1. From the Start menu, select **Control Panel**.
2. From the **Control Panel** menu, click **System and Security**.




3. From the **System and Security** menu, click **Administrative Tools**.







4. From the **Administrative Tools** menu, select **Computer Management**.



5. In the Computer Management tree, select **Users** under **Local Users and Groups** and **Groups**.



6. Right-click the user account "ANRITSU" to use, and select the **Set Password...** menu.



7. When the message below is shown, select **Proceed**.




8. Type "ANRITSU" for the password.




9. After setting the password, click **OK** in the dialog for confirmation.

## I.2.5 Shared settings for MG3710A/MG3740A


1. From the Start menu, select **Computer**.
2. Right-click the C drive and select **Properties**.




3. Select the **Sharing** tab and click the **Advanced Sharing...** button.



4. Select the **Share this folder** check box and click the **Permission** button.




5. Make sure **Everyone** is selected, and select the **Allow** check boxes for **Full Control** and **Change**.



6. Click **OK** to close two dialogs displayed.
7. Repeat steps 2 to 7 to the D drive.

## I.2.6 Mounting MG3710A/MG3740A drives to external PC drives

1. On the PC connected by way of the network (which is used to run the virus scanning software), mount (assign) all the shared drives of the MG3710A/MG3740A as network drives.
2. On the PC, click **Start** and then click **Computer**.
3. From the **Computer** menu, select **Map Network Drive**.




4. Enter “The IP address of MG3710A/MG3740A + drive name” for the folder name.

**Example** When the IP address of the MG3710A/MG3740A is 192.168.0.1:


To mount the C drive, specify Y for Drive and \\192.168.0.1\c for Folder.

To mount the D drive, specify Z for Drive and \\192.168.0.1\d for Folder.



5. Select the **Connect using different credentials (C)** check box.

6. Enter ANRITSU for the User name, and also ANRITSU for the Password (as specified in Section I.2.4, Step 7).



7. Click **OK – Finish** to complete mounting the network drive.
8. Repeat steps 2 to 7 to the D drive.

### I.2.7 Scanning for virus

Scan the network drives mounted on the external PC for viruses.

Even if network drives cannot be scanned using your software, scanning might be possible by dragging and dropping a network drive onto the virus software icon in Windows Explorer.

### I.2.8 Dismounting MG3710A/MG3740A drives from external PC drives

1. On the PC, click **Start**. From the Start menu, right-click **Computer**.
2. Click **Disconnect Net Drive**.
3. Select the network drive to dismount, and then click **OK**.

Dismount the two mapped drives.

### I.2.9 Making MG3710A/MG3740A drives unshared

1. From the **Start** menu, select **Computer**.
2. Right-click the C drive.
3. Select the **Sharing** tab.
4. Click the **Advanced Sharing...** button.
5. Deselect the **Share this folder** check box.
6. Repeat steps 2 to 5 to the D drive.

### I.2.10 Restoring previous user account setting for MG3710A/MG3740A

The user password has been changed in Section I.2.4 “Changing the user account for the MG3710A/MG3740A” for mounting the MG3710A/MG3740A drives to network drives of the external computer. Restore the password before change in the same way as it was changed. Note that no password is specified by default.

### **I.2.11 Enabling Sharing Settings**

Sharing Settings has been disabled in Section I.2.3 “Configuring shared settings” for sharing drives. To restore the original settings, enable Sharing Settings by using the following procedure:

1. On the MG3710A/MG3740A, click the **Start** button and then click **Control Panel**.
2. From the **Control Panel** menu, click **View network status and tasks**.
3. From the **Network and sharing Center** menu, click **Change advanced sharing settings**.
4. In the **Advanced sharing settings** dialog box, click **Turn on network discovery**, **Turn on file and printer sharing**, and **Turn off Password protected sharing**.
5. Click **Save changes**.



# Appendix J MG3641A/42A Compatible Command

This appendix describes SCPI commands for signal generators supported by the MG3710A/MG3740A.

Supported signal generators

Anritsu MG3641A/MG3642A

J.1	Basic Function Commands.....	J-2
J.1.1	Frequency Setting .....	J-2
J.1.2	Output Setting.....	J-4
J.1.3	Sweep Function.....	J-6
J.1.4	Amplitude Modulation .....	J-8
J.1.5	Frequency Modulation .....	J-9
J.1.6	Phase Modulation.....	J-10
J.1.7	Modulation Signal Source .....	J-11
J.1.8	Memory Setting .....	J-13
J.2	System Commands .....	J-14
J.2.1	Display Subsystem .....	J-14
J.2.2	SCPI Commands.....	J-15
J.2.3	IEEE 488.2 Common Commands .....	J-16

# J.1 Basic Function Commands

## J.1.1 Frequency Setting

Frequency setting device messages available in MG3710A/MG3740A are shown in Table J.1.1-1.

**Table J.1.1-1 Frequency Setting Device Messages**

MG3641A/MG3642A Commands	MG3710A/MG3740A Compatible Command	MG3710A/MG3740A Original Command /Remarks
:FREQuency[:CW] <freq>	[:SOURce[1] 2]:FREQuency[:CW :FIXed] <freq>	Same as the compatible command
:FREQuency[:CW]?	[:SOURce[1] 2]:FREQuency[:CW :FIXed]?	Same as the compatible command
:FREQuency[:CW]:STEP[:INCRement] <freq>	[:SOURce[1] 2]:FREQuency:STEP[:INCRement] <freq>	Same as the compatible command
:FREQuency[:CW]:STEP[:INCRement]?	[:SOURce[1] 2]:FREQuency:STEP[:INCRement] <freq>	Same as the compatible command
:FREQuency:RELative <boolean>	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:FREQuency:REFerence:STATE <boolean>
:FREQuency:RELative?	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:FREQuency:REFerence:STATE?
:FREQuency:OFFSet	[:SOURce[1] 2]:FREQuency:OFFSet <freq>	Same as the compatible command
:FREQuency:OFFSet?	[:SOURce[1] 2]:FREQuency:OFFSet?	Same as the compatible command
:FREQuency:SWEep RUN STOP PAUSE CONT	MG3641A/MG3642A Commands can be used.	:INITiate[:IMMediate][:ALL] Available only for a function corresponding to RUN.
:FREQuency:SWEep:START <freq>	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:FREQuency:START <freq>
:FREQuency:SWEep:START?	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:FREQuency:START?

**Table J.1.1-1 Frequency Setting Device Messages (Continued)**

<b>MG3641A/MG3642A Commands</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>MG3710A/MG3740A Original Command /Remarks</b>
:FREQuency:SWEep:STOP <freq>	MG3641A/MG3642A Commands can be used.	[ :SOURce [1]   2 ] :FREQuency:STOP <freq>
:FREQuency:SWEep:STOP?	MG3641A/MG3642A Commands can be used.	[ :SOURce [1]   2 ] :FREQuency:STOP?
:FREQuency:SWEep:CENTer <freq>	MG3641A/MG3642A Commands can be used.	[ :SOURce [1]   2 ] :FREQuency:CENTer <freq>
:FREQuency:SWEep:CENTer?	MG3641A/MG3642A Commands can be used.	[ :SOURce [1]   2 ] :FREQuency:CENTer?
:FREQuency:SWEep:SPAN <freq>	MG3641A/MG3642A Commands can be used.	[ :SOURce [1]   2 ] :FREQuency:SPAN <freq>
:FREQuency:SWEep:SPAN?	MG3641A/MG3642A Commands can be used.	[ :SOURce [1]   2 ] :FREQuency:SPAN?
:FREQuency:SWEep:STEP:SIZE	Not supported.	
:FREQuency:SWEep:STEP:SIZE?	Not supported.	
:FREQuency:SWEep:STEP:NUMBer	MG3641A/MG3642A Commands can be used.	[ :SOURce [1]   2 ] :SWEep:POINts Refer to the same parameter in frequency and level.
:FREQuency:SWEep:STEP:NUMBer?	MG3641A/MG3642A Commands can be used.	[ :SOURce [1]   2 ] :SWEep:POINts? Refer to the same parameter in frequency and level.
:FREQuency:SWEep:MODE AUTO   SINGLE   MANUAL	MG3641A/MG3642A Commands can be used.	[ :SOURce ] :LIST:MODE AUTO   MANUal Refer to the same parameter in frequency and level.
:FREQuency:SWEep:MODE?	MG3641A/MG3642A Commands can be used.	[ :SOURce ] :LIST:MODE? Refer to the same parameter in frequency and level.
:FREQuency:SWEep:TIME	MG3641A/MG3642A Commands can be used.	[ :SOURce [1]   2 ] :SWEep:DWELL Refer to the same parameter in frequency and level.

## J.1.2 Output Setting

Output setting device messages available in MG3710A/MG3740A are shown in Table J.1.2-1.

**Table J.1.2-1 Output Setting Device Messages**

MG3641A/MG3642A Commands	MG3710A/MG3740A Compatible Command	MG3710A/MG3740A Original Command /Remarks
:FREQuency:SWEep:TIME?	MG3641A/MG3642A Commands can be used.	[ :SOURce[1]   2] :SWEep:DWELL? Refer to the same parameter in frequency and level.
:FREQuency:SWEep:MARKer	Not supported.	
:FREQuency:SWEep:MARKer?	Not supported.	
:FREQuency:SWEep:PATTern SIZE NO LOG	Not supported.	
:FREQuency:SWEep:PATTern?	Not supported.	
:FREQuency:SWEep:TYPE 0 1	Not supported.	
:FREQuency:SWEep:TYPE?	Not supported.	
:AMPLitude[:OUT]:LEVel	MG3641A/MG3642A Commands can be used.	[ :SOURce[1]   2] :POWer[:LEVel] [:IMM ediate] [:AMPLitude]
:AMPLitude[:OUT]:LEVel?	MG3641A/MG3642A Commands can be used.	[ :SOURce[1]   2] :POWer[:LEVel] [:IMM ediate] [:AMPLitude]?
:AMPLitude[:OUT]:LEVel:STEP[:INCre ment]	MG3641A/MG3642A Commands can be used.	[ :SOURce[1]   2] :POWer[:LEVel] [:IMM ediate]:STEP[:INCRement]
:AMPLitude[:OUT]:LEVel:STEP[:INCre ment]?	MG3641A/MG3642A Commands can be used.	[ :SOURce[1]   2] :POWer[:LEVel] [:IMM ediate]:STEP[:INCRement]?
:AMPLitude[:OUT]:UNIT	Not supported.	
:AMPLitude[:OUT]:UNIT?	Not supported.	

**Table J.1.2-1 Output Setting Device Messages (Continued)**

<b>MG3641A/MG3642A Commands</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>MG3710A/MG3740A Original Command /Remarks</b>
:AMPLitude[:OUT]:STATE <boolean>	MG3641A/MG3642A Commands can be used.	:OUTPut[1] 2[:STATE] <boolean>
:AMPLitude[:OUT]:STATE?	MG3641A/MG3642A Commands can be used.	:OUTPut[1] 2[:STATE]?
:AMPLitude[:OUT]:CONTinuous	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:POWer:ATTenuation:AUTO
:AMPLitude[:OUT]:CONTinuous?	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:POWer:ATTenuation:AUTO?
:AMPLitude[:OUT]:SAFety	Not supported.	
:AMPLitude[:OUT]:SAFety?	Not supported.	
:AMPLitude[:OUT]:VOLT EMF TERM	MG3641A/MG3642A Commands can be used.	:UNIT[1] 2:POWer DBM DBUV DBUVEMF
:AMPLitude[:OUT]:VOLT?	MG3641A/MG3642A Commands can be used.	:UNIT[1] 2:POWer?
:AMPLitude[:OUT]:RELative <boolean>	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:POWer:REFerence:STATe <boolean>
:AMPLitude[:OUT]:RELative?	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:POWer:REFerence:STATe?
:AMPLitude[:OUT]:OFFSet <rel_amp1>	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:POWer[:LEVel][:IMM ediate]:OFFSet <rel_amp1>
:AMPLitude[:OUT]:OFFSet?	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:POWer[:LEVel][:IMM ediate]:OFFSet?
:AMPLitude[:OUT]:ISOLation <boolean>	Not supported.	
:AMPLitude[:OUT]:ISOLation?	Not supported.	
:AMPLitude[:OUT]:RPPReset	MG3641A/MG3642A Commands can be used.	:OUTPut:PROTection:RESume

### J.1.3 Sweep Function

Sweep function device messages available in MG3710A/MG3740A are shown in Table J.1.3-1.

**Table J.1.3-1 Sweep Function Device Messages**

MG3641A/MG3642A Commands	MG3710A/MG3740A Compatible Command	MG3710A/MG3740A Original Command /Remarks
:AMPLitude[:OUT]:SWEep RUN STOP PAUSE CONT	MG3641A/MG3642A Commands can be used.	:INITiate[:IMMediate][:ALL] Available only for a function corresponding to RUN.
:AMPLitude[:OUT]:SWEep:START	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:POWer:START <ampl>
:AMPLitude[:OUT]:SWEep:START?	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:POWer:START?
:AMPLitude[:OUT]:SWEep:STOP	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:POWer:STOP <ampl>
:AMPLitude[:OUT]:SWEep:STOP?	MG3641A/MG3642A Commands can be used.	[:SOURce[1] 2]:POWer:STOP?
:AMPLitude[:OUT]:SWEep:CENTer	Not supported.	
:AMPLitude[:OUT]:SWEep:CENTer?	Not supported.	
:AMPLitude[:OUT]:SWEep:SPAN	Not supported.	
:AMPLitude[:OUT]:SWEep:SPAN?	Not supported.	
:AMPLitude[:OUT]:SWEep:STEP:SIZE	Not supported.	
:AMPLitude[:OUT]:SWEep:STEP:SIZE?	Not supported.	

**Table J.1.3-1 Sweep Function Device Messages (Continued)**

<b>MG3641A/MG3642A Commands</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>MG3710A/MG3740A Original Command /Remarks</b>
:AMPLitude[:OUT]:SWEep:STEP:NUMBER	MG3641A/MG3642A Commands can be used.	[:SOURCE[1] 2]:SWEep:POINTs Refer to the same parameter in frequency and level.
:AMPLitude[:OUT]:SWEep:STEP:NUMBER?	MG3641A/MG3642A Commands can be used.	[:SOURCE[1] 2]:SWEep:POINTs? Refer to the same parameter in frequency and level.
:AMPLitude[:OUT]:SWEep:MODE AUTO SINGLE MANUAL	MG3641A/MG3642A Commands can be used.	[:SOURCE]:LIST:MODE AUTO MANual Refer to the same parameter in frequency and level.
:AMPLitude[:OUT]:SWEep:MODE?	MG3641A/MG3642A Commands can be used.	[:SOURCE]:LIST:MODE? Refer to the same parameter in frequency and level.
:AMPLitude[:OUT]:SWEep:TIME	MG3641A/MG3642A Commands can be used.	[:SOURCE[1] 2]:SWEep:DWELL Refer to the same parameter in frequency and level.
:AMPLitude[:OUT]:SWEep:TIME?	MG3641A/MG3642A Commands can be used.	[:SOURCE[1] 2]:SWEep:DWELL? Refer to the same parameter in frequency and level.
:AMPLitude[:OUT]:SWEep:MARKer <rel_ampl>	Not supported.	
:AMPLitude[:OUT]:SWEep:MARKer?	Not supported.	
:AMPLitude[:OUT]:SWEep:PATtern SIZE NO	Not supported.	
:AMPLitude[:OUT]:SWEep:PATtern?	Not supported.	
:AMPLitude[:OUT]:SWEep:TYPE 0 1	Not supported.	
:AMPLitude[:OUT]:SWEep:TYPE?	Not supported.	

## J.1.4 Amplitude Modulation

Amplitude modulation device messages available in MG3710A/MG3740A are shown in Table J.1.4-1.

**Table J.1.4-1 Amplitude Modulation Device Messages**

MG3641A/MG3642A Commands	MG3710A/MG3740A Compatible Command	MG3710A/MG3740A Original Command /Remarks
:AM[:DEPTh] <percent>	[:SOURce[1] 2]:AM[1] 2[:DEPTh] [:LI Near] <percent>	Same as the compatible command
:AM[:DEPTh]?	[:SOURce[1] 2]:AM[1] 2[:DEPTh] [:LI Near]?	Same as the compatible command
:AM:STATe <boolean>	[:SOURce[1] 2]:AM[1] 2:STATe <boolean>	Same as the compatible command
:AM:STATe?	[:SOURce[1] 2]:AM[1] 2:STATe?	Same as the compatible command
:AM:SOURce INT1 INT2 INT3 EXT1 EXT2	MG3641A/MG3642A Commands can be used. (Numeric characters will be ignored.)	
:AM:SOURce?	MG3641A/MG3642A Commands can be used.	



## J.1.5 Frequency Modulation

Frequency modulation device messages available in MG3710A/MG3740A are shown in Table J.1.5-1.

**Table J.1.5-1 Frequency Modulation Device Messages**

MG3641A/MG3642A Commands	MG3710A/MG3740A Compatible Command	MG3710A/MG3740A Original Command /Remarks
:FM[:FM1][:DEVIation] <freq>	[:SOURce[1] 2]:FM[1] 2[:DEVIation] <freq>	Same as the compatible command
:FM[:FM1][:DEVIation]?	[:SOURce[1] 2]:FM[1] 2[:DEVIation] ?	Same as the compatible command
:FM[:FM1]:STATe	[:SOURce[1] 2]:FM[1] 2:STATe <boolean>	Same as the compatible command
:FM[:FM1]:STATe?	[:SOURce[1] 2]:FM[1] 2:STATe?	Same as the compatible command
:FM[:FM1]:SOURce INT1 INT2 INT3 EXT1 EXT2	MG3641A/MG3642A Commands can be used. (Numeric characters will be ignored.)	
:FM[:FM1]:SOURce?	MG3641A/MG3642A Commands can be used.	
:FM:FM2[:DEVIation] <freq>	Not supported.	
:FM:FM2[:DEVIation]?	Not supported.	
:FM:FM2:STATe	Not supported.	
:FM:FM2:STATe?	Not supported.	
:FM:FM2:SOURce INT1 INT2 INT3 EXT1 EXT2	Not supported.	
:FM:FM2:SOURce?	Not supported.	

## J.1.6 Phase Modulation

Phase modulation device messages available in MG3710A/MG3740A are shown in Table J.1.6-1.

**Table J.1.6-1 Phase Modulation Device Messages**

<b>MG3641A/MG3642A Commands</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>MG3710A/MG3740A Original Command /Remarks</b>
:PM:STATE <boolean>	[:SOURCE[1] 2]:PM:STATE <boolean>	[:SOURCE[1] 2]:PULM:STATE <boolean>
:PM:STATE?	[:SOURCE[1] 2]:PM:STATE?	[:SOURCE[1] 2]:PULM:STATE?
:PM:IMPedance HIGH LOW	Not supported.	
:PM:IMPedance?	Not supported.	

## J.1.7 Modulation Signal Source

Modulation signal source device messages available in MG3710A/MG3740A are shown in Table J.1.7-1.

**Table J.1.7-1 Modulation Signal Source Device Messages**

MG3641A/MG3642A Commands	MG3710A/MG3740A Compatible Command	MG3710A/MG3740A Original Command /Remarks
:LFSOURCE:FREQUENCY 0 1 400HZ 1kHz	[:SOURCE[1] 2]:LFSOURCE:FREQUENCY <freq>	[:SOURCE[1] 2]:FM[1]:INTERNAL:FREQUENCY <freq> Cannot change to 400Hz 1kHz by 0 1.
:LFSOURCE:FREQUENCY?	[:SOURCE[1] 2]:LFSOURCE:FREQUENCY?	[:SOURCE[1] 2]:FM[1]:INTERNAL:FREQUENCY?
:LFSOURCE:FREQUENCY2 <freq>	[:SOURCE[1] 2]:LFSOURCE:FREQUENCY2 <freq>	[:SOURCE[1] 2]:FM2:INTERNAL:FREQUENCY <freq>
:LFSOURCE:FREQUENCY2?	[:SOURCE[1] 2]:LFSOURCE:FREQUENCY2?	[:SOURCE[1] 2]:FM2:INTERNAL:FREQUENCY?
:LFSOURCE:WAVEFORM2 SIN TRI SAW SQR	[:SOURCE[1] 2]:LFSOURCE:WAVEFORM2 SIN TRI SAW SQR	[:SOURCE[1] 2]:FM[1] 2:INTERNAL:FUNCTION:SHAPE SINE TRIANGLE SQUARE RAMP
:LFSOURCE:WAVEFORM2?	[:SOURCE[1] 2]:LFSOURCE:WAVEFORM2?	[:SOURCE[1] 2]:FM[1] 2:INTERNAL:FUNCTION:SHAPE?
:LFSOURCE:FREQUENCY3 <freq>	Not supported.	
:LFSOURCE:FREQUENCY3?	Not supported.	
:LFSOURCE:WAVEFORM3 SIN TRI SAW SQR	Not supported.	
:LFSOURCE:WAVEFORM3?	Not supported.	
:LFSOURCE:EXTERNAL:COUPLING AC DC	[:SOURCE[1] 2]:LFSOURCE:EXTERNAL:COUPLING AC DC	[:SOURCE[1] 2]:EXTMOD:COUPLING DC AC
:LFSOURCE:EXTERNAL:COUPLING?	[:SOURCE[1] 2]:LFSOURCE:EXTERNAL:COUPLING?	[:SOURCE[1] 2]:EXTMOD:COUPLING?

Table J.1.7-1 Modulation Signal Source Device Messages (Continued)

MG3641A/MG3642A Commands	MG3710A/MG3740A Compatible Command	MG3710A/MG3740A Original Command /Remarks
:LFSOURCE:EXTERNE12:COUPLING AC DC	Not supported.	
:LFSOURCE:EXTERNE12:COUPLING?	Not supported.	
:LFSOURCE:OUTPUT:LEVEL	Not supported.	
:LFSOURCE:OUTPUT:LEVEL?	Not supported.	
:LFSOURCE:OUTPUT:SOURCE INT1   INT2   INT3   EXT1   EXT2   OFF	Not supported.	
:LFSOURCE:OUTPUT:SOURCE?	Not supported.	

## J.1.8 Memory Setting

Memory Setting device messages available in MG3710A/MG3740A are shown in Table J.1.8-1.

**Table J.1.8-1 Memory Setting Device Messages**

MG3641A/MG3642A Commands	MG3710A/MG3740A Compatible Command	MG3710A/MG3740A Original Command /Remarks
:MEMory:RECall <ext_numeric>	Not supported.	:MMEMory:LOAD:STATe <string>[,<device>]
:MEMory:RECall:TYPE 0 1 2	Not supported.	
:MEMory:STORe <numeric>	Not supported.	:MMEMory:STORe:STATe [<string>[,<device>]]
:MEMory:SKIP	Not supported.	
:MEMory:CLear	Not supported.	:MMEMory:DElete:STATe <filename>,<device>
:MEMory:SWEep RUN STOP PAUSE CONT	Not supported.	
:MEMory:SWEep:SATRt	Not supported.	
:MEMory:SWEep:START?	Not supported.	
:MEMory:SWEep:STOP	Not supported.	
:MEMory:SWEep:STOP?	Not supported.	
:MEMory:SWEep:MODE AUTO SINGLE MANUAL	Not supported.	
:MEMory:SWEep:MODE?	Not supported.	
:MEMory:SWEep:TIME	Not supported.	
:MEMory:SWEep:TIME?	Not supported.	
:MEMory:SWEep:MARKer	Not supported.	
:MEMory:SWEep:MARKer?	Not supported.	

## J.2 System Commands

### J.2.1 Display Subsystem

Display subsystem device messages available in MG3710A/MG3740A are shown in Table J.2.1-1.

**Table J.2.1-1 Display Subsystem Device Messages**

MG3641A/MG3642A Commands	MG3710A/MG3740A Compatible Command	MG3710A/MG3740A Original Command /Remarks
:DISPlay:STATe 0 1 2	MG3641A/MG3642A Commands can be used.	:DISPlay:ENABLe ON OFF 1 0
:DISPlay:STATe?	:DISPlay:STATe?	:DISPlay:ENABLe?
:DISPlay:MENU	Not supported.	
:SYSTem:BELL <boolean>	MG3641A/MG3642A Commands can be used.	:SYSTem:BEEPer ON OFF 0 1 No distinction between bell and alarm.
:SYSTem:BELL?	MG3641A/MG3642A Commands can be used.	:SYSTem:BEEPer? No distinction between bell and alarm.
:SYSTem:ALARm	MG3641A/MG3642A Commands can be used.	:SYSTem:BEEPer ON OFF 0 1 No distinction between bell and alarm.
:SYSTem:ALARm?	MG3641A/MG3642A Commands can be used.	:SYSTem:BEEPer? No distinction between bell and alarm.
:SYSTem:MEMory SET CLEAR	Not supported.	
:SYSTem:ERRor?	MG3641A/MG3642A Commands can be used.	:SYSTem:ERRor:CODe[:NEXT]?
:SYSTem:TRIGger?	Not supported.	

## J.2.2 SCPI Commands

SCPI device messages available in MG3710A/MG3740A are shown in Table J.2.2-1.

**Table J.2.2-1 SCPI Device Messages**

<b>MG3641A/MG3642A Commands</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>MG3710A/MG3740A Original Command /Remarks</b>
:STATus:QUEStionable [:EVENT]?	MG3641A/MG3642A Commands can be used.	
:STATus:QUEStionable:CONDition?	MG3641A/MG3642A Commands can be used.	
:STATus:QUEStionable:ENABle	MG3641A/MG3642A Commands can be used.	
:STATus:QUEStionable:ENABle?	MG3641A/MG3642A Commands can be used.	
:STATus:QUEStionable:PTRansition?	MG3641A/MG3642A Commands can be used.	
:STATus:QUEStionable:NTRansition?	MG3641A/MG3642A Commands can be used.	
:STATus:OPERation [:EVENT] ?	MG3641A/MG3642A Commands can be used.	
:STATus:OPERation:CONDition?	MG3641A/MG3642A Commands can be used.	
:STATus:OPERation:ENABle	MG3641A/MG3642A Commands can be used.	
:STATus:OPERation:ENABle?	MG3641A/MG3642A Commands can be used.	
:STATus:OPERation:PTRansition?	MG3641A/MG3642A Commands can be used.	
:STATus:OPERation:NTRansition?	MG3641A/MG3642A Commands can be used.	

## J.2.3 IEEE 488.2 Common Commands

IEEE 488.2 Common Commands device messages available in MG3710A/MG3740A are shown in Table J.2.3-1.

**Table J.2.3-1 IEEE 488.2 Common Commands Device Messages**

MG3641A/MG3642A Commands	MG3710A/MG3740A Compatible Command	MG3710A/MG3740A Original Command /Remarks
*IDN?	*IDN?	
*OPC	*OPC	
*OPC?	*OPC?	
*TST?	*TST?	
*WAI	*WAI	
*CLS	*CLS	
*ESE	*ESE	
*ESE?	*ESE?	
*ESR?	*ESR?	
*SRE	*SRE	
*SRE?	*SRE?	
*STB?	*STB?	



**Table J.2.3-1 Modulation Signal Source Device Messages (Continued)**

<b>MG3641A/MG3642A Commands</b>	<b>MG3710A/MG3740A Compatible Command</b>	<b>MG3710A/MG3740A Original Command /Remarks</b>
*PCS	Not supported.	
*PCS?	Not supported.	
*SAV	Not supported.	
*RCL	Not supported.	
*OPT?	Not supported.	
*RST	*RST	



References are to page numbers.

## Symbol and Numbers

### $\phi$

$\phi$ M.....	7-43
$\phi$ M Deviation .....	7-44
$\phi$ M Source .....	7-48

### A

A/B Ratio.....	7-98
A/B Signal Setting.....	7-97
AC inlet.....	3-10
Active function frame.....	3-23
Additional Analog Modulation	
Input SG1 connector.....	3-10
Additional Analog Modulation	
Input SG2 connector.....	3-10
Alarm History.....	9-20
Saving.....	9-21
ALC .....	3-18
Alt key .....	3-4
Alt-Tab key .....	3-4
AM.....	7-14, 7-16
AM Depth (Lin) .....	7-17
AM Depth (Log).....	7-19
AM Depth Type.....	7-16
AM modulation.....	7-14
AM Modulation On/Off .....	7-16
AM Rate .....	7-20
AM Source.....	7-22
Analog I/Q Input Adjustments .....	7-248
Analog I/Q Output Adjustments.....	7-251
Analog Modulation .....	7-12
Analog/Pulse .....	7-12
Applicable parts.....	1-8
Application software .....	1-10
ARB .....	7-74, 7-77
ARB On/Off.....	7-77
ARB Setup .....	7-94
Arrow keys.....	3-4
at SyncLoss.....	8-31
ATT Hold.....	5-25

Auto Restart.....	8-17
Auto Resync .....	8-29
AUX connector .....	3-9
Auxiliary Function .....	9-2
Averaging .....	5-55, 9-17
Averaging Count.....	5-56
Averaging Count Value .....	9-18
AWGN.....	7-228, 7-229
On/Off .....	7-229

### B

Back key.....	3-3
Back-up battery .....	vi
Baseband Clock .....	7-161
Baseband Mode.....	7-71
Baseband Reference Clock Input connector ..	3-7
Baseband Reference Clock Output connector	3-7
BBDAC.....	3-18
Beep Sound .....	9-29
BER Count	
Clear .....	8-16
BER dialog box .....	8-6
BER function menu .....	8-12
BER Interface .....	8-32
BER Log .....	8-54
BER Test Log .....	8-55, 8-56
Board Info .....	9-35
Boot Loader Service.....	9-51
BS key .....	3-4
Buffer Output connector .....	3-8
Buffered Trigger .....	7-157

### C

C/N Ratio.....	7-233
C/N Set Signal .....	7-234
Cal .....	9-77
Cal key .....	3-2
Cal Type .....	7-245
Calibration.....	11-6
Cancel key.....	3-4
Carrier Level.....	7-231
Center Signal.....	7-103
Channel.....	4-23

## Index

---

- Channel A/B..... 9-6
- Channel A/B Setup ..... 9-8
- Channel Freq ..... 9-14
- Channel group
  - Resitering ..... 4-28
- Channel Group ..... 4-25
- Channel groups
  - adding ..... 4-33
  - Deleting ..... 4-34
- Channel Offset..... 9-15
- Channel Offset Value ..... 9-16
- Channel selection ..... 4-23
- Channel Setting..... 4-20
- Channel Settings..... 9-13
- Channel table ..... 4-26
- Channel tables
  - Deleting ..... 4-35
  - Opening ..... 4-36
  - Saving ..... 4-38
- Clear
  - BER logs ..... 8-57
  - correction table ..... 5-39
  - Deleting channel table ..... 4-35
  - Error Information ..... 9-50
  - List Table..... 6-38
- Clear Memory ..... 7-127
- Clock Edge ..... 8-32
- Color
  - setting scheme for screen copies ..... 9-71
- COM Port..... 9-10
- COM Port setting ..... 9-10
- Combination Mode ..... 7-80
- Common indicator frame ..... 3-17
- Common Setting Operations ..... 3-38
- Configure Correction
  - User correction setting ..... 5-32
- Configure List Sweep ..... 6-29
- Configure Step Sweep ..... 6-18
- Confirm Reset To Factory Default..... 9-47
- Connection Settings ..... 5-46, 9-10
- Context key ..... 3-4
- Copy
  - External waveform pattern..... 7-129
  - screen..... 9-70
- Copy All Patterns/Copy All Packages..... 7-134
- Copy key ..... 3-2
- Copy Pattern/Copy Package ..... 7-133
- Correction
  - User..... 5-30
- Correction Points ..... 5-54
- Count Mode..... 8-21
- Coupling ..... 7-26, 7-39, 7-50
- Create Correction File..... 5-58
- Ctrl key ..... 3-4
- Current Point..... 6-4
- Cycle ..... 7-143, 7-173
- D**
- Data ..... 8-22
- Data Count..... 8-11
- Data Polarity ..... 8-33
- Data Type..... 8-24
- Delay ..... 7-152
  - Trigger ..... 6-50
- Delete ..... 7-126, 9-57
  - BER logs ..... 8-60
- Delete pattern from selected drive ..... 7-117
- Delete Row ..... 4-34, 5-38, 6-38
- Deleting Parameter File ..... 9-57
- Display ..... 4-21
- Display of 2SG ..... 3-31
- Displaying Error Information..... 9-48
- Displaying Windows desktop..... 9-80
- Disposal..... 11-5
- Division ..... 7-163
- Drive..... 7-111, 7-132
  - destination drive for screen copies..... 9-70
- Dwell Time ..... 6-26
- Dwell Type ..... 6-40
- E**
- Edge..... 7-153, 7-186
  - Trigger ..... 6-51
- Edit Item ..... 5-34
  - Dwell Time ..... 6-34
  - Frequency..... 6-31
  - Level ..... 6-33
- Edit Mode..... 7-137, 7-169

- 
- Edit Table..... 4-26
- Enable Active..... 8-34
- Enter key ..... 3-4
- Equipment Certificate ..... viii
- Error..... 8-8, 8-23
- Error Count ..... 8-10
- Error Info..... 9-48
- Error Rate..... 8-9
- Ethernet connector..... 3-9
- Event..... 7-155
- Execute Cal..... 7-244
- Ext DC Cal..... 7-28, 7-41, 7-52
- Ext. In Polarity..... 7-68
- Ext. Out Polarity ..... 7-67
- External connection ..... 8-5
- external display ..... 9-89
- EXTMOD ..... 3-20
- ## F
- Factory Preset ..... 9-46
- File name  
  setting..... 3-42
- File Type  
  file format for screen copies ..... 9-70
- FIR Error ..... 7-11
- Firmware  
  updating ..... 9-43
- FM ..... 7-32
- FM Deviation..... 7-33
- FM Rate ..... 7-35
- FM Source..... 7-37
- FM/  $\phi$ M..... 7-30
- Focus ..... 7-111, 7-124, 7-132
- Footer frame ..... 3-28
- FPGA Info ..... 9-37
- Frame Count..... 7-158
- Freq Offset..... 7-100
- Freq Offset A/Freq Offset B..... 7-102
- Freq Ref..... 4-14
- Freq Start ..... 6-19
- Freq Stop..... 6-20
- Freq Sync ..... 4-41
- Frequency ..... 4-2, 4-22  
  Changing with arrow keys ..... 4-9  
  changing with rotary knob ..... 4-8  
  setting method ..... 4-6
- Frequency display ..... 4-22
- Frequency information frame..... 3-22
- Frequency offset multiplier ..... 4-18
- Frequency relative display..... 4-14
- Frequency setting  
  Numeric keypad..... 4-7
- Frequency Setting Items..... 4-12
- Frequency setting resolution ..... 4-10
- Frequency synchronization..... 4-41
- Frequency/Channel display ..... 4-21
- Frequency-related functions..... 4-41
- front-panel keys..... 3-2
- Function display frame ..... 3-25
- Function keys..... 3-3
- Function menu frame..... 3-29
- Functions specific to remote commands ..... 9-75
- ## G
- Gain Balance..... 7-262
- GPIB..... 9-25
- GPIB address..... 9-25
- GPIB connector..... 3-9
- ## H
- Hard Disk  
  How to replace..... 11-10
- Hard disk access lamp..... 3-2
- HDD slot ..... 3-10  
  for options..... 3-10
- Help key ..... 3-4
- ## I
- I Diff Offset ..... 7-257
- I Input connector ..... 3-5
- I Level Trimming ..... 7-254
- I Offset..... 7-248, 7-259
- I Output connector ..... 3-8
- I/Q Calibration..... 7-244
- I/Q Common Offset..... 7-256
- I/Q Delay ..... 7-202, 7-266
- I/Q Modulation..... 7-236
- I/Q Output..... 7-240
-

## Index

---

I/Q Phase..... 7-201, 7-264  
I/Q Skew..... 7-265  
I/Q Source ..... 7-237  
Impedance..... 7-27, 7-40, 7-51  
Incr Set key..... 3-4  
Initial Pattern..... 8-36  
Insert Row..... 4-33, 5-37, 6-37  
Install ..... 9-43  
Installation Location..... 2-2  
Installation orientation..... 2-2  
Instrument Info ..... 9-31  
Instrument Options..... 9-34  
Interface Settings..... 9-25  
Internal Baseband Adjustments ..... 7-259  
Internal Channel Correction ..... 7-242  
Internal hard disk ..... vii  
(Inverted I) Output connector ..... 3-8  
(Inverted Q) Output connector ..... 3-8  
IQ Pro key ..... 3-3

**L**

label ..... 2-4  
Language ..... 9-27  
Length ..... 8-37  
Level..... 5-7  
Level A/Level B..... 7-96  
Level information frame ..... 3-22  
Level offset..... 5-19  
Level Offset..... 5-52  
Level Offset Value ..... 5-53  
Level Start ..... 6-23  
Level Stop ..... 6-24  
List Function ..... 6-29  
List Table ..... 6-30  
LO Sync..... 7-198  
Load  
    waveform pattern ..... 7-106  
Load All Patterns ..... 7-116  
Load Pattern..... 7-113  
Local  
    switching remote/local..... 9-55  
Local Input connector..... 3-7  
Local key ..... 3-3  
Local Output connector..... 3-7

Local signal source ..... 4-49

## M

Main function keys..... 3-3  
Manual mode ..... 6-12  
Manual Mode ..... 6-12  
Manual Point ..... 6-13  
Marker 1..... 7-221  
Marker 1 connector ..... 7-221  
Marker 2..... 7-223  
Marker 2 connector ..... 7-223  
Marker 3..... 7-224  
Marker 3 connector ..... 7-224  
Marker Setup..... 7-167  
Marker1 Output connector ..... 3-9  
Measure Mode ..... 8-19  
Measurement end conditions..... 8-21  
Measurement Units..... 9-19  
Mode ..... 7-150  
    Trigger ..... 6-48  
Model..... 9-11  
Model setting ..... 9-11  
Modulation..... 3-35  
Modulation control key ..... 3-5  
Monitor Out connector ..... 3-9

## N

Next key ..... 3-3  
Next Pattern ..... 7-176  
No Retrigger..... 7-156  
Noise Bandwidth ..... 7-230  
Noise Level..... 7-232  
Number of Slaves ..... 7-196  
Numeric keypad..... 3-4

## O

Offset ..... 7-170  
    Level ..... 5-19  
Offset 1/ Offset 2..... 7-140  
On Memory ..... 7-126  
Open ..... 4-36  
    List Table..... 6-41  
    parameter file..... 9-67  
    user correction table ..... 5-40

- 
- user defined patterns ..... 8-51
  - Optimize..... 7-69
  - Optimize S/N ..... 5-29
  - Options
    - adding..... 9-45
  - Out..... 7-165
  - Output A/Output B..... 7-95
  - output level
    - Changing output level with rotary knob.. 5-10
  - Output Level..... 5-2
  - Output level change
    - arrow keys .....5-11
  - Output level limit..... 5-22
  - Output level setting
    - numeric keypad ..... 5-9
  - Output Level Setting Item..... 5-14
  - Output Level Setting Method..... 5-7
  - Output level setting resolution..... 5-12
  - OVEN COLD ..... 3-19
- P**
- Panel Keys ..... 9-52
  - Parameter file list
    - displaying ..... 9-68
  - Pattern File Name..... 8-46
  - Pattern generation mode ..... 7-80
  - Pattern length ..... 8-37
  - Pattern Length ..... 8-46
  - Pattern Status ..... 7-210
  - Pattern Trigger..... 7-182, 7-207, 7-208, 7-209
  - Pattern Trigger 1/2/3..... 7-183
  - Pattern Trigger Type..... 7-211
  - Pattern Trigger1 Input connector ..... 3-9
  - PatternTrigger ..... 7-181
  - Performance Test
    - Vector accuracy .....10-11
  - Phase Adjust ..... 7-29, 7-42, 7-53
  - Phase noise optimization ..... 4-44
  - Phase Noise Optimize ..... 4-44
  - Play Mode ..... 7-178
  - PN Fix Pattern ..... 8-35, 8-36
  - PN\_Fix patterns
    - Examples of using..... 8-41
    - Synchronization establishing conditions . 8-39
  - Point Trigger..... 6-46, 6-47
  - Points..... 6-25
  - Polarity..... 7-174
  - power cord..... 2-9
  - Power Meter..... 9-3
  - Power Meter setting ..... 9-13
  - Power On..... 9-30
  - Power On/Off ..... 3-12
  - power voltage..... 2-8
  - power-on
    - parameters at ..... 9-30
  - Preset ..... 9-52
  - Preset All..... 9-53
  - Preset key..... 3-3
  - Product Info ..... 9-31
  - Pulse ..... 7-54, 7-56
  - Pulse 2 Delay ..... 7-65
  - Pulse 2 Width..... 7-66
  - Pulse Delay ..... 7-63
  - Pulse Mod..... 7-211
  - Pulse Period..... 7-62
  - Pulse Rate ..... 7-61
  - Pulse Source..... 7-57
  - Pulse Sync..... 7-226
  - Pulse Video..... 7-225
  - Pulse Width..... 7-64
- Q**
- Q Diff Offset..... 7-258
  - Q Input connector..... 3-5
  - Q Level Trimming..... 7-255
  - Q Offset ..... 7-249, 7-261
  - Q Output connector ..... 3-8
  - Quad. Angle..... 7-263
- R**
- Rate Mismatch..... 7-10
  - Raw Socket Port Number..... 9-28
  - rear-panel..... 3-7
  - Recall..... 9-67
  - Recall key ..... 3-2
  - Recalling Parameter File ..... 9-67
  - Ref Clock Adjustment..... 4-53
  - Reference..... 5-16
-

## Index

---

- Reference Input connector ..... 3-8
- Reference oscillator ..... 4-47
- Relative level display ..... 5-16
- Remote lamp ..... 3-3
- Repacking ..... 11-4
- Repeat Mode ..... 7-179
- Resident frame ..... 3-27
- Restart ..... 7-78, 9-53
- Restart on Trigger ..... 7-157
- Restore Default ..... 7-247
- Resync Condition ..... 8-26
- Reverse power ..... 2-4
- RF Gate ..... 7-136, 7-137
- RF Output ..... 3-36
- RF Output connector ..... 3-5
- RF Output control key ..... 3-5
- RF Spectrum ..... 4-45
- RMS Value Tuning ..... 7-78
- Rotary knob ..... 3-5
- Route Connectors ..... 7-203
- Route Input Connectors ..... 7-204
- Route Output Connectors ..... 7-214
- RPP ..... 3-32
- S**
- S/F Trigger ..... 7-206
- Sampling Clock ..... 7-166
- Sampling Rate A/Sampling Rate ..... 7-99
- Save ..... 4-38, 9-21, 9-56
  - BER logs ..... 8-58
  - List Table ..... 6-43
  - parameter file ..... 9-56
  - screens ..... 9-72
  - user correction table ..... 5-42
- Save key ..... 3-2
- Saving Parameter File ..... 9-56
- Screen display On/Off function ..... 9-75
- Screen Layout ..... 3-15
- Select
  - Output waveform pattern ..... 7-119
  - Waveform pattern ..... 7-124
- Sequence Mode ..... 7-175
- Sequence Restart ..... 7-177
- Setting character strings ..... 3-40
- Setup AM Source ..... 7-21
- Setup FM Source ..... 7-36
- Setup  $\phi$ M Source ..... 7-47
- SG Port ..... 3-37
- SG1 key ..... 3-3
- SG2 key ..... 3-3
- Shift key ..... 3-4
- Show Details ..... 7-113
- Slave Position ..... 7-197
- Source ..... 7-151, 7-161, 7-184
  - Trigger ..... 6-49
- Spectrum A/Spectrum B ..... 7-105
- Spectrum reverse ..... 4-45
- Standard configuration ..... 1-3
- Start BER Test ..... 8-14
- Start Frame Trigger Input connector ..... 3-8
- Start Freq ..... 5-50
- Start Offset ..... 7-104
- Start/Frame Trigger ..... 7-145, 7-146
- Start/Stop Sweep ..... 6-10
- Status ..... 8-7
- Step Shape ..... 6-27
- Stop BER Test ..... 8-14
- Stop Freq ..... 5-51
- Subitem ..... 7-112, 7-124, 7-132
- Sweep Direction ..... 6-11
- Sweep Function ..... 6-18
- Sweep Out ..... 6-14
- Sweep point number
  - Recalling ..... 6-4
- Sweep points ..... 6-25
- Sweep Repeat ..... 6-10
- Sweep start frequency ..... 6-19
- Sweep start level ..... 6-23
- Sweep stop frequency ..... 6-20
- Sweep stop level ..... 6-24
- Sweep Type ..... 6-9
- Sweep/List ..... 6-5
  - for frequency ..... 6-7
  - for level ..... 6-8
  - Setting all Sweep/List function to Off ..... 6-6
- Sweep/List Function ..... 6-2
- Sweet Output connector ..... 3-8
- Switching Point ..... 7-187



---

Sync ..... 7-199  
    Level ..... 5-27  
Sync Length ..... 8-50  
Sync Loss  
    Conditions for detecting ..... 8-30  
    Operations when detecting ..... 8-31  
Sync Multi SG ..... 7-189  
Sync Start ..... 8-49  
Sync Trig Out ..... 7-227  
Sync Type ..... 7-195  
SyncLoss Count ..... 8-9  
System Recovery ..... 9-93  
System Settings ..... 9-29

**T**

Tab key ..... 3-4  
TCP/IP port number ..... 9-28  
Terminator ..... 9-26  
Threshold X, Threshold Y ..... 8-30  
Timer Period ..... 6-52  
To Drive ..... 7-135  
To Memory ..... 7-117  
Top Function Menu ..... 3-34  
Top key ..... 3-3  
Touch Panel ..... 9-78  
Transportation ..... 11-4  
Trigger Key ..... 6-52, 7-154, 7-188  
Trigger Out Polarity ..... 6-16  
Troubleshooting ..... 11-12

Type ..... 7-139

**U**

UNLOCK ..... 3-19  
Update Info ..... 7-111  
USB connector  
    Type A ..... 3-6, 3-9  
USB memory ..... vi  
    How to store ..... 11-3  
Use Power Sensor ..... 5-45  
User Defined Pattern ..... 8-43, 8-47  
User defined patterns  
    Displaying ..... 8-45  
User Pattern ..... 8-48  
Utility Function ..... 9-24

**W**

Warranty ..... viii  
Waveform ..... 7-23, 7-38, 7-49  
Waveform Licenses ..... 9-39, 9-44  
    Adding and deleting ..... 9-44  
Waveform Restart ..... 7-200  
Wideband ..... 7-243  
Width ..... 7-171  
Width 1/ Width 2 ..... 7-141

**Z**

Zero Sensor ..... 5-57, 9-8

