

FLUKE®

XS, XST
IR InSight Thermal Imager

Users Manual

PN 2670680

May 2006

© 2006 Fluke Corporation, All rights reserved. Printed in USA
All product names are trademarks of their respective companies.

LIMITED WARRANTY AND LIMITATION OF LIABILITY

Each Fluke product is warranted to be free from defects in material and workmanship under normal use and service. The warranty period is two years and begins on the date of shipment. Parts, product repairs, and services are warranted for 90 days. This warranty extends only to the original buyer or end-user customer of a Fluke authorized reseller, and does not apply to fuses, disposable batteries, or to any product which, in Fluke's opinion, has been misused, altered, neglected, contaminated, or damaged by accident or abnormal conditions of operation or handling. Fluke warrants that software will operate substantially in accordance with its functional specifications for 90 days and that it has been properly recorded on non-defective media. Fluke does not warrant that software will be error free or operate without interruption.

Fluke authorized resellers shall extend this warranty on new and unused products to end-user customers only but have no authority to extend a greater or different warranty on behalf of Fluke. Warranty support is available only if product is purchased through a Fluke authorized sales outlet or Buyer has paid the applicable international price. Fluke reserves the right to invoice Buyer for importation costs of repair/replacement parts when product purchased in one country is submitted for repair in another country.

Fluke's warranty obligation is limited, at Fluke's option, to refund of the purchase price, free of charge repair, or replacement of a defective product which is returned to a Fluke authorized service center within the warranty period.

To obtain warranty service, contact your nearest Fluke authorized service center to obtain return authorization information, then send the product to that service center, with a description of the difficulty, postage and insurance prepaid (FOB Destination). Fluke assumes no risk for damage in transit. Following warranty repair, the product will be returned to Buyer, transportation prepaid (FOB Destination). If Fluke determines that failure was caused by neglect, misuse, contamination, alteration, accident, or abnormal condition of operation or handling, including overvoltage failures caused by use outside the product's specified rating, or normal wear and tear of mechanical components, Fluke will provide an estimate of repair costs and obtain authorization before commencing the work. Following repair, the product will be returned to the Buyer transportation prepaid and the Buyer will be billed for the repair and return transportation charges (FOB Shipping Point).

THIS WARRANTY IS BUYER'S SOLE AND EXCLUSIVE REMEDY AND IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. FLUKE SHALL NOT BE LIABLE FOR ANY SPECIAL, INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES OR LOSSES, INCLUDING LOSS OF DATA, ARISING FROM ANY CAUSE OR THEORY.

Since some countries or states do not allow limitation of the term of an implied warranty, or exclusion or limitation of incidental or consequential damages, the limitations and exclusions of this warranty may not apply to every buyer. If any provision of this Warranty is held invalid or unenforceable by a court or other decision-maker of competent jurisdiction, such holding will not affect the validity or enforceability of any other provision.

Fluke Corporation
P.O. Box 9090
Everett, WA 98206-9090
U.S.A.

Fluke Europe B.V.
P.O. Box 1186
5602 BD Eindhoven
The Netherlands

Table of Contents

Chapter	Title	Page
1	Introduction	1-1
	Introduction	1-1
	Contacting Fluke	1-1
	Safety Information	1-2
	Unpacking Your Camera	1-3
	Charge and Insert Battery	1-4
	Power Camera On	1-5
	Select Palette Color	1-6
	Focus	1-7
	Capture Image	1-8
	Camera Features and Controls	1-8
	Using Display Screen Menus	1-12
	Menu Options	1-12
	SmartView Software for Your PC	1-13
	SmartView Software Installation Guide	1-13
2	Basic Operation	2-1
	Powering the Camera On and Off	2-1
	Understanding the Internal Calibration Function	2-1
	Focusing	2-2
	Changing Color Palettes	2-2
	Changing Date and Time	2-2
	Using External Video Output Devices	2-3
	Obtaining the Center Point Temperature	2-3
	Setting Emissivity and Background Temperature	2-4
	Acquiring and Reviewing Images	2-4
	Scan Target	2-4
	Pause/Save	2-5
	Review Images	2-5
	Saving and Naming an Image	2-6
	Connecting the Camera to a Computer	2-6
	Using an RS-232 Port Connection	2-6
	Using a USB Port Connection	2-7
	Downloading Images to a Computer	2-9
	Deleting Images from Camera Memory	2-9
	Camera Optics	2-10

XS, XST

Users Manual

Charging and Replacing the Battery.....	2-11
Using the Battery Charger.....	2-11
Inserting and Removing the Battery.....	2-12
Camera Care.....	2-13

Appendices

A Emissivity Values.....	A-1
B Camera Specifications and Dimensions	B-1

Index

List of Tables

Table	Title	Page
1-1.	Standard Accessories	1-4
1-2.	Features and Controls--Camera Front	1-9
1-3.	Features and Controls--Camera Back.....	1-10
1-4.	Display Screen Features and Controls--Scan Target Mode	1-11
1-5.	Display Screen Features and Controls--Review Image Mode	1-12
2-1.	Lens Field of View and Instantaneous Field of View	2-10
2-2.	Battery Charging Status	2-12
A-1.	Emissivity Values of Common Materials.....	A-1
B-1.	Camera Specifications, IR InSight XS, XST.....	B-1

List of Figures

Figure	Title	Page
1-1.	Standard Accessories	1-3
1-2.	Charging the Battery	1-5
1-3.	Inserting the Charged Battery.....	1-5
1-4.	Powering the Camera On and Off.....	1-6
1-5.	Selecting Palette Color.....	1-6
1-6.	Focusing the Camera.....	1-7
1-7.	Features and Controls--Camera Front	1-8
1-8.	Features and Controls--Camera Back.....	1-9
1-9.	Display Screen Features and Controls--Scan Target Mode.....	1-10
1-10.	Display Screen Features and Controls--Review Image Mode.....	1-11
2-1.	Charging the Battery	2-11
2-2.	Inserting the Charged Battery.....	2-12
B-1.	Camera Depth	B-4
B-2.	Camera Dimensions	B-4

Chapter 1

Introduction

Introduction

Thank you for choosing the IR InSight™ portable video-rate infrared imaging camera (hereafter, “Camera”). Using the Camera, you can obtain instant and accurate thermal images and radiometric readings from distant targets. This Camera is ergonomically designed for right-hand or left-hand use, and captures thermal images and data with a simple trigger press.

The Camera stores up to 255 images that can be downloaded to a personal computer (PC). Using the SmartView™ companion PC software application, you can examine, analyze, enhance, and archive your images and data.

Your Camera provides high performance thermal imaging and is designed for building diagnostics and entry level predictive maintenance.

The IR InSight:

- Has ease of use “point and shoot” single trigger operation.
- Delivers industry leading image quality.
- Has rugged tool-like durable housing.
- Has large 3.5 inch display.

Contacting Fluke

To contact Fluke, call:

1-888-993-5853 in USA

1-800-363-5853 in Canada

+31-402-675-200 in Europe

+81-3-3434-0181 in Japan

+65-738-5655 in Singapore

+1-425-446-5500 from anywhere in the world

Or, visit Fluke’s Web site at www.fluke.com

To register your product, visit register.fluke.com

For Thermography related questions, contact Fluke at 1.800.760.4523 in USA

Safety Information

Use your Camera only as specified in this manual.

A **⚠ Warning** identifies hazardous conditions and actions that could cause bodily harm or death.

A **⚠ Caution** identifies conditions and actions that could damage the camera or cause permanent loss of data.

⚠ Caution

- **Your infrared Camera is a precision instrument that uses a sensitive infrared (IR) detector. Pointing your Camera towards highly-intense energy sources—including devices that emit laser radiation and reflections from these devices—may adversely affect Camera accuracy and may harm or permanently damage your Camera’s IR detector.**
- **Your Camera was calibrated prior to shipping. We recommend that you have your camera checked for proper calibration every two years. Some ISO 9000 programs require more frequent checks for certification. Contact Fluke for details.**
- **Your Camera requires five minutes to warm up before achieving the most accurate measurements.**
- **Do not use Camera in a manner not specified in this manual or the protection provided by the equipment may be impaired.**



Note

This camera contains a Nickel-Cadmium battery.

Do not mix with the solid waste stream. Spent batteries should be disposed of by a qualified recycler or hazardous materials handler.

Contact your authorized Fluke Service Center for recycling information.

Unpacking Your Camera

Begin by opening the shipping box. Be sure to save the box and shipping materials in case you need to ship the Camera. Inside the shipping box, you will find a hard carrying case containing the standard accessories shown in Figure 1-1 and described in Table 1-1.




Figure 1-1. Standard Accessories

eiw001.eps

Table 1-1. Standard Accessories

①	Camera with Battery	⑤	Extra Battery
②	RS-232 Communications Cable & USB Adaptor	⑥	SmartView Software <i>Flexcam Users Manual</i> , and USB drivers CD-ROM disks
③	Shoulder and Neck Strap	⑦	Battery Charger
④	Users Manual		

Charge and Insert Battery

Note

The battery fits into the charger and the Camera only one way.

Charge a new battery as shown in Figure 1-2 for 24 hours; thereafter, a completely discharged battery requires 30 minutes to charge. Use only the rechargeable battery supplied. A battery is fully charged when the LED light on the charger is flashing green.

Insert the charged battery into the bottom of the camera as shown in Figure 1-3.




Figure 1-2. Charging the Battery

eiw002.eps





Figure 1-3. Inserting the Charged Battery

eiw003.eps

Power Camera On

With a charged battery inserted, toggle the ON/OFF switch to the right as shown in Figure 1-4.



eiw004.eps


Figure 1-4. Powering the Camera On and Off

Note

After powering on the Camera, it requires a boot up and warm up period of approximately 30 seconds in order to maintain a crisp, clear, real-time image. About five minutes after powering on the camera, the temperature measurement accuracy will be within the specification requirements. The start-up screen appears after approximately 10 seconds.

Select Palette Color

Toggle the ON/OFF switch to either of two on positions, I or II depending on which palette you want, as shown in Figure 1-5. See *Changing Color Palettes* in Chapter 2 for additional palette options.



eiw005.eps

Figure 1-5. Selecting Palette Color

Focus

Remove the lens cap, point the lens at the target, and manually rotate the lens with your finger, as shown in Figure 1-6 until the image is in focus.




Figure 1-6. Focusing the Camera

eiw006.eps

Capture Image

Pull and release the Frame Capture Trigger. The image on the screen freezes for approximately 2-3 seconds and is saved to the Camera internal memory.

To retain the saved image on the display screen for further review, do not release the Frame Capture Trigger when capturing the image. The Camera automatically returns to the Scan Target mode once you release the Frame Capture Trigger.

Camera Features and Controls

Features and controls found on the front of the Camera are shown in Figure 1-7 and described in Table 1-2.





Figure 1-7. Features and Controls--Camera Front

eiw007.eps

Table 1-2. Features and Controls--Camera Front

Number	Description
①	Focus Ring & Lens Bumper—Finger grip for manual focus and bumper to protect lens.
②	Infrared Germanium Lens
③	Frame Capture Trigger—Used to pause and save an image frame and to advance through saved images or menu items.
④	Battery—3-hour 12 V nickel-cadmium battery to power camera.
⑤	Battery Latch—Pinch to release battery.
⑥	Pistol Grip Handle
⑦	Display Bumper and Shield
⑧	Attachment for optional laser pointer.

Camera features and controls found on the back are shown in Figure 1-8 and described in Table 1-3.



eiw008.eps

Figure 1-8. Features and Controls--Camera Back

Table 1-3. Features and Controls--Camera Back

Number	Description
①	3 1/2" Liquid Crystal Display (LCD) Screen
②	Camera Lanyard Bracket
③	ON/OFF Switch—Used to power camera on and off and to select desired color palette option.
④	RS-232 Port—Used to connect camera to a computer for downloading or deleting images.
⑤	Standard Composite NTSC Video Port—Used to output infrared video to an external video monitor or recording device.

Display screen features and controls for scan target mode are shown in Figure 1-9 and described in Table 1-4.




eiw009.eps

Figure 1-9. Display Screen Features and Controls--Scan Target Mode

Table 1-4. Display Screen Features and Controls--Scan Target Mode

Number	Description
①	Center Point Temperature—Shows the average temperature in degrees Fahrenheit of four central pixels (XST model only).
②	Palette Bar—Shows the palette colors or gray shades from coldest to hottest temperature.
③	Center Point—Includes the center 2 X 2 pixels (XST model only).
④	Date—Displays the current month, day, and year.
⑤	Time—Displays the current time (24-hour clock).
⑥	Saved Image Numbers—Indicates the number of images saved to the camera memory. Memory holds up to 255 images.

Display screen features and controls for review image mode are shown in Figure 1-10 and described in Table 1-5.



eiw010.eps

Figure 1-10. Display Screen Features and Controls--Review Image Mode

Table 1-5. Display Screen Features and Controls--Review Image Mode

Number	Description
①	Center Point Temperature—Shows the average temperature in degrees Fahrenheit of four central pixels (XST model only).
②	Center Point—Includes the center 2 X 2 pixels (XST model only).
③	Date—Indicates the year, month, day, and day of the week an image was captured.
④	Time—Indicates the time (24-hour clock) an image was captured.
⑤	Saved Image ID Numbers—Indicates the identification number of the saved image you are reviewing and the total number of saved images in the camera memory.

Using Display Screen Menus

Your camera is user-friendly and easy to operate using the Frame Capture Trigger to access and navigate through display screen menus.

To access the main menu, start the Camera while simultaneously pulling and holding the Frame Capture Trigger.

From the main menu, pull and release the Frame Capture Trigger to advance through the list of menu options until you reach the desired function. Release the Frame Capture Trigger for 4 seconds to select the desired function; a 4-second countdown appears on the display screen.

Menu Options

Highlight “Run Normally” and release the Frame Capture Trigger for 4 seconds to access Scan Target mode. See Chapter 2, *Acquiring and Reviewing Images*.

Highlight “Change Palette” and release the Frame Capture Trigger for 4 seconds to access a submenu listing 10 palette options. The palette bar for the palette chosen is shown on the right of the Camera display screen. See Chapter 2, *Changing Color Palettes*.

Highlight “Review Images” and release the Frame Capture Trigger for 4 seconds to access Review Image mode. If there are no saved images, “Review Images” does not appear in the main menu list. See Chapter 2, *Acquiring and Reviewing Images*.

Highlight “Erase All Images” and release the Frame Capture Trigger for 4 seconds to erase all images at once. If there are no saved images, “Erase All Images” does not appear in the main menu list. See Chapter 2, *Deleting Images from Camera Memory*.

SmartView Software for Your PC

Your system includes a CD containing SmartView™ software that you install on your personal computer (PC). SmartView, together with your Camera, enables you to:

- Transfer thermographic images to a computer and efficiently manage them
- Optimize and analyze your infrared and visible light control images
- Create and print detailed, professional reports containing important image data

SmartView Software Installation Guide

SmartView image analysis software is compatible with a PC running Microsoft® Windows™ 98/ME/2000/XP. This software is provided on the SmartView CD-ROM disk included with your Camera.

To install SmartView software on your computer:

1. Start your computer and close any open applications.
2. Insert the CD-ROM disk containing the SmartView software in the CD-ROM drive.

After a moment, the installation program should start automatically. If the installation program does not start automatically, use Windows explorer to locate the file named “launch.exe” on the CD-ROM disk. Start the installation by double clicking the “launch.exe” file.

3. Follow the on-screen instructions to complete the installation.

Chapter 2

Basic Operation

Powering the Camera On and Off

Note

After powering on the Camera, it requires a boot up and warm up period of approximately 30 seconds in order to maintain a crisp, clear, real-time image. Approximately five minutes after powering on the camera, the temperature measurement accuracy will be within the specification requirements. The start-up screen appears after approximately 10 seconds.

Insert a charged battery. See *Charging and Replacing the Battery* later in this Chapter.

To start the Camera in Scan Target mode, toggle the ON/OFF switch to the right.

To access the main menu upon start up, toggle the ON/OFF switch to the right, while simultaneously pulling and holding the Frame Capture Trigger.

To power the camera off, toggle the ON/OFF switch to the left.

Understanding the Internal Calibration Function

Your Camera has an internal calibration function that automatically adjusts the camera electronics as needed to maintain a high quality image. During an internal calibration, you may hear a faint “double click” sound from the camera and see the word “Calibrating” appear on the display screen. The image is frozen for approximately 1-2 seconds during the internal calibration process.

Focusing

Your Camera has a manual lens/image focus. To focus the camera, remove the lens cap, point the lens at the target, and manually rotate the lens focus ring with your finger until the image is in focus.

Changing Color Palettes

You can switch between two of ten palettes by toggling the ON/OFF switch between the two on positions, “I” and “II.”

To change one or both selected palettes:

1. Start the Camera by toggling the ON/OFF switch to the right, while simultaneously pulling and holding the Frame Capture Trigger. This opens the main menu.
2. Toggle the ON/OFF switch to either on position “I” or “II,” depending on which palette you want to change.
3. Advance the main menu option by pulling and releasing the Frame Capture Trigger until “Change Palette” is highlighted, and then release the Frame Capture Trigger for 4 seconds.
4. Advance the submenu option by pulling and releasing the Frame Capture Trigger to highlight the desired palette, and then release the Frame Capture Trigger for 4 seconds to activate the palette change and return to the main menu. Maintain the Frame Capture Trigger release for another 4 seconds to return to Scan Target mode or go to Step 5 to change the second selected palette.
5. To change the second palette, toggle the ON/OFF switch to either on position “I” or “II,” depending on which palette you want to change and repeat Steps 3 and 4.

Changing Date and Time

Your Camera has an internal calendar and clock. The date and time are recorded within the image file when the image is saved. Using the SmartView PC software provided with the Camera, you can update the time and date of the Camera to the time and date in your PC.

Follow the appropriate procedure under *Connecting Camera to a Computer* found later in this Chapter. If the Camera clock and calendar do not match within 10 minutes of the PC clock and calendar, a pop-up window appears asking if you want to set the Camera clock and calendar to match the PC. If you select “Yes,” the Camera time and calendar change to match the PC. If you select “No,” the Camera time and calendar remain unchanged.

Using External Video Output Devices

Using the video port and video cable, you can display the live, paused, or saved images on a TV, video projector, or video monitor. You can also record images on a video recorder. Video output is National Television Standards Committee (NTSC) format.

To view images on or record images to an external device, plug the end of the video cable with the cylindrical noise suppressor into the Camera video port. Plug the other end of the cable into the TV, projector, monitor, or video recorder.

Obtaining the Center Point Temperature

Note

For most accurate measurements allow your camera to warm up for five minutes.

The center 4 pixels on your Camera display screen are calibrated to output a single average temperature referred to as the center point temperature. This reading assumes the target emissivity is 0.95 and the background temperature is 68°F. Many common target materials, such as painted surfaces, human skin, water, electrical wire insulation, wood, and most types of tape, have an emissivity value of approximately 0.95. See Appendix A for the emissivity values of other common materials.

If the target object’s emissivity value is something other than 0.95 and/or the ambient temperature is significantly higher or lower than, 20 °C (68 °F), then the center point temperature becomes a relative temperature only. See *Setting Emissivity and Background Temperature* later in this Chapter.

Your Camera is calibrated to operate at ambient temperatures from 0 °C to 50 °C (32 °F to 122 °F) and to display an accurate center point

temperature (within 2 °C or 2 % of the reading, which ever is largest) when used within this ambient temperature range.

For ambient temperatures outside the 0 °C to 50 °C (32 °F to 122 °F) range, the measurement accuracy may degrade, but is generally within 5 °C or 5 % of the target temperature.

When the Camera is abruptly moved from one ambient temperature to another, it requires about five minutes per 10 °C ambient temperature change to adjust to the new ambient temperature before the temperature measurement meets the accuracy specification.

Setting Emissivity and Background Temperature

Emissivity and background temperature are fixed on the Camera. However, they can be adjusted to other values to obtain accurate temperatures of targets that have emissivity other than 0.95 and/or a background temperature different from 20 °C (68 °F).

Using a PC installed with the SmartView software application, download the images following the procedure under *Downloading Images to a Computer* found later in this Chapter. Then, in SmartView, highlight the desired image, click on the emissivity value or background temperature value, and enter the desired value. See the SmartView online help for more details.

Acquiring and Reviewing Images

Your Camera has three operating modes: Scan Target, Pause/Save, and Review Images.

Scan Target

To scan target area of interest:

1. Toggle the ON/OFF switch to the right; DO NOT pull the Frame Capture Trigger while the Camera is booting up.
2. Remove the lens cap and point the lens at the target area.
3. Focus and view the target area on the display screen.
4. Move the Camera as necessary to view various scenes.

Pause/Save

To pause and save a target area image:

1. Follow the procedure under *Scan Target*.
2. When an area of interest is visible on the display screen, pull and release the Frame Capture Trigger. The image on the screen freezes for approximately 2-3 seconds and is saved to the Camera internal memory. The image ID number and number of saved images in the camera memory is displayed in the upper left corner of the display screen. See *Naming Image Files* later in this Chapter.

To retain the saved image on the display screen for further review, do not release the Frame Capture Trigger when capturing the image. The Camera automatically returns to the Scan Target mode once you release the Frame Capture Trigger.

Review Images

To view images saved to the Camera's internal memory:

Note

Review Images mode must be started from the main menu. If there are no saved images, "Review Images" does not appear in the main menu and the Camera will start in Scan Target mode after releasing the Frame Capture Trigger for 4 seconds with "Run Normally" highlighted.

1. If the Camera is ON, toggle the ON/OFF switch to the left to power the Camera off.
2. If the Camera is OFF, power the Camera on by toggling the ON/OFF switch to the right, while simultaneously pulling and holding the Frame Capture Trigger. This opens the main menu.
3. From the main menu, pull and release the Frame Capture Trigger to highlight "Review Images," and then release the Frame Capture Trigger for 4 seconds.
4. View each saved image one at a time by repeatedly pulling and releasing the Frame Capture Trigger. The images are displayed beginning with the most recent image saved.

5. Return to the main menu by pulling and holding the Frame Capture Trigger for 3 seconds.
6. Return to Scan Target mode by highlighting “Run Normally” from the main menu, then releasing the Frame Capture Trigger for 4 seconds.

Saving and Naming an Image

Whenever an image is saved, the image ID number is increased progressively from 1 to 255. The image file name, when first saved, consists of a four character year, a two character month, a two character day, a week day, a two character hour, a two character minute, a two character second, and a three digit image ID number.

You can rename the file using SmartView installed on a personal computer (See Chapter 1). However, the original time and date stamp imbedded in the image file remains unchanged.

Connecting the Camera to a Computer

You can connect your Camera to a personal computer (PC) installed with SmartView™ software (see Chapter 1) and transfer images saved in the Camera’s memory to the PC. Then, use SmartView to add annotations, references, and comments to your InSight images, as well as change image color palettes and rename, analyze, organize, and print images.

Note

If the PC you are using has both RS-232 and USB options, connect the Camera to the PC using the RS-232 port and cable. If the PC has only a USB port, use a combination of the RS-232/USB cable and RS-232 cable. The procedures for both options are described on the following pages.

Using an RS-232 Port Connection

To connect the Camera to a PC using the PC RS-232 port:

1. Connect the RS-232 cable to the PC and Camera.
2. Be sure SmartView is installed on your PC (see Chapter 1) then open the application.

3. Configure SmartView to use the proper communications port:
 - Click “Edit” on the SmartView Menu Bar, then click “Preferences...” then click the InSight Settings tab.
 - Select the appropriate default communications port and click “OK.”

Note

The following instructions are for Microsoft Windows XP. If you are using a different version, check the users manual that came with your Windows operating system.

If you are unsure which communications port to select, access the PC device manager on the PC desktop. Right click on the “My Computer” icon and select “Properties.” Go to the “Hardware” tab and select “Device Manager.” A “Device Manager” window will appear. Left click on the “+” sign next to the word “Ports.” The actual port number may depend on the devices currently in use on the PC.

- When prompted to use these settings in future sessions, select “Yes”.
4. Toggle the ON/OFF switch to the right to power the camera on.
 - If the Camera clock and calendar do not match within 10 minutes of the PC clock and calendar, a pop-up window appears asking if you want to set the Camera clock to match the PC. If you select “Yes,” the Camera time and calendar change to match the PC. If you select “No,” the Camera time and calendar remain unchanged.
 5. The Camera is now connected to the PC and ready to download images. See procedure under *Downloading Images to Computer* later in this Chapter.

Using a USB Port Connection

To connect the Camera to a PC using the USB port:

1. Connect the RS-232/USB cable to the USB communications port on the PC. Do not power on the Camera.

2. Place the USB Serial Converter Product Driver CD-ROM disk into the PC's CD-ROM drive.
3. Follow the directions of the USB Serial Converter User Manual to install the driver software for your PC and operating system.
4. Be sure SmartView is installed on your PC (see Chapter 1), then open the application.
5. Configure SmartView to use the proper communications port:
 - Click "Edit" on the SmartView Menu Bar, then click "Preferences..." then click the InSight Settings tab.
 - Select the appropriate default communications port and click "OK."

Note

The following instructions are for Microsoft Windows XP. If you are using a different version, check the users manual that came with your Windows operating system.

If you are unsure which communications port to select, access the PC device manager on the PC desktop. Right click on the "My Computer" icon and select "Properties." Go to the "Hardware" tab and select "Device Manager." A "Device Manager" window will appear. Left click on the "+" sign next to the word "Ports." The actual port number may depend on the devices currently in use on the PC.

- When prompted to use these settings in future sessions, select "Yes."
6. Connect one end of the RS-232 cable to the Camera and the other end to the end of the RS-232/USB cable already connected to the USB communications port on the PC.
 7. Toggle the Camera's ON/OFF switch to the right to power the Camera on.
 - If the Camera clock and calendar do not match within 10 minutes of the PC clock and calendar, a pop-up window appears asking if you want to set the Camera clock to match the PC. If you select "Yes," the Camera time and calendar change to match the PC. If you select "No," the Camera time and calendar remain unchanged.

8. The camera is now connected to the PC and is ready to download images. See procedure under *Downloading Images to Computer* later in this Chapter.

Downloading Images to a Computer

To download images from the Camera to a PC:

1. Connect the Camera to the PC using either the PC RS-232 or USB port as described earlier in this Chapter. Power on both the Camera and PC.
2. Open the SmartView application on the PC, and then click “File” on the SmartView Menu Bar.
3. Click “Download Images,” then click “InSight Images.” A directory dialog appears to retrieve a file path.
4. In the “Browse for Folder” pop-up window, choose the folder in which you want to store the images.
5. Click “OK” to start the download process. A pop-up window appears indicating the number of images being downloaded. As the image files are downloaded, the download progress is displayed.
6. Once all image files are downloaded, a pop-up window appears, indicates “Download Complete,” and asks if you want to clear the images from the Camera memory.
 - Click “No” to keep saved images in the Camera memory.
 - Click “Yes” to delete ALL images from the Camera memory. A pop-up window appears indicating “Image Memory Cleared.” Click “OK.” See also, *Deleting Saved Images* later in this Chapter.

Deleting Images from Camera Memory

You can delete images saved in the Camera memory either using SmartView software (see Chapter 1) or from the Camera’s main menu.

⚠ Caution

To prevent image loss, be sure to transfer the images saved on the Camera internal memory to a computer hard drive and/or other back up storage device (e.g., CD-R disc) before deleting images.

To delete all saved images from the Camera using SmartView, follow the procedure under *Downloading Images to a Computer* earlier in this Chapter.

or

To delete all saved images using the Camera's main menu:

1. Start the Camera by toggling the ON/OFF switch to the right while simultaneously pulling and holding the Frame Capture Trigger. This opens the main menu.
2. From the main menu, pull and release the Frame Capture Trigger to highlight "Erase All Images," and then release the Frame Capture Trigger for 4 seconds.
3. "Are You Sure" appears. Highlight "Yes," and release the Frame Capture Trigger for 4 seconds to delete all images.

Camera Optics

Your Camera comes with an f0.8 20 mm focal length lens. The lens is made of Germanium crystal and is antireflection coated for high transmission in the 8 to 14 micron wavelength band.

The field of view (FOV), instantaneous field of view (IFOV) and spot size ratio for the Camera is listed in Table 2-1.

Table 2-1. Lens Field of View, Instantaneous Field of View and Spot Size

Lens Focal Length	20 (mm)	Image IFOV	0.146 (degrees)
Horizontal FOV	23.2 (degrees)	Image IFOV	2.55 (mrad)
Vertical FOV	17.4 (degrees)	Image Spot Size	392 to 1
Center Point IFOV	5.10 (mrad)	Center Point Spot Size	196 to 1

Charging and Replacing the Battery

Your Camera is powered by a 12 V rechargeable Nickel-Cadmium (Ni-Cd) battery pack. When fully charged, the battery provides approximately 3 hours of continuous power. Battery charger use is shown in Figure 2-1 and battery placement in Figure 2-2.

Using the Battery Charger

Note

To maximize battery performance and life, charge a new battery for 24 hours the first time. Thereafter, a completely discharged battery takes approximately 30 minutes to charge.

1. Connect the battery charger AC power supply to a power outlet. An outlet adapter and voltage converter may be necessary outside of the United States.
2. Connect the power supply to the battery charger.
3. Insert the battery as shown in Figure 2-1; the battery fits only one way.

The LED indicator on the charger indicates the charging status as shown in Table 2-2.




Figure 2-1. Charging the Battery

eiv002.eps

Table 2-2. Battery Charging Status

Indicator	Charging Status
Red Flashing	Charger is connected to AC outlet and ready for use.
Red Solid	Battery charging underway.
Green Flashing	Battery charging complete.
Orange Solid	Battery pack is warm; charging will begin when battery pack temperature drops.
Orange Flashing	Charging not possible. Battery and/or charger terminals may be dirty or the battery pack is malfunctioning.

Inserting and Removing the Battery

To insert the battery, align the battery with the Camera handle shown in Figure 2-2. Firmly press the battery into the handle until it latches; the battery fits one way.

To remove the battery from the Camera, hold the Camera upright. Squeeze the battery latch with the other hand and pull the battery away from the handle.




Figure 2-2. Inserting the Charged Battery

eiw003.eps

Camera Care

For optimal performance, your Camera should be treated with care and gently cleaned as needed. You should always take great care whenever you touch the lens or display screen. The lens elements are made from Germanium crystal and easily can shatter or be scratched and chipped. The liquid crystal display (LCD) screen is sensitive to excess pressure. To protect your Camera, replace the lens cap and store the camera in the case when you are not using it.

⚠Caution

To avoid damaging your camera, use compressed air to remove large particles and dust prior to using a cloth.

To clean the lens:

- Lightly rub the lens with a soft cotton cloth slightly moistened (not dripping) with a non-abrasive solution marked for lens cleaning or a mild, diluted dish soap solution (never use solvents).

To clean the display screen:

- Lightly rub the display screen with a clean computer monitor cleaning cloth.

To clean the camera body:

- Lightly rub the camera body with a clean, slightly damp cloth. Dampen the cloth in a solution of water and a small amount of mild soap if needed.

XS, XST

Users Manual

Appendices

Appendix	Title	Page
	Emissivity Values	A-1
	Camera Specifications and Dimensions	B-1

Appendix A

Emissivity Values

Use the emissivity values shown in Table A-1 as a guide to properly setting the emissivity value on your Camera.

Table A-1. Emissivity Values of Common Materials

Material	Temperature (°C)	Emissivity
Aluminum, polished	0	0.05
Aluminum, rough surface	0	0.07
Aluminum, strongly oxidized	0	0.25
Asbestos board	0	0.96
Asbestos fabric	0	0.78
Asbestos paper	0	0.94
Asbestos slate	0	0.96
Brass, dull, tarnished	0	0.22
Brass, polished	0	0.03
Brick, common	0	0.85
Brick, glazed, rough	0	0.85
Brick, refractory, rough	0	0.94
Bronze, porous, rough	0	0.55
Bronze, polished	0	0.10

Table A-1. Emissivity Values of Common Materials (cont.)

Material	Temperature (°C)	Emissivity
Carbon, purified	0	0.80
Cast iron, rough casting	0	0.81
Cast iron, polished	0	0.21
Charcoal, powdered	0	0.96
Chromium, polished	0	0.10
Clay, fired	0	0.91
Concrete	0	0.54
Copper, polished, annealed	0-17	0.01-0.02
Copper, commercial burnished	0	0.07
Copper, oxidized	0	0.65
Copper, oxidized to black	0	0.88
Electrical tape, black plastic	0	0.95
Enamel	27	0.90
Formica	0	0.93
Frozen soil	0	0.93
Glass	0	0.92
Glass, frosted	0	0.96
Gold, polished	0	0.02
Ice	0	0.97
Iron, hot rolled	0	0.77
Iron, oxidized	0	0.74

Table A-1. Emissivity Values of Common Materials (cont.)

Material	Temperature (°C)	Emissivity
Iron, sheet galvanized, burnished	0	0.23
Iron, sheet, galvanized, oxidized	0	0.28
Iron, shiny, etched	0	0.16
Iron, wrought, polished	0	0.28
Lacquer, Bakelite	0	0.93
Lacquer, black, dull	0	0.97
Lacquer, black, shiny	0	0.87
Lacquer, white	0	0.87
Lampblack	0	0.96
Lead, gray	0	0.28
Lead, oxidized	0	0.63
Lead, red, powdered	0	0.93
Lead, shiny	0	0.08
Mercury, pure	0	0.10
Nickel, on cast iron	0	0.05
Nickel, pure polished	0	0.05
Paint, silver finish	25	0.31
Paint, oil, average	0	0.94
Paper, black, shiny	0	0.90
Paper, black, dull	0	0.94
Paper, white	0	0.90
Platinum, pure, polished	0	0.08
Porcelain, glazed	0	0.92

Table A-1. Emissivity Values of Common Materials (cont.)

Material	Temperature (°C)	Emissivity
Quartz	0	0.93
Rubber	0	0.93
Shellac, black, dull	0	0.91
Shellac, black, shiny	0	0.82
Snow	0	0.80
Steel, galvanized	0	0.28
Steel, oxidized strongly	0	0.88
Steel, rolled freshly	0	0.24
Steel, rough surface	0	0.96
Steel, rusty red	0	0.69
Steel, sheet, nickel-plated	0	0.11
Steel, sheet, rolled	0	0.56
Tar paper	0	0.92
Tin, burnished	0	0.05
Tungsten	0	0.05
Water	0	0.98
Zinc, sheet	0	0.20

Appendix B

Camera Specifications and Dimensions

Table B-1 lists the technical specifications for the IR InSight XS and XST camera models.

Table B-1. Camera Specifications, IR InSight XS, XST

Imaging Performance	
Detector Type	Uncooled Microbolometer (160 by 120 Focal Plane Array)
Detector Size	51 μm Square
Spectral Band	8 μm to 12 μm
Thermal Sensitivity @ 30 Hz	< 0.07 $^{\circ}\text{C}$ at 30 $^{\circ}\text{C}$
Video Frame Rate	30 Hz
Display and Image Storage	
Digital Display	3 1/2 in LCD
On-screen Indicators	Date, time and saved image numbers, Center point and center point temperature on XST version only
Palettes	10 grayscale and color
Storage Medium	Internal Flash memory with 255 image capacity
PC File Formats Supported	JPEG, TIFF and BMP

Table B-1. Camera Specifications, IR InSight XS, XST

Temperature Measurement (for XST Version Only)	
Calibration Temperature Range	0 °C to 100 °C (32 °F to 212 °F)
Accuracy	± 2 °C or ± 2 % for targets with 0.95 emissivity and background temperature of 20 °C (68 °F)
Measurement Modes	Center point only
Emissivity and Ambient Temperature Correction	Emissivity fixed at 0.95 and background temperature at 20 °C (68 ° F) on camera, both can be changed on PC with analysis software, SmartView, provided with camera
Optics	
Standard Lens	Germanium 20 mm f/0.8; 23 ° Horizontal x 17° Vertical FOV and 2.6 mrad IFOV
Optional Lenses	Germanium 10.5 mm f/0.8 and 54 mm f/1.0
Focus	Manual
Power	
Battery Type	Field-replaceable 12-V NiCd
Battery Operating Time	3 hours continuous operation
Battery Charging	120 V, 60 Hz
Interfaces	
Image Transfer	Via RS-232 connection to PC with supplied software, USB converter included
Video Output	RS170 EIA/NTSC composite video

Table B-1. Camera Specifications, IR InSight XS, XST

Physical Characteristics	
Weight (with battery)	1.86 kg (4.12 lbs)
Size	12.7 cm x 8.89 cm x 27.94 cm (5 in x 3.5 in x 11 in)
Environmental	
Operating Temperature	-10 °C to +50 °C (14 °F to 122 °F)
Storage Temperature	-40 °C to +70 °C (-40 °F to 158 °F)
Humidity	Operating and storage 10 % to 95 %, non-condensing

Camera dimensions are shown in Figures B-1.




Figure B-1. Camera Dimensions

eiw011.eps

—A—

- accessories, 1-3
- acquiring images, 2-4

—B—

- background temperature
 - setting, 2-4
- batteries
 - charging, 2-11
 - disposal, 1-2
 - inserting, 2-12

—C—

- calibration temperature range, B-2
- camera dimensions, B-4
- camera features and controls
 - back, 1-10
 - front, 1-8
- camera memory
 - delete images from, 2-9
 - save images XE "pause image mode"
 - to, 2-5
- camera optics
 - field of view, 2-10
 - instantaneous field of view, 2-10
 - spot size, 2-10
- camera specifications, B-1
- capture image, 1-7, *See* save image mode
- center point temperature, 2-3
- charging batteries, 2-11
- cleaning
 - camera body, 2-13
 - display screen, 2-13
 - lens, 2-13
- color palette

- changing, 2-2
- communication port
 - configuring RS-232, 2-6
 - configuring USB, 2-7
- computer
 - connecting camera to, 2-6
 - downloading images to, 2-9
 - smartview software, 1-14
- connecting camera to computer, 2-6
- contacting Fluke, 1-1

—D—

- date
 - changing, 2-2
- delete images, 2-9
- dimensions, B-4
- display screen
 - menu options, 1-12
 - review image mode, 1-12
 - scan target mode, 1-11
- download images, 2-9

—E—

- emissivity
 - setting, 2-4
 - values table, A-1
- erase all images, 2-9
- external video output, 2-3

—F—

- features and controls
 - camera back, 1-10
 - camera front, 1-8
- field of view (FOV), 2-10
- file naming, 2-6
- Fluke

XS, XST

Users Manual

contact, 1-1
focus, 1-7, 2-2
frame capture trigger, 1-9

—I—

image
 file naming, 2-6
 pause, 2-5
 save, 2-5
image name, 2-6
infrared lens, 1-9
instantaneous field of view (IFOV), 2-10
internal calibration, 2-1

—M—

main menu
 access, 1-12
 options, 1-12
menus, 1-12
 display screen options, 1-12

—N—

naming image files, 2-6
 changing, 2-6

—O—

off switch, 1-10
on switch, 1-10
 on positions I, II, 1-6

—P—

palette
 changing, 2-2
pause image mode, 2-5
PC. *See* personal computer
personal computer
 connect camera, 2-6
 download images to, 2-9
power camera
 off, 2-1
 on, 2-1

—Q—

quick start, 1-4

—R—

register product, 1-1
review image mode, 2-5
reviewing images, 2-4
RS-232 port, 1-10, 2-6

—S—

safety information, 1-2
save image mode
 delete all saved images, 2-9
 review saved image, 2-5
scan target mode, 2-4
smartview software, 1-14
specifications, B-1
spot size, 2-10

—T—

technical support, 1-1
temperature
 center point, 2-3
temperature range. *See* calibration
 temperature range
time
 changing, 2-2
transfer images, 2-9

—U—

unpack camera, 1-3
USB port, 2-7

—V—

video
 external devices, 2-3
video port, 1-10

—W—

warranty, ii