

Germanischer Lloyd

TYPE APPROVAL CERTIFICATE

No. 12 260 - 98 HH

This is to certify, that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

COMPANY	Camille Bauer AG Aargauerstrasse 7 CH-5610 Wohlen
PRODUCT DESCRIPTION	Transducer for Power
TYPE	SINEAX P 530 for Active Power SINEAX Q 531 for Reaktive Power
ENVIRONMENTAL CATEGORY	C
TECHNICAL DATA / RANGE OF APPLICATION	Power supply: 24 - 60 V or 85 - 230 V AC / DC Input: 3 - phases 100 V AC up to 690 V AC Current: 0 - 1 A or 0 - 5 A Power factor (active): cos. 0.8 - 1 - 0.8 Power factor (reactive): sin. 0.8 - 1 - 0.8 Output: 0 - 2,5 mA to 0 - 20 mA, 4 - 20 mA or 0 - 10 V or 2 - 10 V Degree of protection: IP 20 DIN - rail snap on connection
TEST STANDARD	Regulations for the Performance of Type Tests
DOCUMENTS	Test report : P 530, Q 531 Circuit diagram: Dossier E 240 Data sheet: P 530,/ Q 531 Lx
REMARKS	None

TYPE APPROVAL SYMBOL

VALID UNTIL : 29.07.2003



PLACE : Hamburg
DATE : 29.07.1998
PAGE 1 OF 1

File No. : I.D.15

Germanischer Lloyd

H. Reinecke
H. Reinecke

U. Breckwoldt
U. Breckwoldt