



(1) **EC-type-examination Certificate**
(Translation)

(2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres - **Directive 94/9/EC**



(3) EC-type-examination Certificate Number:

PTB 97 ATEX 2191

(4) Equipment: Isolation amplifier SINEAX TV 808 type 808-1... and
Isolation amplifier SIRAX TV 808 type 808-6...

(5) Manufacturer: Camille Bauer AG

(6) Address: Aargauerstrasse 7, CH-5610 Wohlen

(7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

(8) The Physikalisch-Technische Bundesanstalt, notified body No. 0102 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report PTB Ex 97-27160.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
DIN EN 50014:1994-03 DIN EN 50020:1996-04 DIN EN 50014/prA1:1996

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This EC-type-examination Certificate relates only to the design and construction of the specified equipment in accordance with Directive 94/9/EC. Further requirements of this Directive apply to the manufacture and supply of this equipment.

(12) The marking of the equipment shall include the following:

 **II (1) G [EEx ia] IIC**

Zertifizierungsstelle Explosionsschutz

By order


Dr.-Ing. U. Johannsmeyer
Oberregierungsrat



Braunschweig, 26.09.1997

sheet 1/4

(13)

Schedule

(14)

EC-type-examination Certificate No. PTB 97 ATEX 2191

(15) Description of equipment

The isolation amplifier is used for the electrical isolation and transducing of the input quantity into a normalized output signal. Direct current - and direct voltage signals are detected as measured quantities.

The isolation amplifier SIRAX TV 808 of type 808-6... is only used to be plugged on the associated apparatus rack or on the apparatus rack SIRAX BP 902 of type 902-2... with EC-type-examination certificate PTB 97 ATEX 2113, manufactured by Camille Bauer AG.

The isolation amplifier shall be installed outside the explosion hazardous area only.

The maximum permissible ambient temperature of the isolation amplifier SINEAX TV 808 of type 808-1... is 55 °C.

The maximum permissible ambient temperature of the isolation amplifier SIRAX B808 of type 808-6... is 40 °C.

Electrical data

The indicated terminal clamps refer to the design SINEAX TV 808 of type 808-1...

The indicated connections refer to the design SIRAX TV 808 of type 808-6...

Auxiliary power (terminal clamps 10 and 5 resp. 14 and 20)	type 808-113... resp. type 808-613... direct voltage 24 - 60 V -15% / +33% (U _m = 125 V) or alternating voltage 24 - 60 V ± 15% (U _m = 253 V) resp. type 808-114... resp. type 808-614... direct voltage 85 - 110 V -15% / +10% (U _m = 125 V) or alternating voltage 85 - 230 V ± 10% (U _m = 253 V)
Input circuit (terminal clamps 1, 6, 11 resp. connections 1, 3, 5)	type of protection Intrinsic Safety EEx ia IIC/IIB resp. EEx ib IIC/IIB (linear output characteristic) maximum values: U _o = 6 V I _o = 63 μA

Schedule to EC-type-examination Certificate No. PTB 97 ATEX 2191

IIC resp. IIB

max. permissible external inductance 1 H 1 H
 max. permissible external capacitance 40 μ F 1000 μ F

resp.

only for connection to certified intrinsically safe circuits with the following maximum value:

$$U = 30 \text{ V}$$

effective internal inductance: $L_i = 20 \mu\text{H}$

effective internal capacitance: $C_i = 20 \text{ nF}$

The following table shows the assignment of the maximum permissible external inductance (L_o) and capacitance (C_o) to the maximum voltage (U_i) and maximum current (I_i) for the connection to a certified intrinsically safe active circuit with linear (resistive) current limiting:

U_i	I_i	explosion group			
		IIC		IIB	
		L_o	C_o	L_o	C_o
13 V	29 mA	40 mH	258 nF	150 mH	1580 nF
19 V	29 mA	40 mH	110 nF	150 mH	840 nF
24 V	29 mA	40 mH	66 nF	150 mH	560 nF
30 V	29 mA	40 mH	42 nF	150 mH	370 nF
13 V	59 mA	10 mH	258 nF	40 mH	1580 nF
19 V	59 mA	10 mH	110 nF	40 mH	840 nF
24 V	59 mA	10 mH	66 nF	40 mH	560 nF
30 V	59 mA	10 mH	42 nF	40 mH	370 nF
13 V	79 mA	6 mH	258 nF	22 mH	1580 nF
19 V	79 mA	6 mH	110 nF	22 mH	840 nF
24 V	79 mA	6 mH	66 nF	22 mH	560 nF
30 V	79 mA	6 mH	42 nF	22 mH	370 nF
13 V	100 mA	3 mH	258 nF	12 mH	1580 nF
19 V	100 mA	3 mH	110 nF	12 mH	840 nF
24 V	100 mA	3 mH	66 nF	12 mH	560 nF
30 V	100 mA	3 mH	42 nF	12 mH	370 nF

The following table shows the assignment of the maximum permissible external inductance (L_o) and capacitance (C_o) to the maximum voltage (U_i) and maximum current (I_i) for the connection to a certified intrinsically safe active circuit with electronic current limiting:

Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

Schedule to EC-type-examination Certificate No. PTB 97 ATEX 2191

U _i	I _i	type of protection			
		EEx ib IIC		EEx ib IIB	
		L _o	C _o	L _o	C _o
13 V	29 mA	5 mH	147 nF	10 mH	635 nF
19 V	29 mA	9 mH	68 nF	25 mH	367 nF
24 V	29 mA	1,8 mH	31 nF	25 mH	221 nF
30 V	29 mA	not permitted	not permitted	10 mH	137 nF
13 V	59 mA	3 mH	148 nF	10 mH	635 nF
19 V	59 mA	0,33 mH	35 nF	15 mH	225 nF
24 V	59 mA	not permitted	not permitted	5 mH	179 nF
13 V	79 mA	1,5 mH	146 nF	10 mH	459 nF
19 V	79 mA	not permitted	not permitted	6 mH	240 nF
24 V	79 mA	not permitted	not permitted	0,49 mH	59 nF
13 V	100 mA	0,7 mH	143 nF	6 mH	442 nF
19 V	100 mA	not permitted	not permitted	1,8 mH	312 nF

Output circuits
(terminal clamps 4 and 9
resp. connections 26 and
29)

maximum voltage U_m = 253 V

The input circuit is safely electrically isolated from all further circuits up to a peak value of the nominal voltage of 375 V.

(16) Report PTB Ex 97-27160

(17) Special conditions for safe use

not applicable

(18) Essential Health and Safety Requirements

met by standards

Zertifizierungsstelle Explosionsschutz

By order

Dr.-Ing. U. Johannsmeyer
Oberregierungsrat



Braunschweig, 26.09.1997

sheet 4/4

EC-type-examination Certificates without signature and official stamp shall not be valid. The certificates may be circulated only without alteration. Extracts or alterations are subject to approval by the Physikalisch-Technische Bundesanstalt. In case of dispute, the German text shall prevail.