

Germanischer Lloyd

TYPE APPROVAL CERTIFICATE

No. 12 259 - 98 HH

This is to certify, that the undemoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

COMPANY	Camille Bauer AG Aargauerstrasse 7 CH-5610 Wohlen
PRODUCT DESCRIPTION	Transducer for Voltage
TYPE	SINEAX U 539, SINEAX U 543, SINEAX U 553
ENVIRONMENTAL CATEGORY	C
TECHNICAL DATA / RANGE OF APPLICATION	SINEAX U 539: power supply 24 V DC or 24 V to 230 V AC Input: 0 - 100 V up to 0 - 300 V AC 50 / 60 Hz Output: 0 - 20 mA, 4 - 20 mA or 0 - 5 V, 1 - 5 V, 0 - 10 V or 2 - 10 V SINEAX U 543: without power supply Input: 0 - 60 V up to 0 - 250 V AC Output: 0 - 5 mA, 0 - 10 mA or 0 - 20 mA SINEAX U 553: power supply 24 V - 60 V or 85 V - 230 V AC / DC Input: 0 - 20 V up to 0 - 500 V AC Output: 0 - 20 ma, 4 - 20 mA or 0 - 10 V or 2 - 10 V Degree of protection: IP 20 DIN - rail snap on connection
TEST STANDARD	Regulations for the Performance of Type Tests
DOCUMENTS	Test report : U 539, U 543, U 553 Circuit diagram: Dossiers E 250, E 252, E 248 Data sheet: U 539 Lx, U 543 Lx, U 553 Lx
REMARKS	None
TYPE APPROVAL SYMBOL	VALID UNTIL : 29.07.2003



PLACE : Hamburg
DATE : 29.07.1998
PAGE 1 OF 1

File No. : I.D.15

Germanischer Lloyd

H. Reinecke
H. Reinecke

U. Breckwoldt
U. Breckwoldt