# S E R V I C E N O T E

SUPERSEDES: None

Agilent 8591C, 8591E, 8593E, 8594E, 8595E, 8596E, 8591EM, 8593EM, 8594EM, 8595EM, 8596EM, 8594Q, 11757B, and 11758B

# **859XE Spectrum Analyzer Serial Numbers:**

8591C -13	3916A04099 / 3916A04355
8591E -16	3916A07840 / 3916A08000
8593E -17	3926A04414 / 3926A04567
8594E -16	3911A09049 / 3916A09232
8595E -16	3911A04772 / 3911A04951
8596E -16	3911A01814 / 3911A01861

## **EMC Analyzer Serial Numbers:**

8591EM-09	3916A01485 / 3916A01488
8593EM-09	3926A00300 / 3926A00306
8594EM-09	3911A00388 / 3911A00391
8595EM-09	3911A00195 / 3911A00196

### Digital Video Broadcast Analyzer Serial Numbers:

8594Q-04 US00140111 / US00140125

# **Digital Radio Test System Serial Numbers:**

11757B-06	US00140105 / US00140107
11758B-02	US00140103 / US00140116

Instruments within this serial range can experience a 'smplr unlock' error message on the analyzer screen.

Continued

DATE: January 2001

### **ADMINISTRATIVE INFORMATION**

SERVICE NOTE CLASSIFICATION:  MODIFICATION AVAILABLE			
ACTION CATEGORY:	AGREEABLE TIME	☐ PERFORMANCE ENHANCEMENT ■ SERVICE/RELIABILITY ENHANCEMENT	
LOCATION CATEGORY:	☐ CUSTOMER INSTALLABLE ☐ ON-SITE ■ SERVICE CENTER	AVAILABLE UNTIL: End of GMS	
AUTHOR:	ENTITY:	ADDITIONAL INFORMATION:	

© 2000 AGILENT TECHNOLOGIES PRINTED IN U.S.A.



To Be Performed By: Agilent Service Centers Only

### Parts Required:

Remove A9, Third Converter assembly and replace it ONLY if the customer complaint is regarding the 'smplr unlock' message on the analyzer display.

### **Situation:**

Manufacturing discovered that the plastic package for A9U1 prescalar (vendor part number MC12090P) that divides down the 600 MHz SAWR oscillator to 300 MHz for use on the A25 Counterlock board will not divide correctly and result in a 200 MHz output with 600 MHz mixing harmonics. The instrument display will read 'smplr unlock'. The problem can be remedied by leaving the system on for 5 minutes to warm it up, and cycle the power. Once the chip is oscillating correctly, it is stable over temperature as long as the power isn't cycled again while it is cold.

#### **Solution / Action:**

Change out A9, Third Converter assembly. All field stock has been pulled to verify A9U1 is the correct style of prescalar.