cdma2000 Guide with 1xEV-DV

Agilent Technologies PSA Series and VSA E4406A

Options B78, 214

This manual provides documentation for the following instruments:

Transmitter Tester:

E4406A

Spectrum Analyzers:

E4440A (3 Hz - 26.5 GHz)

E4443A (3 Hz - 6.7 GHz)

E4445A (3 Hz - 13.2 GHz)

E4446A (3 Hz - 44.0 GHz)

E4447A (3 Hz - 42.98 GHz)

E4448A (3 Hz - 50.0 GHz)



Manufacturing Part Number: E4406-90312 Supersedes E4406-90280 Printed in USA May 2007

© Copyright 1999 - 2007 Agilent Technologies, Inc.

The information contained in this document is subject to change without notice.

Agilent Technologies makes no warranty of any kind with regard to this material, including but not limited to, the implied warranties of merchantability and fitness for a particular purpose. Agilent Technologies shall not be liable for errors contained herein or for incidental or consequential damages in connection with the furnishing, performance, or use of this material.

1.	Introduction	
	What Does the Agilent PSA Series and	
	VSA E4406A Option B78 Do?	
	Installing Optional Measurement Personalities	
	Do You Have Enough Memory to Load All Your Personality Options?	
	How to Predict Your Memory Requirements	
	Loading an Optional Measurement Personality	. 41
	Obtaining and Installing a License Key	. 42
	Viewing a License Key	. 43
	Using the Delete License Key on PSA	. 44
	Using the Uninstall Key on E4406A	
	Ordering Optional Measurement Personalities	. 45
2 .	Making Measurements	
	cdma2000 and 1xEV-DV Measurements	
	Setting up and Making a Measurement	
	Making the Initial Signal Connection	
	Using Instrument Mode and Measurement Presets	
	The 3 Steps to Set Up and Make Measurements	
	ACPR Measurements	
	Configuring the Measurement System	
	Setting the MS	
	Measurement Procedure	
	Channel Power Measurements	
	Configuring the Measurement System	
	Setting Up the MS	
	Measurement Procedure	
	Code Domain Measurements	
	Configuring the Measurement System	
	Setting the MS	
	Measurement Procedure	
	Intermodulation Measurements	
	Configuring the Measurement System	
	Setting the BTS and Signal Generator	
	Measurement Procedure	
	Modulation Accuracy (Composite Rho) Measurements	
	Configuring the Measurement System	
	Setting the MS	
	Measurement Procedure	
	Occupied Bandwidth Measurements	
	Configuring the Measurement System	
	Setting the MS	
	Measurement Procedure	
	Power Stat CCDF Measurements	
	Configuring the Measurement System	
	Setting the MS	
	Measurement Procedure	
	QPSK EVM Measurements	
	Configuring the Measurement System	. 79

	Setting the MS	
	Measurement Procedure	
	Spectrum (Frequency Domain) Measurements	
	Configuring the Measurement System	
	Setting the MS	85
	Measurement Procedure	85
	Spectrum Emission Mask Measurements	88
	Configuring the Measurement System	88
	Setting the MS	89
	Measurement Procedure	
	Waveform (Time Domain) Measurements	
	Configuring the Measurement System	
	Setting the MS	
	Measurement Procedure	
	Using Option B7C Baseband I/Q Inputs	
	Baseband I/Q Measurements Available for E4406A VSA Series Transmitter Tester	97
	Baseband I/Q Measurement Overview	
	Baseband I/Q Measurement Result Examples	
	Using Basic Mode	
	Basic Mode in E4406A VSA Series Transmitter Testers	
	Basic Mode in PSA Series Spectrum Analyzers	
	If You Have a Problem.	
	22 200 220 0 0 2 100 200 100 100 100 100	
9	Key Reference	
J.	Instrument Front Panel Highlights	110
	Selected E4406A VSA and PSA Front-Panel Features	
	Front Panel Keys	
	FREQUENCY Channel Key Menu	
	MEASURE Key Menu	
	Meas Control Key Menu	
	·	
	Mode Setup Key Menu	
	cdma2000 Measurement Keys	
	Adjacent Channel Power Ratio (ACPR) Keys	
	Channel Power Keys	
	Code Domain Keys	
	Intermod Keys	
	Mod Accuracy (Composite Rho) Keys	
	Occupied Bandwidth Keys	
	Power Statistics CCDF Keys	
	QPSK EVM Keys	
	Spectrum (Frequency Domain) Keys	
	Spectrum Emission Mask Keys	
	Waveform (Time Domain) Keys	
	Baseband I/Q Inputs (Option B7C) Keys	
	Input Port Key Menu	
	I/Q Setup Key Menu	
	I/Q Range Key Menu	
	Baseband I/Q Key Access Locations	246

ŀ.	Programming Commands	
	SCPI Command Subsystems	. 250
	Programming Command Compatibility	
	Across Model Numbers and Across Modes	. 251
	Across PSA Modes: Command Subsystem Similarities	. 251
	Across PSA Modes: Specific Command Differences	. 253
	Using Applications in PSA Series vs. VSA E4406A	
	CALCulate Subsystem	
	Code Domain Power - Limits	
	Test Current Results Against all Limits	
	Data Query	
	Calculate/Compress Trace Data Query	. 262
	Calculate Peaks of Trace Data	
	CALCulate:MARKers Subsystem	
	Occupied Bandwidth - Limits	
	Power Statistic CCDF—Store Reference	
	Modulation Accuracy - Limits	
	Spectrum Emission Mask—Limit Lines	
	Baseband I/Q - Spectrum I/Q Marker Query	
	Baseband I/Q - Waveform I/Q Marker Query	
	CONFigure Subsystem	
	Configure the Selected Measurement	
	Configure Query	
	DISPlay Subsystem	
	Code Domain - Base Code Length	
	Select Display Format	
	Select Display Format	
	Modulation Accuracy (Rho) - View Selection	
	Spectrum - Y-Axis Scale/Div	
	Spectrum - Y-Axis Reference Level	
	Turn a Trace Display On/Off	
	Waveform - Y-Axis Scale/Div	
	Waveform - Y-Axis Reference Level	
	FETCh Subsystem	
	Fetch the Current Measurement Results	
	FORMat Subsystem	
	Byte Order	
	Numeric Data format	
	INITiate Subsystem	
	Take New Data Acquisition for Selected Measurement	
	Continuous or Single Measurements	
	Take New Data Acquisitions	. 306
	Restart the Measurement	. 306
	INSTrument Subsystem	. 307
	Catalog Query	. 307
	Select Application by Number	. 307
	Select Application	
	MEASure Group of Commands	

Command Interactions: MEASure, CONFigure, FETCh, INTTiate and READ	
Adjacent Channel Power Ratio (ACP) Measurement	
Code Domain Power Measurement	
Channel Power Measurement	
QPSK Error Vector Magnitude Measurement	
Intermodulation Measurement	
Occupied Bandwidth Measurement	
Power Statistics CCDF Measurement	
Modulation Accuracy (Rho) Measurement	353
Spurious Emissions Measurement	
Spectrum (Frequency Domain) Measurement	375
Waveform (Time Domain) Measurement	378
READ Subsystem	380
Initiate and Read Measurement Data	380
SENSe Subsystem	381
Adjacent Channel Power Measurement	381
Baseband I/Q Commands (E4406A only)	397
Code Domain Measurement	398
Channel Power Measurement	404
Signal Corrections Commands	409
QPSK Error Vector Magnitude Measurement	410
RF Input Signal Alignments	413
Frequency Commands	414
Intermodulation Measurement	415
Occupied Bandwidth Measurement	421
Select I/Q Power Range (E4406A only)	
Select I/Q Voltage Range (E4406A only)	$\dots .425$
RF Power Commands	
Power Statistics CCDF Measurement	429
Radio Standards Commands	430
Modulation Accuracy (Rho) Measurement	
Reference Oscillator Commands	
Spectrum Emission Mask Measurement (Spurious Emissions)	
Spectrum (Frequency-Domain) Measurement	
Waveform (Time-Domain) Measurement	
TRIGger Subsystem	
Automatic Trigger Control	
Automatic Trigger Time	
External Trigger Delay	
External Trigger Level	
External Trigger Slope	
Frame Trigger Adjust	
Frame Trigger Period	
Trigger Holdoff	
Video (IF) Trigger Delay	
Video (IF) Trigger Level	
Video (IF) Trigger Slope	
RF Burst Trigger Delay	
RF Burst Trigger Level	505

RF Burst Trigger Slope	505
Concepts	
What Is the cdma2000 Communication System?	
Introduction	
Spreading Rate	
Radio Configuration	509
Forward Link Air Interface	510
Reverse link air interface — HPSK	511
Forward link power control	513
Differences between cdma2000 and W-CDMA	514
What Is 1xEV-DV?	515
1xEV-DV and cdma2000	515
1xEV-DV Forward Data Channels	515
Forward Packet Data Channel (F-PDCH)	516
Forward Packet Data Control Channel (F-PDCCH)	
Adjacent Channel Power Ratio (ACPR) Measurement Concepts	
Purpose	
Measurement Method	
Channel Power Measurement Concepts	
Purpose	
Measurement Method	
Code Domain Measurement Concepts	
Purpose	
Measurement Method.	
Intermodulation Measurement Concepts	
Purpose	
Measurement Method	
Modulation Accuracy (Composite Rho) Measurement Concepts	
Purpose	
Measurement Method.	
Occupied Bandwidth Measurement Concepts	
Purpose	
Measurement Method.	
Power Statistics CCDF Measurement Concepts	
Purpose	
Measurement Method.	
QPSK EVM Measurement Concepts.	
Purpose	
Measurement Method.	
Spectrum (Frequency Domain) Measurement Concepts	
Purpose	
Troubleshooting Hints	
Spectrum Emission Mask Measurement Concepts	
Purpose	
Measurement Method	
Waveform (Time Domain) Measurement Concepts	536
PHPMOPA	536

	Measurement Method	536
	Baseband I/Q Inputs (Option B7C) Measurement Concepts	537
	What are Baseband I/Q Inputs?	537
	What are Baseband I/Q Signals?	538
	Why Make Measurements at Baseband?	538
	Selecting Input Probes for Baseband Measurements	538
	Baseband I/Q Measurement Views	541
	Other Sources of Measurement Information	545
	Instrument Updates at www.agilent.com	545
	References	546
6.	Menu Maps	
	cdma2000 Measurement Key Flow	548

:CALCulate:CDPower:ASET:THReshold < numeric>
:CALCulate:CDPower:ASET:THReshold:AUTO OFF ON 0 1
:CALCulate:CDPower:ASET:THReshold:AUTO?
:CALCulate:CDPower:ASET:THReshold?
:CALCulate:CDPower:AXIS[:MS] IPH QPH
:CALCulate:CDPower:AXIS[:MS]?
:CALCulate:CDPower:MTYPe AUTO GATed QPSK OPSK QAM16
:CALCulate:CDPower:MTYPe AUTO GATed QPSK QAM16
:CALCulate:CDPower:MTYPe?
:CALCulate:CDPower:MTYPe?
:CALCulate:CDPower:PNOFfset <time></time>
:CALCulate:CDPower:PNOFfset?
:CALCulate:CDPower:SWEep:OFFSet <integer></integer>
:CALCulate:CDPower:SWEep:OFFSet <time></time>
:CALCulate:CDPower:SWEep:OFFSet?
:CALCulate:CDPower:SWEep:TIME <float></float>
:CALCulate:CDPower:SWEep:TIME <integer></integer>
:CALCulate:CDPower:SWEep:TIME?
:CALCulate:CDPower:TYPE ABSolute RELative
:CALCulate:CDPower:TYPE?
:CALCulate:CDPower:WCODe:BASE <integer></integer>
:CALCulate:CDPower:WCODe:BASE?
:CALCulate:CDPower:WCODe:LENGth <integer></integer>
:CALCulate:CDPower:WCODe:LENGth?
:CALCulate:CDPower:WCODe:ORDer BREVerse (HADMrd HADamard)
:CALCulate:CDPower:WCODe:ORDer?
:CALCulate:CDPower:WCODe[:NUMBer] <integer></integer>
:CALCulate:CDPower:WCODe[:NUMBer]?
:CALCulate:CLIMits:FAIL?
:CALCulate:DATA <n>:COMPress? BLOCk CFIT MAXimum MINimum MEAN</n>
DMEan RMS RMSCubed SAMPle SDEViation PPHase

$: CALCulate: DATA < n > : PEAKs? < threshold >, < excursion > [, AMPLitude \mid FREQuency \mid TIME] . \\$	273
:CALCulate:DATA[n]?	262
:CALCulate:OBWidth:LIMit:STATe OFF ON 0 1	285
:CALCulate:OBWidth:LIMit:STATe?	285
:CALCulate:OBW:LIMit[:TEST] OFF ON 0 1	285
:CALCulate:OBW:LIMit[:TEST]?	285
:CALCulate:PSTatistic:STORe:REFerence ON 1	286
:CALCulate:RHO:ASET:THReshold <numeric></numeric>	286
:CALCulate:RHO:ASET:THReshold:AUTO OFF ON 0 1	286
:CALCulate:RHO:ASET:THReshold:AUTO?	286
:CALCulate:RHO:ASET:THReshold?	286
:CALCulate:RHO:IQOFfset:INCLude OFF ON 0 1	287
:CALCulate:RHO:IQOFfset:INCLude?	287
:CALCulate:RHO:LIMit:CDERror <float></float>	287
:CALCulate:RHO:LIMit:CDERror?	287
:CALCulate:RHO:LIMit:PEAK <float></float>	287
:CALCulate:RHO:LIMit:PEAK?	287
:CALCulate:RHO:LIMit:PHASe <float></float>	288
:CALCulate:RHO:LIMit:PHASe?	288
:CALCulate:RHO:LIMit:RHO <float></float>	288
:CALCulate:RHO:LIMit:RHO?	288
:CALCulate:RHO:LIMit:RMS <float></float>	288
:CALCulate:RHO:LIMit:RMS?	288
:CALCulate:RHO:LIMit:TIMing <float></float>	288
:CALCulate:RHO:LIMit:TIMing?	288
:CALCulate:RHO:PNOFfset <time></time>	289
:CALCulate:RHO:PNOFfset?	289
:CALCulate:SEMask:LLINe:STATe ON OFF 1 0	289
:CALCulate:SEMask:LLINe:STATe?	289
:CALCulate:SPECtrum:MARKer:IQ [1] 2 3 4?	290
·CALCulate·WAVeform·MARKer·IQ[1][2]3]4?	290

:CALCulate: <measurement>:MARKer:AOFF</measurement>	277
:CALCulate: <measurement>:MARKer[1] 2 3 4:FUNCtion:RESult?</measurement>	277
:CALCulate: <measurement>:MARKer[1] 2 3 4:MAXimum</measurement>	27 8
:CALCulate: <measurement>:MARKer[1] 2 3 4:MINimum</measurement>	278
:CALCulate: <measurement>:MARKer[1] 2 3 4:MODE POSition DELTa</measurement>	27 8
:CALCulate: <measurement>:MARKer[1] 2 3 4:MODE POSition DELTa RMSDegree RMSRadian RFM RMSJitter OFF</measurement>	27 8
:CALCulate: <measurement>:MARKer[1] 2 3 4:MODE?</measurement>	278
:CALCulate: <measurement>:MARKer[1] 2 3 4:TRACe <trace_name></trace_name></measurement>	279
:CALCulate: <measurement>:MARKer[1] 2 3 4:TRACe?</measurement>	279
:CALCulate: <measurement>:MARKer[1] 2 3 4:X <param/></measurement>	284
:CALCulate: <measurement>:MARKer[1] 2 3 4:X:POSition <integer></integer></measurement>	284
:CALCulate: <measurement>:MARKer[1] 2 3 4:X:POSition?</measurement>	284
:CALCulate: <measurement>:MARKer[1] 2 3 4:X?</measurement>	284
:CALCulate: <measurement>:MARKer[1] 2 3 4:Y?</measurement>	285
:CALCulate: <measurement>:MARKer[1] 2 3 4[:STATe] OFF ON 0 1</measurement>	279
:CALCulate: <measurement>:MARKer[1] 2 3 4[:STATe]?</measurement>	279
:CONFigure:ACP	315
:CONFigure:CDPower	322
:CONFigure:CHPower	342
:CONFigure:EVMQpsk	343
:CONFigure:IM	346
:CONFigure:OBW	349
:CONFigure:PSTatistic	351
:CONFigure:RHO	353
:CONFigure:SEMask	369
:CONFigure:SPECtrum	375
:CONFigure:WAVeform	378
:CONFigure: <measurement></measurement>	291
:CONFigure?	291
:DISPlay:ACP:VIEW BGRaph SPECtrum	292

:DISPlay:ACP:VIEW?	<mark>292</mark>
:DISPlay:CDPower:BCLength 64 128	292
:DISPlay:CDPower:BCLength?	<mark>292</mark>
:DISPlay:FORMat:TILE	292
:DISPlay:FORMat:ZOOM	293
:DISPlay:RHO:VIEW ERRor POLar QUAD TABLe TPHase	29 3
:DISPlay:RHO:VIEW POLar ERRor	29 3
:DISPlay:RHO:VIEW?	293
:DISPlay:SPECtrum[n]:WINDow[m]:TRACe:Y[:SCALe]:PDIVision <power></power>	294
:DISPlay:SPECtrum[n]:WINDow[m]:TRACe:Y[:SCALe]:PDIVision?	294
:DISPlay:SPECtrum[n]:WINDow[m]:TRACe:Y[:SCALe]:RLEVel <power></power>	295
:DISPlay:SPECtrum[n]:WINDow[m]:TRACe:Y[:SCALe]:RLEVel?	295
:DISPlay:TRACe[n][:STATe] OFF ON 0 1	295
:DISPlay:TRACe[n][:STATe]?	295
:DISPlay:WAVeform[n]:WINDow[m]:TRACe:Y[:SCALe]:PDIVision <power></power>	300
:DISPlay:WAVeform[n]:WINDow[m]:TRACe:Y[:SCALe]:PDIVision?	300
:DISPlay:WAVeform[n]:WINDow[m]:TRACe:Y[:SCALe]:RLEVel <power></power>	301
:DISPlay:WAVeform[n]:WINDow[m]:TRACe:Y[:SCALe]:RLEVel?	3 01
:FETCh:ACP[n]?	315
:FETCh:CDPower[n]?	3 22
:FETCh:CHPower[n]?	342
:FETCh:EVMQpsk[n]?	343
:FETCh:IM[n]?	346
:FETCh:OBW[n]?	349
:FETCh:PSTatistic[n]?	351
:FETCh:RHO[n]?	353
:FETCh:SEMask[n]?	3 69
:FETCh:SPECtrum[n]?	3 75
:FETCh:WAVeform[n]?	3 7 8
:FETCh: <measurement>[n]?</measurement>	30 2
·FORMat·BORDer NORMall SWAPned	303

:FORMat:BORDer?
:FORMat[:DATA] ASCii REAL,32 REAL,64
:FORMat[:DATA]?303
$: FORMat[:TRACe][:DATA] \ ASCii \ \ INTeger, 16 \ \ INTeger, 32 \ \ REAL, 32 \ \ REAL, 64 \ \ UINTeger, 16 \ . \ \ 303 \ \ ASCii \ \ A$
:FORMat[:TRACe][:DATA]?
:INITiate:ACP315
:INITiate:CDPower322
:INITiate:CHPower342
:INITiate:CONTinuous OFF ON 0 1
:INITiate:CONTinuous?
:INITiate:EVMQpsk
:INITiate:IM
:INITiate:OBW
:INITiate:PSTatistic
:INITiate:RESTart
:INITiate:RHO
:INITiate:SEMask
:INITiate:SPECtrum
:INITiate:WAVeform
:INITiate: <measurement_name>305</measurement_name>
:INITiate[:IMMediate]
:INSTrument:CATalog?
:INSTrument:CATalog[:FULL]?307
:INSTrument:NSELect <integer></integer>
:INSTrument:NSELect?
:INSTrument[:SELect] BASIC SERVICE CDMA CDMA2K GSM EDGEGSM IDEN WIDEN NADC PDC WCDMA CDMA1XEV308
:INSTrument[:SELect] SA PNOISE BASIC CDMA CDMA2K EDGEGSM NADC PDC WCDMA CDMA1XEV NFIGURE WLAN MRECEIVE TDSCDMA TDDEMOD EMC DEMODULATION
:INSTrument[:SELect]?
:MEASure:ACP[n]?315

:MEASure:CDPower[n]?
:MEASure:CHPower[n]?
:MEASure:EVMQpsk[n]?
:MEASure:IM[n]?
:MEASure:OBW[n]?
:MEASure:PSTatistic[n]?
:MEASure:RHO[n]?
:MEASure:SEMask[n]?
:MEASure:SPECtrum[n]?
:MEASure:WAVeform[n]?
:READ:ACP[n]?
:READ:CDPower[n]?
:READ:CHPower[n]?
:READ:EVMQpsk[n]?
:READ:IM[n]?
:READ:OBW[n]?
:READ:PSTatistic[n]?
:READ:RHO[n]?
:READ:SEMask[n]?
:READ:SPECtrum[n]?
:READ:WAVeform[n]?
:READ: <measurement>[n]?</measurement>
:TRIGger[:SEQuence]:AUTO:STATe OFF ON 0 1
:TRIGger[:SEQuence]:AUTO:STATe?
:TRIGger[:SEQuence]:AUTO[:TIME] <time></time>
:TRIGger[:SEQuence]:AUTO[:TIME]?
:TRIGger[:SEQuence]:EXTernal[1] 2:DELay <time></time>
:TRIGger[:SEQuence]:EXTernal[1] 2:DELay?
:TRIGger[:SEQuence]:EXTernal[1] 2:LEVel <voltage></voltage>
:TRIGger[:SEQuence]:EXTernal[1] 2:LEVel?
:TRIGger[:SEQuence]:EXTernal[1] 2:SLOPe NEGative POSitive

:TRIGger[:SEQuence]:EXTernal[1] 2:SLOPe?
:TRIGger[:SEQuence]:FRAMe:ADJust <time></time>
:TRIGger[:SEQuence]:FRAMe:PERiod <time></time>
:TRIGger[:SEQuence]:FRAMe:PERiod?
:TRIGger[:SEQuence]:HOLDoff <time></time>
:TRIGger[:SEQuence]:HOLDoff?
:TRIGger[:SEQuence]:IF:DELay <time></time>
:TRIGger[:SEQuence]:IF:DELay?
:TRIGger[:SEQuence]:IF:LEVel <ampl></ampl>
:TRIGger[:SEQuence]:IF:LEVel?
:TRIGger[:SEQuence]:IF:SLOPe NEGative POSitive
:TRIGger[:SEQuence]:IF:SLOPe?
:TRIGger[:SEQuence]:RFBurst:DELay <time></time>
:TRIGger[:SEQuence]:RFBurst:DELay?
:TRIGger[:SEQuence]:RFBurst:LEVel <rel_power></rel_power>
:TRIGger[:SEQuence]:RFBurst:LEVel?
:TRIGger[:SEQuence]:RFBurst:SLOPe NEGative POSitive
:TRIGger[:SEQuence]:RFBurst:SLOPe?
[:SENSe]:ACP:AVERage:COUNt <integer></integer>
[:SENSe]:ACP:AVERage:COUNt?
[:SENSe]:ACP:AVERage:TCONtrol EXPonential REPeat
[:SENSe]:ACP:AVERage:TCONtrol?
[:SENSe]:ACP:AVERage[:STATe] OFF ON 0 1
[:SENSe]:ACP:AVERage[:STATe]?381
[:SENSe]:ACP:BANDwidth[n] BWIDth[n]:INTegration < freq>
[:SENSe]:ACP:BANDwidth[n] BWIDth[n]:INTegration?
[:SENSe]:ACP:BANDwidth[n] BWIDth[n]:INTegration[m] < freq>
[:SENSe]:ACP:BANDwidth[n] BWIDth[n]:INTegration[m]?
[:SENSe]:ACP:BANDwidth BWIDth:INTegration < freq>
[:SENSe]:ACP:BANDwidth BWIDth:INTegration?
[·SENSa]·ACP·OFFSat·ARSoluta < nowar>

[:SENSe]:ACP:OFFSet:ABSolute?
[:SENSe]:ACP:OFFSet:BANDwidth BWIDth <res_bw></res_bw>
[:SENSe]:ACP:OFFSet:BANDwidth BWIDth?
[:SENSe]:ACP:OFFSet:LIST:ABSolute <power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<power>,<pow< td=""></pow<></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power></power>
[:SENSe]:ACP:OFFSet:LIST:ABSolute?
[:SENSe]:ACP:OFFSet:LIST:BANDwidth BWIDth <res_bw>,<res_bw>,<res_bw>,<res_bw>, =</res_bw></res_bw></res_bw></res_bw>
[:SENSe]:ACP:OFFSet:LIST:BANDwidth BWIDth?
[:SENSe]:ACP:OFFSet:LIST:RCARrier <rel_power>,<rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power></rel_power>
[:SENSe]:ACP:OFFSet:LIST:RCARrier?
[:SENSe]:ACP:OFFSet:LIST:RPSDensity <rel_power>,<rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power></rel_power>
[:SENSe]:ACP:OFFSet:LIST:RPSDensity?
[:SENSe]:ACP:OFFSet:LIST:STATe OFF ON 0 1, OFF ON 0 1
[:SENSe]:ACP:OFFSet:LIST:STATe?
[:SENSe]:ACP:OFFSet:LIST:TEST ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative
[:SENSe]:ACP:OFFSet:LIST:TEST?
[:SENSe]:ACP:OFFSet:LIST[:FREQuency] <f_offset>,<f_offset>,<f_offset>,<f_offset>,</f_offset></f_offset></f_offset></f_offset>
[:SENSe]:ACP:OFFSet:LIST[:FREQuency]?
[:SENSe]:ACP:OFFSet:RCARrier <rel_power></rel_power>
[:SENSe]:ACP:OFFSet:RCARrier?
[:SENSe]:ACP:OFFSet:RPSDensity <rel_power></rel_power>
[:SENSe]:ACP:OFFSet:RPSDensity?
[:SENSe]:ACP:OFFSet:TEST ABSolute AND OR RELative
[:SENSe]:ACP:OFFSet:TEST?
[:SENSe]:ACP:OFFSet[n]:LIST:ABSolute <power>,<power>,<power>,<power>,<power>,</power></power></power></power></power>
[:SENSe]:ACP:OFFSet[n]:LIST:ABSolute?
[·SENSe]·ACP·OFFSet[n]·LIST·BANDwidth BWIDth

<res_bw>,<res_bw>,<res_bw>,<res_bw></res_bw></res_bw></res_bw></res_bw>	5
[:SENSe]:ACP:OFFSet[n]:LIST:BANDwidth BWIDth?	5
[:SENSe]:ACP:OFFSet[n]:LIST:RCARrier <rel_power>,<rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power></rel_power>	3
[:SENSe]:ACP:OFFSet[n]:LIST:RCARrier?	3
[:SENSe]:ACP:OFFSet[n]:LIST:RPSDensity <rel_power>,<rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power></rel_power>)
[:SENSe]:ACP:OFFSet[n]:LIST:RPSDensity?)
[:SENSe]:ACP:OFFSet[n]:LIST:STATe OFF ON 0 1, OFF ON 0 1, OFF ON 0 1, OFF ON 0 1, OFF ON 0 1	L
[:SENSe]:ACP:OFFSet[n]:LIST:STATe?	L
[:SENSe]:ACP:OFFSet[n]:LIST:TEST ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative	2
[:SENSe]:ACP:OFFSet[n]:LIST:TEST?	2
[:SENSe]:ACP:OFFSet[n]:LIST[n]:BANDwidth BWIDth <res_bw>,<res_bw>,<res_bw>,<res_bw>,</res_bw></res_bw></res_bw></res_bw>	5
[:SENSe]:ACP:OFFSet[n]:LIST[n]:BANDwidth BWIDth?	5
[:SENSe]:ACP:OFFSet[n]:LIST[n]:RCARrier <rel_power>,<rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power></rel_power>	3
[:SENSe]:ACP:OFFSet[n]:LIST[n]:RCARrier?	3
[:SENSe]:ACP:OFFSet[n]:LIST[n]:RPSDensity <rel_power>,<rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power></rel_power>)
[:SENSe]:ACP:OFFSet[n]:LIST[n]:RPSDensity?)
[:SENSe]:ACP:OFFSet[n]:LIST[n]:STATe OFF ON 0 1, OFF ON 0 1, OFF ON 0 1, OFF ON 0 1, OFF ON 0 1	L
[:SENSe]:ACP:OFFSet[n]:LIST[n]:STATe?	L
[:SENSe]:ACP:OFFSet[n]:LIST[n]:TEST, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative 392	
[:SENSe]:ACP:OFFSet[n]:LIST[n]:TEST?	2
[:SENSe]:ACP:OFFSet[n]:LIST[n][:FREQuency] <f_offset>,<f_offset>,<f_offset>,<f_offset>,</f_offset></f_offset></f_offset></f_offset>	3
[:SENSe]:ACP:OFFSet[n]:LIST[n][:FREQuency]?	7
[:SENSe]:ACP:OFFSet[n]:LIST[:FREQuency]	•

[:SENSe]:ACP:OFFSet[n]:LIST[:FREQuency]?	386
[:SENSe]:ACP:OFFSet[:FREQuency] <f_offset></f_offset>	386
[:SENSe]:ACP:OFFSet[:FREQuency]?	386
$[:SENSe]: ACP: SWEep: BANDwidth \mid BWIDth [:RESolution] < freq > \dots$	394
$[:SENSe]: ACP: SWEep: BANDwidth \mid BWIDth [:RESolution]: AUTO\ OFF \mid ON \mid 0 \mid 1.\dots$	394
$[:SENSe]: ACP: SWEep: BANDwidth \ \ BWIDth \ [:RESolution]: AUTO? \$	394
$[:SENSe]: ACP: SWEep: BANDwidth \ \ BWIDth \ [:RESolution]? \ $	394
[:SENSe]:ACP:SWEep:DETector[:FUNCtion] AAVerage POSitive	394
[:SENSe]:ACP:SWEep:DETector[:FUNCtion]?	394
[:SENSe]:ACP:SWEep:TIME <seconds></seconds>	395
[:SENSe]:ACP:SWEep:TIME?	395
[:SENSe]:ACP:SWEep:TYPE FAST FFT SWEep	396
[:SENSe]:ACP:SWEep:TYPE FFT SWEep	396
[:SENSe]:ACP:SWEep:TYPE?	396
[:SENSe]:ACP:SWEep:TYPE?	396
[:SENSe]:ACP:TYPE PSDRef TPRef	396
[:SENSe]:ACP:TYPE?	396
[:SENSe]:CDPower:ACODe AUTO GATed COMBination	398
[:SENSe]:CDPower:ACODe AUTO PREDefined	398
[:SENSe]:CDPower:ACODe?	398
[:SENSe]:CDPower:CAPTure:TIME <numeric></numeric>	399
[:SENSe]:CDPower:CAPTure:TIME?	399
[:SENSe]:CDPower:CRATe <freq></freq>	399
[:SENSe]:CDPower:CRATe?	400
[:SENSe]:CDPower:INDex <integer></integer>	400
[:SENSe]:CDPower:INDex?	400
[:SENSe]:CDPower:MASK <integer></integer>	400
[:SENSe]:CDPower:MASK:STATe OFF ON 0 1	401
[:SENSe]:CDPower:MASK:STATe?	401
[:SENSe]:CDPower:MASK?	400
[·SENS ₆]·CDP _{0Wor} ·PDCH[0] 1·MTVP ₆ QPSK QPSK QAM16	401

[:SENSe]:CDPower:PDCH[0] 1:MTYPe?
[:SENSe]:CDPower:PDCH[0] 1:NUMBer <integer></integer>
[:SENSe]:CDPower:PDCH[0] 1:NUMBer?
[:SENSe]:CDPower:QOF 0 1 2 3
[:SENSe]:CDPower:QOF?
[:SENSe]:CDPower:SPECtrum INVert NORMal
[:SENSe]:CDPower:SPECtrum?
[:SENSe]:CDPower:SYNC:LCMask <integer></integer>
[:SENSe]:CDPower:SYNC:LCMask?
[:SENSe]:CDPower:TRIGger:SOURce EXTernal[1] External2 FRAMe IF IMMediate RFBurst
[:SENSe]:CDPower:TRIGger:SOURce?
[:SENSe]:CHPower:AVERage:COUNt <integer></integer>
[:SENSe]:CHPower:AVERage:COUNt?
[:SENSe]:CHPower:AVERage:TCONtrol EXPonential REPeat
[:SENSe]:CHPower:AVERage:TCONtrol?
[:SENSe]:CHPower:AVERage[:STATe] OFF ON 0 1
[:SENSe]:CHPower:AVERage[:STATe]?
[:SENSe]:CHPower:BANDwidth BWIDth:INTegration < freq>
[:SENSe]:CHPower:BANDwidth BWIDth:INTegration?
[:SENSe]:CHPower:FREQuency:SPAN <freq></freq>
[:SENSe]:CHPower:FREQuency:SPAN?
[:SENSe]:CHPower:POINts <integer></integer>
[:SENSe]:CHPower:POINts:AUTO OFF ON 0 1
[:SENSe]:CHPower:POINts:AUTO?
[:SENSe]:CHPower:POINts?
[:SENSe]:CHPower:SWEep:TIME <time></time>
[:SENSe]:CHPower:SWEep:TIME:AUTO OFF ON 0 1
[:SENSe]:CHPower:SWEep:TIME:AUTO?
[:SENSe]:CHPower:SWEep:TIME?
[:SENSe]:CHPower:TRIGger:SOURce EXTernal[1] EXTernal2 IMMediate

[:SENSe]:CHPower:TRIGger:SOURce?	08
[:SENSe]:CORRection:BTS[:RF]:LOSS <rel_power></rel_power>	09
[:SENSe]:CORRection:BTS[:RF]:LOSS?	.09
[:SENSe]:CORRection:MS[:RF]:LOSS <rel_power></rel_power>	09
[:SENSe]:CORRection:MS[:RF]:LOSS?	.09
[:SENSe]:EVMQpsk:AVERage:COUNt <integer></integer>	10
[:SENSe]:EVMQpsk:AVERage:COUNt?	10
[:SENSe]:EVMQpsk:AVERage:TCONtrol EXPonential REPeat	10
[:SENSe]:EVMQpsk:AVERage:TCONtrol?	10
[:SENSe]:EVMQpsk:AVERage[:STATe] OFF ON 0 1	10
[:SENSe]:EVMQpsk:AVERage[:STATe]?	10
[:SENSe]:EVMQpsk:CRATe <freq></freq>	11
[:SENSe]:EVMQpsk:CRATe?4	11
[:SENSe]:EVMQpsk:RFCarrier MULTiple SINGle	:11
[:SENSe]:EVMQpsk:RFCarrier?4	:11
[:SENSe]:EVMQpsk:SWEep:POINts <integer></integer>	12
[:SENSe]:EVMQpsk:SWEep:POINts?	12
[:SENSe]:EVMQpsk:TRIGger:SOURce EXTernal[1] EXTernal2 FRAMe IF IMMediate RFBurst	-12
[:SENSe]:EVMQpsk:TRIGger:SOURce?4	
[:SENSe]:FEED RF AREFerence IFAlign	
[:SENSe]:FEED RF IQ IONLy QONLy AREFerence IFALign	13
[:SENSe]:FEED?	13
[:SENSe]:FREQuency:CENTer <freq></freq>	14
[:SENSe]:FREQuency:CENTer:STEP[:INCRement] < freq>	14
[:SENSe]:FREQuency:CENTer:STEP[:INCRement]?	14
[:SENSe]:FREQuency:CENTer?	14
[:SENSe]:IM:AVERage:COUNt < number>4	15
[:SENSe]:IM:AVERage:COUNt?	15
[:SENSe]:IM:AVERage:TCONtrol EXPonential REPeat	16
[:SENSe]:IM:AVERage:TCONtrol?	16

[:SENSe]:IM:AVERage[:STATe] OFF ON 0 1
[:SENSe]:IM:AVERage[:STATe]?
[:SENSe]:IM:BANDwidth BWIDth:INTegration < freq>
[:SENSe]:IM:BANDwidth BWIDth:INTegration?
[:SENSe]:IM:BANDwidth BWIDth[:RESolution] < freq>
[:SENSe]:IM:BANDwidth BWIDth[:RESolution]:AUTO OFF ON 0 1
[:SENSe]:IM:BANDwidth BWIDth[:RESolution]:AUTO?
[:SENSe]:IM:BANDwidth BWIDth[:RESolution]?
[:SENSe]:IM:FREQuency:AUTO OFF ON 0 1
[:SENSe]:IM:FREQuency:AUTO?
[:SENSe]:IM:FREQuency:SPAN <freq></freq>
[:SENSe]:IM:FREQuency:SPAN?
[:SENSe]:IM:FREQuency[:BASE]:DELTa <freq></freq>
[:SENSe]:IM:FREQuency[:BASE]:DELTa?
[:SENSe]:IM:FREQuency[:BASE]:LOWer < freq>
[:SENSe]:IM:FREQuency[:BASE]:LOWer?
[:SENSe]:IM:FREQuency[:BASE]:UPPer <freq></freq>
[:SENSe]:IM:FREQuency[:BASE]:UPPer?
[:SENSe]:IM:MODE AUTO TWOTone TXIM
[:SENSe]:IM:MODE?
[:SENSe]:IM:REFerence AUTO AVERage LOWer UPPer
[:SENSe]:IM:REFerence?
[:SENSe]:OBW:AVERage:COUNt <integer></integer>
[:SENSe]:OBW:AVERage:COUNt?
[:SENSe]:OBW:AVERage:TCONtrol EXPonential REPeat
[:SENSe]:OBW:AVERage:TCONtrol?
[:SENSe]:OBW:AVERage[:STATe] OFF ON 0 1
[:SENSe]:OBW:AVERage[:STATe]?
[:SENSe]:OBW:BANDwidth BWIDth[:RESolution] <freq></freq>
[:SENSe]:OBW:BANDwidth BWIDth[:RESolution]?
[·SENSa]·ORW·FFT·WINDow[·TVPE] RH/Tan RLACkman FLATton

GAUS sian HAMMing HANNing KB70 KB90 KB110 UNIForm	422
[:SENSe]:OBW:FFT:WINDow[:TYPE]?	423
[:SENSe]:OBW:FREQuency:SPAN <freq></freq>	423
[:SENSe]:OBW:FREQuency:SPAN?	423
[:SENSe]:OBW:TRIGger:SOURce EXTernal[1] EXTernal2 FRAMe IF IMMediate LINE RFBurst	424
$[:SENSe]: OBW: TRIGger: SOURce\ EXTernal [1] \ \ EXTernal 2 \ \ IF \ \ IMMediate \ \ RFBurst\$	423
$[:SENSe]: OBW: TRIGger: SOURce\ EXTernal [1] \ \ EXTernal 2 \ \ IF \ \ IMMediate \ \ RFBurst\$	424
[:SENSe]:OBW:TRIGger:SOURce?	424
[:SENSe]:OBW:TRIGger:SOURce?	424
[:SENSe]:OBW:TRIGger:SOURce?	424
[:SENSe]:POWer:IQ:RANGe[:UPPer] <power> [DBM] DBMV W</power>	397
[:SENSe]:POWer:IQ:RANGe[:UPPer] <float 64="">{DBM] DBMV W</float>	424
[:SENSe]:POWer:IQ:RANGe[:UPPer]?	397
[:SENSe]:POWer:IQ:RANGe[:UPPer]?	424
[:SENSe]:POWer[:RF]:ATTenuation <rel_power></rel_power>	426
[:SENSe]:POWer[:RF]:ATTenuation?	426
[:SENSe]:POWer[:RF]:GAIN:ATTenuation <rel_power></rel_power>	426
[:SENSe]:POWer[:RF]:GAIN:ATTenuation?	426
[:SENSe]:POWer[:RF]:GAIN[:STATe] OFF ON 0 1	426
[:SENSe]:POWer[:RF]:GAIN[:STATe]?	426
[:SENSe]:POWer[:RF]:RANGe:AUTO OFF ON 0 1	427
[:SENSe]:POWer[:RF]:RANGe:AUTO?	427
[:SENSe]:POWer[:RF]:RANGe[:UPPer] <power></power>	428
[:SENSe]:POWer[:RF]:RANGe[:UPPer]?	428
[:SENSe]:PSTatistic:BANDwidth BWIDth <freq></freq>	429
[:SENSe]:PSTatistic:BANDwidth BWIDth?	429
[:SENSe]:PSTatistic:COUNts <integer></integer>	429
[:SENSe]:PSTatistic:COUNts?	429
[:SENSe]:PSTatistic:SWEep:TIME <time></time>	429
[:SENSel:PSTatistic:SWEep:TIME?	430

[:SENSe]:PSTatistic:TRIGger:SOURce EXTernal[1] EXTernal2
FRAMe IF IMMediate RFBurst
[:SENSe]:PSTatistic:TRIGger:SOURce?
[:SENSe]:RADio:CARRier:NUMBer SINGle MULTiple
[:SENSe]:RADio:CARRier:NUMBer?
[:SENSe]:RADio:CONFigure:EVDV[:STATe] OFF ON 0 1
[:SENSe]:RADio:CONFigure:EVDV[:STATe]?
[:SENSe]:RADio:DEVice BTS MS
[:SENSe]:RADio:DEVice?
[:SENSe]:RHO:ACODe AUTO COMBination
[:SENSe]:RHO:ACODe AUTO PREDefined
[:SENSe]:RHO:ACODe?
[:SENSe]:RHO:ADC:RANGe AUTO APEak APLock NONE M6 P0 P6 P12 P18 P24 433
[:SENSe]:RHO:ADC:RANGe AUTO APEak APLock NONE P0 P6 P12 P18
[:SENSe]:RHO:ADC:RANGe?
[:SENSe]:RHO:AVERage:COUNt <integer></integer>
[:SENSe]:RHO:AVERage:COUNt?
[:SENSe]:RHO:AVERage:TCONtrol EXPonential REPeat
[:SENSe]:RHO:AVERage:TCONtrol?
[:SENSe]:RHO:AVERage[:STATe] OFF ON 0 1
[:SENSe]:RHO:AVERage[:STATe]?
[:SENSe]:RHO:CRATe <freq></freq>
[:SENSe]:RHO:CRATe?
[:SENSe]:RHO:INDex <integer></integer>
[:SENSe]:RHO:INDex?
[:SENSe]:RHO:MASK <integer></integer>
[:SENSe]:RHO:MASK:STATe OFF ON 0 1
[:SENSe]:RHO:MASK:STATe?
[:SENSe]:RHO:MASK?
[:SENSe]:RHO:MCEStimator OFF ON 0 1
[-SENSo]-RHO-MCEStimator?

[:SENSe]:RHO:PDCH[0] 1:MTYPe QPSK OPSK QAM164	137
[:SENSe]:RHO:PDCH[0] 1:MTYPe?	137
[:SENSe]:RHO:PDCH[0] 1:NUMBer <integer></integer>	138
[:SENSe]:RHO:PDCH[0] 1:NUMBer?	138
[:SENSe]:RHO:SPECtrum INVert NORMal	138
[:SENSe]:RHO:SPECtrum?	138
[:SENSe]:RHO:SYNC:LCMask <integer></integer>	139
[:SENSe]:RHO:SYNC:LCMask?	139
$[:SENSe]: RHO: TRIGger: SOURce\ EXTernal [1] \ \ External 2 \ \ FRAMe \ \ IF \ \ IMMediate \ \ RFBurst\dots 4dd \ Apple 2dd \ Apple 2dd \ Apple 3dd \ Apple 4dd \ Appl$	139
[:SENSe]:RHO:TRIGger:SOURce?	139
[:SENSe]:ROSCillator:EXTernal:FREQuency < frequency>	40
[:SENSe]:ROSCillator:EXTernal:FREQuency?	40
[:SENSe]:ROSCillator:OUTPut?4	40
[:SENSe]:ROSCillator:OUTPut[:STATe] OFF ON 0 1	40
[:SENSe]:ROSCillator:SOURce INTernal EXTernal	40
[:SENSe]:ROSCillator:SOURce?4	40
[:SENSe]:SEMask:AVERage:COUNt <integer></integer>	41
[:SENSe]:SEMask:AVERage:COUNt?	41
[:SENSe]:SEMask:AVERage[:STATe] OFF ON 0 1	41
[:SENSe]:SEMask:AVERage[:STATe]?	41
[:SENSe]:SEMask:BANDwidth[n] BWIDth[n]:INTegration < freq>	42
[:SENSe]:SEMask:BANDwidth[n] BWIDth[n]:INTegration?	42
$[:SENSe]: SEMask: BANDwidth[n] \mid BWIDth[n]: RESolution < freq > \dots \\4$	42
$[:SENSe]: SEMask: BANDwidth[n] \mid BWIDth[n]: RESolution: AUTO\ OFF \mid ON \mid 0 \mid 1,\ldots,4,4,4,4,4,4,4,4,4,4,4,4,4,4,4,4,4,4,$	43
[:SENSe]:SEMask:BANDwidth[n] BWIDth[n]:RESolution:AUTO?	43
[:SENSe]:SEMask:BANDwidth[n] BWIDth[n]:RESolution?	42
[:SENSe]:SEMask:BANDwidth BWIDth:INTegration[m] <freq></freq>	42
[:SENSe]:SEMask:BANDwidth BWIDth:INTegration[m]?	42
[:SENSe]:SEMask:BANDwidth BWIDth:RESolution[m] <freq></freq>	42
$[:SENSe]:SEMask:BANDwidth \mid BWIDth:RESolution [m]:AUTO\ OFF \mid ON \mid 0 \mid 1 \ \dots \ \dots \ .4$	43
[:SENSe]:SEMask:BANDwidth BWIDth:RESolution[m]:AUTO?4	143

[:SENSe]:SEMask:BANDwidth BWIDth:RESolution[m]?	43
[:SENSe]:SEMask:DETector[:FUNCtion] AAVerage POSitive	44
[:SENSe]:SEMask:DETector[:FUNCtion]?	44
[:SENSe]:SEMask:FREQuency:STEP[m] <freq></freq>	45
[:SENSe]:SEMask:FREQuency:STEP[m]:AUTO OFF ON 0 1	45
[:SENSe]:SEMask:FREQuency:STEP[m]:AUTO?	45
[:SENSe]:SEMask:FREQuency:STEP[m]?	45
[:SENSe]:SEMask:FREQuency[n]:SPAN[m] <freq></freq>	44
[:SENSe]:SEMask:FREQuency[n]:SPAN[m]?	44
[:SENSe]:SEMask:FREQuency[n]:STEP <freq></freq>	45
[:SENSe]:SEMask:FREQuency[n]:STEP:AUTO OFF ON 0 1	45
[:SENSe]:SEMask:FREQuency[n]:STEP:AUTO?	45
[:SENSe]:SEMask:FREQuency[n]:STEP?	45
[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth BWIDth <res_bw>,<res_bw>,<res_bw>,<res_bw></res_bw></res_bw></res_bw></res_bw>	46
[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth BWIDth:AUTO OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1	47
[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth BWIDth:AUTO?44	47
[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth BWIDth:IMULti <integer>,<integer>,<integer>,<integer>,<integer>,<integer></integer></integer></integer></integer></integer></integer>	48
[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth BWIDth:IMULti?44	48
[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth BWIDth?44	46
[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STARt <f_offset>,<f_offset>,<f_offset>,<f_offset>, description (44)</f_offset></f_offset></f_offset></f_offset>	49
[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STARt?44	49
[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STEP <f_offset>,<f_offset>,<f_offset>,<f_offset>,<f_offset>4</f_offset></f_offset></f_offset></f_offset></f_offset>	5 0
[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STEP:AUTO OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1	50
[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STEP:AUTO?	5 0
[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STEP?	5 0
[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STOP <f_offset>,<f_offset>,<f_offset>,<f_offset>,<f_offset>,</f_offset></f_offset></f_offset></f_offset></f_offset>	51
[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STOP?	

[:SENSe]:SEMask:OFFSet:LIST[m]:RATTenuation <rel_power>,<rel_power>,<rel_power>,</rel_power></rel_power></rel_power>
[:SENSe]:SEMask:OFFSet:LIST[m]:RATTenuation?
[:SENSe]:SEMask:OFFSet:LIST[m]:RAT lendation:
[:SENSe]:SEMask:OFFSet:LIST[m]:SIDE?453
[:SENSe]:SEMask:OFFSet:LIST[m]:STARt:ABSolute <abs_power>,<abs_power>,<abs_power>,<abs_power></abs_power></abs_power></abs_power></abs_power>
[:SENSe]:SEMask:OFFSet:LIST[M]:STARt:ABSolute?
[:SENSe]:SEMask:OFFSet:LIST[m]:STARt:RCARrier <rel_power>,<rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power></rel_power>
[:SENSe]:SEMask:OFFSet:LIST[m]:STARt:RCARrier?
[:SENSe]:SEMask:OFFSet:LIST[m]:STATe OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:OFFSet:LIST[m]:STATe?
[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:ABSolute <abs_power>,<abs_power>,<abs_power></abs_power></abs_power></abs_power>
[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:ABSolute:COUPle OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:ABSolute:COUPle?
[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:ABSolute?
[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:RCARrier <rel_power>,<rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power></rel_power>
[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:RCARrier:COUPle OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:RCARrier:COUPle?
[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:RCARrier?
[:SENSe]:SEMask:OFFSet:LIST[m]:TEST ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative
[:SENSe]:SEMask:OFFSet:LIST[m]:TEST?
[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth BWIDth
<pre>cres_bw>,<res_bw>,<res_bw>,<res_bw></res_bw></res_bw></res_bw></pre>
[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth BWIDth:AUTO OFF ON 0 1.OFF ON 0 1.OFF ON 0 1.OFF ON 0 1.OFF ON 0 1

[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth BWIDth:AUTO?
[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth BWIDth:IMULti <integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<integer>,<</integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer></integer>
[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth BWIDth:IMULti?
[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth BWIDth?446
[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STARt <f_offset>,<f_offset>,<f_offset>,<f_offset>, 449</f_offset></f_offset></f_offset></f_offset>
[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STARt?
[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STEP <f_offset>,<f_offset>,<f_offset>,<f_offset>, 450</f_offset></f_offset></f_offset></f_offset>
[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STEP:AUTO OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STEP:AUTO?
[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STEP?
[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STOP <f_offset>,<f_offset>,<f_offset>,<f_offset>, description (451)</f_offset></f_offset></f_offset></f_offset>
[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STOP?
[:SENSe]:SEMask:OFFSet[n]:LIST:RATTenuation <rel_power>,<rel_power>,<rel_power>,<rel_power>, 452</rel_power></rel_power></rel_power></rel_power>
[:SENSe]:SEMask:OFFSet[n]:LIST:RATTenuation?
[:SENSe]:SEMask:OFFSet[n]:LIST:SIDE BOTH NEGative POSitive, BOTH NEGative POSitive,BOTH NEGative POSitive, BOTH NEGative POSitive,BOTH NEGative POSitive
[:SENSe]:SEMask:OFFSet[n]:LIST:SIDE?
[:SENSe]:SEMask:OFFSet[n]:LIST:STARt:ABSolute <abs_power>,<abs_power>,<abs_power></abs_power></abs_power></abs_power>
[:SENSe]:SEMask:OFFSet[n]:LIST:STARt:ABSolute?
[:SENSe]:SEMask:OFFSet[n]:LIST:STARt:RCARrier <rel_power>,<rel_power>,<rel_power>,<rel_power>, 455</rel_power></rel_power></rel_power></rel_power>
[:SENSe]:SEMask:OFFSet[n]:LIST:STARt:RCARrier?
[:SENSe]:SEMask:OFFSet[n]:LIST:STATe OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:OFFSet[n]:LIST:STATe?
[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:ABSolute <abs power="">,<abs power="">,<abs power=""></abs></abs></abs>

:SENSe :SEMask:OFFSet[n]:LIST:STOP:ABSolute:COUPle OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:ABSolute:COUPle?
[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:ABSolute?
[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:RCARrier <rel_power>,<rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power></rel_power>
$[:SENSe]: SEMask: OFFSet[n]: LIST: STOP: RCARrier: COUPle \\ OFF ON 0 1, OFF$
[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:RCARrier:COUPle?
[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:RCARrier?
[:SENSe]:SEMask:OFFSet[n]:LIST:TEST ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative
[:SENSe]:SEMask:OFFSet[n]:LIST:TEST?
[:SENSe]:SEMask:REGion:LIST:BANDwidth BWIDth <res_bw>,<res_bw>,<res_bw>,<res_bw>,<.463</res_bw></res_bw></res_bw></res_bw>
[:SENSe]:SEMask:REGion:LIST:BANDwidth BWIDth:AUTO OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:REGion:LIST:BANDwidth BWIDth:AUTO?
[:SENSe]:SEMask:REGion:LIST:BANDwidth BWIDth?
[:SENSe]:SEMask:REGion:LIST:FREQuency:STARt <f_region>,<f_region>,<f_region>,<f_region></f_region></f_region></f_region></f_region>
[:SENSe]:SEMask:REGion:LIST:FREQuency:STARt?
[:SENSe]:SEMask:REGion:LIST:FREQuency:STEP <f_region>,<f_region>,<f_region>,<f_region></f_region></f_region></f_region></f_region>
[:SENSe]:SEMask:REGion:LIST:FREQuency:STEP:AUTO OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:REGion:LIST:FREQuency:STEP:AUTO?
[:SENSe]:SEMask:REGion:LIST:FREQuency:STEP?
[:SENSe]:SEMask:REGion:LIST:FREQuency:STOP <f_region>,<f_region>,<f_region>,<f_region></f_region></f_region></f_region></f_region>
[:SENSe]:SEMask:REGion:LIST:FREQuency:STOP?
[:SENSe]:SEMask:REGion:LIST:RATTenuation <rel_power>,<rel_power>,<rel_power>,</rel_power></rel_power></rel_power>
[:SENSe]:SEMask:REGion:LIST:RATTenuation?

[:SENSe]:SEMask:REGion:LIST:STARt:ABSolute
<abs_power>,<abs_power>469</abs_power></abs_power>
[:SENSe]:SEMask:REGion:LIST:STARt:ABSolute?
[:SENSe]:SEMask:REGion:LIST:STARt:RCARrier <rel_power>,<rel_power>,<rel_power>, 470</rel_power></rel_power></rel_power>
[:SENSe]:SEMask:REGion:LIST:STARt:RCARrier?
[:SENSe]:SEMask:REGion:LIST:STATe OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:REGion:LIST:STATe?
[:SENSe]:SEMask:REGion:LIST:STOP:ABSolute <abs_power>,<abs_power>,<abs_power></abs_power></abs_power></abs_power>
[:SENSe]:SEMask:REGion:LIST:STOP:ABSolute?
[:SENSe]:SEMask:REGion:LIST:STOP:RCARrier <rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power>
[:SENSe]:SEMask:REGion:LIST:STOP:RCARrier:COUPle OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:REGion:LIST:STOP:RCARrier:COUPle?
[:SENSe]:SEMask:REGion:LIST:STOP:RCARrier?
[:SENSe]:SEMask:REGion:LIST:TEST ABSolute AND OR RELative, ABSolute AND OR RELative,ABSolute AND OR RELative, ABSolute AND OR RELative,ABSolute AND OR RELative
[:SENSe]:SEMask:REGion:LIST:TEST?
[:SENSe]:SEMask:REGion[n]:LIST:BANDwidth BWIDth <res_bw>,<res_bw>,<res_bw>,<res_bw>, 463</res_bw></res_bw></res_bw></res_bw>
[:SENSe]:SEMask:REGion[n]:LIST:BANDwidth BWIDth:AUTO OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:REGion[n]:LIST:BANDwidth BWIDth:AUTO?
[:SENSe]:SEMask:REGion[n]:LIST:BANDwidth BWIDth?
[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STARt <f_region>,<f_region>,<f_region>,<f_region>, 464</f_region></f_region></f_region></f_region>
[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STARt?
[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STEP <f_region>,<f_region>,<f_region>,<f_region>,</f_region></f_region></f_region></f_region>
[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STEP:AUTO OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STEP:AUTO?

[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STEP?
[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STOP <f_region>,<f_region>,<f_region>,<f_region>,</f_region></f_region></f_region></f_region>
[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STOP?
[:SENSe]:SEMask:REGion[n]:LIST:RATTenuation <rel_power>,<rel_power>,<rel_power>,</rel_power></rel_power></rel_power>
[:SENSe]:SEMask:REGion[n]:LIST:RATTenuation?
[:SENSe]:SEMask:REGion[n]:LIST:STARt:ABSolute <abs_power>,<abs_power></abs_power></abs_power>
[:SENSe]:SEMask:REGion[n]:LIST:STARt:ABSolute?
[:SENSe]:SEMask:REGion[n]:LIST:STARt:RCARrier <rel_power>,<rel_power>,<rel_power>,<rel_power>,</rel_power></rel_power></rel_power></rel_power>
[:SENSe]:SEMask:REGion[n]:LIST:STARt:RCARrier?
[:SENSe]:SEMask:REGion[n]:LIST:STATe OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:REGion[n]:LIST:STATe?
[:SENSe]:SEMask:REGion[n]:LIST:STOP:ABSolute <abs_power>,<abs_power>,<abs_power></abs_power></abs_power></abs_power>
[:SENSe]:SEMask:REGion[n]:LIST:STOP:ABSolute:COUPle OFF ON 0 1 {,OFF ON 0 1}
[:SENSe]:SEMask:REGion[n]:LIST:STOP:ABSolute:COUPle?
[:SENSe]:SEMask:REGion[n]:LIST:STOP:ABSolute?
[:SENSe]:SEMask:REGion[n]:LIST:STOP:RCARrier <rel_power>,<rel_power>,<rel_power></rel_power></rel_power></rel_power>
[:SENSe]:SEMask:REGion[n]:LIST:STOP:RCARrier:COUPle OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1,OFF ON 0 1
[:SENSe]:SEMask:REGion[n]:LIST:STOP:RCARrier:COUPle?
[:SENSe]:SEMask:REGion[n]:LIST:STOP:RCARrier?
[:SENSe]:SEMask:REGion[n]:LIST:TEST ABSolute AND OR RELative, ABSolute AND OR RELative,ABSolute AND OR RELative, ABSolute AND OR RELative,ABSolute AND OR RELative
[:SENSe]:SEMask:REGion[n]:LIST:TEST?
[:SENSe]:SEMask:SEGMent OFFSet REGion
[:SENSe]:SEMask:SEGMent?
[:SENSe]:SEMask:SWEep:TIME <time> <no. chips="" of=""></no.></time>

[:SENSe]:SEMask:SWEep:TIME?	6
[:SENSe]:SEMask:TRIGger:SOURce EXTernal[1] EXTernal2 FRAMe IMMediate LINE 47	6
[:SENSe]:SEMask:TRIGger:SOURce?	6
[:SENSe]:SEMask:TYPE PSDRef TPRef	7
[:SENSe]:SEMask:TYPE?	7
[:SENSe]:SPECtrum:ACQuisition:PACKing AUTO LONG MEDium SHORt	8
[:SENSe]:SPECtrum:ACQuisition:PACKing?	8
[:SENSe]:SPECtrum:ADC:DITHer[:STATe] AUTO ON OFF 2 1 0	8
[:SENSe]:SPECtrum:ADC:DITHer[:STATe]?	8
[:SENSe]:SPECtrum:ADC:RANGe AUTO APEak APLock M6 P0 P6 P12 P18 P24 47	8
[:SENSe]:SPECtrum:ADC:RANGe AUTO APEak APLock NONE P0 P6 P12 P18 47	9
[:SENSe]:SPECtrum:ADC:RANGe?	9
[:SENSe]:SPECtrum:AVERage:CLEar	0
[:SENSe]:SPECtrum:AVERage:COUNt <integer></integer>	0
[:SENSe]:SPECtrum:AVERage:COUNt?	0
[:SENSe]:SPECtrum:AVERage:TCONtrol EXPonential REPeat	1
[:SENSe]:SPECtrum:AVERage:TCONtrol?	1
[:SENSe]:SPECtrum:AVERage:TYPE LOG MAXimum MINimum RMS SCALar	1
[:SENSe]:SPECtrum:AVERage:TYPE?	1
[:SENSe]:SPECtrum:AVERage[:STATe] OFF ON 0 1	1
[:SENSe]:SPECtrum:AVERage[:STATe]?	1
[:SENSe]:SPECtrum:BANDwidth BWIDth:IF:AUTO OFF ON 0 1	2
[:SENSe]:SPECtrum:BANDwidth BWIDth:IF:AUTO?	2
[:SENSe]:SPECtrum:BANDwidth BWIDth:IF:FLATness OFF ON 0 1	2
[:SENSe]:SPECtrum:BANDwidth BWIDth:IF:FLATness?	2
[:SENSe]:SPECtrum:BANDwidth BWIDth:PADC OFF ON 0 1	3
[:SENSe]:SPECtrum:BANDwidth BWIDth:PADC?	3
[:SENSe]:SPECtrum:BANDwidth BWIDth:PFFT:TYPE FLAT GAUSsian	4
[:SENSe]:SPECtrum:BANDwidth BWIDth:PFFT:TYPE?	4
[:SENSe]:SPECtrum:BANDwidth BWIDth:PFFT[:SIZE] <freq></freq>	3
[:SENSe]:SPECtrum:BANDwidth BWIDth:PFFT[:SIZE]?	3

$[:SENSe]: SPECtrum: BANDwidth \mid BWIDth [:RESolution] < freq> \dots \dots$.484
$[:SENSe]: SPECtrum: BANDwidth \mid BWIDth [:RESolution]: AUTO\ OFF \mid ON \mid 0 \mid 1 \dots \dots$.485
$[:SENSe]: SPECtrum: BANDwidth \mid BWIDth [:RESolution]: AUTO?$.485
$[:SENSe]: SPECtrum: BANDwidth \mid BWIDth [:RESolution]? \\ \ldots \\ \ldots \\ \ldots$.484
[:SENSe]:SPECtrum:DECimate[:FACTor] <integer></integer>	.485
[:SENSe]:SPECtrum:DECimate[:FACTor]?	.485
[:SENSe]:SPECtrum:FFT:LENGth <integer></integer>	.486
[:SENSe]:SPECtrum:FFT:LENGth:AUTO OFF ON 0 1	.486
[:SENSe]:SPECtrum:FFT:LENGth:AUTO?	.486
[:SENSe]:SPECtrum:FFT:LENGth?	.486
[:SENSe]:SPECtrum:FFT:RBWPoints < real>	.487
[:SENSe]:SPECtrum:FFT:RBWPoints?	.487
[:SENSe]:SPECtrum:FFT:WINDow:DELay <real></real>	.487
[:SENSe]:SPECtrum:FFT:WINDow:DELay?	.487
[:SENSe]:SPECtrum:FFT:WINDow:LENGth <integer></integer>	.488
[:SENSe]:SPECtrum:FFT:WINDow:LENGth?	.488
[:SENSe]:SPECtrum:FFT:WINDow[:TYPE] BH4Tap BLACkman FLATtop GAUSsian HAMMing HANNing KB70 KB90 KB110 UNIForm	.488
[:SENSe]:SPECtrum:FFT:WINDow[:TYPE]?	.488
[:SENSe]:SPECtrum:FREQuency:SPAN <freq></freq>	.489
[:SENSe]:SPECtrum:FREQuency:SPAN?	.489
[:SENSe]:SPECtrum:SWEep:TIME:AUTO OFF ON 0 1	.490
[:SENSe]:SPECtrum:SWEep:TIME:AUTO	.490
[:SENSe]:SPECtrum:SWEep:TIME?	.489
[:SENSe]:SPECtrum:SWEep:TIME[:VALue] <time></time>	.489
[:SENSe]:SPECtrum:TRIGger:SOURce EXTernal[1] EXTernal2 FRAMe IF LINE IMMediate RFBurst	.490
[:SENSe]:SPECtrum:TRIGger:SOURce?	.490
[:SENSe]:VOLTage:IQ:RANGe[:UPPer] <level></level>	.397
[:SENSe]:VOLTage:IQ:RANGe[:UPPer] <float 64=""> [V]</float>	.425
[:SENSe]:VOLTage:IQ:RANGe[:UPPer]?	.397
[·SENSe]·VOLTage·IQ·RANGe[·HPPer]?	425

[:SENSe]:WAVeform:ACQuistion:PACKing AUTO LONG MEDium SHORt
[:SENSe]:WAVeform:ACQuistion:PACKing?
[:SENSe]:WAVeform:ADC:DITHer[:STATe] OFF ON 0 1
[:SENSe]:WAVeform:ADC:DITHer[:STATe]?
[:SENSe]:WAVeform:ADC:FILTer[:STATe] OFF ON 0 1
[:SENSe]:WAVeform:ADC:FILTer[:STATe]?
[:SENSe]:WAVeform:ADC:RANGe AUTO APEak APLock GROund M6 P0 P6 P12 P18 P24
[:SENSe]:WAVeform:ADC:RANGe AUTO APEak APLock GROund NONE P0 P6 P12 P18
[:SENSe]:WAVeform:ADC:RANGe?
[:SENSe]:WAVeform:APERture?
[:SENSe]:WAVeform:AVERage:COUNt <integer></integer>
[:SENSe]:WAVeform:AVERage:COUNt?
[:SENSe]:WAVeform:AVERage:TCONtrol EXPonential REPeat
[:SENSe]:WAVeform:AVERage:TCONtrol?
[:SENSe]:WAVeform:AVERage:TYPE LOG MAXimum MINimum RMS SCALar
[:SENSe]:WAVeform:AVERage:TYPE?495
[:SENSe]:WAVeform:AVERage[:STATe] OFF ON 0 1
[:SENSe]:WAVeform:AVERage[:STATe]?
[:SENSe]:WAVeform:BANDwidth:RESolution]:ACTual?
[:SENSe]:WAVeform:BANDwidth BWIDth[:RESolution] <freq></freq>
$[:SENSe]: WAVe form: BANDwidth \mid BWIDth [:RESolution]: TYPE\ FLAT top \mid GAUS sian. \dots \ 497000000000000000000000000000000000000$
[:SENSe]:WAVeform:BANDwidth BWIDth[:RESolution]:TYPE?
[:SENSe]:WAVeform:BANDwidth BWIDth[:RESolution]?
[:SENSe]:WAVeform:DECimate:STATe OFF ON 0 1
[:SENSe]:WAVeform:DECimate:STATe?
[:SENSe]:WAVeform:DECimate[:FACTor] <integer></integer>
[:SENSe]:WAVeform:DECimate[:FACTor]?
[:SENSe]:WAVeform:SWEep:TIME < time>
[:SENSe]:WAVeform:SWEep:TIME?
[·SENSe]·WAVeform·TRIGger:SOIIRce EXTernal[1]]

EXTernal2 FRAMe IF IMMediate LIN	IE RFBurst	 •	498
:SENSe]:WAVeform:TRIGger:SOURce?.		 •	498

1 Introduction

This chapter provides overall information on the cdma2000 and 1xEV-DV communication systems Options B78 and 214, and describes cdma2000 and 1xEV-DV measurements made by the analyzer. Installation instructions for adding this option to your analyzer are provided in this section, in case you purchased this option separately.

What Does the Agilent PSA Series and VSA E4406A Option B78 Do?

This instrument can help determine if a cdma2000 or 1xEV-DV transmitter is working correctly. The instrument automatically makes measurements using the measurement methods and limits defined in the 3GPP2 standards (For BTS: 3GPP2 C.S0010-A ver.3/30/2001, and for MS: 3GPP2 C.S0011-A ver.3/30/2001. For 1xEV-DV: 3GPP2 C.S0002-C ver 1.0, 5/28/2002). For example, the documents include standardized test methods for the measurement of power in a carrier, a spectrum emission mask, intermodulation, and other critical measurements. The detailed results displayed by the measurements allow you to analyze cdma2000 and 1xEV-DV system performance. You may alter the measurement parameters for specialized analysis.

For infrastructure test, the instrument will test base station transmitters in a non-interfering manner by means of a coupler or power splitter.

This instrument makes the following measurements:

- Channel Power
- Adjacent Channel Power Ratio (ACPR)
- Intermodulation
- Spectrum Emission Mask
- Occupied Bandwidth
- Code Domain Power
- Modulation Accuracy (Composite Rho)
- QPSK EVM
- Power Statistics CCDF
- Spectrum (Frequency Domain)
- Waveform (Time Domain)

36 Chapter 1

Installing Optional Measurement Personalities

When you install a measurement personality, you need to follow a three step process:

- 1. Determine whether your memory capacity is sufficient to contain all the options you want to load. If not, decide which options you want to install now, and consider upgrading your memory. Details follow in "Do You Have Enough Memory to Load All Your Personality Options?" on page 37.
- 2. Install the measurement personality firmware into the instrument memory. Details follow in "Loading an Optional Measurement Personality" on page 41.
- 3. Enter a license key that activates the measurement personality. Details follow in "Obtaining and Installing a License Key" on page 42.

Adding measurement personalities requires the purchase of an upgrade kit for the desired option. The upgrade kit contains the measurement personality firmware and an entitlement certificate that is used to generate a license key from the internet website. A separate license key is required for each option on a specific instrument serial number and host ID.

For the latest information on Agilent Spectrum Analyzer options and upgrade kits, visit the following web location:

http://www.agilent.com/find/sa_upgrades

Do You Have Enough Memory to Load All Your Personality Options?

If you do not have memory limitations then you can skip ahead to the next section "Loading an Optional Measurement Personality" on page 41. If after installing your options you get error messages relating to memory issues, you can return to this section to learn more about how to optimize your configuration.

If you have 64 MBytes of memory installed in your instrument, you should have enough memory to install at least four optional personalities, with plenty of memory for data and states.

The optional measurement personalities require different amounts of memory. So the number of personalities that you can load varies. This is also impacted by how much data you need to save. If you are having memory errors you must swap the applications in or out of memory as needed. If you only have 48 MBytes of memory, you can upgrade your

Chapter 1 37

Installing Optional Measurement Personalities

hardware to 64 MBytes.

Additional memory can be added to any PSA Series analyzer by installing Option 115. With this option installed, you can install all currently available measurement personalities in your analyzer and still have memory space to store more state and trace files than would otherwise be possible.

To see the size of your installed memory for PSA Series Spectrum Analyzers:

- 1. Ensure that the spectrum analyzer is in spectrum analyzer mode because this can affect the screen size.
- 2. Press System, More, Show Hdwr.
- 3. Read Flash Memory size in the table. If Option 115 is installed (PSA only), the table will also show Compact Flash Type and Compact Flash Size.

PSA Flash Memory Size	Available Memory Without Option B7J and Option 122 or 140	Available Memory With Option B7J and Option 122 or 140
64 Mbytes	32.5 MBytes	30.0 MBytes
48 Mbytes	16.9 MBytes	14.3 MBytes

PSA Compact Flash	Available Additional Memory for	
Memory Size	Measurement Personalities	
512 Mbytes (Opt. 115)	512 MBytes	

To see the size of your installed memory for E4406A Transmitter Testers:

- 1. Press the System key, MORE (1 of 3), and MORE (2 of 3) keys.
- 2. Read the File System Key The total of the entries for Used and Free memory will total the installed flash memory, either 48 or 64 MBytes.

If you have 48 MBytes of memory, and you want to install more than 3 optional personalities, you may need to manage your memory resources. The following section, "How to Predict Your Memory Requirements" on page 39, will help you decide how to configure your installed options to provide optimal operation.

How to Predict Your Memory Requirements

If you plan to install many optional personalities, you should review your memory requirements, so you can determine whether you have enough memory (unless you have a PSA Series with Option 115). There is an Agilent "Memory Calculator" available online that can help you do this, or you can make a calculated approximation using the information that follows. You will need to know your instrument's installed memory size as determined in the previous section and then select your desired applications.

NOTE

If you have a PSA Series analyzer with Option 115, there is adequate memory to install all of the available optional personalities in your instrument.

To calculate the available memory on your E4406, see: http://sa.tm.agilent.com/E4406A/memory/

To calculate the available memory on your PSA, see: http://sa.tm.agilent.com/PSA/memory/

Select the "Memory Calculator" link. You can try any combination of available personalities to see if your desired configuration is compatible with your installed memory.

NOTE

For PSA: After loading all your optional measurement personalities, you should have a reserve of ~2 MBytes memory to facilitate mode switching. Less available memory will increase mode switching time. For example, if you employ excessive free memory by saving files of states and/or data, your mode switching time can increase to more than a minute.

You can manually estimate your total memory requirements by adding up the memory allocations described in the following steps. Compare the desired total with the available memory that you identified in the previous section.

- 1. Program memory Select option requirements from the table "Measurement Personality Options and Memory Required" on page 40.
- 2. For PSA only: shared libraries require 7.72 MBytes
- 3. For PSA only: recommended mode swap space is 2 MBytes
- 4. Screens .gif files need 20-25 kBytes each
- 5. State memory State file sizes range from 21 kB for SA mode to 40 kB for W-CDMA. The state of every mode accessed since power-on will be saved in the state file. File sizes can exceed 150 kB each when several modes are accessed, for each state file saved.

TIP

State memory retains settings for all states accessed before the **Save State** command. To reduce this usage to a minimum, reduce the modes accessed before the **Save State** is executed. You can set the PSA to boot into a selected

Chapter 1 39

mode by accessing the desired mode, then pressing the **System**, **Power On/Preset**, **Power On** keys and toggle the setting to **Last**.

Measurement Personality Options and Memory Required

Personality Options for PSA Series Spectrum Analyzers ^a	Option	File Size (PSA Rev: A.10)
cdmaOne measurement personality	BAC	1.91 Mbytes
NADC and PDC measurement personalities (not available separately)	BAE	2.43 Mbytes
W-CDMA or W-CDMA, HSDPA, HSUPA measurement personality	BAF, 210	5.38 Mbytes ^b
cdma2000 or cdma2000 w/ 1xEV-DV measurement personality	B78, 214	4.00 Mbytes ^b
1xEV-DO measurement personality	204	5.61 Mbytes ^b
GSM (with EDGE) measurement personality	202	3.56 Mbytes ^b
Shared measurement library ^b	n/a	7.72 Mbytes
Phase Noise measurement personality	226	2.82 Mbytes ^c
Noise Figure measurement personality	219	4.68 Mbytes ^c
Basic measurement personality with digital demod hardware	B7J	Cannot be deleted (2.64 Mbytes)
Programming Code Compatibility Suite ^d (8560 Series, 8590 Series, and 8566/8568)	266	1.18 Mbytes ^c
TD-SCDMA Power measurement personality	211	5.47 Mbytes ^c
TD-SCDMA Modulation Analysis or TD-SCDMA Modulation Analysis w/ HSDPA/8PSK measurement personality	212, 213	1.82 Mbytes
Flexible Digital Modulation Analysis	241	2.11 Mbytes ^b
WLAN measurement personality	217	3.24 Mbytes ^b
External Source Control	215	0.72 Mbytes ^c
Measuring Receiver Personality	233	2.91 Mbytes ^b
(available with Option 23A - Trigger support for AM/FM/PM and Option 23B - CCITT filter)		
EMC Analyzer	239	4.06 Mbytes ^b

- a. Available as of the print date of this guide.
- b. Many PSA Series personality options use a 7.72 Mbyte shared measurement library. If you are loading multiple personalities that use this library, you only need to add this memory allocation once.
- c. Shared measurement library allocation not required.

d. This is a no charge option that does not require a license key.

Personality Options for E4406A Transmitter Tester ^a	Option	File Size (E4406A Rev: A.10)
cdmaOne measurement personality	BAC	1.82 Mbytes
NADC measurement personality	BAE	1.10 Mbytes
PDC measurement personality	BAE	1.23 Mbytes
W-CDMA or W-CDMA, HSDPA, HSUPA measurement personality	BAF, 210	5.00 Mbytes
cdma2000 or cdma2000 w/ 1xEV-DV measurement personality	B78, 214	3.88 Mbytes
1xEV-DO measurement personality	204	4.84 Mbytes
GSM (with EDGE) measurement personality	202	3.56 Mbytes
GSM measurement personality	ВАН	2.51 Mbytes
EDGE upgrade from BAH measurement personality	252 (202)	3.56 Mbytes
iDEN measurement personality	HN1	2.10 Mbytes
WiDEN measurement personality	HN1	1.58 Mbytes
Baseband I/Q Inputs	B7C	n/a (hardware only)

a. Available as of the print date of this guide.

Memory Upgrade Kits

The PSA 64 MByte Memory Upgrade kit part number is E4440AU-ANE. The PSA Compact Flash Upgrade kit part number is E4440AU-115.

The VSA 64 MByte Memory Upgrade kit part number is E4406AU-ANE.

For more information about memory upgrade kits contact your local sales office, service office, or see:

http://www.agilent.com/find/sa upgrades

Loading an Optional Measurement Personality

You must use a PC to load the desired personality option into the instrument memory. Loading can be done from a firmware CD-ROM or by downloading the update program from the internet. An automatic loading program comes with the files and runs from your PC.

You can check the Agilent internet website for the latest PSA firmware versions available for downloading:

Chapter 1 41

http://www.agilent.com/find/psa_firmware

You can check the Agilent internet website for the latest E4406 firmware versions available for downloading:

http://www.agilent.com/find/e4406a firmware

NOTE

When you add a new option, or update an existing option, you will get the updated versions of all your current options as they are all reloaded simultaneously. This process may also require you to update the instrument core firmware so that it is compatible with the new option.

Depending on your installed hardware memory, you may not be able to fit all of the available measurement personalities in instrument memory at the same time. You may need to delete an existing option file from memory and load the one you want. Use the automatic update program that is provided with the files. Refer to the table showing "Measurement Personality Options and Memory Required" on page 40. The approximate memory requirements for the options are listed in this table. These numbers are worst case examples. Some options share components and libraries, therefore the total memory usage of multiple options may not be exactly equal to the combined total.

Obtaining and Installing a License Key

If you purchase an optional personality that requires installation, you will receive an "Entitlement Certificate" which may be redeemed for a license key specific to one instrument. Follow the instructions that accompany the certificate to obtain your license key.

To install a license key for the selected personality option, use the following procedure:

NOTE

You can also use this procedure to reinstall a license key that has been deleted during an uninstall process, or lost due to a memory failure.

For PSA:

- 1. Press **System**, **More**, **More**, **Licensing**, **Option** to accesses the alpha editor. Use this alpha editor to enter letters (upper-case), and the front-panel numeric keys to enter numbers for the option designation. You will validate your option entry in the active function area of the display. Then, press the **Enter** key.
- 2. Press **License Key** to enter the letters and digits of your license key. You will validate your license key entry in the active function area of the display. Then, press the **Enter** key.
- 3. Press the Activate License key.

For E4406:

1. Press System, More, More, Install, Choose Option to accesses the alpha

editor. Use this alpha editor to enter letters (upper-case), and the front-panel numeric keys to enter numbers for the option designation. You will validate your option entry in the active function area of the display. Then, press the **Done** key.

NOTE

Before you enter the license key for the EDGE Retrofit Option 252, you must already have entered the license key for the GSM Option BAH.

- 2. Press **License Key** to enter the letters and digits of your license key. You will validate your license key entry in the active function area of the display. Then, press the **Done** key.
- 3. Press the **Install Now** key. The message "New option keys become active after reboot." will appear, along with the **Yes/No** menu: press the **Yes** key and cycle the instrument power off and then on to complete your installation process, or press the **No** key to cancel the installation process.

Viewing a License Key

Measurement personalities purchased with your instrument have been installed and activated at the factory before shipment. The instrument requires a **License Key** unique to every measurement personality purchased. The license key is a hexadecimal number specific to your measurement personality, instrument serial number and host ID. It enables you to install, or reactivate that particular personality.

Use the following procedure to display the license key unique to your personality option that is already installed in your PSA:

Press System, More, More, Licensing, Show License. The System, Personality key displays the personalities loaded, version information, and whether the personality is licensed.

Use the following procedure to display the license key unique to your personality option that is already installed in your E4406:

Press System, More, More, Install, Choose Option to enter the letters and numbers for the option you want. You can see the key on the License Key menu key. Press the Done key.

NOTE

You will want to keep a copy of your license key in a secure location. Press **System**, **More**, then **Licensing**, **Show License Show System**, and print out a copy of the display that shows the license numbers. If you should lose your license key, call your nearest Agilent Technologies service or sales office for assistance.

Chapter 1 43

Using the Delete License Key on PSA

This key will make the option unavailable for use, but will not delete it from memory. Write down the 12-digit license key for the option before you delete it. If you want to use that measurement personality later, you will need the license key to reactivate the personality firmware.

NOTE

Using the **Delete License** key does not remove the personality from the instrument memory, and does not free memory to be available to install another option. If you need to free memory to install another option, refer to the instructions for loading firmware updates located at the URL: http://www.agilent.com/find/psa/

- 1. Press **System**, **More**, **More**, **Licensing**, **Option**. Pressing the **Option** key will activate the alpha editor menu. Use the alpha editor to enter the letters (upper-case) and the front-panel numeric keyboard to enter the digits (if required) for the option, then press the **Enter** key. As you enter the option, you will see your entry in the active function area of the display.
- 2. Press **Delete License** to remove the license key from memory.

Using the Uninstall Key on E4406A

This key will make the option unavailable for use, but will not delete it from memory. The message "Application Not Licensed" will appear in the Status/Info bar at the bottom of the display. Record the 12-digit license key for the option before you delete it. If you want to use that measurement personality later, you will need the license key to reactivate the personality firmware.

NOTE

Using the **Uninstall** key does not remove the personality firmware from the instrument memory, and does not free memory to be available to install another option. If you need to free memory to install another option, refer to the instructions for loading firmware updates available at the URL: http://www.agilent.com/find/ysa/

1. Press System, More(1 of 3), More(2 of 3), Uninstall, Choose Option to access the alpha editor. Use this alpha editor to enter the letters (upper-case), and the front-panel numeric keys to enter the numbers (if required) for the installed option. You will validate your option entry in the active function area of the display. Then, press the Done key.

- 2. Pressing the **Uninstall Now** key will activate the **Yes/No** menu: press the **Yes** key to continue your uninstall process, or press the **No** key to cancel the uninstall process.
- 3. Cycle the instrument power off and then on to complete the uninstall process.

Ordering Optional Measurement Personalities

When you order a personality option, you will receive an entitlement certificate. Then you will need to go to the Web site to redeem your entitlement certificate for a license key. You will need to provide your instrument serial number and host ID, and the entitlement certificate number.

Required Information:	Front Panel Key Path:
Model #: (Ex. E4440A)	
Host ID:	System, Show System
Instrument Serial Number:	System, Show System

Chapter 1 45

ntroduction

2 Making Measurements

This chapter describes procedures used for making measurements of cdma2000 and 1xEV-DV BTS or MS. Instructions to help you set up and perform the measurements are provided, and examples of cdma2000 measurement results are shown.

cdma2000 and 1xEV-DV Measurements

This chapter details all cdma2000 and 1xEV-DV measurements available by pressing the **MEASURE** key.

All the measurements below are one-button measurements. When you press the key to select a measurement it will become active, using settings and displays unique to that measurement. Data acquisition will automatically begin when trigger requirements, if any, are met.

```
"Channel Power Measurements" on page 56
```

A partial list of error messages and troubleshooting hints is given in the following section below. For a complete listing of all error messages, refer to the "Instrument Messages and Functional Tests" manual for your instrument.

"If You Have a Problem" on page 107

[&]quot;ACPR Measurements" on page 51

[&]quot;Code Domain Measurements" on page 59

[&]quot;Intermodulation Measurements" on page 65

[&]quot;Modulation Accuracy (Composite Rho) Measurements" on page 68

[&]quot;Occupied Bandwidth Measurements" on page 73

[&]quot;Power Stat CCDF Measurements" on page 76

[&]quot;QPSK EVM Measurements" on page 79

[&]quot;Spectrum (Frequency Domain) Measurements" on page 84

[&]quot;Spectrum Emission Mask Measurements" on page 88

[&]quot;Waveform (Time Domain) Measurements" on page 92

[&]quot;Using Option B7C Baseband I/Q Inputs" on page 97

[&]quot;Using Basic Mode" on page 106

Setting up and Making a Measurement

Making the Initial Signal Connection

CAUTION

Before connecting a signal to the instrument, make sure the instrument can safely accept the signal level provided. The signal level limits are marked next to the connectors on the front panel.

See "Input Key Menu" for details on selecting input ports and setting internal attenuation to prevent overloading the instrument.

For PSA only: The "Input Key Menu" also provides details of the internal preamplifier (Int Preamp) operation.

Using Instrument Mode and Measurement Presets

If you want to set your current measurement personality to a known, factory default state, press **Preset**. This initializes the instrument by returning the mode setup and all of the measurement setups in the mode to the factory default parameters.

NOTE

For PSA, note that pressing the **Preset** key will switch instrument modes unless the type of preset is selected under **System**, **Power On/Preset** is set to **Mode** or **Save User Preset**.

To preset only the parameters that are specific to an active, selected measurement, press Meas Setup, then Restore Meas Defaults. Restore Meas Defaults will return all the measurement setup parameters to the factory defaults, but only for the currently selected measurement. The Restore Meas Defaults key may not appear on the first page of the Meas Setup menu. If not, press More until the key is available.

The 3 Steps to Set Up and Make Measurements

All measurements need to be set up in 3 steps: first at the Mode level, second at the Measurement level, then finally the result display may be adjusted.

1. Select and Set Up the Mode

Press MODE - All licensed, installed Modes available are shown. Press cdma2000 or cdma2000 w/1xEV-DV, or select Basic mode to make measurements of signals with non-standard formats.

Press **Mode Setup** - Make any required adjustments to the mode settings. These settings apply to all measurement in the mode.

2. Select and Set Up the Measurement

Press **MEASURE** - Select a specific measurement to be performed (for example. **ACP**, **Spectrum** or **Waveform**). The measurement begins as soon as any required trigger conditions are met. The resulting data is shown on the display or is available for export.

Press **Meas Setup -** Make any adjustments as required to the selected measurement settings. The settings only apply to this measurement.

3. Select and Set Up a View of the Results

Press **Trace/View** - Select a display format for the current measurement data. Depending on the mode and measurement selected, other graphical and tabular data presentations may be available. **X-Scale** and **Y-Scale** adjustments may also be made now.

NOTE

A setting may be reset at any time, and will be in effect on the next measurement cycle or View.

Step	Primary Key	Setup Keys	Related Keys
1. Select & set up a Mode	MODE	Mode Setup, Input (E4406A), Input/Output (PSA), FREQUENCY Channel	System
2. Select & set up a Measurement	MEASURE	Meas Setup	Meas Control, Restart
3. Select & set up a View of the Results	View/Trace (E4406A), Trace/View (PSA)	SPAN X Scale, AMPLITUDE Y Scale, Display, Next Window, Zoom	$\label{eq:file_power} \begin{aligned} & \text{File, Save, Print,} \\ & \text{Print Setup, Marker,} \\ & \text{Search } (E4406A), \\ & \text{Peak Search } (PSA) \end{aligned}$


ACPR Measurements

This section explains how to make an adjacent channel power ratio (ACPR) measurement on a cdma2000 mobile station. ACPR is a measurement of the amount of interference, or power, in an adjacent frequency channel. The results are displayed as a bar graph or as spectrum data, along with measurement data at specified offsets.

Configuring the Measurement System

The mobile station (MS) under test has to be set to transmit the RF power remotely through the system controller. This transmitting signal is connected to the instruments RF input port. Connect the equipment as shown.

Figure 2-1 Adjacent Channel Power Ratio Measurement System



- 1. Using the appropriate cables, adapters, and circulator, connect the output signal from the MS to the RF input port of the instrument.
- 2. Connect the base transmission station simulator or signal generator to the MS through a circulator to initiate a link constructed with the sync and pilot channels, if required.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the MS through the serial bus cable to control the MS operation.

Setting the MS

From the base transmission station simulator and the system controller, set up a call using Rate Set 1 Fundamental Code Channel loopback mode (Service Option 2) with 9600 bps data rate only required for the MS to transmit the RF power as follows:

MS: Band Class 1, Block Designator A, Class III

Frequency: 1855.000 MHz (preferred set channel number 100)

 $(= 100 \times 0.050 + 1850.000 \text{ MHz})$


Output Power: -3 dBW (0.5 W) controlled by '0' power control bits

Measurement Procedure

- **Step 1.** Press the **Preset** key to preset the instrument.
- **Step 2.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- **Step 3.** Press the Mode Setup, Radio, Device to toggle the device to MS.
- **Step 4.** Press the **FREQUENCY Channel**, **1855**, **MHz** keys to set the center frequency to 1,855.000 MHz.
- **Step 5.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the **Input/Output**, **External RF Atten** keys, enter a value for **MS** or **BTS**, then press the **dB** key to allow the instrument to correct for the external attenuation.
- **Step 6.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.

Step 7. Press the **MEASURE**, **ACPR** keys to initiate the adjacent channel leakage power ratio measurement.


Figure 2-2 ACPR Measurement Results - Bar Graph (Default) View



The ACPR-FFT Bar Graph measurement result should look like the above figure. The bar graph (referenced to the total power) and a text window are displayed. The text window shows the absolute total power reference, while the lower and upper offset channel power levels are displayed in both absolute and relative readings.


Step 8. Press the View/Trace, Spectrum keys to see the ACPR-FFT: Spectrum graph with the bandwidth marker lines in the graph window. The corresponding measured data are also shown in the text window.

Figure 2-3 ACPR-FFT Measurement Results - Spectrum Graph View



Step 9. Press the **Meas Setup**, **More (1 of 2)**, **Sweep Type** keys to select **Swp**. The ACPR-SWP: Spectrum measurement speed is slower with the narrower resolution bandwidth, but the measurement accuracy is improved.

Figure 2-4 ACPR-SWP Measurement Results - Spectrum Graph View



Step 10. Press the **Meas Setup**, **More (2 of 2)** keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107.


Channel Power Measurements

This section explains how to make a channel power measurement on a cdma2000 mobile station. This test measures the total RF power present in the channel. The results are displayed graphically as well as in total power (dB) and power spectral density (dBm/Hz).

Configuring the Measurement System

The mobile station (MS) under test has to be set to transmit the RF power remotely through the system controller. This transmitting signal is connected to the instruments RF input port. Connect the equipment as shown.

Figure 2-5 Channel Power Measurement System



- 1. Using the appropriate cables, adapters, and circulator, connect the output signal from the MS to the RF input port of the instrument.
- 2. Connect the base transmission station simulator or signal generator to the MS through a circulator to initiate a link constructed with the sync and pilot channels, if required.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the MS through the serial bus cable to control the MS operation.

Setting Up the MS

From the base transmission station simulator and the system controller, set up a call using Rate Set 1 Fundamental Code Channel loopback mode (Service Option 2) with 9600 bps data rate only required for the MS to transmit the RF power as follows:

MS: Band Class 1, Block Designator A, Class III

Frequency: 1855.000 MHz (preferred set channel number 100)

 $(= 100 \times 0.050 + 1850.000 \text{ MHz})$


Output Power: -3 dBW (0.5 W) controlled by '0' power control bits

Measurement Procedure

- **Step 1.** Press the **Preset** key to preset the instrument.
- **Step 2.** Press the **System**, **Reference**, **Freq Ref** keys to toggle the frequency reference to EXT, if required. In the annunciator bar you will see EXT REF displayed in green.
- **Step 3.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- **Step 4.** Press the Mode Setup, Radio, Device to toggle the device to MS.
- **Step 5.** Press the **FREQUENCY Channel**, **1855**, **MHz** keys to set the center frequency to 1,855.000 MHz.
- **Step 6.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the **Input/Output**, **External RF Atten** keys, enter a value for **MS** or **BTS**, then press the **dB** key to allow the instrument to correct for the external attenuation.
- **Step 7.** If DUT is **BTS**, set **Sync Type**. If Transmit Diversity (**TxDiv**) is employed by **BTS**, set the instrument to synchronize with antenna2 as well as antenna1 by selecting **TxDiv F-PCICH**. This selection is only available when **Radio**, **Device** is set to **BTS**.
- **Step 8.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.

Step 9. Press the **MEASURE**, **Channel Power** keys to initiate the channel power measurement.

Figure 2-6 Channel Power Measurement Results



The Channel Power measurement result should look like the above figure. The graph window and the text window showing the absolute power and its mean power spectral density values are displayed.

Step 10. Press the **Meas Setup**, **More (1 of 2)** keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107.


Code Domain Measurements

This section explains how to make a code domain measurement on a cdma2000 mobile station. This is the measurement of the power levels of the spread channels in composite RF channels, relative to the total power within the 3.840 MHz channel bandwidth centered at the center frequency.

Configuring the Measurement System

The mobile station (MS) under test has to be set to transmit the RF power remotely through the system controller. This transmitting signal is connected to the instruments RF input port. Connect the equipment as shown.

Figure 2-7 Code Domain Power Measurement System



- 1. Using the appropriate cables, adapters, and circulator, connect the output signal of the MS to the RF input of the instrument.
- 2. Connect the base transmission station simulator or signal generator to the MS through a circulator to initiate a link constructed with sync and pilot channels, if required.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the MS through the serial bus cable to control the MS operation.

Setting the MS

From the base transmission station simulator and the system controller, set up a call using Rate Set 1 Fundamental Code Channel loopback mode (Service Option 2) with 9600 bps data rate only required for the MS to transmit the RF power as follows:

MS: Band Class 1, Block Designator A, Class III

Long Code Mask 0000000000

Frequency: 1855.000 MHz (preferred set channel number 100)

 $(= 100 \times 0.050 + 1850.000 \text{ MHz})$

Output Power: -3 dBW (0.5 W) controlled by '0' power control bits

Measurement Procedure

Step 1. Press the **Preset** key to preset the instrument.

- **Step 2.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- **Step 3.** Press the Mode Setup, Radio, Device to toggle the device to MS.
- **Step 4.** Press the **FREQUENCY Channel**, **1855**, **MHz** keys to set the center frequency to 1,855.000 MHz.
- **Step 5.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the **Input/Output**, **External RF Atten** keys, enter a value for **MS** or **BTS**, then press the **dB** key to allow the instrument to correct for the external attenuation.
- **Step 6.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.

Step 7. Press the MEASURE, More (1 of 2), Code Domain, Meas Setup, More (1 of 3), Long Code Mask, 0000000000 keys to initiate the code domain measurement.


Figure 2-8 Code Domain Power Measurement Results - Power Graph (Default) View



The Code Domain: Power measurement result should look like the above figure. The graph window and a text window is displayed. The text window shows the total power level along with the relative power levels of the various channels.


Step 8. Press the View/Trace, I/Q Error (Quad View) keys to display a combination view of the magnitude error, phase error, EVM graph windows, and the modulation summary results window as shown below:

Figure 2-9 Code Domain Power Measurement Results - I/Q Error Quad View



Step 9. Press the **Code Domain (Quad View)** key to display a combination view of the code domain power, symbol power, and I/Q symbol polar vector graph windows, and the code domain summary results window as shown below:

Figure 2-10 Code Domain Power Measurement Results - Code Domain Quad View



Step 10. Press the **Demod Bits** key to display a combination view of the code domain power, symbol power graph windows, and the I/Q demodulated bit stream data for the symbol power slots selected by the measurement interval and measurement offset parameters.

Figure 2-11 Code Domain Power Measurement Results - Demod Bits View



- **Step 11.** To make a measurement repeatedly, press **Meas Control**, **Measure** to toggle the setting from **Single** to **Cont**.
- **Step 12.** Press the Meas Setup, More (1 of 3), More (2 of 3) keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107 or the "Instrument Messages and Functional Tests" manual.


Intermodulation Measurements

This section explains how to measure cdma2000 intermodulation products. The instrument, by default, measures the third- and fifth-order intermodulation products of the base frequency signal. Either two-tone or transmit intermodulation products are automatically identified.

Configuring the Measurement System

The base transmission station (BTS) under test has to be set to transmit the RF power remotely through the system controller. The cdma2000 modulated interference signal is injected at the antenna output port of the BTS through an amplifier and circulator. The transmitting signal from the BTS is summed with the interferer and connected to the instruments RF input port. Connect the equipment as shown.

Figure 2-12 Intermodulation Product Measurement System



- 1. Using appropriate amplifier, circulators, etc., connect a cdma2000 carrier interference signal to the output connector of the BTS.
- 2. Connect the circulator output signal to the RF input port of the instrument through an attenuator.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the BTS with the serial bus cable.

Setting the BTS and Signal Generator

From the system controller, perform all of the functions required for the BTS to transmit the RF signal. Also set the signal generator to output the 3 MHz offset carrier signal to make an intermodulation measurement with the transmit IM and tone signals.

• BTS (transmit intermodulation signal)

Frequency: 1,935.000 MHz (preferred set channel number 100)

 $(= 100 \times 0.050 + 1930.000 \text{ MHz})$

Output Power: Specified maximum output power level

• Signal Generator (interference carrier signal)

Frequency: 1,938.000 MHz (= 160 channel number)

Signal: CW (unmodulated carrier)

Output Power: Same level to the BTS output power at the BTS


antenna output port

Measurement Procedure

- **Step 1.** Press the **Preset** key to preset the instrument.
- **Step 2.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- Step 3. Press the Mode Setup, Radio, Device to toggle to BTS.
- **Step 4.** Press the **FREQUENCY Channel**, **1935**, **MHz** keys to set the center frequency to 1,935.000 MHz.
- **Step 5.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the Input/Output, External RF Atten keys, enter a value for MS or BTS, then press the dB key to allow the instrument to correct for the external attenuation.
- **Step 6.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.

Step 7. Press the **MEASURE**, **Intermod** keys to initiate the intermodulation measurement.

Figure 2-13 Intermodulation Measurement Results



The Intermodulation measurement result should look like the above figure. The intermodulation products are graphically displayed in the graph window. The absolute and relative power levels along with the lower and upper power spectral density levels are shown in the text window.

Step 8. Press the **Meas Setup**, **More (1 of 2)** keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107.


Modulation Accuracy (Composite Rho) Measurements

This section explains how to make a modulation accuracy (composite Rho) measurement on a cdma2000 mobile station. Rho is the ratio of the correlated power in a multi coded channel to the total signal power.

Configuring the Measurement System

The mobile station (MS) under test has to be set to transmit the RF power remotely through the system controller. This transmitting signal is connected to the instruments RF input port. Connect the equipment as shown.

Figure 2-14 Modulation Accuracy Measurement System



- 1. Using the appropriate cables, adapters, and circulator, connect the output signal of the MS to the RF input of the instrument.
- 2. Connect the base transmission station simulator or signal generator to the MS through a circulator to initiate a link constructed with sync and pilot channels, if required.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the MS through the serial bus cable to control the MS operation.

Setting the MS

From the base transmission station simulator and the system controller, set up a call using Rate Set 1 Fundamental Code Channel loopback mode (Service Option 2) with 9600 bps data rate only required for the MS to transmit the RF power as follows:

MS: Band Class 1, Block Designator A, Class III

Long Code Mask 0000000000

Frequency: 1855.000 MHz (preferred set channel number 100)


 $(= 100 \times 0.050 + 1850.000 \text{ MHz})$

Output Power: - 3 dBW (0.5 W) controlled by '0' power control bits

Measurement Procedure

- **Step 1.** Press the **Preset** key to preset the instrument.
- **Step 2.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- **Step 3.** Press the Mode Setup, Radio, Device to toggle the device to MS.
- **Step 4.** Press the **FREQUENCY Channel**, **1855**, **MHz** keys to set the center frequency to 1,855.000 MHz.
- **Step 5.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the **Input/Output**, **External RF Atten** keys, enter a value for **MS** or **BTS**, then press the **dB** key to allow the instrument to correct for the external attenuation.
- **Step 6.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.


- Step 7. Press the MEASURE, More (1 of 2), Mod Accuracy (Composite Rho), Meas Setup, More (1 of 2), Long Code Mask, 0000000000 keys to initiate the measurement.
- Figure 2-15 Modulation Accuracy Measurement Results Polar Vector (Default) View



The Mod Accuracy: I/Q Measured Polar Vector measurement result should look like the above figure. The measurement values for modulation accuracy are shown in the summary result window.


Step 8. Press the **View/Trace**, **I/Q Measured Polar Constln** keys to display a combination view of the I/Q measured polar constellation graph window and the modulation summary result window.

Figure 2-16 Modulation Accuracy Measurement Results - Polar Constellation View



Step 9. Press the View/Trace, I/Q Error (Quad View) keys to display a combination view of the magnitude error, phase error, and EVM graph windows, and the modulation summary result window.

Figure 2-17 Modulation Accuracy Measurement Results - I/Q Error Quad View



Step 10. Press the **Meas Setup**, **More (1 of 2)** keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107.


Occupied Bandwidth Measurements

This section explains how to make an occupied bandwidth measurement on a cdma2000 mobile station. The tester measures power across the band, and then calculates its 99.0% power bandwidth.

Configuring the Measurement System

The mobile station (MS) under test has to be set to transmit the RF power remotely through the system controller. This transmitting signal is connected to the instruments RF input port. Connect the equipment as shown.

Figure 2-18 Occupied Bandwidth Measurement System



- 1. Using the appropriate cables, adapters, and circulator, connect the output signal of the MS to the RF input of the instrument.
- 2. Connect the base transmission station simulator or signal generator to the MS through a circulator to initiate a link constructed with sync and pilot channels, if required.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the MS through the serial bus cable to control the MS operation.

Setting the MS

From the base transmission station simulator and the system controller, set up a call using Rate Set 1 Fundamental Code Channel loopback mode (Service Option 2) with 9600 bps data rate only required for the MS to transmit the RF power as follows:

MS: Band Class 1, Block Designator A, Class III

Frequency: 1855.000 MHz (preferred set channel number 100)

 $(= 100 \times 0.050 + 1850.000 \text{ MHz})$


Output Power: -3 dBW (0.5 W) controlled by '0' power control bits

Measurement Procedure

- **Step 1.** Press the **Preset** key to preset the instrument.
- **Step 2.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- **Step 3.** Press the Mode Setup, Radio, Device to toggle the device to MS.
- **Step 4.** Press the **FREQUENCY Channel**, **1855**, **MHz** keys to set the center frequency to 1,855.000 MHz.
- **Step 5.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the **Input/Output**, **External RF Atten** keys, enter a value for **MS** or **BTS**, then press the **dB** key to allow the instrument to correct for the external attenuation.
- **Step 6.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.

Step 7. Press the MEASURE, Occupied BW keys to initiate the occupied bandwidth measurement.

Figure 2-19 Occupied Bandwidth Measurement Results



The Occupied BW measurement result should look like the above figure. A graph window with text showing the occupied bandwidth and the absolute total power level are displayed.

Step 8. Press the **Meas Setup**, **More (1 of 2)** keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107.


Power Stat CCDF Measurements

This section explains how to make a power statistics CCDF measurement on a cdma2000 mobile station. Power Complementary Cumulative Distribution Function (CCDF) curves characterize the higher level power statistics of a digitally modulated signal.

Configuring the Measurement System

The mobile station (MS) under test has to be set to transmit the RF power remotely through the system controller. This transmitting signal is connected to the instruments RF input port. Connect the equipment as shown.

Figure 2-20 Power Statistics (CCDF) Measurement System



- 1. Using the appropriate cables, adapters, and circulator, connect the output signal of the MS to the RF input of the instrument.
- 2. Connect the base transmission station simulator or signal generator to the MS through a circulator to initiate a link constructed with sync and pilot channels, if required.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the MS through the serial bus cable to control the MS operation.

Making Measurements

Setting the MS

From the base transmission station simulator and the system controller, set up a call using Rate Set 1 Fundamental Code Channel loopback mode (Service Option 2) with 9600 bps data rate only required for the MS to transmit the RF power as follows:

MS: Band Class 1, Block Designator A, Class III

Frequency: 1855.000 MHz (preferred set channel number 100)

 $(= 100 \times 0.050 + 1850.000 \text{ MHz})$

Output Power: -3 dBW (0.5 W) controlled by '0' power control bits

Measurement Procedure

- **Step 1.** Press the **Preset** key to preset the instrument.
- **Step 2.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- **Step 3.** Press the Mode Setup, Radio, Device to toggle the device to MS.
- **Step 4.** Press the **FREQUENCY Channel**, **1855**, **MHz** keys to set the center frequency to 1,855.000 MHz.
- **Step 5.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the Input/Output, External RF Atten keys, enter a value for MS or BTS, then press the dB key to allow the instrument to correct for the external attenuation.
- **Step 6.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.

Step 7. Press the MEASURE, More (1 of 2), Power Stat CCDF keys to initiate the power statistics CCDF measurement.

Figure 2-21 Power Statistics CCDF Measurement Results



The CCDF measurement result should look like the above figure. The measurement result values are shown in the summary result window.

- **Step 8.** To make a measurement repeatedly, press **Meas Control**, **Measure** to toggle the setting from **Single** to **Cont**.
- **Step 9.** Press the **Meas Setup**, **More (1 of 2)** keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107.


QPSK EVM Measurements

This section explains how to make a quadrature phase shift keying (QPSK) error vector magnitude (EVM) measurement on a cdma2000 mobile station. QPSK EVM is a measure of phase and amplitude modulation quality that relates the performance of the actual signal compared to an ideal signal as a percentage, as calculated over the course of the ideal constellation.

Configuring the Measurement System

The mobile station (MS) under test has to be set to transmit the RF power remotely through the system controller. This transmitting signal is connected to the instruments RF input port. Connect the equipment as shown.

Figure 2-22 QPSK EVM Measurement System



- 1. Using the appropriate cables, adapters, and circulator, connect the output signal of the MS to the RF input of the instrument.
- 2. Connect the base transmission station simulator or signal generator to the MS through a circulator to initiate a link constructed with sync and pilot channels, if required.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the MS through the serial bus cable to control the MS operation.

Setting the MS

From the base transmission station simulator and the system controller, set up a call using Rate Set 1 Fundamental Code Channel loopback mode (Service Option 2) with 9600 bps data rate only required for the MS to transmit the RF power as follows:

MS: Band Class 1, Block Designator A, Class III

Frequency: 1855.000 MHz (preferred set channel number 100)

 $(= 100 \times 0.050 + 1850.000 \text{ MHz})$


Output Power: -3 dBW (0.5 W) controlled by '0' power control bits

Measurement Procedure

- **Step 1.** Press the **Preset** key to preset the instrument.
- **Step 2.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- **Step 3.** Press the Mode Setup, Radio, Device to toggle the device to MS.
- **Step 4.** Press the **FREQUENCY Channel**, **1855**, **MHz** keys to set the center frequency to 1855.000 MHz.
- **Step 5.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the **Input/Output**, **External RF Atten** keys, enter a value for **MS** or **BTS**, then press the **dB** key to allow the instrument to correct for the external attenuation.
- **Step 6.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.

Step 7. Press the MEASURE, More (1 of 2), QPSK EVM keys to set the instrument to initiate the QPSK EVM measurement.

Figure 2-23 QPSK EVM Measurement Results - Polar Vector (Default) View



The QPSK EVM: I/Q Measured Polar Vector measurement result should look like the above figure. The measurement values for modulation accuracy are shown in the summary result window.


Step 8. Press the View/Trace, I/Q Measured Polar Constln keys to display a combination view of the I/Q measured polar constellation graph window and the modulation summary result window.

Figure 2-24 QPSK EVM Measurement Results - Polar Constellation View



Step 9. Press the View/Trace, I/Q Error (Quad View) keys to display a combination view of the magnitude error, phase error, and EVM graph windows, and the modulation summary result window.

Figure 2-25 QPSK EVM Measurement Results - I/Q Error Quad View



Step 10. Press the **Meas Setup**, **More (1 of 2)** keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107.


Spectrum (Frequency Domain) Measurements

This section explains how to make a Spectrum measurement on a cdma2000 mobile station. An adjacent or an interfering signal can also be applied, if desired, during spectrum measurements.

Configuring the Measurement System

The mobile station (MS) under test has to be set to transmit the RF power remotely through the system controller. This transmitting signal is connected to the instruments RF input port. Connect the desired equipment as shown.

Figure 2-26 Spectrum Measurement System



- 1. Using the appropriate cables, adapters, and circulator, connect the output signal of the MS to the RF input of the instrument.
- 2. Connect the base transmission station simulator or signal generator to the MS through a circulator to initiate a link constructed with sync and pilot channels, if required.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the MS through the serial bus cable to control the MS operation.

Making Measurements

Setting the MS

From the base transmission station simulator and the system controller, set up a call using Rate Set 1 Fundamental Code Channel loopback mode (Service Option 2) with 9600 bps data rate only required for the MS to transmit the RF power as follows:

MS: Band Class 1, Block Designator A, Class III

Frequency: 1855.000 MHz (preferred set channel number 100)

 $(= 100 \times 0.050 + 1850.000 \text{ MHz})$


Output Power: -3 dBW (0.5 W) controlled by '0' power control bits

Measurement Procedure

- **Step 1.** Press the **Preset** key to preset the instrument.
- **Step 2.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- Step 3. Press the Mode Setup, Radio, Device keys to toggle the device to MS.
- **Step 4.** Press the **FREQUENCY Channel**, **1855**, **MHz** keys to set the center frequency to 1,855.000 MHz.
- **Step 5.** Press the **SPAN**, **2**, and **MHz** keys to set the measurement span to 2 MHz.
- **Step 6.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the **Input/Output**, **External RF Atten** keys, enter a value for **MS** or **BTS**, then press the **dB** key to allow the instrument to correct for the external attenuation.
- **Step 7.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.

Step 8. Press the **MEASURE** to initiate the spectrum measurement, which is the default measurement for cdma2000.

Figure 2-27 Spectrum Measurement Result - Default View




The spectrum measurement result should look like the above figure. The measurement result values are shown in the summary result window.

Step 9. To make a measurement repeatedly, press **Meas Control**, **Measure** to toggle the setting from **Single** to **Cont**.

Step 10. Press **Zoom** to enlarge the Spectrum window, or **Next Window** to select the I/Q Waveform view. When the I/Q Waveform view is selected, you may press **Zoom** to view the time domain I and Q waveforms

Figure 2-28 Spectrum Measurement - I/Q Waveform (Time Domain) Result



Step 11. Press the **Meas Setup**, **More (1 of 2)** keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107.


Spectrum Emission Mask Measurements

This section explains how to make a spectrum emission mask measurement (SEM) on a cdma2000 mobile station. SEM compares the total power level within the defined carrier bandwidth and the given offset channels on both sides of the carrier frequency to levels allowed by the standard. Results of the measurement of each offset segment are viewable separately.

Configuring the Measurement System

The mobile station (MS) under test has to be set to transmit the RF power remotely through the system controller. This transmitting signal is connected to the instruments RF input port. Connect the equipment as shown.

Figure 2-29 Spectrum Emission Mask Measurement System



- 1. Using the appropriate cables, adapters, and circulator, connect the output signal from the MS to the RF input port of the instrument.
- 2. Connect the base transmission station simulator or signal generator to the MS through a circulator to initiate a link constructed with the sync and pilot channels, if required.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the MS through the serial bus cable to control the MS operation.

Making Measurements

Setting the MS

From the base transmission station simulator and the system controller, set up a call using Rate Set 1 Fundamental Code Channel loopback mode (Service Option 2) with 9600 bps data rate only required for the MS to transmit the RF power as follows:

MS: Band Class 1, Block Designator A, Class III

Frequency: 1855.000 MHz (preferred set channel number 100)

 $(= 100 \times 0.050 + 1850.000 \text{ MHz})$


Output Power: -3 dBW (0.5 W) controlled by '0' power control bits

Measurement Procedure

- **Step 1.** Press the **Preset** key to preset the instrument.
- **Step 2.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- **Step 3.** Press the Mode Setup, Radio, Device to toggle the device to MS.
- **Step 4.** Press the **FREQUENCY Channel**, **1855**, **MHz** keys to set the center frequency to 1,855.000 MHz.
- **Step 5.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the Input/Output, External RF Atten keys, enter a value for MS or BTS, then press the dB key to allow the instrument to correct for the external attenuation.
- **Step 6.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.

Step 7. Press the MEASURE, Spectrum Emission Mask keys to initiate the spectrum emission mask measurement.


Figure 2-30 Spectrum Emission Mask Offset Measurement Results (Default)



The Spectrum Emission Mask: Spectrum (Ref: Total Pwr, Seg: Offset) result should look like the above figure. The graph window and a text window are displayed. The text window shows the reference total power and the absolute peak power levels which correspond to the frequency bands on both sides of the reference channel.

Step 8. Press the **Meas Setup**, **Spectrum Segment** keys to toggle to Region. The Spurious Emission: Spectrum (Ref: Total Pwr, Seg: Region) measurement result should look like the next figure.

Figure 2-31 Spectrum Emission Mask Region Measurement Results



Step 9. Press the **Meas Setup**, **More (1 of 2)** keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107.


Waveform (Time Domain) Measurements

This section explains how to make waveform (time domain) measurement on a cdma2000 mobile station. Measurement of I and Q modulated waveforms in the time domain disclose the voltages which comprise the complex modulated waveform of a digital signal.

Configuring the Measurement System

The mobile station (MS) under test has to be set to transmit the RF power remotely through the system controller. This transmitting signal is connected to the instruments RF input port. Connect the equipment as shown. An interfering or adjacent signal may supplied as shown.

Figure 2-32 Waveform Measurement System



- 1. Using the appropriate cables, adapters, and circulator, connect the output signal of the MS to the RF input of the instrument.
- 2. Connect the base transmission station simulator or signal generator to the MS through a circulator to initiate a link constructed with sync and pilot channels, if required.
- 3. Connect a BNC cable between the 10 MHz OUT port of the signal generator and the EXT REF IN port of the instrument.
- 4. Connect the system controller to the MS through the serial bus cable to control the MS operation.

Setting the MS

From the base transmission station simulator and the system controller, set up a call using Rate Set 1 Fundamental Code Channel

Making Measurements

loopback mode (Service Option 2) with 9600 bps data rate only required for the MS to transmit the RF power as follows:

MS: Band Class 1, Block Designator A, Class III

Frequency: 1855.000 MHz (preferred set channel number 100)

 $(= 100 \times 0.050 + 1850.000 \text{ MHz})$


Output Power: -3 dBW (0.5 W) controlled by '0' power control bits

Measurement Procedure

- **Step 1.** Press the **Preset** key to preset the instrument.
- **Step 2.** Press the MODE, More (1 of 2), cdma2000 (3GPP) or cdma2000 w/1xev-DV keys to enable the cdma2000 and 1xEV-DV measurements.
- **Step 3.** Press the Mode Setup, Radio, Device to toggle the device to MS.
- **Step 4.** Press the **FREQUENCY Channel**, **1855**, **MHz** keys to set the center frequency to 1,855.000 MHz.
- **Step 5.** If you need to use external coupling or attenuation to avoid overloading the instrument, press the **Input/Output**, **External RF Atten** keys, enter a value for **MS** or **BTS**, then press the **dB** key to allow the instrument to correct for the external attenuation.
- **Step 6.** If you need to change the scale reference, press the **AMPLITUDE Y Scale** key, enter a value for **Ref Value** key, then press the **dB** key.
- **Step 7.** Press the **AMPLITUDE Y Scale**, and down arrow keys until the waveforms are shown at a convenient voltage scale for viewing.
- **Step 8.** Press the **SPAN X Scale**, and down arrow keys until the waveforms are shown at a convenient time scale for viewing.

The I/Q Waveform measurement result should look something like the next figure. A graph window with text showing the mean power level is displayed.

Figure 2-33 Waveform (Time Domain) Signal Envelope (Default)
Measurement Result




- **Step 9.** Press the View/Trace, I/Q Waveform keys to display the I/Q Waveform view, showing the individual I and Q voltage waveforms in the time domain.
- **Step 10.** Press the **AMPLITUDE Y Scale**, and down arrow keys until the waveforms are shown at a convenient voltage scale for viewing.

Making Measurements

Step 11. Press the **SPAN X Scale**, and down arrow keys until the waveforms are shown at a convenient time scale for viewing.

The I/Q Waveform measurement result should look like the next figure. A graph window with text showing the mean power level is displayed.

Figure 2-34 Waveform (Time Domain) I/Q Waveform Measurement Result



Step 12. Press the **Marker**, **Trace**, and **I/Q Waveform** keys to activate a marker. Rotate the RPG knob until the marker is shown at a desired time in the waveform for viewing the I and Q values at the time position of the marker.

The I/Q Waveform measurement result should look something like the next figure. Marker text showing I and Q values is displayed.

Figure 2-35 Waveform (Time Domain) I/Q Waveform Measurement Result - Marker Values Displayed



- **Step 13.** To make a measurement repeatedly, press **Meas Control**, **Measure** to toggle the setting from **Single** to **Cont**.
- **Step 14.** Press the **Meas Setup**, **More (1 of 2)** keys to check the keys available to change the measurement parameters from the default condition.

If you have a problem, and get an error message, see "If You Have a Problem" on page 107.

Using Option B7C Baseband I/Q Inputs

Baseband I/Q Measurements Available for E4406A VSA Series Transmitter Tester

The following measurements can be made using Baseband I/Q inputs:

- Channel Power
- Occupied Bandwidth
- Code Domain
- Modulation Accuracy (Composite Rho)
- QPSK EVM
- Power Stat CCDF
- Spectrum (Frequency Domain)
- Waveform (Time Domain)

NOTE

The following measurements can not be made using Baseband I/Q Inputs:

- ACPR
- Intermodulation
- Spectrum Emission Mask
- Multi Carrier Power

Baseband I/Q Measurement Overview

Baseband I/Q measurements are similar to RF measurements. To avoid duplication, this section describes only the details unique to using the baseband I/Q inputs. For generic measurement details, refer to the previous "Making Measurements" sections.

To make measurements using baseband I/Q Inputs, make the following selections:

- Select a measurement that supports baseband I/Q inputs. For details see "Baseband I/Q Measurements Available for E4406A VSA Series Transmitter Tester" on page 97.
- Select the appropriate circuit location and probe(s) for measurements. For details see "Slecting Input Probes for Baseband Measurements in the Concepts chapter. .
- Select baseband I/Q input connectors. For details see Input Port Key

Menu in the Key Reference chapter.

- Select just I/Q Setup if desired. For details see IQ Setup Key Menu in the Key Reference chapter.
- Select baseband I/Q input impedance. For details see I/Q Input Z Key Menu in the Key Reference chapter.
- Select a baseband I/Q measurement results view. For details see "Baseband I/Q Measurement Result Examples" on page 98.

Baseband I/Q Measurement Result Examples


The following are examples of new measurement result displays using baseband I/Q Inputs. A notation below each example indicates the nature of the input signal.

Channel Power Measurement

There is a new view for Channel Power measurements with baseband I/Q Inputs: the Channel Power Spectrum view with 0 Hz center frequency.

This measurement is not available if Input Port menu is set to I only or Q only, as the total I/Q channel power cannot be measured.

Figure 2-36 Channel Power - Baseband I/Q Inputs



cdma2000 (Rev.8) Downlink, SR1 9 Channel, Baseband I/Q Inputs

* Agilent 08/01/01 14:57:00 cdma2000 BTS Baseband I/Q Averages: 10 Channel Power SR1 Ref LvI-4.46 dBm 10.00 dB/ I/Q Z 50**Ω** U Trig Free Center 0.0 Hz Res BW 27.857 kHz Span 2.00000 MHz **Channel Power Power Spectral Density** -9.65 dBm/1.23000 MHz -70.55 dBm/Hz

Figure 2-37 cdma2000 Channel Power - Baseband I/Q Inputs

cdma2000 (Rev.8) Downlink, SR3 9 Channel, Baseband I/Q Inputs

Occupied Bandwidth Measurement

There is one new view for Occupied Bandwidth measurements with baseband I/Q Inputs: the Occupied BW Spectrum view with 0 Hz center frequency.

* Agilent 08/01/01 15:11:42 cdma2000 BTS Baseband I/Q Averages: 10 PASS Occupied BW Ref-10.00 dBm Occupied BW 10.00 dB/ I/Q Z 50**Ω** U Trig Free CF 0.0 Hz Res BW 29.9821 kHz Span 3.75000 MHz Points 513 Total Power Occupied BW 1.2764 MHz -9.33 dBm

Figure 2-38 cdma2000 Occupied Bandwidth - Baseband I/Q Inputs

cdma2000 (Rev.8) Downlink, SR1 9 Channel, Baseband I/Q Inputs


Spectrum (Frequency Domain) Measurement

There are two new views with baseband I/Q input Spectrum measurements: the Spectrum view with 0 Hz center frequency, and the Spectrum Linear view with 0 Hz center frequency and the vertical scale in volts.


If you have I only or Q only selected as the Input Port, a Spectrum view does not have 0 Hz as the center frequency. It is displayed with 0 Hz at the left margin, similar to a conventional spectrum display, except that the start frequency remains 0 Hz regardless of Span, and the center frequency is displayed as half the Span.

Making Measurements

Figure 2-39 Spectrum View- Baseband I/Q Inputs




 $Figure \ 2\text{-}40 \qquad \quad cdma2000 \ Spectrum \ View - Baseband \ I/Q \ Inputs$




cdma2000 (Rev.8) Downlink, SR1 9 Channel, Baseband I/Q Inputs

Figure 2-41 Spectrum Linear View- Baseband I/Q Inputs



 $Figure \ 2\text{-}42 \hspace{1cm} cdma2000 \ Spectrum \ Linear \ View - Baseband \ I/Q \ Inputs$



cdma2000 (Rev.8) Downlink, SR1 9 Channel, Baseband I/Q Inputs

Baseband I/Q
Spectrum (Freq Domain)

Ref 40.0 mV
Linear Spectrum

5.00

mV

Trig
Free

CF 500.000 kHz

Basic

R L T S


R L T S

Figure 2-43 Basic Mode Spectrum I only View- Baseband I/Q Inputs


Waveform (Time Domain) Measurement

There are two new views with baseband I/Q input Waveform (Time Domain) measurements: the Linear Envelope view with the vertical scale in volts, and the I and Q Waveform view with separate windows for the I and Q traces.

Figure 2-44 Waveform Linear Envelope - Baseband I/Q Inputs



 ${\bf Figure~2\text{-}45} \qquad \quad {\bf cdma2000~Waveform~Linear~Envelope~-~Baseband~I/Q~Inputs}$



cdma2000 (Rev.8) Downlink, SR1 9 Channel, Baseband I/Q Inputs

Figure 2-46 I and Q Waveform View - Baseband I/Q Inputs





Figure 2-47 cdma2000 I and Q Waveform View - Baseband I/Q Inputs



cdma2000 (Rev.8) Downlink, SR1 9 Channel, Baseband I/Q Inputs

Using Basic Mode

Basic mode is a standard feature of E4406A Transmitter Testers, and is part of Option B7J for the PSA Series Spectrum Analyzers. Basic mode is *not* related to a particular communications standard. That is, it does not default to measurement settings that are for any specific standard. You may want to use Basic Mode if you are making measurements on a signal that is not based on a specific digital communications standard.

Basic Mode in E4406A VSA Series Transmitter Testers

There are five generic measurements available under the **MEASURE** key in Basic mode:

- Adjacent Channel Power (ACP)
- Channel Power
- Power Statistics CCDF
- Spectrum measurement (frequency domain).
- Waveform measurement (time domain)

The ACP, Channel Power, and Power Stat CCDF measurements are fully described in the VSA Series User's Guide. Please refer to that manual for complete information on these measurements.

Spectrum and Waveform Measurements

These measurements provide a spectrum measurement mode that is similar to a standard spectrum analyzer, and a waveform measurement mode that is similar to a microwave oscilloscope. Unlike those standard analyzers, these measurements are optimized for digitally modulated signals, so they can be used to output the measured I/Q data.

For your convenience, Spectrum and Waveform measurements are also available in this mode, with the same functionality, so you can refer to the sections included in this chapter for information about using them.

Basic Mode in PSA Series Spectrum Analyzers

There are three generic measurements available under the **MEASURE** key in Basic mode:

- Spectrum measurement (frequency domain).
- Waveform measurement (time domain)
- Power Statistics CCDF

These Spectrum, Waveform, and CCDF measurements are also available in this mode, with the same functionality, so you can refer to the sections included in this chapter for information about using them.

If You Have a Problem

During the execution of your measurement you may encounter problems which generate error codes. Reference to the following common errors may be helpful.

If Err is shown in the annunciator bar, press the **System**, **Show Errors** hard and soft keys to read the detailed error information.

• Measurement Instability- Low Input Signal Level

If the input signal level is too low to make a valid measurement no code domain power will be displayed in the Power graph window. In this situation, no error message can be displayed to indicate the nature of the fault. If you cannot increase the power into the tester, you need to increase the input sensitivity by adjusting the ADC range.

Press Meas Setup, More (1 of 3), More (2 of 3), Advanced, ADC Range, and then Manual keys. Increase the setting from the -6~dB (for E4406A) or None (for PSA) default to 6~dB, for example. Another option is to use the **Auto** setting (the **Auto** setting is not used as the default to improve measurement speed).

Press **Restart** to make another measurement and observe the results. Re-adjust the ADC as necessary to obtain a valid measurement.

• Error Code 16 "Input overload"

This error means that your measurement has erroneous results due to the excessive input power level. To correct this condition, the input signal level must be reduced by using the internal and/or external attenuators.

Press the Mode Setup, Input, Input Atten keys to enter an attenuation value to reduce the transmitted power from the MS. This allowable range is up to $40~\mathrm{dB}$.

If you want to attenuate more than 40 dB, connect your external attenuator between the **RF INPUT** port and the DUT. Be sure to add its attenuation value to the readings of the measurement result.

To automate this calculation, press the **Mode Setup**, **Input**, **Ext Atten** keys to enter the additional attenuation value. The allowable range is up to 100 dB. The power readings of the measurement will take into account the external attenuation value.

• Error Code 601 "Signal too noisy"

This error means that your input signal is too noisy to capture the correct I/Q components. To make a more stable measurement the trigger source may need to be set to **Frame**, for example.

• Error Code 604 "Can not correlate to input signal"

This error means that the tester has failed to find any active channels in the input signal as specified. To improve the correlation some critical parameter needs to be adjusted, like the input signal level or long code, for example.

For more details consult the chapter in this book dedicated to the measurement in question, or see the "Instrument Messages and Functional Tests" manual.


3 Key Reference

This chapter provides detailed descriptions of the keys used to set up and make cdma2000 and 1xEV-DV measurements, including **Mode Setup**, **Meas Setup**, and **MEASURE**. Keys that allow you to see different presentations of the measurement results are also described, including **View/Trace**, and **Display**, showing the associated screens.

Instrument Front Panel Highlights

The most commonly used function keys on the VSA and PSA front panels are located as shown in the illustrations below. The operation of the keys is briefly explained on the following page. Refer to your User's Guide for complete details on all keys.

Figure 3-1 Selected E4406A VSA Series Front Panel Feature Locations



CONTROL MODE Mode Setup FREQUENC' Channel nput Auto Couple SPAN X Scale AMPLITUDE Display BW/ Avg Trig Single MEASURE MEASURE . -MARKER-Restart Meas Control Source Markei IF NPUT LIC OU. **₹** 1⇔ ⇒1 Next Window (10)

Figure 3-2 Selected PSA Series Front Panel Feature Locations

Selected E4406A VSA and PSA Front-Panel Features

- 1. The **On/Off** switch toggles the AC Line power between On and Standby. A green LED will light when the instrument is On. When energized in the standby mode, a yellow LED is lit above the switch.
- 2. **FREQUENCY Channel** accesses a key menu to set the analyzer center frequency in units of Hz, kHz, MHz, or GHz, or by channel number. These parameters apply to all measurements in the current mode.
- 3. **MODE** accesses a key menu to select one of the measurement

Instrument Front Panel Highlights

- personalities installed in the instrument. Each mode is independent from all other modes.
- 4. **Mode Setup** accesses a key menu that sets parameters specific to the current mode and can affect all measurements within that mode.
- 5. **MEASURE** accesses a display key menu to initiate one of the various measurements that are specific to the current mode.
- 6. **Meas Setup** accesses the menus of test parameters that are specific to the current measurement.
- 7. **Restart** causes a measurement to start again from the initial process according to the current measurement setup parameters.
- 8. **RF INPUT** port: Type N connector for the E4406A VSA and E4443A, E4445A, and E4440A PSAs. It is a 2.4 mm connector on the E4446A and E4448A PSAs and a 3.5 mm connector on all PSAs with Opt BAB. The maximum input power level is shown next to the port.
- 9. The **Data Entry** keypad is used to enter numeric values. Keypad entries are displayed in the active function area of the screen and become valid for the current measurement upon pressing the **Enter** key or selecting a unit of measurement, depending on the parameter.
- 10.The Display Menu keys allow you either to activate a feature or to access a more detailed sub-menu. An arrow on the right side of a softkey label indicates that the key has a further selection menu. The active menu key is highlighted, however, grayed-out keys are currently unavailable for use or only show information. If a menu has multiple pages, succesive pages are accessed by pressing the **More** key located at the bottom of the menu.
- 11. Return allows you to exit the current menu and display the previous menu. If you are on the first page of a mult-page menu (a menu with (1 of 3) for example), the Return key will exit from that menu. When you activate another measurement, the return list is cleared. The Return key will not return you to a previously activated mode, nor will it alter any values you have entered in previous menus.
- 12.Baseband I/Q Inputs (E4406A Option B7C only) allow you to analyze signals at baseband frequencies. See "Using Option B7C Baseband I/Q Inputs" on page 1.
- 13.BNC Audio Input (PSA Option 233 Measuring Receiver only) provides a 100 kOhm input for audio measurements. The frequency range is 20 Hz to 250 kHz. The safe input level is 7 Vrms or 20 V DC.

Front Panel Keys

NOTE

Only front panel keys affected by selection of cdma2000 mode are described here. For a complete description of all front panel keys see the E4406A VSA or PSA Series User's Guide.

FREQUENCY Channel Key Menu

Key path: FREQUENCY Channel

NOTE

FREQUENCY Channel settings apply to all measurements in the mode.

- **Center Freq** Allows you to enter a frequency that corresponds to the desired RF channel to be measured. This is the current instrument center frequency. The range is 1.000 kHz to 4.32140 GHz with 1 Hz resolution for E4406A, however, PSA Series have different ranges.
- **CF Step** Allows you to enter a center frequency step to shift the measurement segment, and to toggle the step function between **Auto** and **Man**. If set to **Auto**, the **CF Step** value automatically changes according to the selection of the standard. The range is 1.000 kHz to 1.00000 GHz with 1 Hz resolution.

NOTE

For E4406A Option B7C, if Input Port is set to I/Q, the Center Freq and CF Step keys are disabled as the baseband I/Q signal frequencies are centered at $0~\mathrm{Hz}$.

Frequency Channel Default Setting		
FREQUENCY Channel: Center Freq CF Step	1.00000 GHz 1.25000 MHz, Auto	

MEASURE Key Menu

Key path: MEASURE

- Channel Power Press this key to make channel power measurements. This is the in-channel power measurement. The channel power graph is displayed in the graph window and both the absolute channel power and mean power spectral density are shown in the text window.
- ACPR Press this key to make adjacent channel power ratio (ACPR)
 measurements. This is the out-of-channel measurement. The
 following windows are available:

Key Reference Front Panel Keys

- Bar graph display to show a histogram of powers within the integration bandwidth
- Spectrum display to show a power distribution curve, like a swept-frequency spectrum analyzer, relative to the center frequency power of the carrier signal.

NOTE

ACPR, Intermod, and Spectrum Emission Mask are not available for E4406A Option B7C if Input Port is set to I/Q.

- Intermod Press this key to make intermodulation products measurements. Three measurement modes are available as follows:
 - Auto Automatically identifies one of two modes between two-tone or transmit intermodulation products.
 - Two-tone Measurements are made assuming two signals present in the span are the two tone signals.
 - Transmit IM Measurements are made assuming the lower frequency signal to be the modulated transmitted signal and the higher frequency signal to be the tone signal.
- Spectrum Emission Mask Press this key to make spectrum emission
 mask measurements. The measurement mask is configurable with
 flat and sloped lines according to the radio specifications. Spurious
 emission measurements can be done with some restrictions from the
 upper frequency bandwidth by selecting Region in Spectrum Segment.
- Occupied BW Press this key to make occupied bandwidth measurements. The frequency bandwidth that contains 100.0% of the total power is measured first, and then 99.0% of the frequency bandwidth is calculated as the measurement result.
- **Code Domain** Press this key to make code domain power (CDP) measurements. The amount of power in each code channel is displayed. The following windows are available:
 - Power graph and metrics to show the code domain power and the summary data
 - Quad view of the I/Q errors in graphs for the spread rate selected, and the summary data
 - Quad view of the code domain power, the selected symbol power vs. symbol rate, and the selected I/Q symbol power polar vector graphs, and the summary data
 - Triad view of the code domain power and the selected symbol power graphs, and the selected demodulated bits stream text
- Mod Accuracy (Composite Rho) Press this key to make modulation accuracy (composite rho) measurements. The input signal should contain the Pilot channel. This is essentially a code domain power

measurement with more than one active channel. The following windows are available:

- Polar vector and/or constellation graph of the I/Q demodulated signals and the summary data
- Quad view for the I/Q errors in graphs and the summary data
- Power, timing, and phase table to list the measurement results for Code, Power (dB), Timing (ns), Phase (rad), and CDE (dB).
- **QPSK EVM** Press this key to make QPSK error vector magnitude (EVM) measurements. The following windows are available:
 - Polar vector graph of the I/Q demodulated signals and the summary data
 - Polar constellation graph of the I/Q demodulated signals and the summary data
 - Quad view for the I/Q errors and the summary data
- Power Stat CCDF Press this key to make power statistics, Complementary Cumulative Distribution Function (CCDF) measurements. This is helpful to observe the time domain characteristics of a spread spectrum signal that can significantly affect the ACPR measurement results for a given UUT.
- **Spectrum (Freq Domain)** Press this key to make frequency domain spectrum measurements. The following windows are available:
 - Spectrum graph with the semi-log graticules and I/Q waveform graph with the linear graticules
 - Linear spectrum graph with the linear graticules (for E4406A)
 - I and Q waveform graphs with the linear graticules (for E4406A)
 - I/Q polar graph of the baseband I/Q signals with the linear graticules (for E4406A)
- **Waveform (Time Domain)** Press this key to make time domain waveform measurements. The following windows are available:
 - Signal Envelope graph with semi-log graticules and summary data
 - Linear Envelope graph with signals measured as voltages and Linear Phase graph with the linear graticules (for E4406A Option B7C, active when using Baseband IQ inputs)
 - I/Q waveform graph and summary data
 - I and Q Waveform graph of the individual I and Q signals (for E4406A Option B7C, active when using Baseband IQ inputs)
 - I/Q polar graph of the baseband I/Q signals (for E4406A)

Meas Control Key Menu

Key path: Meas Control

- **Restart** Press this key to repeat the current measurement from the beginning, while retaining the current measurement settings. When pressed, the scale coupling function is activated for an appropriate display to the current input signal level. This is equivalent to the **Restart** front panel key.
- **Measure** Press this key (not to be confused with the **MEASURE** front panel key which has a different function) to toggle the measurement state between **Single** and **Cont** (continuous). When set to **Single**, the measurement will continue until it has reached the specified number of averages set by the average counter. When set to **Cont**, the measurement will run continuously and execute averaging according to the current average mode, either repeat or exponential. The default setting is **Cont** for most measurements, but the Code Domain and Power Stat CCDF measurements have **Single** as the default.
- Pause Press this key to pause the current measurement until you reactivate the measurement. Once toggled, the label of the Pause key changes to read Resume. The Resume key, once pressed, continues the active measurement from the point at which it was paused.

Mode Setup Key Menu

Key path: Mode Setup

Radio Key Menu

Key Path: Mode Setup, Radio

• **Device** - Allows you to toggle the test device between **BTS** (Base Transmission Station) and **MS** (Mobile Station).

Radio Default Setting	
Radio: Device	BTS

Input Key Menu

Key Path: Mode Setup, Input

NOTE

You can also access the **Input** key from the **Input/Output** front panel key. For details on the **Input** key see "Input/Output Key Menu" on page 119.

Trigger Key Menu

Key Path: Mode Setup, Trigger, <trigger type>

NOTE

The actual trigger source is selected individually for each measurement under the **Meas Setup** key.

- RF Burst, Video (Envlp), Ext Front, Ext Rear- Pressing one of these trigger keys will access each triggering condition setup menu. This menu is used to specify the Delay, Level and Slope settings for each trigger source as follows:
 - Delay Allows you to enter a numerical value to modify the trigger delay time. The range is -100.0 to +500.0 ms with 1 μs resolution. For trigger delay use a positive value, and for pre-trigger use a negative value.
 - **Level** Allows you to enter a numerical value to adjust the trigger level depending on the trigger source selected.
 - □ For RF Burst, the key label reads as Peak Level. The RF level range is 25.00 to 0.00 dB with 0.01 dB resolution, relative to the peak RF signal level. The realistic range can be down to 20 dB.
 - □ For Video (Envlp), the video level range is 200.00 to +50.00 dBm with 0.01 dB resolution at the RF input. The realistic range can be down to around 50 dBm depending on the noise floor level of the input signal.
 - \Box For Ext Front or Ext Rear, the level range is -5.00 to +5.00 V with 1 or 10 mV resolution.
 - Slope Allows you to toggle the trigger slope between Pos at the positive-going edge and Neg at the negative-going edge of the burst signal.
- Trig Holdoff Allows you to set the period of time before the next trigger can occur. The range is 0.000 μs to 500.0 ms with 1 μs resolution.
- **Auto Trig** Allows you to specify a time for a trigger timeout and toggle the auto trigger function between **On** and **Off**. The range is 1.000 ms to 1.000 ks with 1 µs resolution. If no trigger occurs by the specified time, a trigger is automatically generated.
- **Frame Timer** Allows you to access the menu to manually control the frame timer:
 - **Period** Allows you to set the period of the frame clock. The range is 0.000 ns to 559.0000 ms with 1 ps resolution.
 - Offset Allows you to set the offset of the frame clock. The range is 0.000 to 10.00 s with 100 ns resolution over 1.000 μ s range.

- **Reset Offset Display** Allows you to display without any offset of the frame clock.
- **Sync Source** Allows you to access the menu to select one of the sources to be synchronized with.
 - ☐ **Off** Allows you to turn the synchronizing source off for asynchronous tests.
 - □ **RF Burst (Wideband)** Allows you to select the RF burst signal as the synchronizing source.
 - □ **Ext Front** Allows you to select the external input signal from the front panel input port as the synchronizing source.
 - □ **Ext Rear** Allows you to select the external input signal from the rear panel input port as the synchronizing source.

Trigger Default Settings		
RF Burst: Delay Peak Level Slope	0.000 μs - 6.00 dB Pos	
Video (Envlp): Delay Level Slope	0.000 μs - 6.00 dBm Pos	
Ext Front: Delay Level Slope	0.000 μs 2.00 V Pos	
Ext Rear: Delay Level Slope	0.000 μs 2.00 V Pos	
Trig Holdoff	0.000 ms	
Auto Trig	100.0 ms; Off	
Frame Timer: Period Offset Sync Source	26.666667 ms 0.000 ms Off	

Demod Key Menu

Key Path: Mode Setup, Demod

NOTE

The **Demod** key allows you to make measurements on base stations with either the single carrier signal or the multiple carrier signal. This is effective for the code domain, modulation accuracy, and QPSK EVM measurements.

- **RF Carrier** Allows you to toggle the RF structure between **Single** and **Multi**. If set to **Single**, a 3.75 MHz wide carrier is used with 625 kHz guard bands on both sides as an air interface option. If set to **Multi**, three adjacent 1.25 MHz wide carriers are used with 625 kHz guard bands on both sides of each carrier, where overlay operation with TIA/EIA-95-B is allowed.
- 1xEV-DV Enable (Requires Option 214) Enables detection of 1xEV-DV format signals, including QPSK, 8PSK or 16QAM-encoded F-PDCH signals. When 1xEV-DV is enabled, the Mode key cdma2000 changes to cdma2000 w/ 1xEV-DV.

Demodulation Default Settings	
RF Carrier	Single
1xEV-DV Enable	On (Requires Option 214)

Input/Output Key Menu

Key path: Input/Output

NOTE

You can also access this menu from the Mode Setup, Input front panel key.

- Input Port Allows you to access the menu to select one of the signal input ports as follows (including Baseband IQ Inputs for E4406A Option B7C, when installed):
 - RF Allows you to measure an RF signal supplied to the front panel RF input port.
 - **I/Q** (For E4406A Option B7C) Allows you to measure the I/Q input signals supplied to the front panel I and **Q INPUT** ports.
 - I only (Basic mode for E4406A Option B7C) Allows you to measure the I input signal supplied to the front panel I INPUT port.
 - Q only (Basic mode for E4406A Option B7C) Allows you to measure the Q input signal supplied to the front panel Q INPUT port.

- **50 MHz Ref** (For E4406A) Allows you to measure the **50 MHz Reference** signal to calibrate the instrument.
- Amptd Ref (f=50 MHz) (For PSA) Allows you to measure the 50 MHz reference signal to calibrate the instrument.
- **IF Align** Allows you to configure the IF alignment signal. The RF path is switched to bring in the same alignment signal that is automatically switched to perform many alignments.
- **Baseband Align Signal -** (For E4406A Option B7C) Selects an internal signal used for alignment of the baseband I/Q inputs.
- **I/Q Setup** (For E4406A Option B7C) Allows you to access the menu to select the input impedance for the baseband I/Q input signals, and to set the dc offset voltages for I/Q input signals. This key is grayed out unless **Input Port** is set to **I/Q**.
 - I Offset Allows you to set a dc offset voltage value for the I input signal. The range is 0.0000 to 2.5600 V in 0.0001 V.
 - Q Offset Allows you to set a dc offset voltage value for the Q input signal. The range is 0.0000 to 2.5600 V in 0.0001 V.
 - **I/Q Input Z** Allows you to access the menu to select one of the input impedances for baseband I/Q input signals as follows:
 - **50** Ω **Unbalanced** Allows you to set the input impedance to unbalanced 50 Ω for use with the I/Q input ports. This is the default setting.
 - **GOO** Ω Balanced Allows you to set the input impedance to balanced 600 Ω for use with the I/Q input ports and the $\overline{I}/\overline{Q}$ input ports.
 - **1 M**Ω **Unbalanced** Allows you to set the input impedance to unbalanced 1 MΩ for use with the I/Q input ports.
 - **1 M**Ω **Balanced** Allows you to set the input impedance to balanced 1 MΩ for use with the I/Q input ports and the $\overline{I/Q}$ input ports.
 - I/Q Z Ref for Input Z = 1 MΩ Allows you to enter a numeric value to set the reference impedance if I/Q Input Z is set to 1 MΩ, otherwise this key is grayed out. The range is 1.0 Ω to 10.0 M Ω in steps 1 Ω . The default value is 50.0 Ω .
- RF Input Range Allows you to toggle the RF input range control between Auto and Man (manual). If Auto is chosen, the instrument automatically sets the attenuator based on the carrier power level, where it is tuned. Once you change the Max Total Pwr or RF Input Atten value with the RPG knob, for example, the RF Input Range key is automatically set to Man. If there are multiple carriers present, the total power might overdrive the front end. In this case you need to set the RF Input Range to Man and enter the expected maximum total

power by activating the **Max Total Pwr** key. **Man** is also useful to hold the input attenuation constant for the best relative power accuracy. For single carriers it is generally recommended to set this to **Auto**.

For PSA, when you use the internal preamplifier, Int Preamp, the selections using the RF Input Range key are not available, and the key is grayed out.

For E4406A Option B7C, if Input Port is set to I/Q, this key is grayed out

- **I/Q Range** (For E44046A Option B7C) Allows you to select a value for the maximum voltage range of the baseband I/Q input signals, when **Input Port** is set to **I/Q**, otherwise this key is not available. The choices are 125.0 mV, 250.0 mV, 500.0 mV, and 1.00 V.
- Max Total Pwr Allows you to set the maximum total power level from the UUT (Unit Under Test). The range is -200.00 to 100.00 dBm with 0.01 dB resolution. This is the expected maximum value of the mean carrier power referenced to the output of the UUT; it may include multiple carriers. The Max Total Pwr setting is coupled together with the Input Atten and Ext Atten settings. Once you change the Max Total Pwr value with the RPG knob, for example, the Input Range key is automatically set to Man.

For PSA, when you use the internal preamplifier, Int Preamp, the selections using the Max Total Pwr key are not available, and the key is grayed out.

For E4406A Option B7C, when **Input Port** is set to **I/Q**, this key label changes to **I/Q** Range.

• Input Atten - Allows you to control the internal input attenuator setting. The range is 0 to 40 dB with 1 dB resolution. The Input Atten key reads out the actual hardware value that is used for the current measurement. If more than one input attenuator value is used in a single measurement, the value used at the carrier frequency will be displayed. The Input Atten setting is coupled to the Max Total Pwr setting. Once you change the Input Atten setting with the RPG knob, for example, the Input Range key is automatically set to Man.

For PSA, when you use the internal preamplifier, Int Preamp, the electronic attenuator selections using the Input Atten key are not available, and the key is grayed out. Use the mechanical attenuator under More 1 of 2, Attenuator, below.

For E4406A Option B7C, if **Input Port** is set to I/Q, this key is not available as this attenuator is located in front of the first down converter, therefore it cannot be used for the baseband I/Q input signals.

NOTE

The Max Total Pwr and Input Atten settings are coupled together, so changing the input Max Total Pwr setting by x dB changes the Input Atten setting by x dB. When you switch to a different measurement, the Max Total Pwr setting is kept constant, but the Input Atten may change if the two measurements have different mixer margins. Therefore, you can set the input attenuator manually, or you can set it indirectly by specifying the expected maximum power from the UUT.

- Ext RF Atten Allows you to access the following menu to enter the external attenuation values. Either of the Ext RF Atten settings is coupled together with the RF Input Range setting. However, pressing Ext RF Atten does not switch the RF Input Range key to Man. This will allow the instrument to display the measurement results referenced to the output of the UUT.
 - **MS** Allows you to set an external attenuation value for MS tests. The range is −50.00 to +50.00 dB with 0.01 dB resolution.
 - **BTS** Allows you to set an external attenuation value for BTS tests. The range is −50.00 to +50.00 dB with 0.01 dB resolution.
- Int Preamp (For PSA Option 1DS) Allows you to control the internal RF input preamplifier. The internal preamplifier provides +30 dB of gain and is useful for lower power measurements. The Int Preamp setting default is Off. RF power values displayed for these measurements are adjusted to compensate for the internal preamplifier gain, and indicate power levels at the input port. The preamplifier is only available for Modulation Accuracy (EVM and Peak Code Domain Error) measurements, QPSK EVM, and Code Domain measurements. If the Int Preamp is not available for a particular measurement, the key is grayed out.

To avoid damaging the internal preamplifier, limit the total power applied to the RF input to $\leq +25$ dBm.

When using the internal preamplifier, the electronic attenuator selections using the **Input Atten** key are not available, and the key is grayed out. Use the mechanical attenuator under **More**, **Attenuator**, below.

• Attenuator - (For PSA Option 1DS) When Int Preamp is set to On, this key allows you to control an internal mechanical input attenuator setting. The choices are 0 dB, 10 dB, and 20 dB. The Attenuator key shows the actual hardware value that is used for the current measurement. The Attenuator setting is not coupled to the Max Total Pwr setting.

The **Attenuator** is only available for measurements which can use the **Int Preamp**: Modulation Accuracy (EVM and Peak Code Domain Error) measurements, QPSK EVM, and Code Domain measurements. If the **Int Preamp** is not available for a particular measurement, the key is grayed out.

- **IF Align Signal** Allows you to access the following menu to select one of the signals to be used for IF alignment.
 - **Signal Rate** Allows you to set a value to be used for dividing the fundamental frequency of 468.75 kHz. The value ranges from 0 to 12 as the power of 2.
 - **Signal Amptd** Allows you to set an amplitude value to be applied to the digital analog converter, for the IF alignment signal. The value ranges from 0 to 4095.
 - **Signal Type** Allows you to access the following menu to select one of the signal types.
 - □ **CW** Sets the IF alignment signal to CW.
 - □ **Comb** Sets the IF alignment signal to comb wave.
 - ☐ **Pulse** Sets the IF alignment signal to pulse wave.

See Table 3-1, "Input Menu Default Settings," on page 124.

Table 3-1 Input Menu Default Settings

Input Port	RF
RF Input Range ^a	Auto ^b
I/Q Setup ^c (E4406A Option B7C)	(disabled)
I/Q Range ^c (E4406A Option B7C)	1.00 V (disabled)
Max Total Pwr ^a	- 15.00 dBm ^d
Input Atten ^a	$0.00~\mathrm{dB^d}$
Ext RF Atten: MS BTS	0.00 dB 0.00 dB
Int Preamp ^e (PSA)	OFF
Attenuator ^e (PSA)	0 dB
IF Align Signal: Signal Rate Signal Amptd Signal Type	0; = 468.75 kHz DAC 500 CW

- a. This key is greyed-out or not available if Input Port is set to $\mbox{I/Q}.$
- b. Auto is not used for Spectrum (frequency domain) measurements.
- c. This key is not available if Input Port is set to RF.
- d. This may differ if the maximum input power is more than $-15.00~\mathrm{dBm}$, or depending on the previous measurements.
- e. The internal preamplifier and attenuator are available for Modulation Accuracy (EVM and Peak Code Domain Error) measurements, QPSK EVM, and Code Domain measurements on PSA with Option 1DS.

cdma2000 Measurement Keys

Adjacent Channel Power Ratio (ACPR) Keys

NOTE

You must have selected ACPR at Key Path: **MEASURE** to access these menus.

Measurement Setup Key Menu

Key Path: Meas Setup


- **Avg Number** Allows you to change the number of N averages.
- Avg Mode Allows you to toggle the averaging mode between Exp (exponential) and Repeat. This selection only effects on the averaging result after the number of N averages is reached. The N is set using the Avg Number key.
 - Normal averaging: Normal (linear) averaging is always used until the specified number of N averages is reached. When the Measure key under Meas Control is set to Single, data acquisition is stopped when the number of N averages is reached, thus Avg Mode has no effect in the single measurement mode.
 - Exponential averaging: When Measure is set to Cont, data acquisition will continue indefinitely. Exponential averaging is used with a weighting factor of N (the displayed count of averages stops at N). Exponential averaging weights new data more heavily than old data, which allows tracking of slow-changing signals. The weighting factor N is set using the Avg Number key.
 - Repeat averaging: When Measure is set to Cont, data acquisition will continue indefinitely. After the number of N averages is reached, all previous result data is cleared and the average count displayed is set back to 1. This is equivalent to being in Measure Single and pressing the Restart key each time the single measurement finishes.
- **Chan Integ BW** Allows you to specify the channel integration bandwidth in which the channel power levels are measured. The range is 300.0 Hz to 20.0000 MHz with 1 Hz resolution.
- **Ref Channel** Allows you to access the following parameters for the reference channel settings:
 - **Chan Integ BW** Allows you to specify the channel integration bandwidth in which the carrier power is measured. The range is 1.000 kHz to 20.0000 MHz with the best resolution of 1 Hz.
 - **Avg Type** Allows you to set to power averaging type to either **Pwr**

Avg (RMS) or Maximum.

- **Ref Chan Adv** Allows you to access the menu to change the following advanced parameters for the reference channel:
 - □ Sweep Time Allows you to toggle the sweep time function between Auto and Man (manual), and to set a value for the sweep time ranging from 1.0 ms to 50.000 ms if set to Man. If set to Auto, the reference channel measurement sweep time is derived from the data points and the number of FFT segments.
 - □ Data Points Allows you to toggle the control function of the number of data points between Auto and Man (manual), and to set the number of data points ranging from 64 to 65536. The automatic mode chooses the optimum number of points (= 2ⁿ⁺⁶ where n = 0 to 11) for the fastest measurement time with acceptable repeatability. The minimum number of points that could be used is determined by the sweep time and the sampling rate. You can increase the length of the measured time record (capture more of the burst) by increasing the number of points, but the measurement will take longer.
 - □ **Res BW** This key is always grayed out. However, it allows you to see the resolution bandwidth that is derived from the combination of sweep time, data points, and FFT segments.
 - □ Num FFT Seg Allows you to select the number of FFT segments used in making the measurement of the reference channel (carrier). In the automatic mode the measurement optimizes the number of FFT segments required for the shortest measurement time. The minimum number of segments required to make a measurement is set by your desired measurement bandwidth. Selecting more than the minimum number of segments will give you more dynamic range for making the measurement, but the measurement will take longer to execute.
- Ofs & Limits Allows you to access the menu to change the following parameters for offset frequency settings and pass/fail tests:
 - Offset Allows you to access the memory selection menu from A to E to store 5 sets of values for Offset Freq, Ref BW, Abs Limit and so forth. Only one selection at a time (A, B, C, D, or E) is shown on this key.
 - Offset Freq- Allows you to enter an offset frequency center value, and to toggle the offset function between On and Off, according to each offset key selected. The range is 0.0 Hz to 100.000 MHz. While this key is activated, enter an offset frequency center value from the numeric keypad by terminating with one of the frequency unit keys shown. One offset frequency center value corresponding to the Offset menu selection is shown on this key,

however, this is titled as Offset to Edge in the measurement result window considering the measurement bandwidth.

The following figure illustrates the difference between the offset frequency center and the offset to edge frequency.



- **Ref BW** Allows you to enter a reference bandwidth ranging from 300.0 Hz to 20.0000 MHz with 1 Hz resolution. When this parameter is changed, the integration bandwidth Integ BW in the summary data window changes to that value.
- **Abs Limit** Allows you to enter an absolute limit value ranging from 200.00 to +50.00 dBm with 0.01 dB resolution.
- Fail Allows you to access the following menu to select one of the logic keys for fail conditions between the measurement results and the test limits:
 - ☐ **Absolute** Fail is shown if one of the absolute ACPR measurement results is larger than the limit for **Abs Limit**.
 - ☐ Relative Fail is shown if one of the relative ACPR measurement results is larger than the limit for Rel Lim (Car) or Rel Lim (PSD).
 - □ Abs AND Rel Fail is shown if one of the absolute ACPR measurement results is larger than the limit for Abs Limit AND one of the relative ACPR measurement results is larger than the limit for Rel Lim (Car) or Rel Lim (PSD).
 - □ **Abs OR Rel** Fail is shown if one of the absolute ACPR measurement results is larger than the limit for **Abs Limit** OR one of the relative ACPR measurement results is larger than the limit for **Rel Lim (Car)** or **Rel Lim (PSD)**.
- Rel Lim (Car) Allows you to enter a relative limit value of the carrier level ranging from - 200.00 to +50.00 dBc with 0.01 dB

resolution.

 Rel Lim (PSD) - Allows you to enter a relative limit value of the power spectral density level ranging from – 200.00 to +50.00 dB with 0.01 dB resolution.

Table 3-2 Default Offsets and Limits


Offset	Offset Fr (kI	requency Hz)	Abs Limit (dBm)	Rel Limit (Car) (dBc)	Rel Limit (PSD) (dB)
Offset	BTS	MS	(ubiii)	BTS/MS	BTS/MS
A, On	765.0	900.0	50.00	0.00	0.00
B, On	1995.0	1995.0	50.00	0.00	0.00
C, Off	0.000	0.000	50.00	0.00	0.00
D, Off	0.000	0.000	50.00	0.00	0.00
E, Off	0.000	0.000	50.00	0.00	0.00

- **Offset/Limits** Allows you to access the menu to change the following parameters for offset frequency settings and pass/fail tests:
 - **Offset** Allows you to select one of five offsets (**A** through **E**). Only one selection at a time (A, B, C, D, or E) is shown on this key label. The remaining softkeys on the **Offset/Limits** menu then apply to the selected offset.
 - Offset Freq Allows you to enter an offset frequency value and toggle the offset function between On and Off. The range is 0.0 Hz to 45.000 MHz. While this key is activated, enter an offset value from the numeric keypad by terminating with one of the frequency unit keys shown. Offsets A and B are defaulted as follows for BS tests, while others are defaulted to 0.0 Hz and Off:

Offset A: 750.00 kHz, On Offset B: 1.9800 MHz, On

One offset frequency center value corresponding to the **Offset** menu selection is shown on this key label.

- Offset Side Choose Neg (negative) or Pos (positive) to have single-sided offsets relative to the carrier, or Both (the default) to have offset frequency pairs.
- Ref BW Allows you to enter a reference bandwidth ranging from 300 Hz to 20.0000 MHz with the best resolution of 1 Hz. When this parameter is changed, the integration bandwidth Integ BW in the summary data window changes to that value.
- Avg Type Choose the type of averaging between Pwr Avg (RMS) or Maximum.



of the measured time record (capture more of the burst) by increasing the number of points, but the measurement will take longer.

- ☐ **Res BW** This key is always grayed out. However, it allows you to see the resolution bandwidth that is derived from the combination of sweep time, data points, and FFT segments.
- □ Num FFT Seg The automatic mode selects the optimum number of FFT segments to measure the offset, while making the fastest possible measurement.
- □ Relative Atten Allows you to set a relative amount of attenuation for the measurements made at your offsets. The amount of attenuation is always specified relative to the attenuation that is required to measure the carrier channel. Since the offset channel power is lower than the carrier channel power, less attenuation is required to measure the offset channel and you get wider dynamic range for the measurement.
- **Meas Type** Allows you to access the menu to select one of the measurement reference types.
 - Total Pwr Ref Select this to set the total carrier power to the measurement reference level and the measured data is shown in dBc and dBm.
 - PSD Ref Select this to set the mean power spectral density of the carrier to the measurement reference level and the measured data is shown in dB and dBm/Hz.
- **Fast ACP** Allows you to increase the speed of the measurement. A time domain computation method is used rather than an FFT transformation. When this faster measurement method is selected, repeatability is slightly reduced.
- **Spectrum Trace** Turns off the spectrum trace data calculations. This is only applicable when using the Spectrum View. It speeds up the display of the other measured data values by not calculating the spectrum trace.
- **Limit Test** Turns on or off the limit test function.
- **Sweep Type** Allows you to select the method of measurement between **FFT** and **Swp** (swept).

If set to FFT, the signal is digitized in a series of moderate bandwidth measurements. The LO (local oscillator) changes frequency to center the analysis region for each step in this series. A Fast Fourier Transform is used to convert the digitized signal to a spectrum at each step. The steps are combined to create a spectrum. The power in each offset is computed from that spectrum. The FFT Sweep Type provides maximum dynamic range and accuracy.

If set to swept (**Swp**), the LO is stepped in small steps to simulate swept spectrum analysis. Swept spectrum analysis can provide a spectrum display with peak detection that is more familiar to many users. But swept analysis is slower and no more accurate than FFT analysis. Only **Spectrum** view is available in swept analysis.

- **Swp RBW** Allows you to control the resolution bandwidth to be used when the Sweep Type is swept. If set to **Auto**, the RBW is automatically selected based on the sweep span, which is determined by the **Offset Freq** and **Ref BW**. If set to **Man**, the RBW is set manually. The allowed range is 1.000 kHz to 1.000000 MHz with 1 Hz resolution.
- **Swp Det** Allows you to select **Avg** (average) or **Peak** detection to be used when the Sweep Type is swept. Both detectors operate during the data acquisition time for each measurement point of the sweep. Average detection measures the average power during that time, as required for accurate adjacent channel power measurements. Peak detection measures the peak power during the data acquisition time.
- Restore Meas Defaults Allows you to preset only the settings that are specific to the selected measurement by pressing Meas Setup, More (1 of 2), Restore Meas Defaults. This will set the measure setup parameters, for the currently selected measurement only, to the factory defaults.
- **Advanced** Allows you to access the menu to set the following parameters:
 - Swp Acq Time Allows you to set the data acquisition time when Sweep Type is set to Swp. The range is $500~\mu s$ to 10.000~m s with $1~\mu s$ resolution.

The next table shows the factory default settings for adjacent channel power ratio measurements.

Table 3-3 Adjacent Channel Power Ratio Measurement Defaults

Measurement Parameter	Factory Default Condition
View/Trace	Bar Graph (Total Pwr Ref)
Spectrum Trace	On
Avg Number	2010; On
Avg Mode	Repeat

 Table 3-3
 Adjacent Channel Power Ratio Measurement Defaults

Measurement Parameter	Factory Default Condition
Ref Channel:	1 00000 MII
Chan Integ BW	1.23000 MHz
Avg Type	Pwr Avg (RMS)
Ref Chan Adv.: Sweep Time	EAG 1 was Arriva
Data Points	546.1 μs; Auto 2048; Auto
Res BW	1.620 kHz (grayed out)
Num FFT Seg	1; Auto
Offset/Limits:	
Offset	A
Offset Freq	A: 750.000 kHz; On
•	B: 1.98000 MHz; On
Offset Side	Both
Ref BW	30.000 kHz
Avg Type	Pwr Avg (RMS)
Limit Setup:	
Abs Limit	0.00 dBm
Fail	Relative
Rel Lim (Car)	A: –45.00 dBc
	B: -60.00 dBc
Rel Lim (PSD)	A: –28.87 dB
	B: -43.87 dB
Offset Adv.:	
Sweep Time	11.20 ms; Auto
Data Points	1024; Auto
Res BW	79.0 Hz (grayed out)
Num FFT Seg	1; Auto
Relative Atten	0.00 dB
Chan Integ BW	1.23000 MHz
Ofs & Limits:	
Offset	A
Offset Freq	A: 765.000 kHz; On
	B: 1.99500 MHz; On
	C: 0.0 Hz; Off
	D: 0.0 Hz; Off
Dof DW	E: 0.0 Hz; Off A to E: 30.000 kHz
Ref BW Abs Limit	A to E: 30.000 kHz A to E: 50.00 dBm
Abs Limit Fail	A to E: 50.00 dbm A to E: Relative
Rel Lim (Car)	A to E. Relative A to E: 0.00 dBc
Rel Lim (PSD)	A to E: 0.00 dB
Meas Type	Total Pwr Ref
Trig Source	Free Run (Immediate)
Fast ACP	Off
1 450 1101	VIII

Table 3-3 Adjacent Channel Power Ratio Measurement Defaults

Measurement Parameter	Factory Default Condition	
Limit Test	On	
Sweep Type	FFT	
Swp RBW (grayed out for FFT)	6.667 kHz; Auto	
Swp Det (grayed out for FFT)	Avg	
Advanced		
Swp Acq Time	1.250 ms (grayed out for FFT)	

View/Trace Key Menu

Key Path: View/Trace

The **View/Trace** key accesses the menu to select either **Bar Graph** or **Spectrum** for the measurement result, depending on the **Sweep Type** setting.


• **Bar Graph** - In the factory default condition 5 of the total integration power levels, centered at the carrier frequency and ±765.0 kHz and ±1.995 MHz offset frequencies, are shown in the figure for the "Results" section. The corresponding measured data is shown in the text window. Depending on the **Meas Type** selection, one of the two following displays is obtained:

 ${\tt Bar\ Graph\ (Total\ Pwr\ Ref)}$ - $A\ histogram\ of\ powers\ referenced$ to the total power

Bar Graph (PSD Ref) - A histogram of powers referenced to the mean power spectral density of the carrier in dBm/Hz

• **Spectrum** - In the factory default condition, the frequency spectrum with the FFT sweep type is displayed with the bandwidth marker lines in the graph window. The corresponding measured data in the text window is the total integration power levels, in dBc and dBm, within the defined bandwidth as shown in the figure below.

Figure 3-3 ACP Measurement - Spectrum View






Figure 3-4 ACPR Measurement - FFT Spectrum (Total Pwr Ref) View

*Meas Setup: View/Trace = Spectrum,

Others = Factory default settings

*Input signal: -10.00 dBm, 9 channels of SR1, cdma2000 Rev 8

Depending on the **Meas Type** setting, one of the two following displays is obtained:


 $\label{eq:spectrum} \mbox{(Total Pwr Ref)} \mbox{-} A \mbox{ spectrum display referenced to the total power}$

Spectrum (PSD Ref) - A spectrum display referenced to the mean power spectral density of the carrier in dBm/Hz

You can improve the update speed of the displayed data values by turning off the spectrum trace in **Meas Setup**.

Figure 3-5 If **Sweep Type** is set to **Swp**, the swept frequency ACPR is displayed as shown below and only **Spectrum** is available for **View/Trace**.

Figure 3-6 ACPR Measurement - Swept Spectrum (Total Pwr Ref) View



*Meas Setup: View/Trace = Spectrum,

Sweep Type = Swp,

Others = Factory default settings

*Input signal: -10.00 dBm, 9 channels of SR1, cdma2000 Rev 8

NOTE

If **Sweep Type** is set to **FFT**, the spectrum graph does not show the actual power level measured at each of the offsets. Select **Swp** for the more accurate spectrum graph.

While in this view, you can change the vertical scale by pressing the **AMPLITUDE Y Scale** key. You can also activate or deactivate the reference bandwidth markers by pressing the **Display** key.

AMPLITUDE Y Scale Key Menu

Key Path: AMPLITUDE Y Scale

NOTE

View/Trace must be set to Spectrum to acess following the AMPLITUDE Y Scale keys

- Scale/Div Allows you to enter a numeric value to change the vertical display sensitivity. The range is 0.10 to 20.00 dB with 0.01 dB resolution. The default setting is 10.00 dB. However, since the Scale Coupling is defaulted to On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Value** Allows you to set the absolute power reference value ranging from -250.00 to 250.00 dBm with 0.01 dB resolution. The default setting is 10.00 dBm. However, since the **Scale Coupling** is defaulted to **On**, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- Ref Position Allows you to set the reference position to either Top, Ctr (center), or Bot (bottom). The default setting is Top.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front-panel key or Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

Key Reference cdma2000 Measurement Keys

Display Key Menu

Key Path: Display

NOTE

View/Trace must be set to Spectrum, to access the following Display key.

• Ref BW Marker - Allows you to toggle the reference bandwidth markers function between On and Off. If set to On, the vertical line markers with the reference bandwidth are shown on the measurement result display.

Marker Key Menu

The **Marker** key is not available for this measurement function.

Channel Power Keys

NOTE

You must have selected Channel Power at Key Path: **MEASURE** to use these menus.

Measurement Setup Key Menu

Key Path: Meas Setup

- Avg Number Allows you to change the number of N averages.
- **Avg Mode** Allows you to toggle the averaging mode between **Exp** (exponential) and **Repeat**. This selection only effects on the averaging result after the number of N averages is reached. The N is set using the **Avg Number** key.
 - Normal averaging: Normal (linear) averaging is always used until the specified number of N averages is reached. When the Measure key under Meas Control is set to Single, data acquisition is stopped when the number of N averages is reached, thus Avg Mode has no effect in the single measurement mode.
 - Exponential averaging: When Measure is set to Cont, data acquisition will continue indefinitely. Exponential averaging is used with a weighting factor of N (the displayed count of averages stops at N). Exponential averaging weights new data more heavily than old data, which allows tracking of slow-changing signals. The weighting factor N is set using the Avg Number key.
 - Repeat averaging: When Measure is set to Cont, data acquisition will continue indefinitely. After the number of N averages is reached, all previous result data is cleared and the average count displayed is set back to 1. This is equivalent to being in Measure Single and pressing the Restart key each time the single measurement finishes.
- Integ BW Allows you to specify the integration bandwidth in which

the power is measured. The range is 1.000 kHz to 10.0000 MHz with 1 Hz resolution. Since Integ BW is coupled to Chan Power Span in the factory default condition, if you change the integration bandwidth setting, the channel power span setting changes by a proportional amount, 1.2 times the integration bandwidth, until a limit value is reached.

- **Chan Power Span** Allows you to set the frequency span for the channel power measurement. The range is 1.000 kHz to 10.0000 MHz with 1 Hz resolution. This span is used for the current integration bandwidth setting. Since Chan Power Span is coupled to Integ BW in the factory default condition, if you change the integration bandwidth setting, the channel power span setting changes by a proportional amount, 1.2 times the integration bandwidth, until a limit value is reached. However, the channel power span can be individually set.
- **Restore Meas Defaults** Allows you to preset only the settings that are specific to the selected measurement by pressing Meas Setup, More (1) of 2), Restore Meas Defaults. This will set the measure setup parameters, for the currently selected measurement only, to the factory defaults.
- Advanced Allows you to access the following menu to modify the channel power measurement parameters:

Parameters under the **Advanced** key seldom need to be changed. Any changes from the factory default values may result in invalid measurement data.

- Sweep Time Allows you to manually change the sweep time and also to toggle the sweep time control between Auto and Man (manual). The range is 1.0 us to 50.00 ms with 1 us resolution. If set to Auto, the sweep time derived from the data point setting is shown on this key regardless of the manual entry range.
- Data Points Allows you to select the number of data points and also to toggle the data point control between Auto and Man (manual). The range is 64 to 65536 with the acceptable entry in powers of 2 (for example: 64, 128, 512). If set to Auto, the optimum number of points is determined for the fastest measurement time with acceptable repeatability. The minimum number of points that could be used is determined by the sweep time and the sampling rate. You can increase the length of the measured time record (capture more of the burst) by increasing the number of points, but the measurement will take longer.
- **Res BW** Shows information on the resolution bandwidth derived from the sweep time. This key is always grayed out.
- Trig Source Allows you to choose a trigger source from Free Run

Chapter 3 139

NOTE

- (Immediate), Video (Envlp), RF Burst (Wideband), Ext Front, Ext Rear, Frame, I/Q Input, or Line.
- Trig Source Allows you to choose a trigger source from Free Run (Immediate), Video (Envlp), RF Burst, Ext Front, Ext Rear, Frame, or Line.

The next table shows the factory default settings for channel power measurements.

Table 3-4 Channel Power Measurement Defaults

Measurement Parameter	Factory Default Condition	
Meas Setup:		
Avg Number	200; On	
Avg Mode	Repeat	
Integ BW ^a	5.00000 MHz	
Chan Power Span ^a	6.00000 MHz	
Advanced		
Sweep Time	68.27 μs; Auto	
Data Points	2048; Auto	
Res BW (grayed out)	27.857 kHz (grayed out)	
Trig Source	Free Run (Immediate)	

a. The Integ BW setting proportionally changes the Chan Power Span setting up to 10 MHz.

AMPLITUDE Y Scale Key Menu

Key Path: AMPLITUDE Y Scale

The **AMPLITUDE Y Scale** key accesses the menu to set the desired vertical scale and associated settings:

- Scale/Div Allows you to enter a numeric value to change the vertical display sensitivity. The range is 0.10 to 20.00 dB with 0.01 dB resolution. The default setting is 10.00 dB. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Value** Allows you to set the absolute power reference value ranging from -250.00 to 250.00 dBm with 0.01 dB resolution. The default setting is 10.00 dBm. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- **Ref Position** Allows you to set the display reference position to either **Top**, **Ctr** (center), or **Bot** (bottom). The default setting is **Top**.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front-panel key or Restart softkey under the Meas Control menu, the scale coupling function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

Marker Key Menu

The Marker key is not available for this measurement function.

Code Domain Keys

NOTE

You must have selected **Code Domain** under the **MEASURE** key to access the following menus.


Meas Setup Key Menu

Key Path: Code Domain, Meas Setup

- Meas Type Allows you to toggle the code domain power
 measurement type between Rel (relative) and Abs (absolute). If set to
 Rel, the measurement is made in the relative power in dBc. If set to
 Abs, the measurement is made in the absolute power in dBm.
- Walsh Code Length Allows you to set the Walsh code length ranging from 4 to 128 = 2n+2 where n = 0 to 5 for BTS measurements, or

from 2 to 32 for MS measurements. The parameter automatically sets the maximum value for **Walsh Code Number** when appropriate. If **Walsh Code Length** is set to 64 and **Code Number** is set to 0, the Pilot channel is automatically selected as the channel type. When the channel type is set to Pilot, the search code portion is not included in the symbol EVM calculation. In other cases, the channel type is set to DCCH (dedicated control channel) which enables power offset measurements.

- Walsh Code Number Allows you to set the Walsh code number. The range is 0 to (Walsh Code Length -1).
- Mod Scheme This key is available when Mode Setup, Device is set to BTS and Walsh Code Length is set to 32 only. Specify a Modulation Scheme from the following list:
 - Auto Select Auto to allow the instrument to determine the modulation method for the BTS signal. Auto results are best if the modulation scheme remains constant over the entire capture interval. If the modulation scheme changes, for best results, use the Auto (Gated) setting, below.
 - Auto (Gated) Select Auto (Gated) to allow the instrument to determine the modulation method within the slots defined by Meas Interval and Meas Offset settings. For best results, set the Meas Interval and Meas Offset parameters to confine the instrument to a portion of the signal of interest that has only one modulation scheme.
 - **8PSK** Select when modulation scheme is QPSK.
 - **16QAM** Select when modulation scheme is 16QAM.
- I/Q Branch This key is available when Mode Setup, Device is set to MS only. Toggle the key to select either the I or the Q branch of the MS signal to be analyzed.
- Meas Interval Allows you to set the time interval in PCG (power control groups) over which the symbol power measurement is made. The range is 1 to (32 Meas Offset) PCG. The marker lines reflecting this value are displayed in the symbol power graph of the Code Domain (Quad View) and Demod Bits displays. Refer to the illustration in Meas Offset below.
- **Meas Offset** Allows you to set the number of offsets in PCG (power control groups) to make the symbol power measurement. The range is 0 to 31 PCG in conjunction with the **Meas Interval** value. The maximum value is 32 minus the **Meas Interval** value. The marker lines shift left or right by this value in the symbol power graph of the **Code Domain (Quad View)** and **Demod Bits** displays. The following illustration shows the relationship between the capture interval and the measurement interval.



- PN Offset Allows you to set the number of PN offsets in the unit of 64 chips to make the symbol power measurement. The range is 0 to 511. This value corresponds to the time offset between the trigger signal and the external frame signal.
- Sync Type If Transmit Diversity (TxDiv) is employed by BTS, this menu allows you to set the instrument to synchronize with antenna2 as well as antenna1 by selecting TxDiv F-PCICH. This selection is only available when Radio, Device is set to BTS.
 - **F-PCICH** Select **F-PCICH** to allow the instrument to synchronize with a BTS that does not use Transmit Diversity.
 - TxDiv F-PCICH Select TxDiv F-PCICH to allow the instrument to synchronize with a BTS that uses Transmit Diversity. If STS-TD mode is used, Auto Active Channel Detection is disabled, and the Walsh code must be manually set using Walsh Code Number and Walsh Code Length measurement setup keys. Timing Error may be measured using an external trigger.
- Long Code Mask Allows you to set the long code mask to either 0000000000 or 2000000000. This value is used in the long code generation process. This key is available if **Device** is set to **MS**, otherwise grayed out.
- 1xEV-DV Active Chan Allows you to select the method by which the 1xEV-DV active channel is determined. The default is **Auto**.
 - Auto Select Auto to allow the instrument to determine the modulation method for the BTS signal. Auto results are best if the modulation scheme remains constant over the entire capture interval. If the modulation scheme changes, for best results, use the Auto (Gated) setting, below.
 - Auto (Gated) Select Auto (Gated) to allow the instrument to determine the modulation method within the slots defined by Meas Interval and Meas Offset settings. For best results, set the Meas Interval and Meas Offset parameters to confine the

instrument to a portion of the signal of interest that has only one modulation scheme.

— Combination - Select Combination to allow the instrument to identify the active channel using a combination of Auto and a manual selection from the Predefined Active Channel key menu below. Predefined Active Channel will detect active channels with Walsh code length 32.

NOTE

The following 1xEV-DV Predefined Active Chan menu is only available when Mode Setup, Device is set to BTS, and 1xEV-DV Active Chan is set to Combination.

1xEV-DV Predefined Active Chan - Selecting 1xEV-DV Predefined Active Chan provides a menu that allows you to specify the active channel properties. This key is unavailable if 1xEV-DV Active Chan is set to Auto or Auto (Gated).

- Walsh Code Col Index Specify a Walsh Code Index from 0 to 3. This setting applies to the current measurement regardless of the setting for Walsh Mask or Walsh Mask Bitmap below.
- Walsh Mask On I Off Toggle to specify if the Walsh Mask settings below should apply to the current measurement. When Walsh Mask is On, and when Walsh Mask Bitmap is set to a number other than 0, the settings for F-PDCH below are accepted by the instrument.
- Walsh Mask Bitmap (Hex) Specify a Walsh Mask from 0 to 1FFF. Use the front-panel keypad to make your hexadecimal entry. The instrument accepts this setting only when Walsh Mask Bitmap is set to a number other than 0, and when Walsh Mask is set to On,
- Num of F-PDCH0 Select a number for the F-PDCH0 active channel. The instrument accepts this setting only when Walsh Mask is set to On, or Walsh Mask Bitmap is set to a number other than 0.
- **F-PDCH0 Mod Scheme** Select a Modulation Scheme for the F-PDCH0 active channel from the following list:
 - QPSK
 - 8PSK
 - 16QAM

The instrument accepts this setting only when Walsh Mask is set to On, or Walsh Mask Bitmap is set to a number other than 0.

• Num of F-PDCH1 - Select a number for the F-PDCH1 active channel. The instrument accepts this setting only when Walsh Mask is set to On, or Walsh Mask Bitmap is set to a number other than 0.

- **F-PDCH1 Mod Scheme** Select a Modulation Scheme for the F-PDCH1 active channel from the following list:
 - QPSK
 - 8PSK
 - 16QAM

The instrument accepts this setting only when Walsh Mask is set to On, or Walsh Mask Bitmap is set to a number other than 0.

- Restore Meas Defaults Allows you to preset only the settings that are specific to the selected measurement by pressing Meas Setup, More (1 of 2), Restore Meas Defaults. This will set the measure setup parameters, for the currently selected measurement only, to the factory defaults.
- Capture IntvI Allows you to set the number of power control groups to make the symbol power measurement. The range is 2 to 32 PCG in conjunction with the Meas Interval value. The maximum value is (32 Meas Interval). The marker lines shift to the right or left by this value in the symbol power graph of the Code Domain (Quad View) and Demod Bits display.
- Spectrum Allows you to toggle the spectrum function between Normal and Invert. This key, when set to Invert, conjugates the spectrum, which equivalently negates the quadrature component in demodulation. The correct setting (Normal or Invert) depends on whether the signal being input to the instrument has a high or low side mix.
- **Advanced** Allows you to access the menu to set the following parameter.
 - **Active Set Th** Allows you to toggle the active channel identification function between **Auto** and **Man**. If set to **Auto**, the active channels are determined automatically by the internal algorithm. If set to **Man**, the active channel identification for each code channel is determined by a user definable threshold ranging from 0.00 to -100.00 dB.
 - Walsh Code QOF Allows you to access the menu to specify a value 0, 1, 2, or 3 to the Walsh code quasi-orthogonal function for expanding the number of downlink channels (subscribers). Walsh Code QOF under the Display menu is identical with this key. These keys are only available if Device is set to BTS.
 - **Chip Rate** Allows you to change the chip rate. The range is 1.10592 to 1.35168 MHz.
 - **ADC Range** Allows you to access the following selection menu to define one of the ADC ranging functions:
 - Auto Select this to automatically set the ADC range. For most

Key Reference cdma2000 Measurement Keys

FFT measurements, the auto feature should not be selected. An exception is when measuring a "bursty" signal, in which case **Auto** can maximize the time domain dynamic range, if FFT results are less important to you than time domain results.

- Auto Peak Select this to set the ADC range automatically to the peak signal level. Auto Peak is a compromise that works well for both CW and burst signals.
- Auto Peak Lock Select this to hold the ADC range automatically at the peak signal level. Auto Peak Lock is more stable than Auto Peak for CW signals, but should not be used for bursted signals, or for signals resembling bursted signals.
- Manual Allows you to access the selection menu of values to set the ADC range level. Ranges are -6 to +24 dB for E4406A with a 12-bit ADC, and None to +18 dB for PSA and E4406A with 14-bit ADC. Select None to retain the present value as set by Auto without selection of a range. Also note that manual ranging is best for CW signals.

Table 3-5 Code Domain Power Measurement Defaults

Measurement Parameter	Factory Default Condition
View/Trace	Power Graph & Metrics
Display: Code Order Base Code Length Consolidated Marker Composite Walsh Code Length Meas Setup:	Hadamard 64 On On 64
Meas Type	Rel (relative)
Walsh Code Length	64
Walsh Code Number	0
Mod Scheme	Auto
Meas Interval	1 PCG
Meas Offset	0 PCG
Long Code Mask (grayed out)	20000000000 (for MS tests)
1xEV-DV Active Channel	Auto
Capture Intvl	5 PCG
Trig Source	Free Run (Immediate)
Spectrum	Normal
Meas Control: Measure	Single
Advanced	
Active Set Th	Auto; dB
Walsh Code QOF	0
Chip Rate	1.228800 MHz
ADC Range	-6 (for E4406A with 12-bit DAC) None (for PSA and E4406A with 14-bit DAC)


View/Trace Key Menu

Key Path: Code Domain, View/Trace

- Power Graph & Metrics Provides a combination view of the code domain power graph and the summary data as shown in Figure 3-7 on page 148.
- *I/Q* Error (Quad View) Provides a combination view of the magnitude error, phase error, and EVM graphs, and the summary data for the code number and detected Mod Scheme, RMS and Peak EVM's, magnitude error, phase error, absolute total power, and channel power, are all shown in the text window, as in Figure 3-7.

If the **Radio**, **Device** is set to **BS**, or is set to **MS** with a Walsh Code length other than 32, the detected Mod Scheme is shown as "---".

Figure 3-7 Code Domain Measurement - I/Q Error with Quad View



*Meas Setup: View/Trace = I/Q Error (Quad View),


Others = Factory default settings

*Input signal: -10.00 dBm, 9 channels of SR1, cdma2000 Rev 8

• Code Domain (Quad View) - Provides a combination view of the code domain power, symbol power, and I/Q symbol power polar vector graphs in the graph window, and the summary data for the code number and detected Mod Scheme, rms and peak EVM's, magnitude error, phase error, absolute total power, and channel power in the text window as shown in Figure 3-8.

If the **Radio**, **Device** is set to **BS**, or is set to **MS** with a Walsh Code length other than 32, the detected Mod Scheme is shown as "---".

Figure 3-8 Code Domain Measurement - Code Domain with Quad View




*Meas Setup: View/Trace = Code Domain (Quad View),

Others = Factory default settings

*Input signal: -10.00 dBm, 9 channels of SR1, cdma2000 Rev 8

• **Demod Bits** - Provides a combination view of the code domain power and symbol power graphs, and the I/Q demodulated bit stream data with the corresponding slot or measure offset number in the power control groups, in the text window as shown in Figure 3-9.

Figure 3-9 Code Domain Measurement - Demod Bits View



*Meas Setup: View/Trace = Demod Bits,

Others = Factory default settings

*Input signal: -10.00 dBm, 9 channels of SR1, cdma2000 Rev 8

NOTE

While the Code Domain Power graph is active, press the Marker key to place a marker on any active spread channel. Then, press the Mkr->Despread key to observe the Symbol Power and the I/Q Symbol Polar Vector graphs with the Walsh code number for that active channel in other graph windows. The I/Q symbol polar vector graph and the demodulated bit stream are displayed for the symbol power specified by the measurement interval and measurement offset.

Display Key Menu

Key Path: Code Domain, Display


NOTE

In symbol power measurements in the code domain, phase trajectories between constellation points are not significant to the measurement. Therefore, by default, the points per chip is always set to 1 and **Chip Dots** is set to On.

NOTE

The following additional keys appear in Code Domain, Code Domain (Quad View), or Demod Bits view when the Power graph window is active.

- **Code Order** Allows you to access the selection menu for the Walsh code order function.
 - Hadamard Allows you to set the Walsh code order function to Hadamard. The next figure shows code domain power graphs for Walsh Code4 and OVSF Code 4 to illustrate their relationship.



- **Bit Reverse** Allows you to set the Walsh code order function to Bit Reverse. When selected, the **Consolidated Marker** key is disabled.
- Base Code Length Allows you to toggle the Walsh base code length between 64 and 128.
- Consolidated Marker Allows you to toggle the consolidated marker function between On and Off. If set to On, the corresponding Walsh code channel power will be marked in the different color upon placing the marker at the consolidated Walsh code channel power. The Consolidated Marker key is disabled when the Code Order Bit Reverse key is selected.
- **Composite** Allows you to toggle the composite code channel power display function between **On** and **Off**.
- Walsh Code Length Allows you to set the Walsh code length displayed on the screen to read the total power level of the combined code channels. The choices are 4, 8, 16, 32, 64, and 128 for BTS, and 2, 4, 8, 16, 32 for MS.

Key Reference cdma2000 Measurement Keys

NOTE	The following key appears in Code Domain (Quad View), or Demod Bits view when the Symbol Power window is active.
	• Composite Chip Power - Allows you to toggle the composite chip power display function between On and Off . The default setting is On .
NOTE	The following additional keys appear in Demod Bits view when the Demod Bits window is active.
	 Prev Page - Returns one page back to the previous page of the measurement results.
	 Next Page - Moves one page forward to the next page of the measurement results.
	• Scroll Up - Moves one line upward from the current page of the measurement results by each pressing.

- **Scroll Down** Moves one line downward from the current page of the measurement results by each pressing.
- **First Page** Moves from the current page to the first page of the measurement results.
- Last Page Moves from the current page to the last page of the measurement results.
- **Demod Bit Format** Use this key to toggle the default **Binary** selection to **Hex**. For 8PSK, channels have 3 bits/symbol, with the index bits defined by 3GPP2 C.S0002-C 3.1.3.1.113, and displayed in binary format. When Binary is selected, each character represents a binary digit. If the Modulation Scheme is 16QAM, channels have 4 bits/symbol, and you may select either format for the screen data presentation. The number to the left of each row of data displayed indicates the symbol offset of the first character in the row.

NOTE

The following key menu is active for Power Graph & Metrics, Code Domain, or Demod Bits view when the Power window is active.

SPAN X Scale

- Scale/Div Allows you to set the horizontal scale by changing a spread code value. The range is 64.00 to 128.0 Walsh spread codes. The default setting is 64.00 Walsh spread codes.
- **Ref Value** Allows you to set the spread code reference value. The range is 0.000 to 64.00 Walsh spread codes with the scale at least 64 Walsh spread codes. The default setting is 0.000 Walsh spread code.
- **Ref Position** Allows you to set the reference position to either

Left, Ctr (center) or Right. The default setting is Left.

— Expand - Allows you to toggle the expanding function of the Walsh code domain power graph between On and Off. If set to On, the power graph is expanded horizontally to show 64 Walsh spread codes centered at the scale or the marker position. Upon toggling back to Off, the Walsh spread code range returns to the previous setting.

AMPLITUDE Y Scale

NOTE

The following additional keys appear in Power Graph & Metrics, Code Domain, or Demod Bits view when the Power window is active.

- Scale/Div Allows you to set the vertical scale by changing the value per division. The range is 0.10 to 20.0 dB per division. The default setting is 5.00 dB.
- Ref Value Allows you to set the reference value ranging from -250.00 to 250.00 dB. The default setting is 0.00 dB.

NOTE

The following additional keys become active when the Symbol Power window is active.

SPAN X Scale

- Scale/Div Allows you to set the horizontal scale by changing a symbol value per division. The range is 1.000 to 100.0 symbols per division with 0.01 symbol resolution. The default setting is 11.90 symbols. However, since Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Value** Allows you to set the symbol reference value ranging from 0.000 to 1000.0 symbols. The default setting is 0.000 symbol. However, since **Scale Coupling** default is **On**, this value is automatically determined by the measurement results. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- Ref Position Allows you to set the reference position to either Left, Ctr (center) or Right. The default setting is Left.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

AMPLITUDE Y Scale

- Scale/Div Allows you to set the vertical scale by changing the value per division. The range is 0.10 to 20.00 dB. The default setting is 5.00 dB. However, since Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Value Allows you to set the reference value ranging from -250.00 to 250.00 dB. The default setting is 0.00 dB. However, since Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Position Allows you to set the reference position to either Top,
 Ctr (center) or Bot (bottom). The default setting is Ctr.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

The following additional keys become active for I/Q Error (Quad View) view when either the EVM, Phase Error, or Mag Error window is active.

SPAN X Scale

- Scale/Div Allows you to set the horizontal scale by changing a symbol value per division. The range is 1.00 to 100.00 symbols per division with 0.01 symbol resolution. The default setting is 1.900 symbols. However, since Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Value Allows you to set the symbol reference value ranging from 0.00 to 1000.0 symbols. The default setting is 0.00 symbol. However, since Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Position Allows you to set the reference position to either Left, Ctr (center) or Right. The default setting is Left.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value

manually, Scale Coupling automatically changes to Off.

NOTE

The following additional keys become active for I/Q Error (Quad View) view when either the EVM, or Mag Error window is active.

AMPLITUDE Y Scale

- Scale/Div Allows you to set the vertical scale by changing the value per division. The range is 0.100 to 50.0% per division. The default setting is 5.00%. However, since Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Value Allows you to set the reference value ranging from -500.00 to 500.0%. The default setting is 0.00%. However, since Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Position Allows you to set the reference position to either Top, Ctr (center) or Bot (bottom). For the EVM graph, the default setting is Bot. For the Maq Error graph, the default setting is Ctr.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

The following additional keys become active for **I/Q** Error (Quad View) view when the Phase Error window is active.

• AMPLITUDE Y Scale

- Scale/Div Allows you to set the vertical scale by changing the value per division. The range is 0.0100 to 3600.0 degrees. The default setting is 5.00 degrees. However, since Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
 - Ref Value Allows you to set the reference value ranging from -36000.0 to 36000.0 degrees. The default setting is 0.00 degrees. However, since Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
 - Ref Position Allows you to set the reference position to either Top,
 Ctr (center) or Bot (bottom). The default setting is Ctr.

— Scale Coupling - Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

The following key appears when View/Trace is set to **Demod Bits**.

Print Setup Key

— Print Demod - Allows you to toggle the print function between Screen and Report. The default setting is Screen to dump a screen image. To create a text file of the demodulated data bits, press Print Setup, HCOPy Dest, select = Print To Key, and toggle the Print Demod key to Report. A text file named "demodbit.txt" will be written to the destination drive selected.

Marker Key Menu

Key Path: Code Domain, Marker

- **Select** Allows you to activate up to four markers with the corresponding numbers, respectively. The selected number is underlined and its function is defined by pressing the **Function** key. The default setting is 1.
- **Normal** Allows you to activate the selected marker to read the power level and symbol code with the code layer. The marker position is controlled either by manual adjustment of the RPG knob or by direct entry of the Walsh code number via the front panel keypad.
- **Delta** Allows you to read the differences in the power levels and symbols codes between the selected marker and the next.
- Function Allows you to set the selected marker function to Band Power, Noise, or Off. The default setting is Off. The Band Power and Noise functions are not available for this measurement.
- Trace Allows you to place the selected marker on the Code Domain Power, Symbol Power, Chip Power, EVM, Phase Error, or Mag Error trace. The default setting is Code Domain Power.
- **Off** Allows you to turn off the selected marker.
- Shape Allows you to access the menu to set the selected marker shape to Diamond, Line, Square, or Cross. The default setting is Diamond.
- Marker All Off Allows you to turn off all of the markers.
- Mkr->Despread While a maker is set on any active spread channel of the code domain power graph in the Power Graph and Metrics, Code

Domain (Quad View), or Demod Bits view, this key allows you to observe the Symbol Power and the I/Q Symbol Polar Vector graphs with the Walsh spread code number for that active channel in other windows. The I/Q symbol polar vector graph is displayed for the symbol power specified by the measurement interval and measurement offset.

NOTE

The front panel **Search** key performs a peak search when pressed. A marker will automatically be activated at the highest peak.

Troubleshooting Hints

Uncorrelated interference may cause CW interference like local oscillator feedthrough or spurs. Another uncorrelated noise may be due to I/Q modulation impairments. Correlated impairments can be due to the phase noise on the local oscillator in the upconverter or I/Q modulator of the UUT. These will be analyzed by the code domain measurements along with the QPSK EVM measurements and others.

A poor phase error indicates a problem at the I/Q baseband generator, filters, and/or modulator in the transmitter circuitry of the UUT. The output amplifier in the transmitter can also create distortion that causes unacceptably high phase error. In a real system, a poor phase error will reduce the ability of a receiver to correctly demodulate the received signal, especially in marginal signal conditions.

Intermod Keys

NOTE

You must have selected **Intermod** under the **MEASURE** key to access the following menus.

Meas Setup Key Menu

Key Path: Intermod, Meas Setup

- **Meas Mode** Allows you to specify one of the following measurement modes:
 - Auto Automatically identifies whether the intermodulation is caused by the two-tone or transmit intermodulation signals and that mode is labeled in the middle line of the Meas Mode key. If appropriate signals are not identified, "------" is shown instead.
 - **Two-tone** Measures the two-tone intermodulation products.
 - **Transmit IM** Measures the transmit intermodulation products.
- **Reference** Allows you to access the selection menu for the reference channel:
 - Auto Select this to set the reference channel automatically to the

- highest level signal in two base frequency signals.
- Lower Freq Select this to set the reference channel to the base lower frequency signal.
- **Upper Freq** Select this to set the reference channel to the base upper frequency signal.
- Average Select this to set the reference channel to the average frequency signals, (base lower frequency signal + base upper frequency signal)/2.
- **Span** Allows you to specify the frequency span in which intermodulation products are measured. The range is 100.000 kHz to 100.000 MHz with 1 Hz resolution.
- **Res BW** Allows you to specify the resolution bandwidth in which intermodulation products are measured, and to toggle this function between **Auto** and **Man**. If set to **Auto**, the resolution bandwidth is automatically set according to the frequency span. The range is 100.0 Hz to 300.000 kHz with 1 Hz resolution.
- Base Freq Auto Search Allows you to toggle the base frequency auto search function between **On** and **Off**. If set to **On**, the base frequency is automatically searched for.
- Base Freq Allows you to specify the base frequency values with the followings items if Base Freq Auto Search is set to Off:
 - **Lower Freq (f0)** Accepts a frequency value for the base lower frequency signal (f0).
 - **Upper Freq (f1)** Accepts a frequency value for the base upper frequency signal (f1).
 - **Delta Freq (f1-f0)** Automatically shows the difference between the base lower and base upper frequencies.
- Restore Meas Defaults Allows you to preset only the settings that are specific to the selected measurement by pressing Meas Setup, More (1 of 2), Restore Meas Defaults. This will set the measure setup parameters, for the currently selected measurement only, to the factory defaults.
- **Advanced** Allows you to access the menu to set the following items:
 - RRC Filter Allows you toggles the root-raised cosine filter between **On** and **Off**.
 - **Integ BW** Allows you to specify the integration bandwidth ranging from 100.0 kHz to 5.000 MHz.

Table 3-6 Intermodulation Measurement Defaults

Measurement Parameter	Factory Default Condition
Display: IM Prod Ref	On
Meas Setup:	
Avg Number	10; On
Avg Mode	Repeat
Meas Mode	Two-tone, Transmit IM, or; Auto
Reference	Lower Freq or Upper Freq; Auto
Span	$20.0000~\mathrm{MHz}$
Res BW	140.000 kHz; Auto
Base Freq Auto Search	On
Base Freq	(not available as Base Freq Auto Search is set to On)
Advanced	
RRC Filter	Off
Integ BW	1.23000 MHz

View/Trace Key Menu

The **View/Trace** key is not available for this measurement.

AMPLITUDE Y Scale

- Scale/Div Allows you to enter a numeric value to change the vertical display sensitivity. The range is 0.10 to 20.00 dB with 0.01 dB resolution. The default setting is 10.00 dB. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Value** Allows you to set the absolute power reference value ranging from -250.00 to 250.00 dBm with 0.01 dB resolution. The default setting is 10.00 dBm. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- Ref Position Allows you to set the reference position to either Top, Ctr (center), or Bot (bottom). The default setting is Top.

• Scale Coupling - Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or Restart softkey under the Meas Control menu, the scale coupling function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

Display Key Menu

Key Path: Intermod, Display

• IM Prod Ref - Allows you to toggle the intermodulation product lines display function between **On** and **Off**. If set to **On**, two pairs of dual vertical lines with the integration bandwidth are shown on the third-order or fifth-order intermodulation products display.

Marker Key Menu

Key Path: Intermod, Marker

- **Select 1 2 3 4** Allows you to activate up to four markers with the corresponding numbers, respectively. The selected number is underlined and its function is defined by pressing the **Function** key. The default is 1.
- **Normal** Allows you to activate the selected marker to read the time position and amplitude of the marker on the Signal envelope trace, for example. Marker position is controlled by the **RPG** knob.
- **Delta** Allows you to read the differences in time positions and amplitudes between the selected marker and the next.
- Function Allows you to define the selected marker function to be Band Power, Noise, or Off. The default is Off. For measuring Band Power, you need to place the Normal marker and then place the Delta marker.
- **Trace** Allows you to place the selected marker on the **Spectrum** trace.
- Off Allows you to turn off the selected marker.
- Shape Diamond Allows you to access the menu to define the selected marker shape to be Diamond, Line, Square, or Cross. The default is Diamond.
- Marker All Off Allows you to turn off all of the markers.

NOTE

The front panel **Search** key performs a peak search when pressed. A marker will automatically be activated at the highest peak.

Troubleshooting Hints

Intermodulation distortion (IMD) measurements can reveal the presence of degraded or defective parts in the transmitter section of the UUT. The following are examples of problems which, once indicated by IMD testing, may require further attention:

- Faulty DC power supply control of the transmitter power amplifier.
- RF power controller of the pre-power amplifier stage.
- I/Q control of the baseband stage.
- Reduction in the gain and output power level of the amplifier due to a degraded gain control and/or increased distortion.
- Degradation of amplifier linearity and other performance characteristics.

Power amplifiers are one of the final stage elements of a base or mobile transmitter and play a critical part in meeting the important power and spectral efficiency specifications. Measuring the spectral response of these amplifiers to complex wideband signals is crucial to linking amplifier linearity and other performance characteristics to the stringent system specifications.

Mod Accuracy (Composite Rho) Keys

NOTE

You must have selected **Mod Accuracy** under the **MEASURE** key to access the following menus.

Meas Setup Key Menu

Key Path: Mod Accuracy, Meas Setup

NOTE

The chip rate is fixed at 1.2288 MHz for SR1 in this measurement.

- **Avg Number** Allows you to change the number of N averages.
- Avg Mode Allows you to toggle the averaging mode between Exp (exponential) and Repeat. This selection only effects on the averaging result after the number of N averages is reached. The N is set using the Avg Number key.
 - Normal averaging: Normal (linear) averaging is always used until the specified number of N averages is reached. When the Measure key under Meas Control is set to Single, data acquisition is stopped when the number of N averages is reached, thus Avg Mode has no effect in the single measurement mode.
 - **Exponential averaging**: When **Measure** is set to **Cont**, data acquisition will continue indefinitely. Exponential averaging is used with a weighting factor of N (the displayed count of averages

- stops at N). Exponential averaging weights new data more heavily than old data, which allows tracking of slow-changing signals. The weighting factor N is set using the Avg Number key.
- Repeat averaging: When Measure is set to Cont, data acquisition will continue indefinitely. After the number of N averages is reached, all previous result data is cleared and the average count displayed is set back to 1. This is equivalent to being in Measure Single and pressing the Restart key each time the single measurement finishes.
- 1xEV-DV Active Chan Allows you to select the method by which the 1xEV-DV active channel is determined. The default is **Auto**.
 - **Auto** Select **Auto** to allow the instrument to determine the modulation method for the BTS signal. **Auto** results are best if the modulation scheme remains constant over the entire capture interval. If the modulation scheme changes, for best results, use the **Auto** (**Gated**) setting, below.
 - Auto (Gated) Select Auto (Gated) to allow the instrument to determine the modulation method within the slots defined by Meas Interval and Meas Offset settings. For best results, set the Meas Interval and Meas Offset parameters to confine the instrument to a portion of the signal of interest that has only one modulation scheme.
 - Combination Select Combination to allow the instrument to identify the active channel using a combination of Auto and a manual selection from the Predefined Active Channel key menu below. Predefined Active Channel will detect active channels with Walsh code length 32.
- Limits Allows you to access the menu to set the following limits:
 - RMS EVM (Composite) Allows you to set the limit for composite RMS EVM measurement result. The range is 0.00 to 50.00%.
 - **Peak EVM (Composite)** Allows you to set the limit for composite peak EVM measurement result. The range is 0.00 to 100.00%.
 - **Rho (Composite)** Allows you to set the limit for composite rho measurement result. The range is 0.00000 to 1.00000. For MS tests, the default value changes to 0.94400.
 - Peak Code Domain Error Allows you to set the limit for peak code domain error measurement result. The range is 0.0 to -100.0 dBm.
 - Timing Allows you to set the limit for timing tolerance tests used in the Power Timing & Phase view. The range is 0.0 to 500.0 ns. For MS tests, the default value changes to 10.0 ns.
 - Phase Allows you to set the limit for phase tolerance tests used

in the **Power Timing & Phase** view. The range is 0.00 to 3.00 rad.

- PN Offset Allows you to specify a multiplier for the Walsh code length of 64 chips. The range is 0 to 511. For example, set a value of 16 from the numeric keypad and press the Enter key. PN Offset 16 × 64 [chips] will be displayed in the screen annotation area.
- Sync Type If Transmit Diversity (TxDiv) is employed by BTS, this menu allows you to set the instrument to synchronize with antenna2 as well as antenna1 by selecting TxDiv F-PCICH. This selection is only available when Radio, Device is set to BTS.
 - **F-PCICH** Select **F-PCICH** to allow the instrument to synchronize with a BTS that does not use Transmit Diversity.
 - TxDiv F-PCICH Select TxDiv F-PCICH to allow the instrument to synchronize with a BTS that uses Transmit Diversity. If STS-TD or OTD mode is used, composite signals will not be synchronized. Timing Error may be measured using an external trigger.
- Long Code Mask Allows you to access the menu to set the long code mask to either 20000000000 or 0000000000. This value is used in the long code generation process. This key is available if **Device** is set to MS, otherwise this key is grayed out.
- Spectrum Allows you to toggle the spectrum function between Normal and Invert. When set to Invert, it conjugates the spectrum, which effectively inverts the quadrature component in demodulation. The correct setting (Normal or Invert) depends on whether the signal being input to the instrument has a high or low side mix.
- Restore Meas Defaults Allows you to preset only the settings that are specific to the selected measurement by pressing Meas Setup, More (1 of 2), Restore Meas Defaults. This will set the measure setup parameters, for the currently selected measurement only, to the factory defaults.
- **Advanced** Allows you to access the menu to change the following parameters:
 - **EVM Result I/Q Offset** Allows you to toggle the I/Q origin offset function between **Std** (standard) and **Exclude**. If set to **Std**, the measurement results for EVM, Rho, and code domain error take into account the I/Q origin offset. If set to **Exclude**, the measurement results for EVM, Rho, and code domain error do not take into account the I/Q origin offset, and the message "EVM excludes I/Q Offset" is displayed in the lower right-hand graph display area. The default setting is **Std**.
 - Active Set Th Allows you to toggle the active channel identification function between Auto and Man. If set to Auto, the active channels are determined automatically by the internal

- algorithm. If set to Man, the active channel identification for each code channel is determined by a user definable threshold ranging from 0.00 to -100.00 dB.
- **Chip Rate** Allows you to change the chip rate ranging from 1.10592 to 1.35168 MHz.
- Multi Channel Estimator Allows you to toggle the multi channel estimator function between On and Off. When set to On, the Power Timing and Phase view will be available, and the measurement accuracy will be improved, but measurement speed will be reduced.
- ADC Range Allows you to access the following selection menu to define one of the ADC ranging functions:
 - Auto Select this to automatically set the ADC range. For most FFT measurements, the auto feature should not be selected. An exception is when measuring a "bursty" signal, in which case Auto can maximize the time domain dynamic range, if FFT results are less important to you than time domain results.
 - **Auto Peak** Select this to set the ADC range automatically to the peak signal level. **Auto Peak** is a compromise that works well for both CW and burst signals.
 - Auto Peak Lock Select this to hold the ADC range automatically at the peak signal level. Auto Peak Lock is more stable than Auto Peak for CW signals, but should not be used for "bursty" signals.
 - Manual Allows you to access the selection menu of values to set the ADC range level. Ranges are 6 to +24 dB for E4406A with a 12-bit ADC, and None to +18 dB for PSA and E4406A with 14-bit ADC. Select None to retain the present value as set by Auto without selection of a range. Also note that manual ranging is best for CW signals.

Table 3-7 Modulation Accuracy (Composite Rho) Measurement Defaults


Measurement Parameter	Factory Default Condition
View/Trace	I/Q Measured Polar Vector
Display:	
I/Q Polar Vec/Constln	Vec & Constln
Chip Offset	10 chips
Chip Interval	1516 chips
+45 deg Rot	Off
Full Vector (Background)	Off
Meas Setup:	
Avg Number	10; On
Avg Mode	Repeat
1xEV-DV Active Channel	Auto
Limits:	
RMS EVM (Composite)	50.0 pcnt
Peak EVM (Composite)	100.0 pcnt
Rho (Composite)	0.91200
Peak Code Domain Error	0.0 dB
Timing	50.0 ns
Phase	0.05 rad
Trig Source	Free Run (Immediate)
PN Offset	0×64 [chips]
Long Code Mask (grayed out)	20000000000 (for MS tests)
Spectrum	Normal
Advanced	
EVM Result I/Q Offset	Std
Active Set Th	Auto
Chip Rate	1.228800 MHz
Multi Channel Estimator	Off
ADC Range	-6 (for E4406A with 12-bit ADC) None (for PSA and E4406A with 14-bit ADC)

View/Trace Key Menu

Key Path: Mod Accuracy, View/Trace

- I/Q Measured Polar Graph Provides a combination view of an I/Q measured polar vector graph and the summary data as shown in Figure 3-10 on page 166.
- *I/Q* Error (Quad-View) Four display windows show Mag Error, Phase Error, and EVM graphs, and the summary data for the composite rho, rms and peak EVM, peak code domain error with the code number, rms magnitude error, rms phase error, frequency error, and other parameters as shown in Figure 3-10.

Figure 3-10 Modulation Accuracy Measurement - I/Q Error Quad View



*Meas Setup: View/Trace = Power Timing and Phase Others = Factory Default Settings

*Input signal: 0.00 dBm, 9 channels of SR1, cdma2000 Rev 8

NOTE

Any one of these windows can be selected by the **Next Window** key and made full size using the **Zoom** key.

• Power Timing & Phase - Provides a measurement result for the active channels with power levels, timing, phase, and code domain errors in tabular form. Timing and phase are referenced to the Pilot channel as shown in Figure 3-11. To activate this view, press Meas Setup, More, Advanced, and toggle Multi Channel Estimator to ON.

Figure 3-11 Modulation Accuracy Measurement - Power, Timing, and Phase View



*Meas Setup: Advanced/Multi Channel Estimator = ON

View/Trace = Power Timing & Phase, Others = Factory default settings

*Input signal: -10.00 dBm, 9 channels of SR1, cdma2000 Rev 8

Display Key Menu

Key Path: Mod Accuracy, Display

- I/Q Polar Vec/Constln Allows you to access the following menu to select vector and/or constellation display.
 - **Vec & Constin** Sets to display the I/Q polar graph with the vector trajectory traces and constellation spots.
 - Vec Sets to display the I/Q polar graph with the vector trajectory traces.
 - **Constin** Sets to display the I/Q polar graph with the constellation spots.
- Chip Offset Allows you to specify the number of chips offset from the

Key Reference cdma2000 Measurement Keys

first chip in one power control group (PCG) for the I/Q waveforms. The range is 0 to 1535 chips.

- **Chip Interval** Allows you to specify the number of chips to be displayed from the offset chip specified by **Chip Offset**. The range is 1, or the number of chips specified by **Chip Offset**, to 1536 chips.
- **+45 deg Rot** Allows you to toggle the display rotation function between **On** and **Off**. If this is set to **On**, the I/Q polar vector or constellation graph is rotated by +45 degrees to see a rectangular display. The default setting is **Off**. This key does not affect the I/Q **Error (Quad View)** display.
- Full Vector (Background) Allows you to toggle the full vector display function between On and Off. If set to On, the full vector traces in gray color are displayed in the background of the polar vector solid traces in yellow. The default setting is Off. If View/Trace is set to I/Q Measured Polar ConstIn, this key is grayed out. This key does not affect the I/Q Error (Quad View) display.

NOTE

The following additional keys appear in **Power Timing & Phase** view when the Power Timing & Phase window is active.

- **Prev Page** Returns to the previous page of the measurement results.
- **Next Page** Moves to the next page of the measurement results.
- **Scroll Up** Moves one line upward on the current page of the measurement results each time it is pressed.
- **Scroll Down** Moves one line downward on the current page of the measurement results each time it is pressed.
- **First Page** Moves from the current page to the first page of the measurement results.
- Last Page Moves from the current page to the last page of the measurement results.

NOTE

The following additional keys become active for the I/Q Error (Quad-View) view when either the EVM, Phase Error, or Mag Error window is active.

SPAN X Scale

- Scale/Div Allows you to set the horizontal scale by changing a chip value per division. The range is 1.000 to 500000.0 chips per division with 0.001 chip resolution. The default setting is 152.7 chips per division. However, since the Scale Coupling default On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Value** Allows you to set the chip reference value ranging from

0.000 to 5000000.0 chips. The default setting is 0.000 chip. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement results. When you set a value manually, **Scale Coupling** automatically changes to **Off**.

- Ref Position Allows you to set the reference position to either Left, Ctr (center) or Right. The default setting is Left.
- **Scale Coupling** Allows you to toggle the scale coupling function between **On** and **Off**. The default setting is **On**. Upon pressing the **Restart** front panel key or the **Restart** softkey under the **Meas Control** menu, scale coupling automatically determines the scale per division and reference values based on the measurement results. When you set a value to either **Scale/Div** or **Ref Value** manually, **Scale Coupling** automatically changes to **Off**.

NOTE

The following additional keys become active for the I/Q Error (Quad-View) view when either the EVM, or Mag Error window is active.

AMPLITUDE Y Scale

- Scale/Div Allows you to set the vertical scale by changing the value per division. The range is 0.100 to 50.0% per division. The default setting is 5.00%. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Value Allows you to set the reference value ranging from 0.00 to 500.0%. The default setting is 0.00%. However, since the Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Position Allows you to set the reference position to either Top, Ctr (center) or Bot (bottom). For the EVM graph, the default setting is Bot. For the Mag Error graph, the default setting is Ctr.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, scale coupling automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

The following additional keys become active for the I/Q Error (Quad-View) view when the Phase Error window is active.

• AMPLITUDE Y Scale

— **Scale/Div** - Allows you to set the vertical scale by changing the

value per division. The range is 0.01 to 3600.0 degrees. The default setting is 5.00 degrees per division. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.

- Ref Value Allows you to set the reference value ranging from -36000 to 36000 degrees. The default setting is 0.00 degrees.
 However, since the Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Position Allows you to set the reference position to either Top,
 Ctr (center) or Bot (bottom). The default setting is Ctr.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, scale coupling automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

Marker Key Menu

Key Path: Mod Accuracy, Marker

- **Select** Allows you to activate up to four markers with the corresponding numbers, respectively. The selected number is underlined and its function is defined by pressing the **Function** key. The default setting is 1.
- Normal Allows you to activate the selected marker to read the
 magnitude or phase error and the number of chips of the marker
 position on the selected trace, for example. Marker position is
 controlled by the RPG knob.
- Delta Allows you to read the differences in the magnitude or phase errors and the number of chips between the selected marker and the next.
- Function Allows you to set the selected marker function to Band Power, Noise, or Off. The default setting is Off. The Band Power and Noise functions are not available for this measurement.
- Trace Allows you to place the selected marker on the EVM, Phase Error, or Mag Error trace. The default setting is EVM.
- Off Allows you to turn off the selected marker.
- Shape Allows you to access the menu to set the selected marker shape to Diamond, Line, Square, or Cross. The default setting is Diamond.

• Marker All Off - Allows you to turn off all of the markers.

Troubleshooting Hints

A poor phase error often indicates a problem with the I/Q baseband generator, filters, and/or modulator in the transmitter circuitry of the UUT. The output amplifier in the transmitter can also create distortion that causes unacceptably high phase error. In a real system, a poor phase error will reduce the ability of a receiver to correctly demodulate the received signal, especially in marginal signal conditions.

Occupied Bandwidth Keys

NOTE

You must have selected **Occupied BW** under the **MEASURE** key to access the following menus.

Meas Setup Key Menu

Key Path: Occupied BW, Meas Setup

- **Span** Allows you to specify the frequency span in which the total power is measured. The range is 10.000 kHz to 10.0000 MHz with 1 Hz resolution.
- **Res BW** Allows you to specify the resolution bandwidth value. The frequency range is 1.000 kHz to 1.00000 MHz. A narrower bandwidth will result in a longer data acquisition time but you will be able to examine the signal more closely.
- Limit Test Allows you to toggle the limit test function between On and Off, for occupied bandwidth measurements.
- Limit Allows you to specify the limit frequency value with which the limit test is made. The range is 10.000 kHz to 10.0000 MHz with 1 Hz resolution.
- Restore Meas Defaults Allows you to preset only the settings that are specific to the selected measurement by pressing Meas Setup, More (1 of 2), Restore Meas Defaults. This will set the measure setup parameters, for the currently selected measurement only, to the factory defaults.
- Advanced Allows you to access the selection menu of FFT windows.
 - **FFT Window** Allows you to access the following selection menu for FFT windows. If you are familiar with FFT windows, you can use other digital filters but the use of the flat top filter is recommended. Changes from the default setting may result in invalid data.
 - ☐ **Flat Top** Select this filter for best amplitude accuracy by reducing scalloping error.

Uniform - Select this filter to have no active window.
Hanning - Press this key to activate the Hanning filter.
Hamming - Press this key to activate the Hamming filter.
Gaussian (Alpha 3.5) - Press this key to activate the Gaussian
filter with an alpha of 3.5.
Blackman - Press this key to activate the Blackman filter.
Blackman-Harris - Press this key to activate the
Blackman-Harris filter.
K-B 70dB/90dB/110dB (Kaiser-Bessel) - Allows you to select one
of the Kaiser-Bessel filters with sidelobes at -70 , -90 , or
– 110 dB.

Table 3-8 Occupied Bandwidth Measurement Defaults

Measurement Parameter	Factory Default Condition
Meas Setup:	
Avg Number	10; On
Avg Mode	Repeat
Span	3.75000 MHz
Res BW	30.000 kHz
Trig Source	Free Run (Immediate)
Limit Test	On
Limit	1.48000 MHz
Advanced	
FFT Window	Gaussian (Alpha 3.5)

View/Trace Key Menu

The **View/Trace** key is not available for this measurement.

Display Key Menu

The **Display** key is not available for this measurement.

AMPLITUDE Y Scale Key Menu

Key Path: Occupied BW, AMPLITUDE Y Scale

- Scale/Div Allows you to enter a numeric value to change the vertical display sensitivity. The range is 0.10 to 20.00 dB with 0.01 dB resolution. The default setting is 10.00 dB. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Value Allows you to set the absolute power reference value

ranging from -250.00 to 250.00 dBm with 0.01 dB resolution. The default setting is 10.00 dBm. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to **Off**.

- Ref Position Allows you to set the reference position to either Top, Ctr (center), or Bot (bottom). The default setting is Top.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

Marker Key Menu

The Marker key is not available for this measurement.

Troubleshooting Hints

Any distortion such as harmonics or intermodulation, for example, produces undesirable power outside the specified bandwidth.

Shoulders on either side of the spectrum shape indicate spectral regrowth and intermodulation. Rounding or sloping of the top shape can indicate filter shape problems.

Power Statistics CCDF Keys

NOTE

You must have selected **Power Stat CCDF** under the **MEASURE** key to access the following menus.

Meas Setup Key Menu

Key Path: Power Stat CCDF, Meas Setup

- **Meas BW** Allows you to set the measurement bandwidth according to the channel bandwidth. The range is 10.000 kHz to 6.70000 MHz with 0.1 kHz resolution.
- **Counts** Allows you to set the accumulated number of sampling points for data acquisition. The range is 1.000 kpoints to 2.000 Gpoints with 1 or 10 kpoints resolution. While this key is activated, enter a value from the numeric keypad by terminating with one of the unit keys shown.
- Meas Interval Allows you to specify the time interval over which the measurement is made. The range is $100.0~\mu s$ to 10.00~m s with $1~\mu s$ resolution.

- Trig Source Allows you to select one of the trigger sources: Free Run (Immediate), Video (IF EnvIp), RF Burst (Wideband), Ext Front, Ext Rear, or Frame.
- Restore Meas Defaults Allows you to preset only the settings that are specific to the selected measurement by pressing Meas Setup, More (1 of 2), Restore Meas Defaults. This will set the measure setup parameters, for the currently selected measurement only, to the factory defaults.

Table 3-9 Power Statistics CCDF Measurement Defaults

Measurement Parameter	Factory Default Condition
Meas Setup:	
Meas BW	5.00000 MHz
Counts	10.0000 Mpoints
Meas Interval	1.000 ms
Trig Source	Free Run (Immediate)
Meas Control:	
Measure	Single
Display:	
Ref Trace	Off
Gaussian Line	On

View/Trace Key Menu

The **View /Trace** key is not available for this measurement.

Display Key Menu

Key Path: Power Stat CCDF, Display

- **Store Ref Trace** Allows you to copy the currently measured curve as the user-definable reference trace. The captured data will remain until the other mode is chosen. Pressing this key refreshes the reference trace.
- **Ref Trace** Allows you to toggle the reference trace display function between **On** and **Off**.
- **Gaussian Line** Allows you to toggle the Gaussian line display function between **On** and **Off**.

SPAN X Scale Key Menu

Key Path: Power Stat CCDF, SPAN X SCALE

• Scale/Div - Allows you to enter a numeric value to change the

horizontal display sensitivity. The range is 0.10 to 20.00 dB with 0.01 dB resolution. The default setting is 2.00 dB.

Marker Key Menu

Key Path: Power Stat CCDF, Marker

- **Select** Allows you to activate up to four markers with the corresponding numbers, respectively. The selected number is underlined and its function is defined by pressing the **Function** key. The default selection is 1.
- Normal Allows you to activate the selected marker to read the power level and probability of the marker position on the selected curve.
 Marker position is controlled by the RPG knob.
- **Delta** Allows you to read the differences in the power levels and probabilities between the selected marker and the next.
- Function Allows you to set the selected marker function to Band Power, Noise, or Off. The default setting is Off. The Band Power and Noise functions are not available for this measurement.
- Trace Allows you to place the selected marker on the Measured, Gaussian, or Reference curve. The default setting is Measured.
- Off Allows you to turn off the selected marker.
- Shape Allows you to access the menu to set the selected marker shape to Diamond, Line, Square, or Cross. The default setting is Diamond.
- Marker All Off Allows you to turn off all of the markers.

Troubleshooting Hints

The power statistics CCDF measurement can help in determining the signal power specifications used as design criteria for systems, amplifiers, and other components. For example, it can help determine the optimum operating point to adjust code timing for appropriate peak/average power ratio throughout the wide channel bandwidth of the transmitter for a cdma2000 system.

As this measurement becomes more widely used the correlation between CCDF curve degradation and digital radio system measurement parameters such as BER, FER, code domain power, and ACPR will become more established. Further studies will eventually yield standards for radio design by specifying the maximum allowed CCDF curve degradation for specific systems.

QPSK EVM Keys

NOTE

You must have selected **QPSK EVM** under the **MEASURE** key to access the following menus.

Meas Setup Key Menu

Key Path: QPSK EVM, Meas Setup

- **Meas Interval** Allows you to set the time interval over which the measurement is made. The range is 128 to 1536 chips.
- Restore Meas Defaults Allows you to preset only the settings that are specific to the selected measurement by pressing Meas Setup, More (1 of 2), Restore Meas Defaults. This will set the measure setup parameters, for the currently selected measurement only, to the factory defaults.
- Advanced Allows you to access the menu to change the following parameters:
 - **Chip Rate** Allows you to change the chip rate. The range is 1.10592 to 1.35168 MHz for SR1.
 - ADC Range Allows you to access the following selection menu to define one of the ADC ranging functions:
 - □ Auto Peak Select this to set the ADC range automatically to the peak signal level. Auto Peak is a compromise that works well for both CW and burst signals.
 - □ Auto Select this to set the ADC range automatically. For most FFT measurements, the auto feature should not be selected. An exception is when measuring a "bursty" signal, in which case Auto can maximize the time domain dynamic range, if FFT results are less important to you than time domain results.
 - □ Auto Peak Lock Select this to hold the ADC range automatically at the peak signal level. Auto Peak Lock is more stable than Auto Peak for CW signals, but should not be used for "bursty" signals.
 - Manual Allows you to access the selection menu of values to set the ADC range level. Ranges are 6 to +24 dB for E4406A with a 12-bit ADC, and None to +18 dB for PSA and E4406A with 14-bit ADC. Select None to retain the present value as set by Auto without selection of a range. Also note that manual ranging is best for CW signals.

Table 3-10 QPSK EVM Measurement Defaults


Measurement Parameter	Factory Default Condition
View/Trace	I/Q Measured Polar Vector
Display:	
I/Q Points	1280
Chip Dots	On
Meas Setup:	
Avg Number	10; On
Avg Mode	Repeat
Meas Interval	256 chips
Trig Source	Free Run (Immediate)
Advanced	
Chip Rate:	1.22880 MHz
ADC Range	- 6 dB (for E4406A w/ 12-bit ADC), None (for PSA and E4406A w/ 14-bit ADC)

View/Trace Key Menu

Key Path: QPSK EVM, View/Trace

- I/Q Measured Polar Vector Provides a combination view of an I/Q measured polar vector graph and the maximum and average summary data as shown in Figure 3-12 on page 178.
- I/Q Measured Polar Constln Provides a combination view of an I/Q measured polar constellation graph and the maximum and average summary data for the rms EVM, peak EVM, magnitude error, phase error, frequency error, and so forth in the text window as shown in Figure 3-12.

Figure 3-12 QPSK EVM Measurement - I/Q Polar Constellation View



*Meas Setup: View/Trace = I/Q Measured Polar Constln, Others = Factory default settings

*Input signal: -10.00 dBm, Pilot channel of SR1, cdma2000 Rev 8

— I/Q Error (Quad-View) - Four display windows show Mag Error, Phase Error and EVM graphs and the maximum and average summary data for the rms EVM, peak EVM, magnitude error, phase error, frequency error, and so forth in the text window as shown in Figure 3-13.




Figure 3-13 QPSK EVM Measurement - I/Q Error Quad View

*Meas Setup: View/Trace = I/Q Error (Quad View), Others = Factory default settings

*Input signal: -10.00 dBm, Pilot channel of SR1, cdma2000 Rev 8

NOTE

Any of these windows can be selected using the **Next Window** key and made full size using the **Zoom** key.

Display Key Menu

Key Path: QPSK EVM, Display

- **I/Q Points** Allows you to specify the number of displayed points for the I/Q waveforms. The range is 1 to 2560 points with the points per chip fixed at 5, depending on the **Meas Interval** setting. This key has no affect on the **I/Q Error (Quad View)** display.
- Chip Dots Allows you to toggle the chip dot display between On and Off. If set to On, the chip dots in yellow are overlaid on the I/Q polar graph. If View/Trace is set to I/Q Measured Polar ConstIn, this key is grayed out.

NOTE

The following additional keys appear in the I/Q Error (Quad-View) view when either the EVM, Phase Error, or Mag Error window is active.

SPAN X Scale

— **Scale/Div** - Allows you to set the horizontal scale by changing a chip value per division. The range is 1.00 to 500000.0 chips per

division. The default setting is 25.50 chips per division. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to **Off**.

- Ref Value Allows you to set the chip reference value ranging from 0.000 to 5000000.0 chips. The default setting is 0.000 chip.
 However, since the Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Position Allows you to set the reference position to either
 Left, Ctr (center) or Right. The default setting is Left.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, scale coupling automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

The following additional keys appear in the I/Q Error (Quad-View) view when either the EVM, or Mag Error window is active.

AMPLITUDE Y Scale

- Scale/Div Allows you to set the vertical scale by changing the value per division. The range is 0.100 to 50.0% per division. The default setting is 5.00%. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Value** Allows you to set the reference value ranging from 0.00 to 500.0%. The default setting is 0.00%. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement results. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- Ref Position Allows you to set the reference position to either Top,
 Ctr (center) or Bot (bottom). For the EVM graph, the default setting is Bot. For the Mag Error graph, the default setting is Ctr.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, scale coupling automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

180 Chapter 3

NOTE

NOTE

The following additional keys appear in the I/Q Error (Quad-View) view when the Phase Error window is active.

AMPLITUDE Y Scale

- Scale/Div Allows you to set the vertical scale by changing the value per division. The range is 0.01 to 3600 degrees. The default setting is 0.10 degrees per division. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Value Allows you to set the reference value ranging from -36000 to 36000 degrees. The default setting is 0.00 degrees.
 However, since the Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Position Allows you to set the reference position to either Top,
 Ctr (center) or Bot (bottom). The default setting is Ctr.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, scale coupling automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

Marker Key Menu

Key Path: QPSK EVM, Marker

- **Select** Allows you to activate up to four markers with the corresponding numbers, respectively. The selected number is underlined and its function is defined by pressing the **Function** key. The default setting is 1.
- Normal Allows you to activate the selected marker to read the magnitude or phase error and the number of chips of the marker position on the selected trace, for example. Marker position is controlled by the RPG knob.
- **Delta** Allows you to read the differences in the magnitude or phase errors and the number of chips between the selected marker and the next.
- Function Allows you to set the selected marker function to Band Power, Noise, or Off. The default setting is Off. The Band Power and Noise functions are not available for this measurement.
- Trace Allows you to place the selected marker on the EVM, Phase Error, or Mag Error trace. The default setting is EVM.

Key Reference cdma2000 Measurement Keys

- Off Allows you to turn off the selected marker.
- Shape Allows you to access the menu to set the selected marker shape to Diamond, Line, Square, or Cross. The default setting is Diamond.
- Marker All Off Allows you to turn off all of the markers.

Troubleshooting Hints

A poor phase error indicates a problem with the I/Q baseband generator, filters, and/or modulator in the transmitter circuitry of the UUT. The output amplifier in the transmitter can also create distortion that causes unacceptably high phase error. In a real system, a poor phase error will reduce the ability of a receiver to correctly demodulate the received signal, especially in marginal signal conditions.

Spectrum (Frequency Domain) Keys

NOTE

You must have selected **Spectrum** under the **MEASURE** menu to access these menus

Meas Setup Key Menu

Key Path: Meas Setup

- **Span** Modifies the frequency span. The range is 10 Hz to 10 MHz with 1 Hz resolution, depending on the **Res BW** setting. Changing the span causes the resolution bandwidth to change automatically, and will affect data acquisition time. For PSA Option 122 wideband operation, the maximum span is 80 MHz. For PSA Option 140 wideband operation, the maximum span is 40 MHz.
- **Res BW** Sets the resolution bandwidth for the FFT, and to toggle its mode between **Auto** and **Man** (manual). If set to **Auto**, the resolution bandwidth is set to **Span**/50 (2% of the span). If set to **Man**, you can enter a value ranging from 100.0 mHz to 3.00000 MHz. A narrower bandwidth will result in a longer data acquisition time.
- Wideband Setup (PSA Options 122 and 140 only.) configures the wideband hardware path.
 - Wideband IF Gain Sets the gain for the wideband IF path in 2 dB steps from 12 to +12 dB. You must have selected IF Path Wide. Increasing the gain can increase the amplitude of small signals as long as you don't overdrive the hardware. Wideband gain should usually be adjusted after setting the input attenuation.
 - Wideband Filtering Accesses the keys to configure the optional channel filter. The default is no filtering.
 - ☐ Filter Type Selects None for no filtering, or Raised Cosine, RRC (root-raised cosine), Nyquist, Root Nyquist, and Gaussian.
 - ☐ Filter Alpha Selects the filter alpha.
 - □ **Filter BW** Selects the filter bandwidth. Bandwidth is not entered as a frequency. The value is entered as a ratio of the current instrument sampling rate (that is, BW/sample rate).
 - Wideband Advanced These keys are only for the PSA Option 122 or 140 in wideband operation. Accesses the advanced settings for the wideband IF hardware path.

NOTE

Parameters under the **Wideband Advanced** key seldom need to be changed. Any changes from the default advanced values may result in invalid measurement data.

- □ ADC Corr Turning corrections on performs an ADC calibration to reduce the spectral image and applies the corrections.
- □ **IF Flat Corr** Turns IF flatness corrections on and off for the Option 122 or 140 wideband IF. This control is independent of the narrowband IF flatness control.
- □ Analog Filter Manually selects the 80 MHz (Option 122), 40 MHz (Option 140), or 36 MHz anti-alias filter, which overides the automatic selection of the bandwidth.
- □ WB ADC Dither Toggles the ADC dither function on/off.. The "ADC dither" refers to the introduction of noise to the digitized steps of the analog-to-digital converter; the result is an improvement in amplitude accuracy. The wideband dither control does not affect the ADC dither in the narrowband IF path.
- ☐ **FFT Window** Accesses the following selection menu. Unless you are familiar with FFT windows, use the flat top filter (the default filter).
 - **Flat Top** Selects this filter for best amplitude accuracy by reducing scalloping error.
 - **Uniform** Select this filter to have no window active by using the uniform setting.
 - **Hanning** Press this key to activate the Hanning filter.
 - **Hamming** Press this key to activate the Hamming filter.
 - **Gaussian** Press this key to activate the Gaussian filter with the roll-off factor (alpha) of 3.5.
 - **Blackman** Press this key to activate the Blackman filter.
 - **Blackman Harris** Press this key to activate the Blackman Harris filter.
 - K-B 70dB/90dB/110dB (Kaiser-Bessel) Select one of the Kaiser-Bessel filters with sidelobes at -70, -90, or -110 dBc.
- ☐ **FFT Size** Accesses the menu to change the following parameters:
 - **Length Ctrl** Toggles the FFT and window length setting function between **Auto** and **Man** (manual).
 - **Min Pts in RBW** Sets the minimum number of data points that will be used inside the resolution bandwidth. The range is 0.10 to 100.00 points with 0.01 resolution. This key is grayed out if **Length Ctrl** is set to **Man**.
 - Window Length Enters the FFT window length in the

number of capture samples, ranging from 8 to 1048576. This length represents the actual quantity of I/Q samples that are captured for processing by the FFT ("Capture Time" is the associated parameter shown on the screen). This key is grayed out if **Length Control** is set to **Auto**.

— **FFT Length** - Enters the FFT length in the number of captured samples, ranging from 8 to 1048576. The FFT length setting is automatically limited so that it is equal to or greater than the FFT window length setting. Any amount greater than the window length is implemented by zero-padding. This key is grayed out if **Length Control** is set to **Auto**.

Average

- Avg Number llows you to select whether averages are made or not, and allows you to change the number of N averages that are made.
- Avg Mode Allows you to choose either Exp (exponential) or Repeat. This selection only affects the averaging result after the number of N averages is reached. The N is set using the Avg Number key.
 - □ Normal averaging: Normal (linear) averaging is always used until the specified number of N averages is reached. When the Measure key under Meas Control is set to Single, data acquisition is stopped when the number of N averages is reached, thus Avg Mode has no effect in the single measurement mode.
 - □ **Exponential averaging**: When **Measure** is set to **Cont**, data acquisition will continue indefinitely. Exponential averaging is used with a weighting factor of N (the displayed count of averages stops at N). Exponential averaging weights new data more heavily than old data, which allows tracking of slow-changing signals. The weighting factor N is set using the **Avg Number** key.
 - □ Repeat averaging: When Measure is set to Cont, data acquisition will continue indefinitely. After the number of N averages is reached, all previous result data is cleared and the average count displayed is set back to 1. This is equivalent to being in Measure Single and pressing the Restart key each time the single measurement finishes.
- Avg Type Accesses the menu of the following average types only for making spectrum (frequency domain) and waveform (time domain) measurements:
 - ☐ **Pwr Avg (RMS)** Executes the true power averaging which is calculated by averaging the rms voltage. This is the most

accurate type. ☐ Log-Pwr Avg (Video) - Simulates the traditional spectrum analyzer type of averaging by calculating the log of the power. This type of averaging will underestimate the power when the signal is noise-like. □ Voltage Avg - Executes voltage averaging. ☐ Maximum - Captures peak voltage data. Simulates the traditional spectrum analyzer peak hold function. ☐ Minimum - Captures the minimum voltage data, similar to the maximum function. - Time Avg Num - Changes the number of time averages to be made when using the Option 122 or 140 wideband hardware (PSA) only). This averaging requires a frame trigger and is much faster than the standard averaging. This hardware averaging is done on the complex voltage time trace data before any measurement application averaging is done. Both types of averaging can be done on the same measurement data. When time averaging is being done, each trace update represents N fresh data acquisitions averaged together, where N is the number of averages. You cannot access the individual time records that are being averaged in the hardware averager. NOTE If your triggering is not set correctly, the signal can be averaged away to nothing. A HW Average message is displayed to show that the averaging is on. Trig Source **Key path: Meas Setup, Trig Source** NOTE Changing the selection in the **Trig Source** menu alters the trigger source for the selected measurement only. — Free Run (Immediate) - A trigger occurs at the time the data is requested, completely asynchronous with the RF or IF signal. — **Video (Envlp)** - An internal IF envelope trigger that occurs at the absolute threshold level of the IF signal level.

- RF Burst (Wideband) An internal wideband RF burst trigger that has automatic level control for burst signals. It triggers at the level that is set relative to the peak RF signal (12 MHz bandwidth) input level. (Not available for Option 122 or 140 when using the wideband IF path.)
- **Ext Front** Activates the front panel external trigger input (**EXT TRIGGER INPUT**) port. The external signal must be between -5.00

and +5.00 V with 1 or 10 mV resolution.

- Ext Rear Activates the rear-panel external trigger input
 (TRIGGER IN) port. The external signal must be between 5.00 and +5.00 V with 1 or 10 mV resolution.
- Frame Uses the internal frame clock to generate a trigger signal. The clock parameters are controlled under the Mode Setup key or the measurement firmware, but not both. Refer to the specific measurement section for details.
- **Line** Sets the trigger to the internal line mode. Sweep triggers occur at intervals synchronous to the line frequency. See the specific measurement section for details.
- IF Path (Only for PSA with Option B7J and either Option 122 or 140 installed.) Selects either the standard narrowband IF hardware path or the wideband hardware.
- Restore Meas Defaults Presets only the settings that are specific to the selected measurement by pressing Meas Setup, More (1 of 2),
 Restore Meas Defaults - This will set the measure setup parameters, for the currently selected measurement only, to the factory defaults.
- (Narrowband) Advanced Accesses the menu to change the following parameters.

NOTE

The advanced features should be used only if you are familiar with their operation. Changes from the default values may result in invalid data.

The Narrowband key is only present if you have Option B7J and either Option 122 or 140 installed. Parameters that are under the (Narrowband) Advanced key only affect the standard narrow band IF path. The wideband IF advanced functions are found under the Wideband Advanced key.

- **Pre-ADC BPF** Toggles the pre-ADC bandpass filter function between **On** and **Off**. The pre-ADC bandpass filter is useful for rejecting nearby signals, so that sensitivity within the span range can be improved by increasing the ADC range gain.
- Pre-FFT Filtr Toggles the pre-FFT filter between Flat (flat top) and Gaussian. The pre-FFT filter defaults to a flat top filter which has better amplitude accuracy. The Gaussian filter has better pulse response.
- **Pre-FFT BW** Toggles the pre-FFT bandwidth function between **Auto** and **Man** (manual). The pre-FFT bandwidth filter can be set between 1 Hz and 10 MHz. If set to **Auto**, this pre-FFT bandwidth is nominally 50% wider than the span. This bandwidth determines the ADC sampling rate.
- FFT Window Accesses the following selection menu. Unless you

		e familiar with FFT windows, use the flat top filter (the default ter).
		Flat Top - Selects this filter for best amplitude accuracy by reducing scalloping error.
		Uniform - Select this filter to have no window active by using the uniform setting.
		Hanning - Press this key to activate the Hanning filter.
		Hamming - Press this key to activate the Hamming filter.
		$\begin{tabular}{ll} \textbf{Gaussian - Press this key to activate the Gaussian filter with the roll-off factor (alpha) of 3.5. \end{tabular}$
		Blackman - Press this key to activate the Blackman filter.
		Blackman Harris - Press this key to activate the Blackman Harris filter.
		K-B 70dB/90dB/110dB (Kaiser-Bessel) - Select one of the Kaiser-Bessel filters with sidelobes at – 70 , – 90 , or – 110 dBc.
_	FF	\boldsymbol{T} \boldsymbol{Size} - $\boldsymbol{Accesses}$ the menu to change the following parameters:
		Length Ctrl - Toggles the FFT and window length setting function between Auto and Man (manual).
		$\begin{array}{l} \textbf{Min Pts in RBW} \text{ -} Sets \text{ the minimum number of data points that} \\ \text{will be used inside the resolution bandwidth. The range is } 0.10 \\ \text{to } 100.00 \text{ points with } 0.01 \text{ resolution.} \end{array}$
		Window Length - Enters the FFT window length in the number of capture samples, ranging from 8 to 1048576 . This length represents the actual quantity of I/Q samples that are captured for processing by the FFT ("Capture Time" is the associated parameter shown on the screen). This key is grayed out if Length Control is set to Auto.
		FFT Length - Enters the FFT length in the number of captured samples, ranging from 8 to 1048576. The FFT length setting is automatically limited so that it is equal to or greater than the FFT window length setting. Any amount greater than the window length is implemented by zero-padding. This key is grayed out if \textbf{Length} $\textbf{Control}$ is set to \textbf{Auto} .
_		OC Range - Accesses the menu to define one of the following ADC
		nging functions:
		Auto - Sets the ADC range automatically. For most FFT spectrum measurements, the auto feature should not be selected. An exception is when measuring a signal which is "bursty", in which case auto can maximize the time domain dynamic range, if FFT results are less important to you than

time domain results.

- ☐ Auto Peak Sets the ADC range automatically to the peak signal level. Auto peak is a compromise that works well for both CW and burst signals.
- ☐ Auto Peak Lock Select this to hold the ADC range automatically at the peak signal level. Auto peak lock is more stable than auto peak for CW signals, but should not be used for "bursty" signals.
- ☐ Manual Accesses the selection menu of values, -6 to +24 dB for E4406A or None to +18 dB for PSA, to set the ADC range level. Also note that manual ranging is best for CW signals.
- Data Packing Selects Auto (the default) or the Short (16 bit), Medium (24 bit) and Long (32 bit) methods of data packing. The short, medium, and long methods are not compatible with all settings and should not be used unless you are familiar with data packing methods. Auto is the preferred choice.
 - □ **Auto** The data packing value most appropriate for current instrument settings is selected automatically.
 - □ Short (16 bit) Select this to pack data every 16 bits.
 - ☐ Medium (24 bit) Select this to pack data every 24 bits.
 - □ Long (32 bit) Select this to pack data every 32 bits.
- ADC Dither Toggles the ADC dither function between Auto, On, and Off. When set to Auto (the default), the ADC dither function will be activated when a narrow bandwidth is being measured, and deactivated when a wide bandwidth is being measured. "ADC dither" refers to the introduction of noise to the digitized steps of the analog-to-digital converter; the result is an improvement in amplitude accuracy. Use of the ADC dither, however, reduces dynamic range by approximately 3 dB.
- **Decimation** Toggles the decimation function between **Auto** and **Man**, and to set the decimation value. **Auto** is the preferred setting, and the only setting that guarantees alias-free FFT spectrum measurements. If you are familiar with the decimation feature, you can change the decimation value by setting to **Man**, but be aware that aliasing can result in higher values. Decimation numbers 1 to 1000 describe the factor by which the number of points are reduced. The default setting is 0, which results in no data point reduction. Decimation by 3 keeps every 3rd sample, throwing away the 2 in between.
- IF Flatness Toggles the IF flatness function between On and Off. If set to On (the default), the IF flatness feature causes background amplitude corrections to be performed on the FFT spectrum. The Off setting is used for adjustment and

cdma2000 Measurement Keys

troubleshooting of the test instrument.

The following table shows the factory default settings for spectrum (frequency domain) measurements.

 Table 3-11
 Spectrum (Frequency Domain) Measurement Defaults

Measurement Parameter	Factory Default Condition
Trace Display	All
Res BW	20.0000 kHz; Auto
Averaging: Avg Number Avg Mode Avg Type Time Avg Num (Opt. 122 or 140) Trig Source	25; On Exp Log-Pwr Avg (Video) 1 Free Run (Immediate)
Region/Limits:	Free Run (Immediate)
Region Upper Mask Lower Mask Offset Start Offset Stop Interval	A A: – 40.00 dB; On A: – 100.00 dB; Off A: – 667.0 μs A: – 25.0 μs A: 642.0 μs
IF Path (requires Option B7J and Option 122 or 140)	Narrow
Wideband IF Gain (Opt. 122 or 140)	0.00 dB
Wideband Filtering (Opt. 122 or 140 Filter Type Filter Alpha Filter BW	None 0.30 0.50
Spectrum View: SPAN AMPLITUDE Y Scale - Scale/Div	1.000 MHz (VSA), 10.000 MHz (PSA) 10.00 dB
I/Q Waveform View: Capture Time AMPLITUDE Y Scale - Scale/Div	188.00 μs 100.0 mV
Spectrum Linear View: SPAN AMPLITUDE Y Scale - Scale/Div	(for E4406A) 1.00000 MHz 100.0 mV
I and Q Waveform View: Capture Time AMPLITUDE Y Scale - Scale/Div	(for E4406A) 188.00μs 100.0 mV

Table 3-11 Spectrum (Frequency Domain) Measurement Defaults

Measurement Parameter	Factory Default Condition
I/Q Polar View: I/Q Scale/Div I or Q Origin	(for E4406A) 100.0 mV 0.00 V
(Narrowband) Advanced	
Pre-ADC BPF	On
Pre-FFT Filter	Flat
Pre-FFT BW	1.55000 MHz; Auto
FFT Window	Flat Top (High Amptd Acc)
FFT Size: Length Control Min Points/RBW Window Length FFT Length	Auto 3.100000 706 (VSA), 566 (PSA) 1024
ADC Range	Auto Peak
Data Packing	Auto
ADC Dither	Auto
Decimation	0; Auto
IF Flatness	On
Wideband Advanced (Option 122 of	or 140 PSA only)
ADC Correction	On
IF Flatness Corrections	On
Analog Filter	Auto, 80 MHz (Opt 122), 40 MHz (Opt 140)
WB ADC Dither	On
FFT Window	Flat Top (High Amptd Acc)
FFT Size: Length Control Min Points/RBW Window Length FFT Length	Auto 3.100 236 (Opt. 122), 118 (Opt. 140) 256 (Opt. 122), 128 (Opt. 140)

Key Reference cdma2000 Measurement Keys

View/Trace Key Menu

The **View/Trace** key allows you to select the desired view of the measurement from the following. You can use the Next Window key to move between the multiple windows (if any) and make it full size by pressing the **Zoom** key.

• **Spectrum** - Provides a combination view of the spectrum graph in parameters of power versus frequency with semi-log graticules, and the I/Q waveform graph in parameters of voltage and time. Changes to frequency span or power will sometimes affect data acquisition. This is equivalent to changing the selected window with the **Next** key.

Figure 3-14 Spectrum Measurement - Spectrum and I/Q Waveform (Default View)




Figure 3-15 Spectrum Measurement - Spectrum and I/Q Waveform (Default) View





Figure 3-16 Spectrum Measurement - Spectrum and I/Q Waveform (Default View)



*Meas Setup: Span = 3.000 MHz, Capture Time = 62.70 µs, Others = Factory default settings

*Input signal: - 10.00 dBm, Pilot channel of SR1, cdma2000 Rev 8

Figure 3-17 Spectrum Measurement - Spectrum and I/Q Waveform (Default View)





Figure 3-18 Spectrum Measurement - Spectrum and I/Q Waveform (Default View)



*Meas Setup: Span = 3.000 MHz, Capture Time = 62.70 µs, Others = Factory default settings

*Input signal: -10.00 dBm, Pilot channel, 1xEV-DO

The Spectrum measurement result should look like the above figure. The measurement result values are shown in the summary result window.

- Spectrum (Time Domain) I/Q Waveform (Key for PSA only) This graph is shown below the Spectrum graph in the default dual-window display. I/Q Waveform provides a view of the I/Q waveform in parameters of voltage versus time in linear scale. Changes to sweep time or resolution bandwidth can affect data acquisition. Pressing this button is equivalent to pressing the Next Window button on the front panel. Press the Zoom key to view this display full-screen.
- **Spectrum Linear** (for E4406A) Provides a view of the spectrum graph in parameters of voltage versus frequency in linear scale. Changes to frequency span or voltage can affect data acquisition.

Figure 3-19 Spectrum Measurement - Linear Spectrum View (for E4406A)





Figure 3-20 Spectrum Measurement - Linear Spectrum View (for E4406A)



*Meas Setup: View/Trace = Spectrum Linear,

Span = 3.000 MHz,

Y Scale/Div = 5.00 mV, Ref Value = 30.0 mV,

Others = Factory default settings

*Input signals: -10.00 dBm, 9 channels of SR1, cdma2000 Rev 8




Figure 3-21 Spectrum Measurement - Linear Spectrum View (for E4406A)

*Meas Setup: View/Trace = Spectrum Linear,

Span = 3.000 MHz,

Y Scale/Div = 10.00 mV, Ref Value = 50.0 mV,

Others = Factory default settings

*Input signals: - 10.00 dBm, Pilot channel, 1xEV-DO

NOTE

(for E4406A) For the widest spans, the I/Q window becomes just "ADC time domain samples", because the I/Q down-conversion is no longer in effect. This is not the case for E4406A Option B7C if the Input Port is set to either I/Q, I only, or Q only and you have connected baseband I/Q signals to the I/Q INPUT connectors.

• I and Q Waveform - (for E4406A) Provides individual views of the I and Q signal waveform windows in parameters of voltage versus time.

To select the I or Q trace view, press the **Next** key at the bottom of the display. The selected window will have a green outline. To view the window full size press the **Zoom** key.

Figure 3-22 Spectrum Measurement - I and Q Waveform View (for E4406A)






Figure 3-23 Spectrum Measurement - I and Q Waveform View (for E4406A)



*Meas Setup: View/Trace = I and Q Waveform, AMPLITUDE Y Scale = 5.00 mV, Others = Factory default settings

^{*}Input signals: - 10.00 dBm, 9 channels of SR1, cdma2000 Rev 8


Figure 3-24 Spectrum Measurement - I and Q Waveform View (for E4406A)



*Meas Setup: View/Trace = I and Q Waveform, Others = Factory default settings

*Input signals: - 10.00 dBm, Pilot channel, 1xEV-DO

Figure 3-25 Spectrum Measurement - I and Q Waveform View (for E4406A)



• I/Q Polar - (for E4406A) Provides a view of the I/Q signal displayed in a polar vector graph.

Figure 3-26 Spectrum Measurement - I/Q Polar View (for E4406A)





Figure 3-27 Spectrum Measurement - I/Q Polar View (for E4406A)




*Meas Setup: View/Trace = I/Q Polar,

Others = Factory default settings

*Input signals: -10.00 dBm, Pilot channel of SR1, cdma2000 Rev 8

Figure 3-28 Spectrum Measurement - I/Q Polar View (for E4406A)




*Meas Setup: View/Trace = I/Q Polar,

Others = Factory default settings

*Input signals: - 10.00 dBm, Pilot channel, 1xEV-DO

Figure 3-29 Spectrum Measurement - I/Q Polar View (for E4406A)



- **Trace Display** Press this key to reveal the trace selection menu. The currently selected trace type is shown on the **Trace Display** key.
 - All Views both the current trace and the average trace.
 - Average Views only the average trace (in blue color). See the
 Meas Setup, Average keys to select different types of averaging.
 - **Current** Views only the trace (in yellow color) for the latest data acquisition.
 - I Trace (for E4406A) Views only the I signal trace.
 - **Q Trace** (for E4406A) Views only the **Q** signal trace.

SPAN X Scale Key Menu

NOTE

The Spectrum or Linear Spectrum (for E4406A) window must be active in the **Spectrum** or **Spectrum Linear** (for E4406A) view to access the following **Span X Scale** key menu:

- **Span** Modifies the frequency span. The range is 10.000 Hz to 10.000 MHz with 1 Hz resolution, depending on the **Res BW** setting. Changing the span causes the resolution bandwidth to change automatically, and will affect data acquisition time. The **Span** key is also accessible under the **Meas Setup** menu.
- **IF Path** This key is only available if you have Option B7J and either Option 122 or 140. Selects either the standard narrowband IF hardware path or the wideband hardware path.

NOTE

The I/Q Waveform (for E4406A) window must be active in the Spectrum or Spectrum Linear (for E4406A) view to access the following Span X Scale key menu:

- Scale/Div Sets the horizontal scale by changing a time value per division. The range is 1.00 ns to 1.00 s per division. The default setting is 18.8 ms per division. However, since the Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Value** Sets the reference value ranging from -1.00 to 10.0 s. The default setting is 0.00 s. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement results. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- Ref Position Sets the reference position to either Left, Ctr (center) or Right. The default setting is Left.
- Scale Coupling Toggles the scale coupling function between **On** and

Off. The default setting is **On**. Upon pressing the **Restart** front-panel key or **Restart** softkey under the **Meas Control** menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

The I/Q Polar window must be active in the I/Q Polar view (for E4406A), for the SPAN X Scale key to access the following menu:

- I/Q Scale/Div Sets the vertical and horizontal scales by changing the value per division. The range is 1.00 nV to 20.00 V per division. The default setting is 100.0 mV.
- I Origin or Q Origin Sets the reference value ranging from −250.00 to 250.00 V. The default setting is 0.00 V.

AMPLITUDE Y Scale Key Menu

NOTE

The Spectrum or Linear Spectrum (for E4406A) window must be active in the Spectrum or Spectrum Linear (for E4406A) view to access the following **AMPLITUDE** Y Scale key menu:

- Scale/Div Sets the vertical scale by changing an amplitude value per division. The range is 0.10 dB to 20.00 dB per division or 1.00 nV to 20.00 V per division, respectively. The default setting is 10.00 dB or 100.0 mV. However, since the Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- **Ref Value** Sets the reference value ranging from -250.00 to 250.00 dBm or -250.00 to 250.00 V. The default setting is 0.00 dBm or 0.00 V. However, since the Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Position** Sets the reference position to either **Top**, **Ctr** (center) or Bot (bottom). The default setting is Ctr.
- **Scale Coupling** Toggles the scale coupling function between **On** and Off. The default setting is On. Upon pressing the Restart front-panel key or **Restart** softkey under the **Meas Control** menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

The I or Q Waveform window must be active in the I and Q Waveform view (for E4406A) for the AMPLITUDE Y Scale key to access the following menu:

Chapter 3 203

NOTE

Key Reference cdma2000 Measurement Keys

- Scale/Div Sets the vertical scale by changing the amplitude value per division. The range is 1.00 nV to 20.00 V per division. The default setting is 100.0 mV. However, since the Scale Coupling default is On, this value is automatically determined by the measurement results. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Value** Sets the reference value ranging from -250.00 to 250.00 V. The default setting is 0.00 V. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement results. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- Ref Position Sets the reference position to either Top, Ctr (center) or Bot (bottom). The default setting is Ctr.
- Scale Coupling Toggles the scale coupling function between On and Off. The default setting is On. The Restart front-panel key or Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values by the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

The I/Q Polar window must be active in the **I/Q Polar** view (for E4406A), for the **AMPLITUDE Y Scale** key to access the following menu:

- I/Q Scale/Div Sets the vertical and horizontal scales by changing the value per division. The range is 1.00 nV to 20.00 V per division. The default setting is 100.0 mV.
- I Origin or Q Origin Sets the reference value ranging from -250.00 to 250.00 V. The default setting is 0.00 V.

Display Key Menu

The Display Key is not active for this measurement.

Marker Key Menu

- **Select 1 2 3 4** Activates up to four markers with the corresponding numbers, respectively. The selected number is underlined and its function is defined by pressing the **Function** key. The default is 1.
- **Normal** Activates the selected marker to read the frequency and amplitude of the marker position on the spectrum trace. Marker position is controlled by the **RPG** knob.
- **Delta** Reads the differences in frequency and amplitude between the selected marker and the next marker.
- Function Off Selects the marker function to be Band Power, Noise, or Off. The default is Off. If set to Band Power, you need to select Delta.

- Trace Spectrum Places the selected marker on the Spectrum,
 Spectrum Avg, Spectrum Linear (for E4406A), Spectrum Avg Linear (for E4406A), I/Q Waveform, I Waveform (for E4406A), or Q Waveform (for E4406A) trace. The default is Spectrum.
- Off Turns off the selected marker.
- Shape Diamond Accesses the menu to define the selected marker shape to be Diamond, Line, Square, or Cross. The default shape is Diamond.
- Marker All Off Turns off all of the markers.

Peak Search Key

The front panel Search key performs a peak search when pressed. A marker will automatically be activated at the highest peak.

Spectrum Emission Mask Keys

NOTE


You must have selected **Spectrum Emission Mask** under the **MEASURE** key to access the following menus.

Meas Setup Key Menu

Key Path: Spectrum Emission Mask, Meas Setup


- **Meas Interval** Allows you to specify the measurement interval ranging from 0.1 to 10.0 ms with 0.001 ms resolution.
- **Ref Channel** Allows you to define the reference channel in the following terms:
 - **Chan Integ BW** Allows you to specify the channel integration bandwidth ranging from 100.0 kHz to the setting of **Chan Span**.
 - **Chan Span** Allows you to specify the channel span to be measured ranging from 100.000 kHz to 10.0000 MHz.
 - **Step Freq** Allows you to specify the step frequency to make measurements ranging from 100.0 Hz to 7.50000 MHz, and to toggle this function between **Auto** and **Man**. If set to **Auto**, this is automatically set to half the **Res BW** setting. If set to **Man**, the step frequency is manually set independently from **Res BW**.


— **Res BW** - Allows you to specify the resolution bandwidth ranging from 1.000 kHz to 7.50000 MHz, and to toggle this function between **Auto** and **Man**. If set to **Auto**, **Res BW** is automatically set to one 50th of **Chan Integ BW**. The next figure illustrates the relationship between **Meas BW**, **Start Freq**, and **Stop Freq**.



- Meas BW Allows you to specify a multiplier of Res BW for the measurement integration bandwidth, ranging from 1 to an integer derived form (Start Freq - Stop Freq)/Res BW. Refer to the illustration under Res BW above.
- Spectrum Segment Allows you to toggle the frequency spectrum segment between Offset and Region. Upon selecting Offset, spectrum emission mask measurements are made. Upon selecting Region, spurious emission measurements are made. Depending on this selection, either the Offset/Limits menu or the Region/Limits menu is available.
- Offset/Limits Allows you to access the menus to change the following parameters for offset frequency settings and pass/fail tests, if Spectrum Segment is set to Offset. Table 3-12 on page 209 and Table 3-13 on page 209 show the default settings for BTS and MS measurements, respectively.

When **Spectrum Segment** is set to **Offset**, the frequency values at Start (Hz) and Stop (Hz) are shown as Offset to Edge in the measurement result window considering the measurement bandwidth, as it is different from the offset frequency center as





- Offset Allows you to access the memory selection menu from A to E to store up to 5 sets of values for Start Freq, Stop Freq, Step Freq, Res BW, and Limits. Only one memory selection at a time (A, B, C, D, or E) is shown on this key label.
- **Start Freq** Allows you to specify the start frequency, and to toggle this function between **On** and **Off**, for each offset. The frequency range is 10.0000 kHz to 100.000 MHz with 100 Hz resolution. However, the high end is limited to the setting of **Stop Freq**. When **Spectrum Segment** is set to **Offset**, the frequency values at Start (Hz) are shown as Offset to Edge in the measurement result window considering the measurement bandwidth.
- Stop Freq Allows you to specify the stop frequency ranging from 10.0000 kHz to 100.000 MHz with 100 Hz resolution, for each offset. The low end is limited to the setting of Start Freq. When Spectrum Segment is set to Offset, the frequency values at Stop (Hz) are shown as Offset to Edge in the measurement result window considering the measurement bandwidth.
- Step Freq Allows you to specify the step frequency ranging from (Stop Freq – Start Freq)/10000 to (Stop Freq – Start Freq), and to toggle this function between Auto and Man, for each offset. If set to Auto, the step frequency is automatically set to half the Res BW setting.
- Res BW Allows you to specify the resolution bandwidth ranging from 300.0 Hz to 7.50000 MHz with 100 Hz resolution, and to toggle this function between Auto and Man, for each offset. If set to Auto, the resolution bandwidth is automatically set to one 50th of (Stop Freq – Start Freq).

- Meas BW Allows you to specify a multiplier of Res BW for the measurement integration bandwidth ranging from 1 to (Stop Freq - Start Freq)/Res BW.
- **Relative Atten** Allows you to enter an attenuation value to adjust the relative level limits ranging from -40.00 to 40.00 dB with 0.01 dB resolution. The default attenuation is the same as the one used by **Ref Channel**.
- Offset Side Allows you to specify which offset side is to be measured. Selections are Neg (negative offset), Both, and Pos (positive offset).
- **Limits** Allows you to access the following menu to set up absolute and relative limit levels and fail conditions for each offset:
 - □ **Abs Start** Allows you to enter an absolute level limit at **Start** Freq ranging from 200.00 to +50.00 dBm with 0.01 dB resolution.
 - □ Abs Stop Allows you to enter an absolute level limit at Stop Freq ranging from 200.00 to +50.00 dBm with 0.01 dB resolution, and to toggle this function between Couple and Man. If set to Couple, Abs Stop is coupled to Abs Start to make a flat limit line. If set to Man, Abs Start and Abs Stop can take different values to make a sloped limit line.
 - □ **Rel Start** Allows you to enter a relative level limit at **Start Freq** ranging from 150.00 to +50.00 dBc with 0.01 dB resolution.
 - □ Rel Stop Allows you to enter a relative level limit at Stop Freq ranging from 150.00 to +50.00 dBc with 0.01 dB resolution, and to toggle this function between Couple and Man. If set to Couple, Rel Stop is coupled to Rel Start to make a flat limit line. If set to Man, Rel Start and Rel Stop can take different values to make a sloped limit line.
 - ☐ Fail Mask- Allows you to access the following menu to select one of the logic keys for fail conditions between the measurement results and the test limits:

Absolute - Fail is shown if one of the absolute spectrum emission mask measurement results is larger than the limit for **Abs Start** and/or **Abs Stop**. This is the default selection for offsets **B** and **C**.

Relative - Fail is shown if one of the relative spectrum emission mask measurement results is larger than the limit for **Rel Start** and/or **Rel Stop**. This is the default selection for offset **A**.

Abs AND Rel - Fail is shown if one of the absolute spectrum emission mask measurement results is larger than the limit for **Abs Start** and **Abs Stop** AND one of the relative spectrum

emission mask measurement results is larger than the limit for **Rel Start** and **Rel Stop**.

Abs OR Rel - Fail is shown if one of the absolute spectrum emission mask measurement results is larger than the limit for **Abs Start** and **Abs Stop** OR one of the relative spectrum emission mask measurement results is larger than the limit for **Rel Start** and **Rel Stop**.

Table 3-12 Offsets & Limits - BTS Measurement Defaults

Offset	Start Freq (MHz)	Stop Freq (MHz)	Step Freq (kHz)	Meas BW (kHz)	Abs Start (dBm)	Abs Stop (dBm)	Rel Start (dBc)	Rel Stop (dBc)	Fail Mask
A, On	0.7650	0.7950	1.500	30.00	-27.00	-27.00	- 45.00	- 45.00	Rel
B, On	0.7950	1.9950	15.00	30.00	-27.00	- 27.00	- 45.00	- 45.00	Rel
C, On	1.9950	4.0150	15.00	30.00	- 27.00	- 27.00	- 55.00	- 55.00	Rel
D, Off	3.2531	4.0031	3.125	6.250	- 46.00	- 46.00	- 55.00	- 55.00	Abs
E, Off	7.5000	12.500	500.00	1000.0	- 13.00	- 13.00	- 55.00	- 55.00	Rel

Table 3-13 Offsets & Limits - MS Measurement Defaults

Offset	Start Freq (MHz)	Stop Freq (MHz)	Step Freq (kHz)	Meas BW (kHz)	Abs Start (dBm)	Abs Stop (dBm)	Rel Start (dBc)	Rel Stop (dBc)	Fail Mask
A, On	0.9000	1.9950	15.00	30.00	- 70.13	- 70.13	- 42.00	- 42.00	AND
B, On	1.9950	4.0150	15.00	30.00	- 70.13	- 70.13	- 54.00	- 54.00	AND
C, Off	2.2531	4.0150	3.125	6.250	- 35.00	- 35.00	- 54.00	- 54.00	Abs
D, Off	8.5000	12.000	500.00	1000.0	- 13.00	- 13.00	- 54.00	- 54.00	Rel
E, Off	12.500	15.000	500.00	1000.0	- 13.00	- 13.00	- 54.00	- 54.00	Rel

- Region/Limits Allows you to access the menus to change the
 following parameters for region frequency settings and pass/fail
 tests, if Spectrum Segment is set to Region. Table 3-14 on page 211
 and Table 3-15 on page 211 show the default setting for BTS and MS
 measurements, respectively.
 - Region Allows you to access the memory selection menu from A to E to store up to 5 sets of values for Start Freq, Stop Freq, Step Freq, Res BW, and Limits. Only one memory selection at a time (A, B, C, D, or E) is shown on this key label. The default is A.
 - **Start Freq** Allows you to specify the start frequency, and to toggle this function between **On** and **Off**, for each region. The frequency range is 329.000 MHz to 3.67800 GHz with 1 kHz resolution. However, the high end is limited to the setting of **Stop Freq**. The

default settings are 1.92000 GHz and On.

- Stop Freq Allows you to specify the stop frequency ranging from 329.000 MHz to 3.67800 GHz with 1 kHz resolution, for each region. The low end is limited to the setting of Start Freq. The default setting is 1.98000 GHz.
- Step Freq Allows you to specify the step frequency ranging from (Stop Freq Start Freq)/10000 to (Stop Freq Start Freq), and to toggle this function between Auto and Man, for each region. If set to Auto, the step frequency is automatically set to half the Res BW setting. The default settings are 600.000 kHz and Auto.
- Res BW Allows you to specify the resolution bandwidth ranging from 1.000 kHz to 7.50000 MHz with 100 Hz resolution, and to toggle this function between Auto and Man, for each region. If set to Auto, Res BW is automatically set to one 50th of (Stop Freq Start Freq). The default settings are 1.20000 MHz and Auto.
- **Relative Atten** Allows you to enter an attenuation value to adjust the relative level limits ranging from 40.00 to 40.00 dB with 0.01 dB resolution. The default attenuation is the same as the one used for **Ref Channel**.
- **Limits** Allows you to access the following menu to set up absolute and relative limit levels and fail conditions for each region:

Abs Start - Allows you to enter an absolute level limit at **Start** Freq ranging from -200.00 to +50.00 dBm with 0.01 dB resolution. The default setting is -50.00 dBm.

Abs Stop - Allows you to enter an absolute level limit at **Stop** Freq ranging from -200.00 to +50.00 dBm with 0.01 dB resolution, and to toggle this function between **Couple** and **Man**. If set to **Couple**, **Abs Stop** is coupled to **Abs Start** to make a flat limit line. If set to **Man**, **Abs Start** and **Abs Stop** can take different values to make a sloped limit line. The default settings are -50.00 dBm and **Couple**.

Rel Start - Allows you to enter a relative level limit ranging from -150.00 to +50.00 dBc with 0.01 dB resolution. The default settings are -30.00 dBm.

Rel Stop - Allows you to enter a relative level limit at **Stop Freq** ranging from – 150.00 to +50.00 dBc with 0.01 dB resolution, and to toggle this function between **Couple** and **Man**. If set to **Couple**, **Rel Stop** is coupled to **Rel Start** to make a flat limit line. If set to **Man**, **Rel Start** and **Rel Stop** can take different values to make a sloped limit line. The default settings are – 30.00 dBm and **Couple**.

Fail Mask- Allows you to access the following menu to select one of the logic keys for fail conditions between the measurement

results and the test limits. The default selection is **Absolute**.

Absolute - Fail is shown if one of the absolute spurious emission mask measurement results is larger than the limit for **Abs Start** and/or **Abs Stop**. This is the default selection for each region.

Relative - Fail is shown if one of the relative spurious emission mask measurement results is larger than the limit for **Rel Start** and/or **Rel Stop**.

Abs AND Rel - Fail is shown if one of the absolute spurious emission mask measurement results is larger than the limit for **Abs Start** and **Abs Stop** AND one of the relative spurious emission mask measurement results is larger than the limit for **Rel Start** and **Rel Stop**.

Abs OR Rel - Fail is shown if one of the absolute spurious emission mask measurement results is larger than the limit for **Abs Start** and **Abs Stop** OR one of the relative spurious emission mask measurement results is larger than the limit for **Rel Start** and **Rel Stop**.

Table 3-14 Regions & Limits- BTS Measurement Defaults

Region	Start Freq (MHz)	Stop Freq (MHz)	Step Freq (kHz)	Res BW (kHz)	Abs Start (dBm)	Abs Stop (dBm)	Rel Start (dBc)	Rel Stop (dBc)	Fail Mask
A, On	1920.0	1980.0	500.00	1000.0	-86.00	- 86.00	- 30.00	- 30.00	Abs
B, On	1893.5	1919.6	150.00	300.00	-41.00	- 41.00	- 30.00	- 30.00	Abs
C, Off	876.00	915.0	50.000	100.00	- 98.00	- 98.00	- 30.00	- 30.00	Abs
D, Off	921.00	960.0	50.000	100.00	- 57.00	- 57.00	- 30.00	- 30.00	Abs
E, Off	800.00	1000.0	2000.0	4000.0	- 50.00	- 50.00	- 30.00	- 30.00	Abs

Table 3-15 Regions & Limits- MS Measurement Defaults

Regio n	Start Freq (MHz)	Stop Freq (MHz)	Step Freq (kHz)	Res BW (kHz)	Abs Start (dBm)	Abs Stop (dBm)	Rel Start (dBc)	Rel Stop (dBc)	Fail Mask
A, On	1893.5	1919.6	150.00	300.00	-41.00	-41.00	- 30.00	- 30.00	Abs
B, On	925.00	935.0	50.00	100.00	-67.00	- 67.00	- 30.00	- 30.00	Abs
C, On	935.00	960.0	50.00	100.00	- 79.00	- 79.00	- 30.00	- 30.00	Abs
D, Off	1805.0	1880.0	50.00	100.00	-71.00	- 71.00	- 30.00	- 30.00	Abs

Table 3-15 Regions & Li	imits- MS Measure	ement Defaults

Regio n	Start Freq (MHz)	Stop Freq (MHz)	Step Freq (kHz)	Res BW (kHz)	Abs Start (dBm)	Abs Stop (dBm)	Rel Start (dBc)	Rel Stop (dBc)	Fail Mask
E, Off	800.0	1000.0	2000.0	4000.0	-50.00	- 50.00	-30.00	- 30.00	Abs

- **Detector** Allows you to toggle the power detection type between **Avg** (average) and **Peak**. If set to **Avg**, the power in a bin is computed as RMS averaged over the entire **Meas Interval**. If set to **Peak**, the peak power in the entire **Meas Interval** is converted to the RMS value, assuming a CW signal.
- **Meas Type** Allows you to access the menu to select one of the measurement reference types.
 - **Total Pwr Ref** Sets the reference to the total carrier power and the measured data is shown in dBc and dBm.
 - **PSD Ref** Sets the reference to the mean power spectral density of the carrier and the measured data is shown in dB and dBm/Hz.
- Trig Source Allows you to select one of the trigger sources: Free Run (Immediate), Ext Front, Ext Rear, Frame, or Line.
- Restore Meas Defaults Allows you to preset only the settings that are specific to the selected measurement by pressing Meas Setup, More (1 of 2), Restore Meas Defaults. This will set the measure setup parameters, for the currently selected measurement only, to the factory defaults.

Table 3-16 Spectrum Emission Mask Measurement Defaults

Measurement Parameter	Factory Default Condition
View/Trace	All
Offset	Pos
Display	Abs Peak Pwr & Freq
Limit Lines	On
Meas Setup:	
Avg Number	10; Off
Meas Interval	1.000 ms
Ref Channel:	
Chan Integ BW	1.23000 MHz

Table 3-16 Spectrum Emission Mask Measurement Defaults


Measurement Parameter	Factory Default Condition
Chan Span	1.25000 MHz
Step Freq	12.300 kHz; Auto
Res BW	24.600 kHz; Auto
Spectrum Segment	Offset
Offset/Limits:	(Refer to Table 3-12 on page 209)
Offset	A
Start Freq	765.000 kHz
Stop Freq	795.000 MHz
Step Freq	15.000 kHz; Auto
Res BW	3.000 kHz; Man
Meas BW (Integ BW)	$30.000~\mathrm{kHz};10 \times \mathrm{Res}\;\mathrm{BW}$
Relative Atten	0.00 dB
Offset Side	Both
Limits:	
Abs Start	– 27.00 dBm
Abs Stop	– 27.00 dBm; Couple
Rel Start	- 45.00 dBc
Rel Stop	- 45.00 dBc; Couple
Fail Mask	Relative
Detector	Avg
Meas Type	Total Pwr Ref
Trig Source	Free Run (Immediate)

View/Trace Key Menu

Key Path: Spectrum Emission Mask, View/Trace

- All In the factory default condition, the spectrum emission mask measurement graph is displayed with all of the active offsets in the graph window as shown in Figure 3-30 on page 214.
- Offset A to Offset E Each spectrum emission mask measurement result, up to 5 sets of offsets, is shown in the graph window. Each offset label set to Off is grayed out.
- **Offset** Allows you to toggle the display function of the offset sides between **Pos** (positive) and **Neg** (negative).
- Spectrum Segment Offset
- Spectrum Segment Region
 - **All** The spurious emission measurement graph is displayed with all of the active regions in the graph window as shown below:

Figure 3-30 Spurious Emission Measurement - All Regions View



*Meas Setup: Spectrum Segment = Region,

View/Trace = All (default),

Others = Factory default settings

*Input signal: 10.00 dBm, 9 channels of SR1, cdma2000 Rev 8

— **Region A** to **Region E** - Each spurious emission measurement result, up to 5 sets of regions, is shown in the graph window. Each region label set to **Off** is grayed out.

AMPLITUDE Y Scale Key Menu

Key Path: Spectrum Emission Mask, AMPLITUDE Y Scale

- Scale/Div Allows you to enter a numeric value to change the vertical display sensitivity. The range is 0.10 to 20.00 dB with 0.01 dB resolution. The default setting is 10.00 dB. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Value** Allows you to set the absolute power reference value ranging from -250.00 to 250.00 dBm with 0.01 dB resolution. The default setting is 10.00 dBm. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- **Ref Position** Allows you to set the reference position to either **Top**, **Ctr** (center), or **Bot** (bottom). The default setting is **Top**.
- Scale Coupling Allows you to toggle the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front panel key or the Restart softkey under the Meas Control menu, scale coupling automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

Display Key Menu

Key Path: Spectrum Emission Mask, Display

- Limit Lines Allows you to toggle the limit lines display function for spectrum emission mask measurements between **On** and **Off**. If set to **On**, the absolute limit lines and the relative limit lines are shown on the spectrum emission mask measurement display.
- Abs Peak Pwr & Freq Allows you to read the absolute peak power levels in dBm and corresponding frequencies in the text window. This key is disabled if Spectrum Segment is set to Region.
- Rel Peak Pwr & Freq Allows you to read the relative peak power levels in dBc and corresponding frequencies in the text window. This key is disabled if Spectrum Segment is set to Region.
- Integrated Power Allows you to read the absolute and relative power levels integrated throughout the bandwidths between the start and stop frequencies in the text window. This key is disabled if **Spectrum Segment** is set to **Region**.

Marker Key Menu

Key Path: Spectrum Emission Mask, Marker

Key Reference cdma2000 Measurement Keys

- **Select 1 2 3 4** Allows you to activate up to four markers with the corresponding numbers, respectively. The selected number is underlined and its function is defined by pressing the **Function** key. The default is 1.
- Normal Allows you to activate the selected marker to read the time
 position and amplitude of the marker on the Signal envelope trace,
 for example. Marker position is controlled by the RPG knob.
- **Delta** Allows you to read the differences in time positions and amplitudes between the selected marker and the next.
- Function Allows you to define the selected marker function to be Band Power, Noise, or Off. The default is Off. For measuring Band Power, you need to place the Normal marker and then place the Delta marker.
- **Trace** Allows you to place the selected marker on the **Spectrum** trace.
- Off Allows you to turn off the selected marker.
- **Shape** Allows you to access the menu to define the selected marker shape to be **Diamond**, **Line**, **Square**, or **Cross**. The default is **Diamond**.
- Marker All Off Allows you to turn off all of the markers.

NOTE

The front panel **Search** key performs a peak search when pressed. A marker will automatically be activated at the highest peak.

Troubleshooting Hints

Spectrum Emission mask measurements can reveal the presence of degraded or defective parts in the transmitter section of the UUT. The following are examples of problems which, once indicated by testing, may require further attention:

- Faulty DC power supply control of the transmitter power amplifier.
- RF power controller of the pre-power amplifier stage.
- I/Q control of the baseband stage.
- Reduction in the gain and output power level of the amplifier due to a degraded gain control and/or increased distortion.
- Degradation of amplifier linearity and other performance characteristics.

Power amplifiers are one of the final stage elements of a base or mobile transmitter and play a critical part in meeting the important power and spectral efficiency specifications. Measuring the spectral response of these amplifiers to complex wideband signals is crucial to linking amplifier linearity and other performance characteristics to the

stringent system specifications.

Waveform (Time Domain) Keys

NOTE You must have selected **Waveform** under the **MEASURE** menu to access these menus.

Measurement Setup Key Menu

Key Path: Meas Setup

- Sweep Time Specifies the measurement acquisition time which is used as the length of the time capture record. The range is $1.0~\mu s$ to 100.0~s, depending upon the resolution bandwidth setting and the available internal memory size for acquisition points.
- **Meas Time** Specifies the measurement acquisition time which is used as the length of the time capture record. The range is 10 ns and 100.0 s, depending upon the resolution bandwidth setting and the available internal memory size for acquisition points.
- Res BW Sets the measurement bandwidth. The range is 10 Hz to 8 MHz using the Gaussian filter selected from RBW Filter under the Advanced menu, or 10 Hz to 10 MHz using the Flat top filter selected from RBW Filter. A larger bandwidth results in a larger number of acquisition points and reduces the maximum value allowed for the sweep time.
- IF BW For PSA Option 122 or 140 only. Sets the measurement bandwidth. In wideband operation the range is 10 kHz to 80 MHz.(Option 122) or 10 kHz to 40 MHz (Option 140). The narrowband range is 10 Hz to 10 MHz. A larger bandwidth results in a larger number of acquisition points and reduces the maximum value allowed for the measurement time.
- **Wideband Setup** configures the wideband hardware path. This functionality is only available with the wideband options (122 or 140, PSA only).
 - Wideband IF Gain Sets the gain for the wideband IF path. You must have selected IF Path Wide. Increasing the gain can increase the amplitude of small signals as long as you don't overdrive the hardware
 - **Wideband Filtering** Accesses the menu to configure several aspects of the wideband filter.
 - ☐ Filter Type Selects None for no filtering, or Raised Cosine, RRC (root-raised cosine), Nyquist, Root Nyquist, Gaussian and Flat Top.
 - ☐ Filter Alpha Selects the filter alpha.

- ☐ **Filter BW** Selects filter bandwidth. Bandwidth is not entered as a frequency. The value is entered as a ratio of the current instrument sampling rate (i.e. BW/sample rate).
- Sample Rate Allows arbitrary sample rates with 5 digits of resolution from 12.5 kHz to 100 MHz. Sample rate is coupled with the selected filter shape and bandwidth, and with the maximum available captured data.
- **Block Size** This key is for information only. Block size is coupled with the IF bandwidth and the measurement time.
- **Wideband Advanced** Accesses the advanced settings for the Option 122 wideband IF hardware path (PSA only).


NOTE

Parameters under the **Wideband Advanced** key seldom need to be changed. Any changes from the default advanced values may result in invalid measurement data.

- □ **ADC Corr** Turning corrections on performs an ADC calibration to reduce the spectral image and applies the corrections.
- ☐ **IF Flat Corr** turns IF flatness corrections on and off for the Option 122 or 140 wideband IF. This control is independent of the narrowband IF flatness control.
- ☐ Analog Filter manually selects the 80 MHz (Opt 122), 40 MHz (Opt 140), or 36 MHz anti-alias filter, which overides the automatic selection of the bandwidth.
- □ WB ADC Dither Toggles the ADC dither function on/off.. The "ADC dither" refers to the introduction of noise to the digitized steps of the analog-to-digital converter; the result is an improvement in amplitude accuracy. The wideband dither control does not affect the ADC dither in the narrowband IF path.
- ☐ **Trig Interp** This is an advanced function that usually does not need to be changed. During normal operation trigger interpolation is on and the trigger offset is 0 seconds. At low sample rates the trigger interpolation can cause hardware unlock errors, so you may want to turn it off. You must have an external trigger source to use this functionality.

Average

- Avg Number Changes the number of N averages.
- Avg Mode Toggles the averaging mode between Exp (exponential) and Repeat. This selection only affects the averaging result after the number of N averages is reached. The N is set using the Avg Number key.
 - ☐ **Normal averaging**: Normal (linear) averaging is always used



Key path: Meas Setup, Trig Source

NOTE

Changing the selection in the **Trig Source** menu alters the trigger source for the selected measurement only.

- **Free Run (Immediate)** A trigger occurs at the time the data is requested, completely asynchronous with the RF or IF signal.
- **Video (Envlp)** An internal IF envelope trigger that occurs at the absolute threshold level of the IF signal level.
- **RF Burst (Wideband)** An internal wideband RF burst trigger that has the automatic level control for burst signals. It triggers at the level that is set relative to the peak RF signal (12 MHz bandwidth) input level. (Not available for Option 122 or 140 when using the wideband IF path.)
- Ext Front Activates the front panel external trigger input (EXT TRIGGER INPUT) port. The external signal must be between 5.00 and +5.00 V with 1 or 10 mV resolution.
- **Ext Rear** Activates the rear-panel external trigger input (**TRIGGER IN**) port. The external signal must be between 5.00 and +5.00 V with 1 or 10 mV resolution.
- Frame Uses the internal frame clock to generate a trigger signal. The clock parameters are controlled under the Mode Setup key or the measurement firmware, but not both. Refer to the specific measurement section for details.
- Line Sets the trigger to the internal line mode. Sweep triggers occur at intervals synchronous to the line frequency. See the specific measurement section for details.
- IF Path Only for PSA with Option B7J and either Option 122 or 140 installed. Selects either the standard narrowband IF hardware path or the wideband hardware path.
- Restore Meas Defaults Presets only the settings that are specific to
 the selected measurement by pressing Meas Setup, More (1 of 2),
 Restore Meas Defaults. This will set the measure setup parameters,
 for the currently selected measurement only, to the factory defaults.
- (Narrowband) Advanced Accesses the menu to change the following parameters.

CAUTION

The advanced features should be used only if you are familiar with their operation. Changes from the default values may result in invalid data.

The **Narrowband** key label word is only present if you have Option B7J and either Option 122 or 140 installed. Parameters that are under the **(Narrowband) Advanced** key only affect the standard narrow band IF path. The wideband IF advanced functions are

found under the Wideband Advanced key.

- Pre-ADC BPF Toggles the pre-ADC bandpass filter function between On or Off. The default setting is Off. The pre-ADC bandpass filter is useful for rejecting nearby signals, so that sensitivity within the span range can be improved by increasing the ADC range gain.
- **RBW Filter** Toggles the resolution bandwidth filter selection between **Flat** and **Gaussian**. If set to **Gaussian**, the filter provides more even time-domain response, particularly for "bursts". If set to **Flat**, the filter provides a flatter bandwidth but is less accurate for "pulse responses". A flat top filter also requires less memory and allows longer data acquisition times. For most waveform applications, the Gaussian filter is recommended. The resolution bandwidth range is 10 Hz to 8 MHz using the Gaussian filter or 10 Hz to 10 MHz using the Flat top filter.
- **ADC Range** Accesses the menu to select one of the ADC ranging functions:
 - ☐ Auto Automatically adjusts the signal range for optimal measurement results.
 - ☐ AutoPeak Continuously searches for the highest peak signal.
 - □ AutoPeakLock Adjusts the range for the highest peak signal it identifies. It retains the range settings determined by that peak signal, even when the peak signal is no longer present.
 - ☐ Manual Accesses the selection menu of values, -6 to +24 dB for E4406A or None to +18 dB for PSA, to set the ADC range level. Also note that manual ranging is best for CW signals.
- Data Packing Selects Auto (the default) or the Short (16 bit), Medium (24 bit) and Long (32 bit) methods of data packing. The short, medium, and long methods are not compatible with all settings and should not be used unless you are familiar with data packing methods. Auto is the preferred choice.
 - ☐ **Auto** The data packing value most appropriate for current instrument settings is selected automatically.
 - □ Short (16 bit) Select this to pack data every 16 bits.
 - ☐ Medium (24 bit) Select this to pack data every 24 bits.
 - □ Long (32 bit) Select this to pack data every 32 bits.
- ADC Dither Toggles the ADC dither function between On and Off. The default setting is Off. If set to On, the ADC dither refers to the introduction of noise to the digitized steps of the analog-to-digital converter, and results in better amplitude linearity and resolution in low level signals. However, it also results in reduced dynamic range by approximately 3 dB.

Key Reference cdma2000 Measurement Keys

— **Decimation** - Toggles the decimation function between **On** and **Off**, and to set the decimation value. Decimation allows longer acquisition times for a given bandwidth by eliminating data points. Long time captures can be limited by the instrument data acquisition memory. Decimation numbers 1 to 4 describe the factor by which the number of points are reduced. The default setting is 1, which results in no data point reduction.

Table 3-17 Waveform (Time Domain) Measurement Defaults

Measurement Parameter	Factory Default Condition	
Sweep Time	2.000 ms	
Res BW	100.000 kHz	
Averaging: Avg Number Avg Mode Avg Type	10; Off Exp Pwr Avg (RMS)	
Trig Source	Free Run (Immediate)	
IF Path (requires Option B7J and Option 122 or 140)	Narrow	
Wideband IF Gain (Option 122 or 140)	0.00 dB	
Wideband Filtering (Option 122 or 140) Filter Type Filter Alpha Filter BW	None 0.30 0.50	
Signal Envelope View SPAN X Scale - Scale/Div AMPLITUDE Y Scale - Scale/Div	(for E4406A) 200.0 μs 10.00 dB	
RF Envelope View SPAN X Scale - Scale/Div AMPLITUDE Y Scale - Scale/Div	(for PSA) 200.0 μs 10.00 dB	
Linear Envelope View SPAN X Scale - Scale/Div Linear Envelope window: AMPLITUDE Y Scale - Scale/Div Phase window: AMPLITUDE Y Scale - Scale/Div	(for E4406A Option B7C) 200.0 μs 100.0 mV 30.0 deg	
I/Q Waveform View: SPAN X Scale -Scale/Div AMPLITUDE Y Scale - Scale/Div	200.0 μs 100.0 mV	
I and Q Waveform View: SPAN X Scale -Scale/Div AMPLITUDE Y Scale - Scale/Div	(for E4406A Option B7C) 200.0 μs 100.0 mV	
I/Q Polar View: I/Q Scale/Div I or Q Origin	(for E4406A) 100.0 mV 0.00 V	
(Narrowband) Advanced		
Pre-ADC BPF	Off	

Table 3-17 Waveform (Time Domain) Measurement Defaults


Measurement Parameter	Factory Default Condition	
RBW Filter	Gaussian	
ADC Range	Auto	
Data Packing	Auto	
ADC Dither	Off	
Decimation	Off	
Wideband Advanced (Option 122 or 140)		
ADC Correction	On	
IF Flatness Corrections	On	
Analog Filter	Auto, 80 MHz (Opt 122), 40 MHz (Opt 140)	
WB ADC Dither	On	
Trigger Interpolation	On	

View/Trace Key Menu

Key Path: View/Trace

• **RF Envelope** (for E4406A) or **Signal Envelope** (for PSA) - Displays a time domain graph of the signal. The measured values for the mean power and peak-to-mean power are shown in the text window.

Figure 3-31 Waveform Measurement - RF Envelope (Default View)




*Meas Setup: Trace/View = RF Envelope,

Others = Factory default settings

*Input signal: cdma2000 Rev 8, SR1, 9 Channel

Figure 3-32 Waveform Measurement - RF Envelope (Default View)




*Meas Setup: Trace/View = RF Envelope,

Others = Factory default settings

*Input signal: cdma2000 Rev 8, SR1, 9 Channel

Figure 3-33 Waveform Measurement - RF Envelope (Default View)




*Meas Setup: View/Trace = RF Envelope,

Trigger Source = Ext Rear,

Others = Factory default settings


- *Input signal: 10 dBm, Idle slot, 1xEV-DO
- **Linear Envelope** (for E4406A Option B7C) Provides a combination view of a linear signal envelope graph and a phase graph with linear graticules. Use the **Next Window** and **Zoom** keys to select and enlarge either graph.

Figure 3-34 Waveform Measurement - Linear Envelope View



*Meas Setup: **Figure 3-35** View/Trace = Linear Envelope View, GSM signal Others = Factory defaults, except X and Y scales

Figure 3-36 Waveform Measurement - Linear Envelope View



*Meas Setup: View/Trace = Linear Envelope View,

Others = Factory defaults, except X and Y scales


*Input signal: cdma2000 Rev 8, SR1, 9 Channel

• **I/Q Waveform** - Provides a view of the I and Q waveforms together on the same graph in parameters of voltage versus time in linear scale. Changes to sweep time or resolution bandwidth can affect data acquisition.

NOTE

For the widest spans, the I/Q Waveform window becomes just "ADC time domain samples", because the I/Q down-conversion is no longer in effect.

Figure 3-37 Waveform Measurement - I/Q Waveform View




*Meas Setup: View/Trace = I/Q Waveform,

Others = Factory defaults, except X and Y scales

*Input signal: cdma2000 Rev 8, SR1, 9 Channel

Figure 3-38 Waveform Measurement - I/Q Waveform View



*Meas Setup: View/Trace = I/Q Waveform,

Trigger Source = Ext Rear,

Others = Factory default settings

*Input signal: - 10 dBm, Idle slot, 1xEV-DO

• I and Q Waveform - (for E4406A Option B7C) Provides a combination view of the I and Q signal waveform graphs in the linear scales.

Figure 3-39 Waveform Measurement - I and Q Waveform View





Figure 3-40 Waveform Measurement - I and Q Waveform View



*Meas Setup: View/Trace = I and Q Waveform View,

Others = Factory defaults, except X and Y scales

*Input signal: cdma2000 Rev 8, SR1, 9 Channel

• **I/Q Polar** - (for E4406A) Provides a view of the I/Q signal in a polar vector graph.

Figure 3-41 Waveform Measurement - I/Q Polar View





Figure 3-42 Waveform Measurement - I/Q Polar View



*Meas Setup: View/Trace = I/Q Polar View,

Others = Factory defaults, except X and Y scales

*Input signal: cdma2000 Rev 8, SR1, 9 Channel




Figure 3-43 Waveform Measurement - I/Q Polar View

*Meas Setup: View/Trace = I/Q Polar,

Trigger Source = Ext Rear, Others = Factory default settings

*Input signal: - 10 dBm, Idle slot, 1xEV-DO

- **Trace Display** Press this key to access the trace selection menu. The currently selected trace type is shown on the **Trace Display** key.
 - **All** Views both the current trace and the average trace.
 - Average Views only the average trace (in blue color). See the
 Meas Setup, Average keys to select different types of averaging.
 - Current Views only the trace (in yellow color) for the latest data acquisition.
 - I Trace (for E4406A) Views only the I signal trace.
 - **Q Trace** (for E4406A) Views only the Q signal trace.

SPAN X Scale Key Menu

Key Path: SPAN X Scale

NOTE

The SPAN X Scale key accesses the menu to modify the horizontal parameters common to the scaled windows for this measurement. Use the Sweep Time key under the Meas Setup menu tp control the horizontal time span for this measurement:

• **Scale/Div** - Sets the horizontal scale by changing a time value per division. The range is 1.0 ns to 1.000 s per division with 0.01 ns

resolution. The default setting is $200.0 \,\mu s$ per division. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to **Off**.

- Ref Value Sets the reference value ranging from -1.0 to 10.0 s. The default setting is 0.00 s. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Position Sets the reference position to either Left, Ctr (center) or Right. The default setting is Left.
- Scale Coupling Toggles the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front-panel key or Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

For E4406A, if the I/Q Polar window is active in the I/Q Polar view, the SPAN X Scale key accesses the following menu:

- **I/Q Scale/Div** Sets the vertical and horizontal scales by changing a value per division. The range is 1.00 nV to 20.00 V per division. The default setting is 100.0 mV.
- I or **Q Origin** Sets the reference value ranging from -250.00 to 250.00 V. The default setting is 0.00 V.

AMPLITUDE Y Scale Key Menu

Key Path: AMPLITUDE Y Scale

NOTE

If the RF Envelope (for PSA) or Signal Envelope (for E4406A) window is active in the RF Envelope (for PSA) or Signal Envelope (for E4406A) view, the AMPLITUDE Y Scale key accesses the following menu:

- **Scale/Div** Sets the vertical scale by changing an amplitude value per division. The range is 0.10 to 20.00 dB per division with 0.01 dB resolution. The default setting is 10.00 dB per division. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- Ref Value Sets the reference value ranging from -250.00 to 250.00 dBm. The default setting is 0.00 dBm. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- Ref Position Sets the reference position to either Top, Ctr (center) or Bot (bottom). The default setting is Top.
- Scale Coupling Toggles the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front-panel key or Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

For E4406A with Option B7C, if the Linear Envelope window is active in the **Linear Envelope** view, the **AMPLITUDE Y Scale** key accesses the following menu:

- Scale/Div Sets the vertical scale by changing an amplitude value per division. The range is 1.00 nV to 20.00 V per division. The default setting is 100.0 mV per division. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Value** Sets the reference value ranging from -250.00 to 250.00 V. The default setting is 0.00 V. However, since the **Scale Coupling** default is **On**, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to **Off**.
- Ref Position Sets the reference position to either Top, Ctr (center) or Bot (bottom). The default setting is Top.

Key Reference cdma2000 Measurement Keys

Scale Coupling - Toggles the scale coupling function between On and **Off.** The default setting is **On**. Upon pressing the **Restart** front-panel key or Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to **Off**.

NOTE

For E4406A with Option B7C, if the Phase window is active in the Linear Envelope view, the AMPLITUDE Y Scale key accesses the menu to modify the following parameters:

- Scale/Div Sets the vertical scale by changing an amplitude value per division. The range is 0.10 to 3600.0 deg per division. The default setting is 30.00 deg. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to **Off**.
- **Ref Value** Sets the reference value ranging from 36000.0 to 36000.0 deg. The default setting is 0.00 deg. However, since the Scale **Coupling** default is **On**, this value is automatically determined by the measurement result. When you set a value manually, Scale Coupling automatically changes to Off.
- **Ref Position** Sets the reference position to either **Top**, **Ctr** (center) or **Bot** (bottom). The default setting is **Ctr**.
- **Scale Coupling** Toggles the scale coupling function between **On** and Off. The default setting is On. Upon pressing the Restart front-panel key or **Restart** softkey under the **Meas Control** menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

If the I/Q Waveform window is active in the I/Q Waveform view (or the I Waveform, or Q Waveform window is active in the I and Q Waveform view for E4406A with Option B7C), the AMPLITUDE Y Scale key accesses the menu to modify the following parameters:

- Scale/Div Sets the vertical scale by changing an amplitude value per division. The range is 1.00 nV to 20.00 V per division. The default setting is 100.0 mV. However, since the Scale Coupling default is On, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to Off.
- **Ref Value** Sets the reference value ranging from 250.00 to 250.00 V. The default setting is 0.00 V. However, since the Scale Coupling

default is **On**, this value is automatically determined by the measurement result. When you set a value manually, **Scale Coupling** automatically changes to **Off**.

- Ref Position Sets the reference position to either Top, Ctr (center) or Bot (bottom). The default setting is Ctr.
- Scale Coupling Toggles the scale coupling function between On and Off. The default setting is On. Upon pressing the Restart front-panel key or Restart softkey under the Meas Control menu, this function automatically determines the scale per division and reference values based on the measurement results. When you set a value to either Scale/Div or Ref Value manually, Scale Coupling automatically changes to Off.

NOTE

For E4406A, if the I/Q Polar window is active in the **I/Q Polar** view, the **SPAN X Scale** or **AMPLITUDE Y Scale** key accesses the menu to modify the following parameters:

- I/Q Scale/Div Sets the vertical and horizontal scales by changing a value per division. The range is 1.00 nV to 20.00 V per division. The default setting is 100.0 mV.
- I or **Q Origin** Sets the reference value ranging from -250.00 to 250.00 V. The default setting is 0.00 V.

Display Key Menu

The **Display** key is not available for this measurement.

Marker Key Menu

Key Path: Marker

The **Marker** front-panel key accesses the menu to configure the markers.

- **Select 1 2 3 4** Activates up to four markers with the corresponding numbers, respectively. The selected number is underlined and its function is defined by pressing the **Function** key. The default is 1.
- **Normal** Activates the selected marker to read the time position and amplitude of the marker on the RF envelope or Signal Envelope trace. The marker position is controlled by the **RPG** knob.
- **Delta** Reads the differences in frequency and either time position or amplitude, between the selected marker and the next marker.
- Function Off Selects the marker function to be Band Power, Noise, or Off. The default is Off. If set to Band Power, you need to select Delta.
- Trace Places the selected marker on RF Envelope (for PSA), Signal Envelope (for E4406A), or I/Q Waveform. Also, for E4406A with Option B7C, you can place the marker on Linear Envelope, Linear Phase, I Waveform, or Q Waveform.

Key Reference cdma2000 Measurement Keys

- Off Turns off the selected marker.
- Shape Diamond Accesses the menu to define the selected marker shape to be Diamond, Line, Square, or Cross. The default shape is Diamond.
- Marker All Off Turns off all of the markers.

Peak Search Key

Key Path: Search

The front panel **Search** key performs a peak search when pressed. A marker will automatically be activated at the highest peak.

NOTE

In the Waveform measurement, the Mean Pwr (Entire Trace) value plus the Pk-to-Mean value will sum to equal the current Max Pt. value as shown in the data window below the RF Envelope or Signal Envelope display. If you do a marker peak search (Search) with averaging turned off, the marker will find the same maximum point. However, if you turn averaging on, the Pk-to-Mean value will use the highest peak found for any acquisition during averaging, while the marker peak will look for the peak of the display, which is the result of n-averages. This will usually result in differing values for the maximum point.

Baseband I/Q Inputs (Option B7C) Keys

Input Port Key Menu

Key Path: Mode Setup, Input

Option B7C adds a softkey menu that lets you select I/Q inputs. This menu is located under the **Input/Output** front-panel key. To select an input connector press Input/Output, or **Input Port** under **Mode Setup**. Select the desired input connector(s) from the following choices displayed:

- RF Press to select the 50 Ω N-type RF connector.
- I/Q Select if using 2-connector "unbalanced" or 4-connector "balanced" I/Q connections. Complete your selection by choosing the appropriate input impedance and connectors in the section "I/Q Input Z Key Menu" on page 242.
- I only Select if using I and/or \bar{I} input connectors (available in the Basic mode). Complete your selection by choosing the appropriate input impedance and connectors in the section "I/Q Input Z Key Menu" on page 242.
- **Q only** Select if using Q and/or Q input connectors (available in the Basic mode). Complete your selection by choosing the appropriate input impedance and connectors in the section "I/Q Input Z Key Menu" on page 242.
- 50 MHz Ref Select to view the 50 MHz CW calibration signal (signal level is approximately -25.0~dBm).
- IF Align Select to view the IF alignment signal. This signal is available as a diagnostic function, to check the operation of the alignment signal in the case of alignment failure. Once selected, a menu accessing the IF alignment signal parameters is available at the bottom of the Input menu. Either CW, comb, or pulse signals may be selected. Because the alignment signal is input at the IF frequency, it is displayed on any active Spectrum (Freq Domain) window, regardless of center frequency.
- Baseband Align Signal Select On to view the baseband alignment signal. This is available as a diagnostic function, to check the operation of the alignment signal in the case of alignment failure. Because the alignment signal is input at the IF frequency, it is displayed on any Spectrum (Freq Domain) window.

I/Q Setup Key Menu

Key Path: Mode Setup, Input


• I Offset - Use to enter a voltage value to offset the measured I value. The default value is 0.0000 V. The range is -2.5600 to +2.5600 V. The tuning increment depends on the I/Q Range setting as shown in Table 3-18. This value only affects the displayed results, and does not appear as a correcting voltage at the probe.

Table 3-18 I and Q Offset Increment vs. I/Q Range

I/Q Range	I and Q Offset Increment
1 V	2 mV
500 mV	1 mV
250 mV	.5 mV
125 mV	.25 mV


- **Q Offset** Use to enter a voltage value to offset the measured Q value. The default value is 0.0000 V. The range is -2.5600 to +2.5600 V. The tuning increment depends on the **I/Q Range** setting as shown in Table 3-18. This value only affects the displayed results, and does not appear as a correcting voltage at the probe.
- I/Q Input Z Allows you to access a menu to select an input impedance for baseband I/Q input signals. The selection of input impedance is coupled to a connector "balance" configuration. If I/Q Input Z is set to 1 M Ω , the setting for I/Q Z Ref for Input Z = 1 M Ω key becomes effective. For details, refer to "I/Q Input Z Key Menu" on page 242.
- I/Q Z Ref for Input Z = 1 M Ω Allows you to select the 1 M Ω input reference Z value in Ohms. This key is effective only when I/Q Input Z is set to a 1 M Ω setting. The default value is 50.0 Ω The range is 1.0 Ω to 10 M Ω , with a tuning increment of 1.0 Ω For more details, refer to "I/Q Input Z Key Menu" on page 242.

Figure 3-44 Input Menu with Option B7C Baseband I/Q Inputs




cdma2000 (Rev.8) Downlink, SR1 9 Channel, Baseband I/Q Inputs

Figure 3-45 Input Menu with Option B7C Baseband I/Q Inputs




cdma2000 (Rev.8) Downlink, SR3 9 Channel, Baseband I/Q Inputs

Figure 3-46 I/Q Setup Menu with Option B7C Baseband I/Q Inputs



cdma2000 (Rev.8) Downlink, SR1 9 Channel, Baseband I/Q Inputs

Figure 3-47 I/Q Setup Menu with Option B7C Baseband I/Q Inputs



cdma2000 (Rev.8) Downlink, SR3 9 Channel, Baseband I/Q Inputs

I/Q Input Z Key Menu


Key Path: Mode Setup, Input, I/Q Setup

To select an input impedance, press Input/Output, I/Q Setup, I/Q Input ${\bf Z}$ to display the following menu:

- 50 Ω Unbalanced Select to use I and/or Q input connectors.
- 600 Ω Balanced Select to use either I and \overline{I} , Q and \overline{Q} , or all four I, Q, \overline{I} , and \overline{Q} input connectors.
- 1 M Ω Unbalanced This is the default input connector setting. Select to use I and/or Q input connectors in an unbalanced mode. When I/Q Input Z is set to 1 M Ω (either balanced or unbalanced), the setting for I/Q Z Ref for Input Z = 1 M Ω key may be adjusted. Otherwise, the default value for I/Q Z Ref = 1 M Ω is 50 Ω .
- 1 M Ω Balanced Select to use either I and \overline{I} , Q and \overline{Q} , or all four I, Q, \overline{I} , and \overline{Q} input connectors to make a balanced measurement. When I/Q Input Z is set to 1 M Ω (either balanced or unbalanced, the setting for I/Q Z Ref for Input Z = 1 M Ω key may be adjusted. Otherwise, the default value for I/Q Z Ref for Input Z = 1 M Ω is $50~\Omega$.


You can select I only or Q only in the Input Port menu under Mode Setup or Input/Output with any impedance selection.

Figure 3-48 I/Q Input Z Menu - Option B7C Baseband I/Q Inputs



cdma2000 (Rev.8) Downlink, SR1 9 Channel, Baseband I/Q Inputs

Figure 3-49 I/Q Input Z Menu - Option B7C Baseband I/Q Inputs



cdma2000 (Rev.8) Downlink, SR3 9 Channel, Baseband I/Q Inputs

I/Q Range Key Menu

NOTE

You must have I/Q selected under Key Path: Mode Setup, Input, Input Port to make this menu available

Key Path: Mode Setup, Input

The **I/Q Range** key lets you select one of four levels as an upper limit for the signal being applied to the baseband I/Q inputs. The level may be selected in units of dBm, dBmV, dB μ V, V, and W. The following table shows the four-level selections available for each unit of measure: The default is 1 V.

The I/Q Range power levels in Table 3-19 are based on an I/Q Input Z of 50Ω I/Q Range voltage levels are independent of I/Q Input Z.

Table 3-19 I/Q Range Settings by Displayed Unit of Measure

Unit of Measure	Highest Setting			Lowest Setting
dBm	13.0	7.0	1.0	-5.1
dBmV	60	54	48	41.9
dBμV	120.0	114.0	108	101.9
V	1.000	500 m	250 m	125 m
W	20.0 m	5.0 m	1.2 m	310.0 μ

If **I/Q Range** is set below the default and the error message "Input Overload" is displayed, this value may be adjusted to its maximum. Beyond that point, the signal must be attenuated to preserve the measurement accuracy. Using a lower value than the default can provide an increased dynamic measurement range.

Baseband I/Q Key Access Locations

All baseband I/Q input setup and operation features can be located by using the key access table below. The key access path shows the key sequence you enter to access a particular key.

Some features can only be used when specific measurements are active. If a feature is not currently valid the key label for that feature appears as lighter colored text or is not displayed at all.

Table 3-20 Baseband I/Q Key Access Locations

Key	Key Access Path
Align IQ	System>Alignments>Align Subsystem>
Baseband Align Signal	Mode Setup>Input>Input Port>
dBm	Input/Output>I/Q Range>
dBm	Mode Setup>Input>I/Q Range>
dBmv	Input/Output>I/Q Range>
dBmv	Mode Setup>Input>I/Q Range>
dBuv	Input/Output>I/Q Range>
dBuv	Mode Setup>Input>I/Q Range>
I and Q Waveform	View/Trace> (Waveform Measurement)
I Offset	Input/Output>I/Q Setup>
I Offset	Mode Setup>Input>I/Q Setup>
I only	Input/Output>Input Port>
I only	Mode Setup/Input>Input Port>
I/Q	Input/Output>Input Port>
I/Q	Mode Setup>Input>Input Port>
I/Q Input Z	Input/Output>I/Q Setup>
I/Q Input Z	Mode Setup>Input>I/Q Setup>
I/Q Polar	View/Trace>
I/Q Range	Input/Output>
I/Q Range	Mode Setup>Input>
I/Q Setup	Input/Output>
I/Q Setup	Mode Setup>Input>
I/Q Waveform	View/Trace>
I/Q Waveform	Marker>Trace>

Table 3-20 Baseband I/Q Key Access Locations

Key	Key Access Path
I/Q Z Ref for Input Z = 1 M Ω	Mode Setup>Input>I/Q Setup>
I Waveform	View/Trace> (Spectrum Measurement)
Linear Envelope	View/Trace> (Waveform Measurement)
Q Offset	Input/Output>Input>I/Q Setup>
Q Offset	Mode Setup>Input>I/Q Setup>
Q only	Input/Output>Input Port>
Q only	Mode Setup>Input>Input Port>
Q Waveform	Marker>Trace>
Signal Envelope	View/Trace> (Waveform Measurement)
Spectrum Linear	View/Trace> (Spectrum Measurement)
V (olts)	Mode Setup>Input>I/Q Setup>I Offset (or Q Offset)>Keypad Entry
Volts	Input/Output>I/Q Range>
Volts	Mode Setup>Input>I/Q Range>
Watts	Input/Output>I/Q Range>
Watts	Mode Setup>Input>I/Q Range>

Key Reference

Baseband I/Q Inputs (Option B7C) Keys

4 Programming Commands

These commands are only available when the cdma2000 mode has been selected using INSTrument:SELect CDMA2K. If this mode is selected, commands that are unique to another mode are not available.

SCPI Command Subsystems

- "CALCulate Subsystem" on page 256
- "CONFigure Subsystem" on page 291
- "DISPlay Subsystem" on page 292
- "FETCh Subsystem" on page 302
- "FORMat Subsystem" on page 303
- "INITiate Subsystem" on page 305
- "INSTrument Subsystem" on page 307
- "MEASure Group of Commands" on page 311
- "READ Subsystem" on page 380
- "SENSe Subsystem" on page 381
- "TRIGger Subsystem" on page 500

Programming Command Compatibility Across Model Numbers and Across Modes

Across PSA Modes: Command Subsystem Similarities

When you select different modes you get different sets of available programming commands. That is, *only* the commands that are appropriate for the current mode are available. Also, some commands have the same syntax in different modes but have different ranges or settings that are only appropriate to the current mode.

The following table shows which command subsystems are the same across different modes. If there is no "X" by a particular subsystem, then the set of available commands is different in those modes. Command ranges or defaults may also be different. Refer to the programming command descriptions in the documentation for each mode for details.

Command Subsystem	Same command set is available: SA mode compared with the application modes: Digital Modulation, Basic, WLAN, W-CDMA, cdmaOne, cdma2000, 1xEV-DO, GSM, EDGE, NADC, PDC, or Measuring Receiver	Same command set is available: SA mode compared with the application modes: Phase Noise, Noise Figure, TD-SCDMA
IEEE common commands	X	X
ABORt	X	X
CALCulate		
CALibration	X	X
CONFigure		
COUPle	not available in these application modes	not available in these application modes
DISPlay		
FETCh		
FORMat		X
НСОРу	X	X
INITiate		

Chapter 4 251

Command Subsystem	Same command set is available: SA mode compared with the application modes: Digital Modulation, Basic, WLAN, W-CDMA, cdmaOne, cdma2000, 1xEV-DO, GSM, EDGE, NADC, PDC, or Measuring Receiver	Same command set is available: SA mode compared with the application modes: Phase Noise, Noise Figure, TD-SCDMA
INPut	not available in these application modes	X
MEASure		
MEMory	X	X
MMEMory	X	X
MMEMory:STORe:TRACe	not available in these application modes	X
READ		
[SENSe]		
[SENSe:]CHANnel		
[SENSe:]CORRection		
[SENSe:]FEED		
[SENSe:]FREQuency:CE NTer	X	
[SENSe:]FREQuency: <other subsystems=""></other>	not available in these application modes	not available in these application modes
[SENSe:] <measurement></measurement>		
[SENSe:]POWer		
[SENSe:]RADio		
[SENSe:]SYNC		
STATus	X	X
SYSTem	X	X
TRACe	not available in these application modes	X
TRIGger		
UNIT	X	X

Across PSA Modes: Specific Command Differences

Some programming commands operate differently depending on which Mode the analyzer is set to.

Command	Spectrum Analysis, Phase Noise and Noise Figure Mode	Basic, cdmaOne, cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC, PDC Modes	
CONFigure: <measurement></measurement>	Accesses the measurement and sets the instrument settings to the defaults. Averaging is turned on and set to 10. The instrument is put in single measurement mode. It does not initiate a measurement. Use INIT:IMM to make one measurement.	Accesses the measurement and sets the instrument settings to the defaults. If you were already in single measurement mode, it takes one measurement and then waits. If you were in continuous measurement mode it continues to measure.	
*ESE default	Default is 255 which means that every error/status bit change that has occurred will be returned with a *ESR? query. You must set the value of *ESE to choose only the bits/status that you want returned.	Default is 0 which means that none of the error/status bit changes that have occurred will be returned with a *ESR? query. You must set the value of *ESE to choose the bits/status that you want returned.	
TRIGger commands	For these modes, only one trigger source can be selected and it will be common across the modes. Also, only one value can be set for the trigger delay, level, or polarity.	aly Also, each trigger source can have	
Saving and recalling traces	Traces can only be saved when in the Spectrum Analysis mode (MMEM:STOR:TRAC). This is because the instrument state must be saved along with the trace data and the state data varies depending on the number of modes currently available in the instrument.		

Using Applications in PSA Series vs. VSA E4406A

NOTE

This information only applies to the application modes: Basic, cdmaOne, cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC, and PDC.

Command	PSA Series	VSA E4406A: A.04.00	VSA E4406A: A.05.00
*RST	Resets instrument, putting it in continuous measurement mode. Use INIT:CONT OFF to select single measurement mode and INIT:IMM to start one measurement.	Resets instrument, putting it in single measurement mode. One measurement is initiated when the command is sent.	Resets instrument, putting it in single measurement mode. No measurement is initiated when the command is sent. Use INIT:IMM to start one measurement.
CONFigure: <measurement></measurement>	Accesses the measurement and sets the instrument settings to the defaults. If you were already in single measurement mode, it takes one measurement and then waits.	Same as PSA. Accesses the measurement and sets the instrument settings to the defaults. If you were already in single measurement mode, it takes one measurement and then waits.	Accesses the measurement and sets the instrument settings to the defaults. If you were already in single measurement mode, it does not initiate a measurement. Use INIT:IMM to make one measurement.
*ESE default	Default is 255 which means that every error/status bit change that has occurred will be returned with a *ESR? query. You must set the value of *ESE to choose only the bits/status that you want returned.	Default is 0 which means that none of the error/status bit changes that have occurred will be returned with a *ESR? query. You must set the value of *ESE to choose the bits/status that you want returned.	Same as VSA A.04.00. Default is 0 which means that none of the error/status bit changes that have occurred will be returned with a *ESR? query. You must set the value of *ESE to choose the bits/status that you want returned.
*LRN	The command is <i>not</i> available.	The command is available.	The command is available.

Command	PSA Series	VSA E4406A: A.04.00	VSA E4406A: A.05.00
TRIGger commands	In Spectrum Analysis mode only one value can be set for the trigger's source, delay, level, or polarity. Basic, GSM, EDGE, cdmaOne, cdma2000, W-CDMA, NADC, PDC modes function the same as VSA	You can select a unique trigger source for each mode. Each trigger source can have unique settings for the delay, level, and polarity parameters.	Same as VSA A.04.00. You can select a unique trigger source for each mode. Each trigger source can have unique settings for the delay, level, and polarity parameters.
AUTOON OFF control and setting manual values	We recommend that you set a function's automatic state to OFF, before you send it your manual value.	We recommend that you set a function's automatic state to OFF, before you send it your manual value.	We recommend that you set a function's automatic state to OFF, before you send it your manual value.
	Some functions will turn off the automatic mode when you send a specific manual value, but others will not. This also varies with the instrument model.	Some functions will turn off the automatic mode when you send a specific manual value, but others will not. This also varies with the instrument model.	Some functions will turn off the automatic mode when you send a specific manual value, but others will not. This also varies with the instrument model.

CALCulate Subsystem

This subsystem is used to perform post-acquisition data processing. In effect, the collection of new data triggers the CALCulate subsystem. In this instrument, the primary functions in this subsystem are markers and limits.

The SCPI default for data output format is ASCII. The format can be changed to binary with FORMat:DATA which transports faster over the bus.

Code Domain Power - Limits

Code Domain—Active Set Threshold

:CALCulate:CDPower:ASET:THReshold <numeric>

:CALCulate:CDPower:ASET:THReshold?

Set the threshold level for the active channel identification function.

Factory Preset: 0.0 dBm

Range: -100.0 to 0.0 dB

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Code Domain—Active Set Threshold Mode

:CALCulate:CDPower:ASET:THReshold:AUTO OFF ON 0 1

:CALCulate:CDPower:ASET:THReshold:AUTO?

Turn the automatic mode On or Off, for the active channel identification function.

OFF – The active channel identification for each code channel is determined by a value set by CALCulate: CDPower: ASET: THReshold.

ON – The active channels are determined automatically with the internal algorithm.

Factory Preset: ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Code Domain—Decode Axis

:CALCulate:CDPower:AXIS[:MS] IPH QPH

:CALCulate:CDPower:AXIS[:MS]?

Select the I phase or Q phase for the demodulation axis. (For MS only)

IPH - I phase QPH - Q phase

Factory Preset: IPH for cdma2000

QPH for W-CDMA

Remarks: You must be in the cdma2000 or W-CDMA mode to use

this command. Use INSTrument:SELect to set the

mode.

Code Domain—Modulation Scheme

For cdma2000/1xEV-DV:

:CALCulate:CDPower:MTYPe AUTO GATed QPSK OPSK QAM16

:CALCulate:CDPower:MTYPe?

For W-CDMA/HSDPA:

:CALCulate:CDPower:MTYPe AUTO | GATed | QPSK | QAM16

:CALCulate:CDPower:MTYPe?

For cdma2000/1xEV-DV: Select the modulation type to be used for analysis of forward link PDCH (F-PDCH) in 1xEV-DV. This command is not available unless you have a license for the 1xEV-DV option and 1xEV-DV is enabled.

For W-CDMA/HSDPA: selects the type of modulation to be used for HSDPA base station testing. See [:SENSe]:RADio:DEVice is set to BTS. Also, the symbol rate must be set to 240 ksps using CALCulat:CDPower:SRATe. This command is not available unless you have a license for the HSDPA option and HSDPA is enabled.

Example: CALC:CDP:MTYP QAM16

Factory Preset: AUTO

Saved State: Saved in instrument state

Remarks: You must be in the cdma2000, W-CDMA mode to use

this command. Use INSTrument:SELect to set the

mode.

Front Panel

Access: Meas Setup

Code Domain—Psuedo-Random Noise Offset

:CALCulate:CDPower:PNOFfset <time>

:CALCulate:CDPower:PNOFfset?

Sets value for the pseudo-random noise offset. Different pseudo-random noise offsets are used for different base stations. By setting the pseudo-random noise offset to the value that your specific base station is set to, you get the correct time offset value displayed and returned back to you when you query READ:RHO? The instrument, by default, assumes an offset of 0. So if you do not use this command you will have to manually calculate the time offset when the value is other than 0.

Factory Preset: 0 chips offset

Range: 0 to 511 (\times 64 chips) 1 = 64 chip offset, 2 = 128 chips

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Code Domain—Sweep Offset (Measurement Offset)

```
:CALCulate:CDPower:SWEep:OFFSet <integer>
```

:CALCulate:CDPower:SWEep:OFFSet <time>(1xEV-DO only)

:CALCulate:CDPower:SWEep:OFFSet?

1xEV-DO mode:

Set the timing offset of measurement interval in units of slot (1 slot = 1.667 ms).

The sum of CALCulate:CDPower:SWEep:TIME and CALCulate:CDPower:SWEep:OFFSet must be equal to or less than SENSe:CDPower:CAPTure:TIME. If the sum becomes more than the value, CALCulate:CDPower:SWEep:OFFSet is adjusted automatically.

cdma2000 mode:

Set the timing offset of measurement interval in units of Power Control Group (PCG; 1 PCG = 1.25 ms).

The sum of CALCulate:CDPower:SWEep:TIME and CALCulate:CDPower:SWEep:OFFSet must be equal to or less than SENSe:CDPower:CAPTure:TIME. If the sum becomes more than the value, CALCulate:CDPower:SWEep:OFFSet is adjusted automatically.

W-CDMA mode:

Set the timing offset of measurement interval in slots (1 slot = $625 \mu s$).

The sum of CALCulate:CDPower:SWEep:TIME and CALCulate:CDPower:SWEep:OFFSet must be equal to or less than SENSe:CDPower:CAPTure:TIME × 15. If the sum becomes more than the value, CALCulate:CDPower:SWEep:OFFSet is adjusted automatically.

Factory Preset: 0

Range: 0 to SENSe:CDPower:CAPTure:TIME - 1 for cdma2000

0 to SENSe:CDPower:CAPTure:TIME - 0.5 for 1xEV-DO

0 to SENSe: CDPower: CAPTure: TIME \times 15 - 1 for

W-CDMA

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Code Domain—Sweep Time (Measurement Interval)

:CALCulate:CDPower:SWEep:TIME <integer>

:CALCulate:CDPower:SWEep:TIME <float> for (1xEV-DO only)

:CALCulate:CDPower:SWEep:TIME?

For 1xEV-DO

Set the length of measurement interval in units of slot (1 slot = 1.667 ms).

The sum of CALCulate:CDPower:SWEep:TIME and CALCulate:CDPower:SWEep:OFFSet must be equal to or less than SENSe:CDPower:CAPTure:TIME. If the sum becomes more than the value, CALCulate:CDPower:SWEep:OFFSet is adjusted automatically.

• For cdma2000

Set the length of measurement interval in the unit of Power Control Group (PCG; 1 PCG = 1.25 ms).

The sum of CALCulate:CDPower:SWEep:TIME and CALCulate:CDPower:SWEep:OFFSet must be equal to or less than SENSe:CDPower:CAPTure:TIME. If the sum becomes more than the value, CALCulate:CDPower:SWEep:OFFSet is adjusted automatically.

• For W-CDMA

Set the length of measurement interval in slots (1 slot = $625 \mu s$).

The sum of CALCulate:CDPower:SWEep:TIME and CALCulate:CDPower:SWEep:OFFSet must be equal to or less than SENSe:CDPower:CAPTure:TIME × 15. If the sum becomes more than the value, CALCulate:CDPower:SWEep:OFFSet is adjusted automatically.

Factory Preset: 1

Range: 1 to SENSe:CDPower:CAPTure:TIME for cdma2000

0.5 to SENSe: CDPower: CAPTure: TIME for 1xEV-DO

1 to SENSe: CDPower: CAPTure: TIME × 15 for W-CDMA

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Code Domain—Computation Type

:CALCulate:CDPower:TYPE ABSolute RELative

:CALCulate:CDPower:TYPE?

Set the code domain power computation type to either the absolute power or the relative value to the mean power.

ABSolute – code domain power is computed as the absolute power.

RELative – code domain power is computed relative to the mean power.

Factory Preset: RELative

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Code Domain—Walsh Code Base Length

:CALCulate:CDPower:WCODe:BASE <integer>

:CALCulate:CDPower:WCODe:BASE?

Set the Walsh Code base length for BTS. (For MS, this value is always 32.)

Factory Preset: 64

Range: 64, 128

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Code Domain-Walsh Code Length

:CALCulate:CDPower:WCODe:LENGth <integer>

:CALCulate:CDPower:WCODe:LENGth?

Set the Walsh Code length.

Factory Preset: 64 for BTS

32 for MS

Range: 4, 8, 16, 32, 64, 128 for BTS

2, 4, 8, 16, 32 for MS

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Code Domain-Walsh Code Number

:CALCulate:CDPower:WCODe[:NUMBer] <integer>

:CALCulate:CDPower:WCODe[:NUMBer]?

Set the Walsh code number depending on the channel type.

Factory Preset: 0

Range: 0 to CALCulate: CDPower: WCODe: LENGth - 1, for

cdma2000

0 to 31 for Pilot, 0 to 63 for MAC,

0 to 15 for Data (1xEV-DO)

Remarks: You must be in the cdma2000 or 1xEV-DO mode to use

this command. Use INSTrument:SELect to set the

mode.

Code Domain-Walsh Code Order

:CALCulate:CDPower:WCODe:ORDer BREVerse (HADMrd | HADamard)

:CALCulate:CDPower:WCODe:ORDer?

Set the type of the Walsh code order to either of the following:

BREVerse (Bit Reverse) – In the order to show the higher (consolidated) spreading code as a single bundle in the CDP display

HADMrd or HADamard(Hadamard) - Regular order

Factory Preset: Hadamard (HADamard)

Remarks: You must be in the cdma2000, or 1xEV-DO mode to use

this command. Use INSTrument:SELect to set the mode.

Test Current Results Against all Limits

```
:CALCulate:CLIMits:FAIL?
```

Queries the status of the current measurement limit testing. It returns a 0 if the measured results pass when compared with the current limits. It returns a 1 if the measured results fail any limit tests.

Data Query

```
:CALCulate:DATA[n]?
```

Returns the designated measurement data for the currently selected measurement and sub-opcode.

n= any valid sub-opcode for the current measurement. See the "MEASure Group of Commands" on page 311 for information on the data that can be returned for each measurement.

For sub-opcodes that return trace data use the :CALCulate:DATA[n]:COMPress? command below.

Calculate/Compress Trace Data Query

```
:CALCulate:DATA<n>:COMPress?

BLOCk | CFIT | MAXimum | MINimum | MEAN |
| DMEan | RMS | RMSCubed | SAMPle | SDEViation | PPHase [, <soffset>[, <length>[, <roffset>[, <rlimit>]]]]
```

Returns compressed data for the specified trace data. The data is returned in the same units as the original trace and only works with the currently selected measurement. The command is used with a sub-opcode <*n*> since measurements usually return several types of trace data. See the following table for the sub-opcodes for the trace data names that are available in each measurement. For sub-opcodes that return scalar data use the :CALCulate:DATA[n]? command above.

This command is used to compress or decimate a long trace to extract and return only the desired data. A typical example would be to acquire N frames of GSM data and return the mean power of the first burst in each frame. The command can also be used to identify the best curve fit for the data.

• BLOCk or block data - returns all the data points from the region of the trace data that you specify. For example, it could be used to return the data points of an input signal over several timeslots, excluding the portions of the trace data that you do not want.

• CFIT or curve fit - applies curve fitting routines to the data. <soffset> and <length> are required to define the data that you want. <roffset> is an optional parameter for the desired order of the curve equation. The query will return the following values: the x-offset (in seconds) and the curve coefficients ((order + 1) values).

MIN, MAX, MEAN, DME, RMS, RMSC, SAMP, SDEV and PPH return one data value for each specified region (or <length>) of trace data, for as many regions as possible until you run out of trace data (using <roffset> to specify regions). Or they return the number regions you specify (using <rli>rlimit>) ignoring any data beyond that.

- MINimum returns the minimum data point for the specified region(s) of trace data For I/Q trace data, the minimum magnitude of the I/Q pairs is returned.
- MAXimum returns the maximum data point for the specified region(s) of trace data. For I/Q trace data, the maximum magnitude of the I/Q pairs is returned.
- MEAN returns the arithmetic mean of the data point values for the specified region(s) of trace data. For I/Q trace data, the mean of the magnitudes of the I/Q pairs is returned. See the following equations.

Note: If the original trace data is in dB, this function returns the arithmetic mean of those log values, not log of the mean power, which is a more useful value.

Equation 4-1 Mean Value of Data Points for Specified Region(s)

$$MEAN = \frac{1}{n} \sum_{Xi \in region(s)} Xi$$

where Xi is a data point value, and n is the number of data points in the specified region(s).

Equation 4-2 Mean Value of I/Q Data Pairs for Specified Region(s)

$$MEAN = \frac{1}{n} \sum_{Xi \in region(s)} |Xi|$$

where | Xi | is the magnitude of an I/Q pair, and n is the number of I/Q pairs in the specified region(s).

• *DMEan* - returns the mean power (in dB/dBm) of the data point values for the specified region(s) of trace data. See the following equation:

Figure 4-1 DMEan Value of Data Points for Specified Region(s)

DME =
$$10 \times \log_{10} \left(\frac{1}{n} \sum_{Xi \in \text{region(s)}} \left(\frac{Xi}{10} \right) \right)$$

• *RMS* - returns the arithmetic rms of the data point values for the specified region(s) of trace data. See the following equation.

For I/Q trace data, the rms of the magnitudes of the I/Q pairs is returned. See the following equation.

Note: This function is very useful for I/Q trace data. However, if the original trace data is in dB, this function returns the rms of the log values which is not usually needed.

Equation 4-3 RMS Value of Data Points for Specified Region(s)

RMS =
$$\sqrt{\frac{1}{n}} \sum_{Xi \in \text{region(s)}} Xi^2$$

where Xi is a data point value, and n is the number of data points in the specified region(s).

Equation 4-4 RMS Value of I/Q Data Pairs for Specified Region(s)

RMS =
$$\sqrt{\frac{1}{n}} \sum_{Xi \in region(s)} Xi Xi^*$$

where Xi is the complex value representation of an I/Q pair, Xi* its conjugate complex number, and n is the number of I/Q pairs in the specified region(s).

Once you have the rms value for a region of I/Q trace data, you may want to calculate the mean power. You must convert this rms I/Q value (peak volts) to power in dB.

$$10 \times \log[10 \times (\text{rms value})^2]$$

• *RMSCubed* - returns the arithmetic rms of the cubed voltage normalized data point values for the specified region(s) of I/Q trace data by following the formula which is specifically defined for calculating the "Cubic Metric." This formula is described in the 3GPP TS.25.101 release-7 document. The RMSCubed parameter can be used on any set of I/Q pairs (DATA0) with units of points, not

time.

Equation 4-5 RMSC Values of I/Q Data Pairs for Specified Region(s)

RMSC = 20 log
$$\sqrt{\frac{1}{n}} \sum_{Xi \in \text{reagion(s)}} \left\{ \left(\frac{\sqrt{XiXi^*}}{\sqrt{\frac{1}{n}} \sum_{Xi \in \text{region(s)}} XiXi^*} \right)^3 \right\}^2$$

$$= 20 \log n \left(\frac{\sum_{XiXi*} \frac{XiXi*}{\sum_{Xi \in \text{region(s)}} XiXi*} \right)^{3}$$

where Xi is the complex value representation of an I/Q pair, Xi* its conjugate complex number, and n is the number of I/Q pairs in the specified region(s).

- *SAMPle* returns the first data value for the specified region(s) of trace data. For I/Q trace data, the first I/Q pair is returned.
- *SDEViation* returns the arithmetic standard deviation for the data point values for the specified region(s) of trace data. See the following equation.

For I/Q trace data, the standard deviation of the magnitudes of the I/Q pairs is returned. See the following equation.

Equation 4-6 Standard Deviation of Data Point Values for Specified Region(s)

SDEV =
$$\sqrt{\frac{1}{n}} \sum_{Xi \in \text{region(s)}} (Xi - \overline{X})^2$$

where Xi is a data point value, X is the arithmetic mean of the data point values for the specified region(s), and n is the number of data points in the specified region(s).

Equation 4-7 Standard Deviation of I/Q Data Pair Values for Specified Region(s)

SDEV =
$$\sqrt{\frac{1}{n}} \sum_{Xi \in \text{region(s)}} (|Xi| - \overline{X})^2$$

where |Xi| is the magnitude of an I/Q pair, X is the mean of the magnitudes for the specified region(s), and n is the number of data points in the specified region(s).

 PPHase - returns the pairs of rms power (dBm) and arithmetic mean phase (radian) for every specified region and frequency offset (Hz). The number of pairs is defined by the specified number of regions. The command can be used for I/Q vector (n=0) in Waveform (time domain) measurement and all parameters are specified by data point in PPH.

The rms power of the specified region may be expressed as:

Power = $10 \times \log [10 \times (RMS I/Q \text{ value})] + 10$.

The RMS I/Q value (peak volts) =
$$\sqrt{\frac{1}{n}} \sum_{Xi \in region} XiXi^*$$

where Xi is the complex value representation of an I/Q pair, Xi* its conjugate complex number, and n is the number of I/Q pairs in the specified region.

The arithmetic mean phase of the specified region may be expressed as:

Phase =
$$\frac{1}{n} \sum_{Yi \in region} Yi$$

Where Yi is the unwrapped phase of I/Q pair with applying frequency correction and n is the number of I/Q pairs in the specified region.

The frequency correction is made by the frequency offset calculated by the arithmetic mean of every specified region's frequency offset. Each frequency offset is calculated by the least square method against the unwrapped phase of I/Q pair.

Figure 4-2 Sample Trace Data - Constant Envelope





Figure 4-3 Sample Trace Data - Not Constant Envelope



<soffset> - start offset is an optional real number (in seconds). It specifies the amount of data at the beginning of the trace that will be ignored before the decimation process starts. It is the time from the start of the trace to the point where you want to start using the data. The default value is zero.

<length> - is an optional real number (in seconds). It defines how much data will be compressed into one value. This parameter has a default value equal to the current trace length.

<roffset> - repeat offset is an optional real number (in seconds). It defines the beginning of the next field of trace elements to be compressed. This is relative to the beginning of the previous field. This parameter has a default value equal to the <length> variable.

<rlimit> - repeat limit is an optional integer. It specifies the number of data items that you want returned. It will ignore any additional items beyond that number. You can use the Start offset and the Repeat limit to pick out exactly what part of the data you want to use. The default value is all the data.

Example: To query the mean power of a set of GSM bursts:

- 1. Set the waveform measurement sweep time to acquire at least one burst.
- 2. Set the triggers such that acquisition happens at a known position relative to a burst.
- 3. Then query the mean burst levels using, CALC:DATA2:COMP? MEAN, 24e-6, 526e-6 (These parameter values correspond to GSM signals, where 526e-6 is the length of the burst in the slot and you just want 1 burst.)

NOTE

There is a more detailed example in the "Improving the Speed of Your Measurements" section in the PSA Series *User's and Programmer's*

CALCulate Subsystem

Reference. There is also a sample program in the Programming Fundamentals chapter of that book, and a copy of it is on the documentation CD-ROM.

NOTE

There is a more detailed example in the "Improving the Speed of Your Measurements" section in the E4406A Programmer's Guide. There is also a sample program in the Programming Fundamentals chapter of that book, and a copy of it is on the documentation CD-ROM.

Remarks: The optional parameters must be entered in the

specified order. For example, if you want to specify

<length>, you must also specify <soffset>.

This command uses the data in the format specified by FORMat:DATA, returning either binary or ASCII data.

Added in revision A.03.00 History:

Changed in revision A.05.00

Measurement	Available Traces	Markers Available?
ACP - adjacent channel power	no traces	no markers
(Basic, cdmaOne, cdma2000, W-CDMA, iDEN, WiDEN, NADC, PDC modes)	$(n=0)^{a}$ for I/Q points	
BER - bit error rate	no traces	no markers
(iDEN, WiDEN mode)	(n=0) ^a for I/Q data	
CDPower - code domain power	POWer (n=2) ^a	yes
(cdmaOne mode)	TIMing $(n=3)^a$	
	PHASe $(n=4)^a$	
	$(n=0)^a$ for I/Q points	
CDPower - code domain power	CDPower (n=2) ^a	yes
(cdma2000 mode)	EVM (<i>n</i> =5) ^a	
	MERRor $(n=6)^a$	
	PERRor $(n=7)^a$	
	SPOWer $(n=9)^a$	
	CPOWer $(n=10)^a$	
	$(n=0)^a$ for I/Q points	

Measurement	Available Traces	Markers Available?
CDPower - code domain power	CDError (n=13) ^a	yes
(W-CDMA mode)	CDPower $(n=2)^a$	
	EVM (<i>n</i> =5) ^a	
	MERRor (n=6) ^a	
	PERRor (n=7) ^a	
	SPOWer $(n=9)^a$	
	CPOWer $(n=10)^a$	
	$(n=0)^a$ for I/Q points	
CHPower - channel power	SPECtrum (n=2) ^a	no markers
(Basic, cdmaOne, cdma2000, W-CDMA modes)	$(n=0)^a$ for I/Q points	
CSPur - spurs close	SPECtrum (n=2) ^a	yes
(cdmaOne mode)	ULIMit (n=3) ^a	
	(n=0) ^a for I/Q points	
EEVM - EDGE error vector magnitude	EVMerror (n=2) ^a	yes
(EDGE mode)	MERRor (n=3) ^a	
	PERRor (n=4) ^a	
	(n=0) ^a for I/Q points	
EORFspectr - EDGE output RF	RFEMod (n=2) ^a	yes, only for
spectrum (EDGE mode)	RFESwitching $(n=3)^a$	a single offset
(EBGE mode)	SPEMod (n=4) ^a	1 0
	LIMMod (n=5) ^a	yes, only for multiple
	(n=0) ^a for I/Q points	offsets
EPVTime - EDGE power versus time	RFENvelope (n=2) ^a	yes
(EDGE mode)	UMASk (n=3) ^a	
	LMASk (n=4) ^a	
	$(n=0)^a$ for I/Q points	

Measurement	Available Traces	Markers Available?
ETSPur - EDGE transmit band spurs	SPECtrum (n=2) ^a	yes
(EDGE mode)	ULIMit (n=3) ^a	
	$(n=0)^a$ for I/Q points	
EVM - error vector magnitude	EVM (n=2) ^a	yes
(NADC, PDC modes)	MERRor (n=3) ^a	
	PERRor (n=4) ^a	
	$(n=0)^a$ for I/Q points	
EVMQpsk - QPSK error vector	EVM (n=2) ^a	yes
magnitude (cdma2000, W-CDMA modes)	MERRor (n=3) ^a	
(camazoo, w ozna modes)	PERRor $(n=4)^a$	
	$(n=0)^a$ for I/Q points	
IM - intermodulation	SPECtrum (n=2) ^a	yes
(cdma2000, W-CDMA modes)	(n=0) ^a for I/Q points	
MCPower - multi-carrier power	no traces	no markers
(W-CDMA mode)	$(n=0)^a$ for I/Q points	
OBW - occupied bandwidth	no traces	no markers
(cdmaOne, cdma2000, iDEN, WiDEN, PDC, W-CDMA modes)	$(n=0)^a$ for I/Q points	
ORFSpectrum - output RF spectrum	RFEMod (n=2) ^a	yes, only for
(GSM, EDGE mode)	RFESwitching $(n=3)^a$	a single offset
	SPEMod (n=4) ^a	
	LIMMod (n=5) ^a	yes, only for multiple
	(n=0) ^a for I/Q points	offsets
PFERror - phase and frequency error	PERRor (n=2) ^a	yes
(GSM, EDGE mode)	PFERror (n=3) ^a	
	RFENvelope (n=4) ^a	
	(n=0) ^a for I/Q points	

Measurement	Available Traces	Markers Available?
PSTatistic - power statistics CCDF	MEASured (n=2) ^a	yes
(Basic, cdma2000, W-CDMA modes)	GAUSian (n=3) ^a	
	REFerence $(n=4)^a$	
	(n=0) ^a for I/Q points	
PVTime - power versus time	RFENvelope (n=2) ^a	yes
(GSM, EDGE, Service modes)	UMASk (n=3) ^a	
	LMASk (n=4) ^a	
	$(n=0)^a$ for I/Q points	
RHO - modulation accuracy	(n=0) ^a for I/Q points	yes
(cdmaOne, cdma2000 mode)	EVM (n=2) ^a	
	MERRor (n=3) ^a	
	PERRor (n=4) ^a	
	$(n=0)^a$ for I/Q points	
RHO - modulation accuracy	(n=0) ^a for I/Q points	yes
(W-CDMA mode)	CDPower (n=8)	
	EVM (n=2) ^a	
	MERRor (n=3) ^a	
	PERRor (n=4) ^a	
	$(n=0)^{a}$ for I/Q points	
SEMask - spectrum emissions mask	SPECtrum (n=2) ^a	yes
(cdma2000, W-CDMA mode)	(n=0) ^a for I/Q points	
TSPur - transmit band spurs	SPECtrum (n=2) ^a	yes
(GSM, EDGE mode)	ULIMit (n=3) ^a	
	$(n=0)^a$ for I/Q points	
TXPower - transmit power	RFENvelope (n=2) ^a	yes
(GSM, EDGE mode)	IQ (n=8) ^a	
	$(n=0)^a$ for I/Q points	

Measurement	Available Traces	Markers Available?
SPECtrum - (frequency domain) (all modes)	RFENvelope $(n=2)^a$ for Service mode IQ $(n=3)^a$ SPECtrum $(n=4)^a$ ASPectrum $(n=7)^a$ $(n=0)^a$ for I/Q points	yes
WAVEform - (time domain) (all modes)	RFENvelope $(n=2)^a$ (also for Signal Envelope trace) $IQ (n=5)^a$ $(n=0)^a$ for I/Q points	yes

a. The *n* number indicates the sub-opcode that corresponds to this trace. Detailed descriptions of the trace data can be found in the MEASure subsystem documentation by looking up the sub-opcode for the appropriate measurement.

Calculate Peaks of Trace Data

:CALCulate:DATA<n>:PEAKs?

<threshold>,<excursion>[,AMPLitude|FREQuency|TIME]

Returns a list of peaks for the designated trace data *n* for the currently selected measurement. The peaks must meet the requirements of the peak threshold and excursion values.

The command can only be used with specific $\langle n \rangle$ (sub-opcode) values, for measurement results that are trace, or scalar, data. See the table above for the appropriate sub-opcodes. Both real and complex traces can be searched, but complex traces are converted to magnitude in dBm. Sub-opcode n=0, is the raw trace data which cannot be searched for peaks. Sub-opcode n=1, is the scaler data which also cannot be searched for peaks.

Threshold - is the level below which trace data peaks are ignored

Excursion - To be defined as a peak, the signal must rise above the threshold by a minimum amplitude change (excursion). Excursion is measured from the lowest point above the threshold (of the rising edge of the peak), to the highest signal point that begins the falling edge. If a signal valley is higher then the threshold, then the excursion is referenced to that valley, and a peak is only defined if the signal following that valley exceeds the excursion.

Amplitude - lists the peaks in order of descending amplitude, so the highest peak is listed first. This is the default peak order listing if the optional parameter is not specified.

Frequency - lists the peaks in order of occurrence, left to right across the x-axis

Time - lists the peaks in order of occurrence, left to right across the x-axis

Example: Select the spectrum measurement.

> Use CALC: DATA4: PEAK? -40, 10, FREQ to identify the peaks above – 40 dBm, with excursions of at least 10 dB, in order of increasing frequency.

Query Results: Returns a list of floating-point numbers. The first value

in the list is the number of peak points that follow. A peak point consists of two values: a peak amplitude followed by the its corresponding frequency (or time).

If no peaks are found the peak list will consist of only

the number of peaks, (0).

The peak list is limited to 100 peaks. Peaks in excess of

100 are ignored.

Remarks: This command uses the data setting specified by the

FORMat:DATA command and can return real 32-bit, real 64-bit, or ASCII data. The default data format is

ASCII.

History: For E4406A:

Added in revision A.03.00 and later

CALCulate:MARKers Subsystem

Markers can be put on your displayed measurement data to supply information about specific points on the data. Some of the things that markers can be used to measure include: precise frequency at a point, minimum or maximum amplitude, and the difference in amplitude or frequency between two points.

When using the marker commands you must specify the measurement in the SCPI command. We recommend that you use the marker commands only on the current measurement. Many marker commands will return invalid results, when used on a measurement that is not current. (This is true for commands that do more than simply setting or querying an instrument parameter.) No error is reported for these invalid results.

You must make sure that the measurement is completed before trying to query the marker value. Using the MEASure or READ command, before the marker command, forces the measurement to complete before allowing the next command to be executed.

Each measurement has its own instrument state for marker parameters. Therefore, if you exit the measurement, the marker settings in each measurement are saved and are then recalled when you change back to that measurement.

Basic Mode - <measurement> key words

- ACPr no markers (E4406A only)
- CHPower no markers (E4406A only)
- PSTatistic markers available (E4406A only)
- CCDF markers available
- SPECtrum markers available
- WAVeform markers available

Service Mode - <measurement> key words

- PVTime no markers
- SPECtrum markers available
- WAVeform markers available

1xEV-DO Mode - <measurement> key words

• CDPower - markers available

- CHPower no markers
- EVMQpsk markers available
- IM markers available
- OBW no markers
- PSTatistic markers available
- PVTime markers available
- RHO markers available
- SEMask markers available
- SPECtrum markers available
- WAVeform markers available

cdmaOne Mode - <measurement> key words

- ACPr no markers
- CHPower no markers
- CDPower markers available
- CSPur markers available
- RHO markers available
- SPECtrum markers available
- WAVeform markers available

cdma2000 Mode - <measurement> key words

- ACP no markers
- CDPower markers available
- CHPower no markers
- EVMQpsk markers available
- IM markers available
- OBW no markers
- PSTatistic markers available
- RHO markers available
- SEMask markers available
- SPECtrum markers available
- WAVeform markers available

GSM (with EDGE) Mode - <measurement> key words

- EEVM markers available
- EORFspectr markers available
- EPVTime no markers
- ETSPur markers available
- ORFSpectrum markers available
- PFERror markers available
- PVTime no markers
- SPECtrum markers available
- TSPur markers available
- TXPower no markers
- WAVeform markers available

GSM Mode - <measurement> key words

- ORFSpectrum markers available
- PFERror markers available
- PVTime no markers
- SPECtrum markers available
- TSPur markers available
- TXPower no markers
- WAVeform markers available

iDEN Mode - <measurement> key words

- ACP no markers
- BER no markers
- OBW no markers
- SPECtrum markers available
- WAVeform markers available

NADC Mode - <measurement> key words

- ACP no markers
- EVM markers available
- SPECtrum markers available
- WAVeform markers available

PDC Mode - <measurement> key words

- ACP no markers
- EVM markers available
- OBW no markers
- SPECtrum markers available
- WAVeform markers available

W-CDMA Mode - <measurement> key words

- ACP no markers
- CDPower markers available
- CHPower no markers
- EVMQpsk markers available
- IM markers available
- MCPower no markers
- OBW no markers
- PSTatistic markers available
- PCONtrol markers available
- ullet PSTatistic markers available
- PVTmask markers available
- SEMask markers available
- SPECtrum markers available
- WAVeform markers available

Example:

Suppose you are using the Spectrum measurement in your measurement personality. To position marker 2 at the maximum peak value of the trace that marker 2 is currently on, the command is:

:CALCulate:SPECtrum:MARKer2:MAXimum

You must make sure that the measurement is completed before trying to query the marker value. Use the MEASure or READ command before using the marker command. This forces the measurement to complete before allowing the next command to be executed.

Markers All Off on All Traces

:CALCulate:<measurement>:MARKer:AOFF

Turns off all markers on all the traces in the specified measurement.

Example: CALC: SPEC: MARK: AOFF

Remarks: The keyword for the current measurement must be

specified in the command. (Some examples include:

SPECtrum, WAVeform)

Front Panel

Access: Marker, More, Marker All Off

Marker Function Result

:CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:FUNCtion:RESult?

Queries the result of the currently active marker function. The measurement must be completed before querying the marker. A particular measurement may not have all the types of markers available.

The marker must have already been assigned to a trace. Use :CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:TRACe to assign a marker to a particular trace.

Example: CALC: SPEC: MARK: FUNC: RES?

Remarks: The keyword for the current measurement must be

specified in the command. (Some examples include:

SPECtrum, WAVeform)

Front Panel

Access: Marker, Marker Function

Marker Peak (Maximum) Search

:CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:MAXimum

Places the selected marker on the highest point on the trace that is assigned to that particular marker number.

The marker must have already been assigned to a trace. Use :CALCulate:<measurement>:MARKer[1] |2|3|4:TRACe to assign a marker to a particular trace.

Example: CALC:SPEC:MARK1:MAX

Remarks: The keyword for the current measurement must be

specified in the command. (Some examples include:

SPECtrum, WAVeform)

Front Panel

Access: Search

Marker Peak (Minimum) Search

:CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:MINimum

Places the selected marker on the lowest point on the trace that is assigned to that particular marker number.

The marker must have already been assigned to a trace. Use :CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:TRACe to assign a marker to a particular trace.

Example: CALC:SPEC:MARK2 MIN

Remarks: The keyword for the current measurement must be

specified in the command. (Some examples include:

SPECtrum, WAVeform)

Marker Mode

E4406A (all modes):

PSA Series (Basic, cdmaOne, cdma2000, W-CDMA, GSM/EDGE, NADC, PDC modes):

:CALCulate:<measurement>:MARKer[1] |2|3|4:MODE POSition | DELTa

ESA/PSA Series (Phase Noise mode only):

:CALCulate:<measurement>:MARKer[1] |2|3|4:MODE POSition|DELTa

| RMSDegree | RMSRadian | RFM | RMSJitter | OFF

:CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:MODE?

E4406A/PSA: Selects the type of marker to be a normal position-type marker or a delta marker. A specific measurement may not have both types of markers. For example, several measurements only have position markers

ESA/PSA Phase Noise Mode: Selects the type of marker to be a normal position-type marker, a delta marker or an RMS measurement marker.

The marker must have already been assigned to a trace. Use :CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:TRACe to assign a marker to a particular trace.

Example: CALC: SPEC: MARK: MODE DELTA

Remarks: For the delta mode only markers 1 and 2 are valid.

The keyword for the current measurement must be specified in the command. (Some examples include:

SPECtrum, WAVeform)

Front Panel

Access: Marker, Marker [Delta]

Marker On/Off

:CALCulate:<measurement>:MARKer[1] |2|3|4[:STATe] OFF |ON|0|1

:CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4 [:STATe]?

Turns the selected marker on or off.

The marker must have already been assigned to a trace. Use :CALCulate:<measurement>:MARKer[1]|2|3|4:TRACe to assign a marker to a particular trace.

Example: CALC: SPEC: MARK2: on

Remarks: The keyword for the current measurement must be

specified in the command. (Some examples include:

SPECtrum, AREFerence, WAVeform)

The WAVeform measurement only has two markers

available.

Front Panel

Access: Marker, Select then Marker Normal or Marker On Off

Marker to Trace

:CALCulate:<measurement>:MARKer[1] |2|3|4:TRACe <trace_name>

:CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:TRACe?

Assigns the specified marker to the designated trace. Not all types of

measurement data can have markers assigned to them.

Example: With the WAVeform measurement selected, a valid

command is CALC: SPEC: MARK2: TRACE rfenvelope.

Range: The names of valid traces are dependent upon the

selected measurement. See the following table for the available trace names. The trace name assignment is

independent of the marker number.

Remarks: The keyword for the current measurement must be

specified in the command. (Some examples include:

SPECtrum, WAVeform)

Front Panel

Access: Marker, Marker Trace

Measurement	Available Traces	Markers Available?
ACP - adjacent channel power	no traces	no markers
(Basic, cdmaOne, cdma2000, W-CDMA, iDEN (E4406A only), NADC, PDC modes)	$(n=0)^{a}$ for I/Q points	
BER - bit error rate	no traces	no markers
(iDEN mode, E4406A only)	(n=0) ^a for I/Q data	
CDPower - code domain power	POWer (n=2) ^a	yes
(cdmaOne mode)	TIMing $(n=3)^a$	
	PHASe $(n=4)^a$	
	(n=0) ^a for I/Q points	
CDPower - code domain power	CDPower (n=2) ^a	yes
(cdma2000, W-CDMA, 1xEV-DO modes)	EVM (<i>n</i> =5) ^a	
,	MERRor (n=6) ^a	
	PERRor (n=7) ^a	
	SPOWer $(n=9)^a$	
	CPOWer (n=10) ^a	
	$(n=0)^a$ for I/Q points	
CHPower - channel power	SPECtrum (n=2) ^a	no markers
(Basic, cdmaOne, cdma2000, W-CDMA, 1xEV-DO modes)	$(n=0)^a$ for I/Q points	

Measurement	Available Traces	Markers Available?
CSPur - spurs close	SPECtrum (n=2) ^a	yes
(cdmaOne mode)	ULIMit (n=3) ^a	
	$(n=0)^a$ for I/Q points	
EEVM - EDGE error vector magnitude	EVMerror (n=2) ^a	yes
(EDGE mode)	MERRor $(n=3)^a$	
	PERRor (n=4) ^a	
	$(n=0)^a$ for I/Q points	
EORFspectr - EDGE output RF	RFEMod (n=2) ^a	yes, only for
spectrum (EDGE mode)	RFESwitching $(n=3)^a$	a single offset
(EDGE Mode)	SPEMod $(n=4)^a$	1 6
	LIMMod (n=5) ^a	yes, only for multiple
	$(n=0)^a$ for I/Q points	offsets
EPVTime - EDGE power versus time	RFENvelope (n=2) ^a	yes
(EDGE mode)	UMASk (n=3) ^a	
	LMASk (n=4) ^a	
	$(n=0)^a$ for I/Q points	
ETSPur - EDGE transmit band spurs	SPECtrum (n=2) ^a	yes
(EDGE mode)	ULIMit (n=3) ^a	
	$(n=0)^a$ for I/Q points	
EVM - error vector magnitude	EVM (n=2) ^a	yes
(NADC, PDC modes)	MERRor $(n=3)^a$	
	PERRor (n=4) ^a	
	$(n=0)^a$ for I/Q points	
EVMQpsk - QPSK error vector	EVM (n=2) ^a	yes
magnitude (cdma2000, W-CDMA, 1xEV-DO	MERRor (n=3) ^a	
modes)	PERRor (n=4) ^a	
	$(n=0)^a$ for I/Q points	

Measurement	Available Traces	Markers Available?
IM - intermodulation	SPECtrum (n=2) ^a	yes
(cdma2000, W-CDMA, 1xEV-DO modes)	$(n=0)^a$ for I/Q points	
MCPower - multi-carrier power	no traces	no markers
(W-CDMA mode)	$(n=0)^a$ for I/Q points	
OBW - occupied bandwidth	no traces	no markers
(cdmaOne, cdma2000, iDEN (E4406A only), PDC, W-CDMA, 1xEV-DO modes)	$(n=0)^a$ for I/Q points	
ORFSpectrum - output RF spectrum	RFEMod $(n=2)^a$	yes, only for
(GSM, EDGE mode)	RFESwitching $(n=3)^a$	a single offset
	SPEMod $(n=4)^a$	1 0
	LIMMod $(n=5)^a$	yes, only for multiple
	$(n=0)^a$ for I/Q points	offsets
PFERror - phase and frequency error	PERRor (n=2) ^a	yes
(GSM, EDGE mode)	PFERror $(n=3)^a$	
	RFENvelope $(n=4)^a$	
	$(n=0)^a$ for I/Q points	
PSTatistic - power statistics CCDF	MEASured (n=2) ^a	yes
(Basic, cdma2000, W-CDMA, 1xEV-DO modes)	GAUSsian $(n=3)^a$	
modes)	REFerence $(n=4)^a$	
	$(n=0)^a$ for I/Q points	
PVTime - power versus time	RFENvelope (n=2) ^a	yes
(GSM, EDGE, 1xEV-DO, Service (E4406A only) modes)	UMASk $(n=3)^a$	
(ETTOOA UIIIy) IIIuues)	LMASk $(n=4)^a$	
	$(n=0)^a$ for I/Q points	

Measurement	Available Traces	Markers Available?
RHO - modulation quality	(n=0) ^a for I/Q points	yes
(cdmaOne, cdma2000, W-CDMA, 1xEV-DO mode)	EVM (<i>n</i> =2) ^a	
	MERRor (n=3) ^a	
	PERRor (n=4) ^a	
	(n=0) ^a for I/Q points	
SEMask - spectrum emissions mask	SPECtrum (n=2) ^a	yes
(cdma2000, W-CDMA, 1xEV-DO mode)	(n=0) ^a for I/Q points	
TSPur - transmit band spurs	SPECtrum (n=2) ^a	yes
(GSM, EDGE mode)	ULIMit (n=3) ^a	
	$(n=0)^a$ for I/Q points	
TXPower - transmit power	RFENvelope (n=2) ^a	yes
(GSM, EDGE mode)	IQ (n=8) ^a	
	(n=0) ^a for I/Q points	
SPECtrum - (frequency domain) (all modes)	RFENvelope (n=2) ^a for Service mode (E4406A only)	yes
	IQ (n=3) ^a	
	SPECtrum (n=4) ^a	
	ASPectrum (n=7) ^a	
	$(n=0)^a$ for I/Q points	
WAVEform - (time domain) (all modes)	RFENvelope (n=2) ^a (also for Signal Envelope trace)	yes
	IQ (n=5) ^a	
	$(n=0)^a$ for I/Q points	

a. The *n* number indicates the sub-opcode that corresponds to this trace. Detailed descriptions of the trace data can be found in the MEASure subsystem documentation by looking up the sub-opcode for the appropriate measurement.

Marker X Value

:CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:X <param>

:CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:X?

Position the designated marker on its assigned trace at the specified X value. The parameter value is in X-axis units (which is often frequency or time).

The marker must have already been assigned to a trace. Use :CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:TRACe to assign a marker to a particular trace.

The query returns the current X value of the designated marker. The measurement must be completed before querying the marker.

Example: CALC:SPEC:MARK2:X 1.2e6 Hz

Range: For Phase Noise mode: Graph Start Offset and Stop

Offset frequencies.

Default Unit: Matches the units of the trace on which the marker is

positioned

Remarks: The keyword for the current measurement must be

specified in the command. (Some examples include:

LPLot, ACP, WAVeform)

Front Panel

Access: Marker, <active marker>, RPG

Marker X Position

:CALCulate:<measurement>:MARKer[1] |2|3|4:X:POSition <integer>

:CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:X:POSition?

Position the designated marker on its assigned trace at the specified X position. A trace is composed of a variable number of measurement points. This number changes depending on the current measurement conditions. The current number of points must be identified before using this command to place the marker at a specific location.

The marker must have already been assigned to a trace. Use :CALCulate:<measurement>:MARKer[1] |2|3|4:TRACe to assign a marker to a particular trace.

The query returns the current X position for the designated marker. The measurement must be completed before querying the marker.

Example: CALC:SPEC:MARK:X:POS 500

Range: 0 to a maximum of (3 to 920,000)

Remarks: The keyword for the current measurement must be

specified in the command. (Some examples include:

SPECtrum, WAVeform)

Front Panel

Access: Marker, <active marker>, RPG

Marker Readout Y Value

:CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:Y?

Readout the current Y value for the designated marker on its assigned trace. The value is in the Y-axis units for the trace (which is often dBm).

The marker must have already been assigned to a trace. Use :CALCulate:<measurement>:MARKer[1] | 2 | 3 | 4:TRACe to assign a marker to a particular trace.

The measurement must be completed before querying the marker.

Example: CALC:SPEC:MARK1:Y?

Default Unit: Matches the units of the trace on which the marker is

positioned

Remarks: The keyword for the current measurement must be

specified in the command. (Some examples include:

LPLot, ACP, WAVeform)

Occupied Bandwidth - Limits

Occupied Bandwidth—Limit Test

PDC, cdma2000, W-CDMA,1xEV-DO mode

:CALCulate:OBW:LIMit[:TEST] OFF ON 0 1

:CALCulate:OBW:LIMit[:TEST]?

iDEN mode (E4406A only)

:CALCulate:OBWidth:LIMit:STATe OFF ON 0 1

:CALCulate:OBWidth:LIMit:STATe?

Turn the limit test function on or off.

Factory Preset: ON

Remarks: You must be in the iDEN (E4406A only), PDC,

cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

History: For E4406A:

Version A.02.00 or later

Power Statistic CCDF—Store Reference

:CALCulate:PSTatistic:STORe:REFerence ON 1

Store the currently measured trace as the user-defined reference trace. No query command is available.

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Modulation Accuracy - Limits

Modulation Accuracy (Rho)—Active Set Threshold

:CALCulate:RHO:ASET:THReshold <numeric>

:CALCulate:RHO:ASET:THReshold?

Set the threshold level for the active channel identification function.

Factory Preset: 0.0 dB

Range: -100.0 to 0.0 dB

Remarks: You must be in W-CDMA, cdma2000, or 1xEV-DO mode

to use this command. Use INSTrument:SELect to set

the mode.

Modulation Accuracy (Rho)—Active Set Threshold Mode

:CALCulate:RHO:ASET:THReshold:AUTO OFF ON 0 1

:CALCulate:RHO:ASET:THReshold:AUTO?

Turn the automatic mode On or Off, for the active channel identification function.

 $OFF-The\ active\ channel\ identification\ for\ each\ code\ channel\ is\ determined\ by\ a\ value\ set\ by\ {\tt CALCulate:RHO:ASET:THReshold}.$

ON – The active channels are determined automatically by the internal algorithm.

Factory Preset: ON

Remarks: You must be in W-CDMA, cdma2000, or 1xEV-DO mode

to use this command. Use INSTrument:SELect to set

the mode.

Modulation Accuracy (Rho)—Rho Result I/Q Offset

:CALCulate:RHO:IQOFfset:INCLude OFF ON 0 1

:CALCulate:RHO:IQOFfset:INCLude?

Turn the automatic mode On or Off, for the I/Q origin offset function.

OFF – The measurement results for EVM and Rho do not take into account the I/Q origin offset.

ON – The measurement results for EVM and Rho take into account the I/Q origin offset.

Factory Preset: ON

Remarks: You must be in the 1xEV-DO mode to use this

command. Use INSTrument:SELect to set the mode.

Modulation Accuracy (Rho)—Code Domain Error Limit (BTS)

:CALCulate:RHO:LIMit:CDERror <float>

:CALCulate:RHO:LIMit:CDERror?

Set the Peak Code Domain Error limit in dB.

Factory Preset: 0.0 dB for cdma2000

-32.0 dB for W-CDMA

Range: -100.0 to 0.0 dB

Remarks: You must be in the cdma2000 or W-CDMA mode to use

this command. Use INSTrument:SELect to set the

mode.

Modulation Accuracy (Rho)—Peak EVM Limit

:CALCulate:RHO:LIMit:PEAK <float>

:CALCulate:RHO:LIMit:PEAK?

Specify a limit value in percent for the peak EVM test.

Factory Preset: 100.0%

Range: 0.0 to 200.0%

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Modulation Accuracy (Rho)—Phase Error Limit

:CALCulate:RHO:LIMit:PHASe <float>

:CALCulate:RHO:LIMit:PHASe?

Specify a limit value in radian for the phase error test.

Factory Preset: 0.05 rad

Range: 0.00 to 3.00 rad

Remarks: You must be in the cdma2000 or 1xEV-DO mode to use

this command. Use INSTrument:SELect to set the

mode.

Modulation Accuracy (Rho)—Rho Limit

:CALCulate:RHO:LIMit:RHO <float>

:CALCulate:RHO:LIMit:RHO?

Specify a limit value for the Rho test.

Factory Preset: 0.5

Range: 0 to 1.0

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Modulation Accuracy (Rho)—RMS EVM Limit

:CALCulate:RHO:LIMit:RMS <float>

:CALCulate:RHO:LIMit:RMS?

Specify a limit value in percent for the rms EVM test.

Factory Preset: 17.5%

Range: 0.0 to 100.0%

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Modulation Accuracy (Rho)—Time Offset Limit

:CALCulate:RHO:LIMit:TIMing <float>

:CALCulate:RHO:LIMit:TIMing?

Specify a limit value in second for the time offset test.

Factory Preset: 0.00000005 s (50 ns)

Range: 0 to 0.0000005 s (0 to 500 ns)

Remarks: You must be in the cdma2000 or 1xEV-DO mode to use

this command. Use INSTrument:SELect to set the

mode.

Modulation Accuracy (Rho)—Pseudo-Random Noise Offset

:CALCulate:RHO:PNOFfset <time>

:CALCulate:RHO:PNOFfset?

Sets value for the pseudo-random noise offset. Different pseudo-random noise offsets are used for different base stations. By setting the pseudo-random noise offset to the value that your specific base station is set to, you get the correct time offset value displayed and returned back to you when you query READ:RHO? The instrument, by default, assumes an offset of 0. So if you do not use this command you will have to manually calculate the time offset when the value is other than 0.

Factory Preset: 0 chips offset

Range: 0 to 511 (\times 64 chips) 1 = 64 chip offset, 2 = 128 chips

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Spectrum Emission Mask—Limit Lines

CDMA2K, WCDMA, CDMA1XEV

:CALCulate:SEMask:LLINe:STATe ON | OFF | 1 | 0

:CALCulate:SEMask:LLINe:STATe?

Toggles the limit line display function for spectrum emission mask measurements On and Off.

Example :CALC:SEM:LLIN:STAT OFF

:CALC:SEM:LLIN:STAT?

Parameter Type Boolean | Binary

Remarks You must be in cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use :INSTrument:SELect

to set the mode.

Preset ON

State Saved Saved in instrument state.

Range ON | OFF

Key Path Display

Baseband I/Q - Spectrum I/Q Marker Query

:CALCulate:SPECtrum:MARKer:IQ [1] |2 |3 |4?

Reads out current I and Q marker values.

Remarks: You must be in the Basic, W-CDMA, cdma2000, or

EDGE with GSM mode to use this command. Use

INSTrument:SELect to set the mode.

History: Added revision A.05.00 for B, WC, C2

Added revision A.06.00 for E

Baseband I/Q - Waveform I/Q Marker Query

:CALCulate:WAVeform:MARKer:IQ [1] |2 |3 |4?

Reads out current I and Q marker values.

Remarks: You must be in the Basic, W-CDMA, cdma2000, or GSM

with EDGE mode to use this command. Use

INSTrument:SELect to set the mode.

History: Added revision A.05.00 for B, WC, C2

Added revision A.06.00 for E

CONFigure Subsystem

The CONFigure commands are used with several other commands to control the measurement process. The full set of commands are described in the section "MEASure Group of Commands" on page 311.

Selecting measurements with the CONFigure/FETCh/MEASure/READ commands sets the instrument state to the defaults for that measurement and to make a single measurement. Other commands are available for each measurement to allow you to change: settings, view, limits, etc. Refer to:

SENSe:<measurement>, SENSe:CHANnel, SENSe:CORRection, SENSe:DEFaults, SENSe:DEViation, SENSe:FREQuency, SENSe:PACKet, SENSe:POWer, SENSe:RADio, SENSe:SYNC CALCulate:<measurement>, CALCulate:CLIMits DISPlay:<measurement> TRIGger

The INITiate[:IMMediate] or INITiate:RESTart commands will initiate the taking of measurement data without resetting any of the measurement settings that you have changed from their defaults.

Configure the Selected Measurement

:CONFigure:<measurement>

A CONFigure command must specify the desired measurement. It will set the instrument settings for that measurements standard defaults, but should not initiate the taking of data. The available measurements are described in the MEASure subsystem.

NOTE

If CONFigure initiates the taking of data, the data should be ignored. Other SCPI commands can be processed immediately after sending CONFigure. You do not need to wait for the CONF command to complete this 'false' data acquisition.

Configure Query

:CONFigure?

The CONFigure query returns the name of the current measurement.

DISPlay Subsystem

The DISPlay controls the selection and presentation of textual, graphical, and TRACe information. Within a DISPlay, information may be separated into individual WINDows.

Adjacent Channel Power - View Selection

:DISPlay:ACP:VIEW BGRaph | SPECtrum

:DISPlay:ACP:VIEW?

Select the adjacent channel power measurement display of bar graph or spectrum.

You may want to disable the spectrum trace data part of the measurement so you can increase the speed of the rest of the measurement display. Use SENSe:ACP:SPECtrum:ENABle to turn on or off the spectrum trace. (Basic and cdmaOne modes only)

Factory Preset: Bar Graph (BGRaph)

Remarks: You must be in the cdmaOne, cdma2000, W-CDMA,

NADC or PDC mode to use this command. Use

INSTrument:SELect to set the mode.

Front Panel

Access: ACP, View/Trace

Code Domain - Base Code Length

:DISPlay:CDPower:BCLength 64 | 128

:DISPlay:CDPower:BCLength?

Set the base code length.

Factory Preset: 64

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Select Display Format

:DISPlay:FORMat:TILE

Selects the viewing format that displays multiple windows of the current measurement data simultaneously. Use DISP:FORM:ZOOM to

return the display to a single window.

Remarks: You must be in the Basic, cdmaOne,cdma2000,

 $1xEV ext{-DO}$, W-CDMA, GSM (w/EDGE), NADC, or PDC mode to use this command. Use INSTrument:SELect to

set the mode

Front Panel

Access: **Zoom** (toggles between Tile and Zoom)

Select Display Format

:DISPlay:FORMat:ZOOM

Selects the viewing format that displays only one window of the current measurement data (the current active window). Use DISP:FORM:TILE to return the display to multiple windows.

Remarks: You must be in the Basic, cdmaOne,cdma2000,

1xEV-DO, W-CDMA, GSM (w/EDGE), NADC, or PDC mode to use this command. Use INSTrument:SELect to

set the mode

Front Panel

Access: **Zoom** (toggles between Tile and Zoom)

Modulation Accuracy (Rho) - View Selection

1xEV-D0

:DISPlay:RHO:VIEW ERRor | POLar | QUAD | TABLe | TPHase

W-CDMA, cdma2000

:DISPlay:RHO:VIEW POLar ERRor

:DISPlay:RHO:VIEW?

Select one of the modulation accuracy (rho) measurement result views as follows:

ERRor (IQ Error: Quad View) - provides a combination view of the EVM vs. symbol, phase error vs. symbol, magnitude error vs. symbol graphs, and the summary data for each channel type specified.

POLar (IQ Measured Polar Graph) - provides a combination view of the I/Q measured polar constellation graph and the summary data for each channel type specified including Overall 1 and Overall 2.

QUAD (IQ Measured: Quad-view) - provides a combination view of an I/Q power vs. chip, I/Q vector absolute power vs. chip, I/Q polar graphs, and the summary data for each channel type specified

including Overall 1 and Overall 2.

TABle (Result Metrics) - provides a measurement result on Rho, EVM, and other metrics of each channel type specified including Overall 1 and Overall 2 in tabular form.

TPHase (Power Timing and Phase) - provides a measurement result on power levels, timing, phase, and code domain errors in tabular form for each active code.

Factory Preset: POLar

Remarks: You must be in the 1xEV-DO, W-CDMA, or cdma2000

mode to use this command. Use INSTrument:SELect to

set the mode.

Front Panel

Access: Mod Accuracy, View/Trace

Spectrum - Y-Axis Scale/Div

:DISPlay:SPECtrum[n]:WINDow[m]:TRACe:Y[:SCALe]:PDIVision
<power>

:DISPlay:SPECtrum[n]:WINDow[m]:TRACe:Y[:SCALe]:PDIVision?

Sets the amplitude reference level for the y-axis.

n – selects the view, the default is Spectrum.

m – selects the window within the view. The default is 1.

- n=1, m=1 Spectrum

- n=1, m=2 I/Q Waveform

— n=1, m=2 I and Q Waveform (Basic, W-CDMA, cdma2000)

— n=3, m=1 I/Q Polar (Basic, W-CDMA, cdma2000)

— n=4, m=1 Linear Spectrum (Basic, W-CDMA, cdma2000)

Factory Preset: 10 dB per division, for Spectrum

100 mV per division, for I/Q Waveform

Range: 0.1 dB to 20 dB per division, for Spectrum

1 nV to 20 V per division, for I/Q Waveform

Default Unit: 10 dB per division, for Spectrum

Remarks: May affect input attenuator setting.

You must be in Basic, cdmaOne, cdma2000, 1xEV-DO, W-CDMA GSM w/EDGE, NADC, or PDC mode. Set the

mode with INSTrument:SELect.

Front Panel

Access: When in Spectrum measurement: Amplitude Y Scale,

Scale/Div.

History: Added revision A.02.00

Spectrum - Y-Axis Reference Level

:DISPlay:SPECtrum[n]:WINDow[m]:TRACe:Y[:SCALe]:RLEVel
<power>

:DISPlay:SPECtrum[n]:WINDow[m]:TRACe:Y[:SCALe]:RLEVel?

Sets the amplitude reference level for the y-axis.

n, selects the view, the default is RF envelope.

— n=1, m=1 Spectrum

— n=1, m=2 I/Q Waveform

— n=1, m=2 I and Q Waveform (Basic, W-CDMA, cdma2000)

— n=3, m=1 I/Q Polar (Basic, W-CDMA, cdma2000)

— n=4, m=1 Linear Spectrum (Basic, W-CDMA, cdma2000)

m – selects the window within the view. The default is 1.

Factory Preset: 0 dBm, for Spectrum

Range: – 250 to 250 dBm, for Spectrum

Default Unit: dBm, for Spectrum

Remarks: May affect input attenuator setting.

You must be in Basic, cdmaOne, cdma2000, 1xEV-DO, W-CDMA GSM w/EDGE, NADC, or PDC mode. Set the

mode with INSTrument:SELect.

Front Panel

Access: When in Spectrum measurement: Amplitude Y Scale, Ref

Level

History: Added revision A.02.00

Turn a Trace Display On/Off

:DISPlay:TRACe[n][:STATe] OFF ON 0 1

:DISPlay:TRACe[n][:STATe]?

Controls whether the specified trace is visible or not.

n is a sub-opcode that is valid for the current measurement. See the "MEASure Group of Commands" on page 311 for more information about sub-opcodes.

Factory Preset: On

Range: The valid traces and their sub-opcodes are dependent

upon the selected measurement. See the following

table.

The trace name assignment is independent of the

window number.

Remarks: You must be in the Basic, cdmaOne,cdma2000,

1xEV-DO, W-CDMA, GSM (w/EDGE), NADC, or PDC mode to use this command. Use INSTrument:SELect to

set the mode

Front Panel

Access: Display, Display Traces

Measurement	Available Traces	Markers Available?
ACP - adjacent channel power	no traces	no markers
(Basic, cdmaOne, cdma2000, W-CDMA, NADC, PDC modes)	$(n=0)^{a}$ for I/Q points	
CDPower - code domain power	POWer (n=2) ^a	yes
(cdmaOne mode)	TIMing $(n=3)^a$	
	PHASe $(n=4)^a$	
	$(n=0)^a$ for I/Q points	
CDPower - code domain power (cdma2000, 1xEV-DO, W-CDMA	(n=0) ^a for I/Q raw data	yes
modes)	CDPower $(n=2)^a$	
	EVM (n=5) ^a	
	MERRor $(n=6)^a$	
	PERRor $(n=7)^a$	
	SPOWer $(n=9)^a$	
	CPOWer $(n=10)^a$	
CHPower - channel power	SPECtrum (n=2) ^a	no markers
(Basic, cdmaOne, cdma2000, 1xEV-DO, W-CDMA modes)	(n=0) ^a for I/Q raw data	

Measurement	Available Traces	Markers Available?
CSPur - spurs close	SPECtrum (n=2) ^a	yes
(cdmaOne mode)	ULIMit (n=3) ^a	
	$(n=0)^a$ for I/Q points	
EEVM - EDGE error vector magnitude	EVMerror (n=2) ^a	yes
(EDGE mode)	MERRor (n=3) ^a	
	PERRor (n=4) ^a	
	$(n=0)^a$ for I/Q points	
EORFspectr - EDGE output RF	RFEMod (n=2) ^a	yes, only for
spectrum (EDGE mode)	RFESwitching $(n=3)^a$	a single offset
(EDGE mode)	SPEMod $(n=4)^a$	1 6
	LIMMod $(n=5)^a$	yes, only for multiple
	$(n=0)^a$ for I/Q points	offsets
EPVTime - EDGE power versus time	RFENvelope (n=2) ^a	yes
(EDGE mode)	UMASk (n=3) ^a	
	LMASk $(n=4)^a$	
	$(n=0)^a$ for I/Q points	
ETSPur - EDGE transmit band spurs	SPECtrum (n=2) ^a	yes
(EDGE mode)	ULIMit (n=3) ^a	
	$(n=0)^a$ for I/Q points	
EVM - error vector magnitude	EVM (n=2) ^a	yes
(NADC, PDC modes)	MERRor $(n=3)^a$	
	PERRor $(n=4)^a$	
	$(n=0)^a$ for I/Q points	
EVMQpsk - QPSK error vector	EVM (n=2) ^a	yes
magnitude (cdma2000, 1xEV-DO, W-CDMA	MERRor $(n=3)^a$	
modes)	PERRor $(n=4)^a$	
	(n=0) ^a for I/Q raw data	

Measurement	Available Traces	Markers Available?
IM - intermodulation	SPECtrum (n=2) ^a	yes
(cdma2000, 1xEV-DO, W-CDMA modes)	$(n=0)^a$ for I/Q raw data	
MCPower - multi-carrier power	no traces	no markers
(W-CDMA mode)	$(n=0)^a$ for I/Q points	
OBW - occupied bandwidth	no traces	no markers
(cdmaOne, cdma2000, 1xEV-DO, PDC, W-CDMA modes)	(n=0) ^a for I/Q raw data	
ORFSpectrum - output RF spectrum	RFEMod (n=2)a	yes, only for
(GSM, EDGE mode)	RFESwitching $(n=3)^a$	a single offset
	SPEMod (n=4) ^a	1 0
	LIMMod (n=5) ^a	yes, only for multiple
	$(n=0)^a$ for I/Q points	offsets
PFERror - phase and frequency error	PERRor (n=2) ^a	yes
(GSM, EDGE mode)	PFERror (n=3) ^a	
	RFENvelope $(n=4)^a$	
	$(n=0)^a$ for I/Q points	
PSTatistic - power statistics CCDF	MEASured (n=2) ^a	yes
(Basic, cdma2000, 1xEV-DO, W-CDMA modes)	GAUSian $(n=3)^a$	
	REFerence $(n=4)^a$	
	$(n=0)^a$ for I/Q points	
PVTime - power versus time (GSM, EDGE, 1xEV-DO modes)	(n=0) ^a for I/Q raw data	yes
(RFENvelope $(n=2)^a$	
	UMASk $(n=3)^a$	
	LMASk $(n=4)^a$	

Measurement	Available Traces	Markers Available?
RHO - modulation quality (cdmaOne, cdma2000, W-CDMA mode)	$(n=0)^{a}$ for I/Q raw data	yes
	EVM (n=2) ^a	
	MERRor $(n=3)^a$	
	PERRor (n=4) ^a	
	(n=5) ^a for I/Q corrected trace data	
RHO - modulation quality (1xEV-DO mode)	(n=0) ^a for I/Q raw data	yes
	(n=1) ^a for various summary results	
	EVM (n=2) ^a	
	MERRor (n=3) ^a	
	PERRor (n=4) ^a	
	(n=5) ^a for I/Q corrected trace data	
SEMask - spectrum emissions mask	SPECtrum (n=2) ^a	yes
(cdma2000, 1xEV-DO, W-CDMA mode)	(n=0) ^a for I/Q raw data	
TSPur - transmit band spurs	SPECtrum (n=2) ^a	yes
(GSM, EDGE mode)	ULIMit (n=3) ^a	
	$(n=0)^a$ for I/Q points	
TXPower - transmit power	RFENvelope (n=2) ^a	yes
(GSM, EDGE mode)	IQ (n=8) ^a	
	(n=0) ^a for I/Q points	
SPECtrum - (frequency domain)	IQ (n=3) ^a	yes
(all modes)	SPECtrum (n=4) ^a	
	ASPectrum (n=7) ^a	
	$(n=0)^{a}$ for I/Q raw data	

Measurement	Available Traces	Markers Available?
WAVEform - (time domain) (all modes)	RFENvelope (n=2) ^a (also for Signal Envelope trace)	yes
	IQ (n=5) ^a	
	(n=0) ^a for I/Q raw data	

a. The *n* number indicates the sub-opcode that corresponds to this trace. Detailed descriptions of the trace data can be found in the MEASure subsystem documentation by looking up the sub-opcode for the appropriate measurement.

Waveform - Y-Axis Scale/Div

:DISPlay:WAVeform[n]:WINDow[m]:TRACe:Y[:SCALe]:PDIVision
<power>

:DISPlay:WAVeform[n]:WINDow[m]:TRACe:Y[:SCALe]:PDIVision?

Sets the scale per division for the y-axis.

n, selects the view, the default is RF envelope.

n=1, m=1 RF envelope

n=2, m=1 I/Q Waveform

n=4, m=1 I/Q Polar (Basic, W-CDMA, cdma2000)

m, selects the window within the view. The default is 1.

Factory Preset: 10 dBm, for RF envelope

Range: .1 dB to 20 dB, for RF envelope

Default Unit: dBm, for RF envelope

Remarks: May affect input attenuator setting.

You must be in Basic, cdmaOne, cdma2000, 1xEV-DO, W-CDMA GSM w/EDGE, NADC, or PDC mode. Set the

mode with INSTrument:SELect.

Front Panel

Access: When in Waveform measurement: Amplitude Y Scale,

Scale/Div.

History: Added revision A.02.00

Waveform - Y-Axis Reference Level

:DISPlay:WAVeform[n]:WINDow[m]:TRACe:Y[:SCALe]:RLEVel
<power>

:DISPlay:WAVeform[n]:WINDow[m]:TRACe:Y[:SCALe]:RLEVel?

Sets the amplitude reference level for the y-axis.

n, selects the view, the default is RF envelope.

n=1, m=1 RF envelope

n=2, m=1 I/Q Waveform

n=4, m=1 I/Q Polar (Basic, W-CDMA, cdma2000)

m, selects the window within the view. The default is 1.

Factory Preset: 0 dBm, for RF envelope

Range: - 250 to 250 dBm, for RF envelope

Default Unit: dBm, for RF envelope

Remarks: May affect input attenuator setting.

You must be in Basic, cdmaOne, cdma2000, 1xEV-DO, W-CDMA GSM w/EDGE, NADC, or PDC mode. Set the

mode with INSTrument:SELect.

Front Panel

Access: When in Waveform measurement: Amplitude Y Scale,

Ref Level

History: Added revision A.02.00

FETCh Subsystem

The FETCh? queries are used with several other commands to control the measurement process. These commands are described in the section on the "MEASure Group of Commands" on page 311. These commands apply only to measurements found in the MEASURE menu.

This command puts selected data from the most recent measurement into the output buffer (new data is initiated/measured). Use FETCh if you have already made a good measurement and you want to look at several types of data (different [n] values) from the single measurement. FETCh saves you the time of re-making the measurement. You can only fetch results from the measurement that is currently active.

If you need to make a new measurement, use the READ command, which is equivalent to an INITiate[:IMMediate] followed by a FETCh.

:FETCh <meas>? will return valid data only when the measurement is in one of the following states:

idle initiated paused

Fetch the Current Measurement Results

:FETCh:<measurement>[n]?

A FETCh? command must specify the desired measurement. It will return the valid results that are currently available, but will not initiate the taking of any new data. You can only fetch results from the measurement that is currently selected. The code number n selects the kind of results that will be returned. The available measurements and data results are described in the "MEASure Group of Commands" on page 311.

FORMat Subsystem

The FORMat subsystem sets a data format for transferring numeric and array information. The TRACe[:DATA] command is affected by FORMat subsystem commands.

Byte Order

:FORMat:BORDer NORMal | SWAPped

:FORMat:BORDer?

Selects the binary data byte order for numeric data transfer. In normal mode the most significant byte is sent first. In swapped mode the least significant byte is first. (PCs use the swapped order.) Binary data byte order functionality does not apply to ASCII.

Factory Preset: Normal

Numeric Data format

```
:FORMat[:DATA] ASCii REAL, 32 REAL, 64
```

:FORMat[:DATA]?

For PSA Spectrum Analysis mode only:

```
:FORMat[:TRACe][:DATA]
```

ASCii | INTeger, 16 | INTeger, 32 | REAL, 32 | REAL, 64 | UINTeger, 16

:FORMat[:TRACe][:DATA]?

This command controls the format of data output, that is, data transfer across any remote port. The REAL and ASCII formats will format trace data in the current amplitude units.

The format of state data cannot be changed. It is always in a machine readable format only.

ASCII - Amplitude values are in ASCII, in amplitude units, separated by commas. ASCII format requires more memory than the binary formats. Therefore, handling large amounts of this type of data, will take more time and storage space.

Integer,16 - Binary 16-bit integer values in internal units (dBm), in a definite length block. **PSA, SA mode only.

Integer,32 - Binary 32-bit integer values in internal units (dBm), in a definite length block.

FORMat Subsystem

Real,32 (or 64) - Binary 32-bit (or 64-bit) real values in amplitude unit, in a definite length block. Transfers of real data are done in a binary block format.

UINTeger,16 - Binary 16-bit unsigned integer that is uncorrected ADC values, in a definite length block. This format is almost never applicable with current data.

A definite length block of data starts with an ASCII header that begins with # and indicates how many additional data points are following in the block. Suppose the header is #512320.

- The first digit in the header (5) tells you how many additional digits/bytes there are in the header.
- The 12320 means 12 thousand, 3 hundred, 20 data bytes follow the header.
- Divide this number of bytes by your selected data format bytes/point, either 8 (for real 64), or 4 (for real 32). In this example, if you are using real 64 then there are 1540 points in the block.

Example: FORM REAL,64

Factory Preset: Real,32 for Spectrum Analysis mode

ASCII for Basic, cdmaOne, cdma2000, W-CDMA, GSM

with EDGE, NADC, PDC modes

Remarks: The acceptable settings for this command changes for

different modes.

INITiate Subsystem

The INITiate subsystem is used to initiate a trigger for a measurement. They only initiate measurements from the MEASURE front panel key or the "MEASure Group of Commands" on page 311. Refer to the TRIGger and ABORt subsystems for related commands.

Take New Data Acquisition for Selected Measurement

:INITiate:<measurement name>

This command initiates a trigger cycle for the measurement specified. The available measurement names are described in the MEASure subsystem. It also holds off additional commands on GPIB until the acquisition is complete. So if it is followed by a FETCh command, valid data will be returned.

If your selected measurement is currently active (in the idle state) it triggers the measurement, assuming the trigger conditions are met. Then it completes one trigger cycle. Depending upon the measurement and the number of averages, there may be multiple data acquisitions, with multiple trigger events, for one full trigger cycle.

If your selected measurement is not currently active it will change to the measurement in your INIT:<meas_name> command and initiate a trigger cycle.

Example: INIT:ACP

Continuous or Single Measurements

:INITiate:CONTinuous OFF | ON | 0 | 1

:INITiate:CONTinuous?

Selects whether a trigger is continuously initiated or not. Each trigger initiates a single, complete, measurement operation.

When set to ON another trigger cycle is initiated at the completion of each measurement.

When set to OFF, the trigger system remains in the "idle" state until an INITiate[:IMMediate] command is received. On receiving the INITiate[:IMMediate] command, it will go through a single trigger/measurement cycle, and then return to the "idle" state.

Example: INIT:CONT ON

Factory Preset: On

*RST: Off (recommended for remote operation)

Front Panel

Access: Meas Control, Measure Cont Single

Take New Data Acquisitions

:INITiate[:IMMediate]

The instrument must be in the single measurement mode. If INIT:CONT is ON, then the command is ignored. The desired measurement must be selected and waiting. The command causes the system to exit the "waiting" state and go to the "initiated" state.

The trigger system is initiated and completes one full trigger cycle. It returns to the "waiting" state on completion of the trigger cycle. Depending upon the measurement and the number of averages, there may be multiple data acquisitions, with multiple trigger events, for one full trigger cycle.

This command triggers the instrument, if external triggering is the type of trigger event selected. Otherwise, the command is ignored. Use the TRIGer[:SEQuence]:SOURce EXT command to select the external trigger.

Example: INIT:IMM

Remarks: See also the *TRG command and the TRIGger

subsystem.

Front Panel

Access: Meas Control, Measure Cont Single

Restart the Measurement

:INITiate:RESTart

This command applies to measurements found in the MEASURE menu. It restarts the current measurement from the "idle" state regardless of its current operating state. It is equivalent to:

INITiate[:IMMediate]

ABORt (for continuous measurement mode)

Example: INIT:REST

Front Panel

Access: Restart

or

Meas Control, Restart

INSTrument Subsystem

This subsystem includes commands for querying and selecting instrument measurement (personality option) modes.

Catalog Query

:INSTrument:CATalog?

For E4406A, :INSTrument:CATalog[:FULL]?

Returns a comma separated list of strings which contains the names of all the installed applications. These names can only be used with the **INST:SELECT** command.

For E4406A if the optional keyword **FULL** is specified, each name is immediately followed by its associated instrument number. These instrument numbers can only be used with the **INST:NSELect** command.

Example:

(PSA and ESA) INST:CAT?

Query response: "CDMA"4,"PNOISE"14

Example:

(E4406A) INST:CAT:FULL?

Query response:

"BASIC"8,"GSM"3,"CDMA"4,"SERVICE"1

Select Application by Number

:INSTrument:NSELect <integer>

:INSTrument:NSELect?

Select the measurement mode by its instrument number. The actual available choices depends upon which applications are installed in the instrument. For E4406A these instrument numbers can be obtained with INST:CATalog:FULL?

1 = SA (PSA)

1 = SERVICE (E4406)

3 = GSM (E4406)

4 = CDMA (cdmaOne) (E4406/PSA)

5 = NADC (E4406/PSA)

6 = PDC (E4406/PSA)

8 = BASIC (E4406/PSA)

9 = WCDMA (W-CDMA with HSDPA/HSUPA) (E4406/PSA)

10 = CDMA2K (cdma2000 with 1xEV-DV) (E4406/PSA)

11 = IDEN (E4406)

12 = WIDEN (E4406)

13 = EDGEGSM (E4406/PSA)

14 = PNOISE (phase noise) (PSA)

15 = CMDA1XEV (1xEV-D0) (E4406/PSA)

18 = WLAN (PSA)

211 = TDSCDMA (PSA)

212 = TDDEMOD (PSA)

219 = NFIGURE (noise figure) (PSA)

231 = LINK (89600 VSA Link software)

233 = MRECEIVE (PSA)

239 = EMC (EMC Analyzer) (PSA)

241 = DMODULATION (PSA)

NOTE

If you are using the SCPI status registers and the analyzer mode is changed, the status bits should be read, and any errors resolved, prior to switching modes. Error conditions that exist prior to switching modes cannot be detected using the condition registers after the mode change. This is true unless they recur after the mode change, although transitions of these conditions can be detected using the event registers.

Changing modes resets all SCPI status registers and mask registers to their power-on defaults. Hence, any event or condition register masks must be re-established after a mode change. Also note that the power up status bit is set by any mode change, since that is the default state after power up.

Example: INST:NSEL 4

Factory Preset: Persistent state with factory default of 1 (PSA)

Persistent state with factory default of 8

(E4406A, BASIC)

Range: 1 to x, where x depends upon which applications are

installed.

Front Panel

Access: MODE

Select Application

VSA E4406A:

:INSTrument[:SELect] BASIC|SERVICE|CDMA|CDMA2K|GSM |EDGEGSM|IDEN|WIDEN|NADC|PDC|WCDMA|CDMA1XEV

PSA Series:

```
:INSTrument[:SELect] SA | PNOISE | BASIC | CDMA | CDMA2K | EDGEGSM | NADC | PDC | WCDMA | CDMA1XEV | NFIGURE | WLAN | MRECEIVE | TDSCDMA | TDDEMOD | EMC | DEMODULATION
```

:INSTrument[:SELect]?

Select the measurement mode. The actual available choices depend upon which modes (measurement applications) are installed in the instrument. A list of the valid choices is returned with the INST:CAT? query.

Once an instrument mode is selected, only the commands that are valid for that mode can be executed.

```
1 = SA (PSA)
```

1 = SERVICE (E4406)

3 = GSM (E4406)

4 = CDMA (cdmaOne) (E4406/PSA)

5 = NADC (E4406/PSA)

6 = PDC (E4406/PSA)

8 = BASIC (E4406/PSA)

9 = WCDMA (W-CDMA with HSDPA/HSUPA) (E4406/PSA)

10 = CDMA2K (cdma2000 with 1xEV-DV) (E4406/PSA)

11 = IDEN (E4406)

12 = WIDEN (E4406)

13 = EDGEGSM (E4406/PSA)

14 = PNOISE (phase noise) (PSA)

15 = CMDA1XEV (1xEV-D0) (E4406/PSA)

18 = WLAN (PSA)

211 = TDSCDMA (PSA)

212 = TDDEMOD (PSA)

219 = NFIGURE (noise figure) (PSA)

231 = LINK (89600 VSA Link software)

233 = MRECEIVE (PSA)

239 = EMC (EMC Analyzer) (PSA)

241 = DMODULATION (PSA)

NOTE

If you are using the status bits and the analyzer mode is changed, the status bits should be read, and any errors resolved, prior to switching modes. Error conditions that exist prior to switching modes cannot be detected using the condition registers after the mode change. This is true unless they recur after the mode change, although transitions of these conditions can be detected using the event registers.

Changing modes resets all SCPI status registers and mask registers to their power-on defaults. Hence, any event or condition register masks must be re-established after a mode change. Also note that the power up status bit is set by any mode change, since that is the default state after power up.

Example: PSA Series instruments: INST:SEL CDMA

Factory Preset:

(PSA) Persistent state with factory default of Spectrum

Analyzer mode

Factory Preset:

(E4406A) Persistent state with factory default of Basic mode.

Front Panel

Access: MODE


MEASure Group of Commands

This group includes the CONFigure, FETCh, MEASure, and READ commands that are used to make measurements and return results. The different commands can be used to provide fine control of the overall measurement process, like changing measurement parameters from their default settings. Most measurements should be done in single measurement mode, rather than measuring continuously.

The SCPI default for the format of any data output is ASCII. The format can be changed to binary with FORMat:DATA which transports faster over the bus.

Command Interactions: MEASure, CONFigure, FETCh, INITiate and READ

Figure 4-4 Measurement Group of Commands



Measure Commands:

:MEASure:<measurement>[n]?

This is a fast single-command way to make a measurement using the factory default instrument settings. These are the settings and units that conform to the Mode Setup settings (e.g. radio standard) that you have currently selected.

- Stops the current measurement (if any) and sets up the instrument for the specified measurement using the factory defaults
- Initiates the data acquisition for the measurement
- Blocks other SCPI communication, waiting until the measurement is complete before returning results.
- After the data is valid it returns the scalar results, or the trace data, for the specified measurement. The type of data returned may be defined by an [n] value that is sent with the command.

The scalar measurement results will be returned if the optional [n] value is not included, or is set to 1. If the [n] value is set to a value other than 1, the selected trace data results will be returned. See each command for details of what types of scalar results or trace data results are available.

ASCII is the default format for the data output. (Older versions of Spectrum Analysis and Phase Noise mode measurements only use ASCII.) The binary data formats should be used for handling large blocks of data since they are smaller and faster than the ASCII format. Refer to the FORMat:DATA command for more information.

If you need to change some of the measurement parameters from the factory default settings you can set up the measurement with the CONFigure command. Use the commands in the SENSe:<measurement> and CALCulate:<measurement> subsystems to change the settings. Then you can use the READ? command to initiate the measurement and query the results. See Figure 4-4.

If you need to repeatedly make a given measurement with settings other than the factory defaults, you can use the commands in the SENSe:<measurement> and CALCulate:<measurement> subsystems to set up the measurement. Then use the READ? command to initiate the measurement and query results.

Measurement settings persist if you initiate a different measurement and then return to a previous one. Use READ:<measurement>? if you want to use those persistent settings. If you want to go back to the default settings, use MEASure:<measurement>?.

Configure Commands:

:CONFigure:<measurement>

This command stops the current measurement (if any) and sets up the instrument for the specified measurement using the factory default instrument settings. It sets the instrument to single measurement mode but should not initiate the taking of measurement data unless INIT:CONTinuous is ON. After you change any measurement settings, the READ command can be used to initiate a measurement without changing the settings back to their defaults.

NOTE	In instruments with firmware older then A.05.00 CONFigure initiates the
	taking of data. The data should be ignored. Other SCPI commands can be
	processed immediately after sending CONFigure. You do not need to wait
	for the CONF command to complete this 'false' data acquisition.

The CONFigure? query returns the current measurement name.

Fetch Commands:

:FETCh:<measurement>[n]?

This command puts selected data from the most recent measurement into the output buffer. Use FETCh if you have already made a good measurement and you want to return several types of data (different [n] values, e.g. both scalars and trace data) from a single measurement. FETCh saves you the time of re-making the measurement. You can only FETCh results from the measurement that is currently active, it will not change to a different measurement.

If you need to get new measurement data, use the READ command, which is equivalent to an INITiate followed by a FETCh.

The scalar measurement results will be returned if the optional [n] value is not included, or is set to 1. If the [n] value is set to a value other than 1, the selected trace data results will be returned. See each command for details of what types of scalar results or trace data results are available. The binary data formats should be used for handling large blocks of data since they are smaller and transfer faster then the ASCII format. (FORMat:DATA)

FETCh may be used to return results other than those specified with the original READ or MEASure command that you sent.

INITiate Commands:

:INITiate:<measurement>

This command is not available for measurements in all the instrument modes:

- Initiates a trigger cycle for the specified measurement, but does not output any data. You must then use the FETCh<meas> command to return data. If a measurement other than the current one is specified, the instrument will switch to that measurement and then initiate it.
 - For example, suppose you have previously initiated the ACP measurement, but now you are running the channel power measurement. If you send INIT:ACP? it will change from channel power to ACP and will initiate an ACP measurement.
- Does not change any of the measurement settings. For example, if you have previously started the ACP measurement and you send INIT:ACP? it will initiate a new ACP measurement using the same instrument settings as the last time ACP was run.
- If your selected measurement is currently active (in the idle state) it triggers the measurement, assuming the trigger conditions are met. Then it completes one trigger cycle. Depending upon the measurement and the number of averages, there may be multiple data acquisitions, with multiple trigger events, for one full trigger cycle. It also holds off additional commands on GPIB until the acquisition is complete.

READ Commands:

:READ:<measurement>[n]?

- Does not preset the measurement to the factory default settings. For example, if you have previously initiated the ACP measurement and you send READ:ACP? it will initiate a new measurement using the same instrument settings.
- Initiates the measurement and puts valid data into the output buffer. If a measurement other than the current one is specified, the instrument will switch to that measurement before it initiates the measurement and returns results.
 - For example, suppose you have previously initiated the ACP measurement, but now you are running the channel power measurement. Then you send READ:ACP? It will change from channel power back to ACP and, using the previous ACP settings, will initiate the measurement and return results.
- Blocks other SCPI communication, waiting until the measurement is complete before returning the results
 - If the optional [n] value is not included, or is set to 1, the scalar measurement results will be returned. If the [n] value is set to a value other than 1, the selected trace data results will be returned. See each command for details of what types of scalar results or trace data results are available. The binary data formats should be used when handling large blocks of data since they are smaller and faster then the ASCII format. (FORMat:DATA)

Adjacent Channel Power Ratio (ACP) Measurement

For E4406A this measures the total rms power in the specified channel and in 5 offset channels. You must be in Basic, cdmaOne, cdma2000, W-CDMA, iDEN, NADC or PDC mode to use these commands. Use INSTrument:SELect to set the mode.

For PSA this measures the total rms power in the specified channel and in 5 offset channels. You must be in cdmaOne, cdma2000, W-CDMA, NADC or PDC mode to use these commands. Use INSTrument:SELect to set the mode.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:ACP commands for more measurement related commands.

:CONFigure:ACP

:INITiate:ACP

:FETCh:ACP[n]?

:READ:ACP[n]?

:MEASure:ACP[n]?

For Basic mode, a channel frequency and power level can be defined in the command statement to override the default standard setting. A comma must precede the power value as a place holder for the frequency, when no frequency is sent.

History: E4406A:

Added to Basic mode, version A.03.00 or later

Front Panel

Access: Measure, ACP or ACPR

After the measurement is selected, press Restore Meas

Defaults to restore factory defaults.

Measurement Results Available

Measurement Type	n	Results Returned
	0	Returns unprocessed I/Q trace data, as a series of trace point values, in volts. The I values are listed first in each pair, using the 0 through even-indexed values. The Q values are the odd-indexed values.

Measurement Type	n	Results Returned
	n=1 (or not specified) NADC and PDC mode	Returns 22 scalar results, in the following order: 1. Center frequency – absolute power (dBm) 2. Center frequency – absolute power (W) 3. Negative offset frequency (1) – relative power (dB) 4. Negative offset frequency (1) – absolute power (dBm) 5. Positive offset frequency (1) – relative power (dB) 6. Positive offset frequency (1) – absolute power (dBm) 1. Positive offset frequency (5) – relative power (dB)
	n=1 (or not specified) iDEN mode E4406A	2. Positive offset frequency (5) – absolute power (dBm) Returns scalar results, in the following order: 1. Center frequency – relative power (dB) 2. Center frequency – absolute power (dBm) 3. Lower offset frequency – relative power (dB) 4. Lower offset frequency – relative power (dBm) 5. Upper offset frequency – relative power (dB) 6. Upper offset frequency – absolute power (dBm) 7. Total power (dBm) 8. Offset frequency (Hz) 9. Reference BW (Hz) 10. Offset BW (Hz) 11. Carrier/center frequency (Hz) 12. Frequency span (Hz) 13. Average count
Total power reference	n=1 (or not specified) Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 24 scalar results, in the following order: 1. Center frequency - relative power (dB) 2. Center frequency - absolute power (dBm) 3. Center frequency - relative power (dB) (same as value 1) 4. Center frequency - absolute power (dBm) (same as value 2) 5. Negative offset frequency (1) - relative power (dBn) 6. Negative offset frequency (1) - absolute power (dBm) 7. Positive offset frequency (1) - relative power (dB) 8. Positive offset frequency (1) - absolute power (dBm) 1. Positive offset frequency (5) - relative power (dBm) NOTE Center frequency relative power is relative to the center frequency absolute power and therefore, is always equal to 0.00 dB.

Measurement Type	n	Results Returned
Power spectral density reference	n=1 (or not specified) Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 24 scalar results, in the following order: 1. Center frequency - relative power (dB) 2. Center frequency - absolute power (dBm/Hz) 3. Center frequency - relative power (dB) (same as value 1) 4. Center frequency - absolute power (dBm/Hz) (same as value 2) 5. Negative offset frequency (1) - relative power (dB) 6. Negative offset frequency (1) - absolute power (dBm/Hz) 7. Positive offset frequency (1) - relative power (dB) 8. Positive offset frequency (1) - absolute power (dBm/Hz) 1. Positive offset frequency (5) - relative power (dB) 2. Positive offset frequency (5) - absolute power (dBm/Hz) NOTE Center frequency relative power is relative to the center frequency absolute power and therefore, is always equal to 0.00 dB.
	2 NADC and PDC mode	Returns 10 scalar values of the pass/fail (0=passed, or 1=failed) results determined by testing the absolute power of the offset frequencies: 1. Negative offset frequency (1) absolute power 2. Positive offset frequency (1) absolute power 3. Negative offset frequency (5) absolute power 4. Positive offset frequency (5) absolute power 5. Positive offset frequency (5) absolute power
	2 iDEN mode	Returns scalar values of the histogram absolute power trace: 1. Lower offset frequency – absolute power 2. Reference frequency – absolute power 3. Upper offset frequency – absolute power

Measurement Type	n	Results Returned
Total power reference	Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 11 scalar values (in dBm) corresponding to the total power histogram display. The values are returned in ascending frequency order: 1. Negative offset frequency (5) 2. Negative offset frequency (4) 3. Negative offset frequency (3)
		 Center frequency Positive offset frequency (1) Positive offset frequency (2) Positive offset frequency (5)
	3 NADC and PDC mode	Returns 10 scalar values of the pass/fail (0=passed, or 1=failed) results determined by testing the relative power of the offset frequencies: 1. Negative offset frequency (1) relative power 2. Positive offset frequency (1) relative power 3
		 Negative offset frequency (5) relative power Positive offset frequency (5) relative power
	iDEN mode E4406A	Returns scalar values of the histogram relative power trace: 1. Lower offset frequency – relative power 2. Reference frequency – relative power 3. Upper offset frequency – relative power
Power spectral density reference	Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 11 scalar values (in dBm/Hz) corresponding to the power spectral density histogram display. The values are returned in ascending frequency order: 1. Negative offset frequency (5) 2. Negative offset frequency (4) 1. Center frequency 2. Positive offset frequency (1) 1. Positive offset frequency (5)

Measurement Type	n	Results Returned
	4 NADC and	Returns the frequency-domain spectrum trace (data array) for the entire frequency range being measured.
	PDC mode	In order to return spectrum data, the ACP display must be in the spectrum view and you must not turn off the spectrum trace.
	4 iDEN	Returns 4 absolute power values for the reference and offset channels.
	mode E4406A	 Reference channel – absolute power Reference channel – absolute power (duplicate of above) Lower offset channel – absolute power Upper offset channel – absolute power
(For cdma2000 and W-CDMA	4 Basic,	Returns the frequency-domain spectrum trace data for the entire frequency range being measured.
the data is only available with spectrum display selected)	cdmaOne, cdma2000, W-CDMA mode	With the spectrum view selected (DISPlay:ACP:VIEW SPECtrum) and the spectrum trace on (SENSe:ACP:SPECtrum:ENABle):
n display selected)		• In FFT mode (SENSe:ACP:SWEep:TYPE FFT) the number of trace points returned are 343 (cdma2000) or 1715 (W-CDMA). This is with the default span of 5 MHz (cdma2000) or 25 MHz (W-CDMA). The number of points also varies if another offset frequency is set.
		• In sweep mode (SENSe:ACP:SWEep:TYPE SWEep), the number of trace points returned is 601 (for cdma2000 or W-CDMA) for any span.
		With bar graph display selected, one point of –999.0 will be returned.
5 iDEN mode E4406A	Returns 4 relative power values for the reference and offset channels:	
		 Reference channel – relative power Reference channel – relative power (duplicate of above) Lower offset channel – relative power Upper offset channel – relative power
reference	5 Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 12 scalar values (in dBm) of the absolute power of the center and the offset frequencies:
		 Upper adjacent chan center frequency Lower adjacent chan center frequency Negative offset frequency (1) Positive offset frequency (1)
		 Negative offset frequency (5) Positive offset frequency (5)

Measurement Type	n	Results Returned
Power spectral density reference	5 Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 12 scalar values (in dBm/Hz) of the absolute power of the center and the offset frequencies: 1. Upper adjacent chan center frequency 2. Lower adjacent chan center frequency 3. Negative offset frequency (1) 4. Positive offset frequency (1) 1. Negative offset frequency (5) 2. Positive offset frequency (5)
	6 iDEN mode E4406A	Returns 4 pass/fail test results for the absolute power of the reference and offset channels: 1. Reference channel absolute power pass/fail 2. Reference channel absolute power pass/fail (duplicate of above) 3. Lower offset channel absolute power pass/fail 4. Upper offset channel absolute power pass/fail
Total power reference	Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 12 scalar values (total power in dB) of the power relative to the carrier at the center and the offset frequencies: 1. Upper adjacent chan center frequency 2. Lower adjacent chan center frequency 3. Negative offset frequency (1) 4. Positive offset frequency (5) 5. Negative offset frequency (5) 1. Negative offset frequency (5) 2. Positive offset frequency (5)
Power spectral density reference	Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 12 scalar values (power spectral density in dB) of the power relative to the carrier at the center and offset frequencies: 1. Upper adjacent chan center frequency 2. Lower adjacent chan center frequency 3. Negative offset frequency (1) 4. Positive offset frequency (1) 1. Negative offset frequency (5) 2. Positive offset frequency (5)

Measurement Type	n	Results Returned
	7 iDEN mode E4406A	Returns 4 pass/fail test results for the relative power of the reference and offset channels: 1. Reference channel relative power pass/fail 2. Reference channel relative power pass/fail (duplicate of above) 3. Lower offset channel relative power pass/fail 4. Upper offset channel relative power pass/fail
Total power reference	7 Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 12 scalar values of the pass/fail (0=passed, or 1=failed) results determined by testing the absolute power limit of the center and offset frequencies (measured as total power in dB): 1. Upper adjacent chan center frequency 2. Lower adjacent chan center frequency 3. Negative offset frequency (1) 4. Positive offset frequency (1) 1. Negative offset frequency (5) 2. Positive offset frequency (5)
Power spectral density reference	7 Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 12 scalar values of the pass/fail (0=passed, or 1=failed) results determined by testing the absolute power limit of the center and offset frequencies (measured as power spectral density in dB): 1. Upper adjacent chan center frequency 2. Lower adjacent chan center frequency 3. Negative offset frequency (1) 4. Positive offset frequency (1) 1. Negative offset frequency (5) 2. Positive offset frequency (5)
Total power reference	8 Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 12 scalar values of the pass/fail (0=passed, or 1=failed) results determined by testing the power limit relative to the center frequency (measured as total power spectral in dB): 1. Upper adjacent chan center frequency 2. Lower adjacent chan center frequency 3. Negative offset frequency (1) 4. Positive offset frequency (1) 1. Negative offset frequency (5) 2. Positive offset frequency (5)

Measurement Type	n	Results Returned
Power spectral density reference	8 Basic, cdmaOne, cdma2000, W-CDMA mode	Returns 12 scalar values of the pass/fail (0=passed, or 1=failed) results determined by testing the power limit relative to the center frequency (measured as power spectral density in dB): 1. Upper adjacent chan center frequency 2. Lower adjacent chan center frequency 3. Negative offset frequency (1) 4. Positive offset frequency (1) 1. Negative offset frequency (5) 2. Positive offset frequency (5)

Code Domain Power Measurement

This measures the power levels of the spread channels in RF channel(s). You must be in the cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use these commands. Use INSTrument:SELect to set the mode.

For 1xEV-DO, this measurement is used only for base stations (Network Access). When measuring 1xEV-DO mobile stations (Access Terminals) use Terminal Code Domain Measurements (MEAS:TCDPower) and set SENSe:RADio:DEVice to MS.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:CDPower commands for more measurement related commands.

:CONFigure:CDPower

:INITiate:CDPower

:FETCh:CDPower[n]?

:READ:CDPower[n]?

:MEASure:CDPower[n]?

Front Panel

Access: Measure, Code Domain

After the measurement is selected, press **Restore Meas Defaults** to restore factory defaults.

Measurement Results Available

n	Results Returned	
0	Returns unprocessed I/Q trace data, as a series of trace point values, in volts. The I values are listed first in each pair, using the 0 through even-indexed values. The Q values are the odd-indexed values.	

n	Results Returned		
n=1 (or not	Returns the following scalar results:		
specified) cdmaOne mode	1. Time offset is a floating point number with units of seconds. This is the time delay of the even second clock with respect to the start of the short code PN sequences, at offsets from the 15 zeros in the characteristic phase of the sequences.		
	2. Frequency error is a floating point number (in Hz) of the frequency error in the measured signal. This error is based on the linear best fit of the uncorrected measured phase.		
	3. Carrier feedthrough is a floating point number (in dB) of the dc offset, of I and Q, from the origin.		
	4. Pilot power is a floating point number with units of dB. It is the relative power of the pilot channel (Walsh code 0) with respect to the carrier power.		
	5. Paging power is a floating point number with units of dB. It is the relative power of the paging channel (Walsh code 1) with respect to the carrier power.		
	6. Sync power is a floating point number with units of dB. It is the relative power of the sync channel (Walsh code 32) with respect to the carrier power.		
	7. Average traffic power is a floating point number with units of dB. It is the average relative power of the active traffic channels with respect to the carrier power. Traffic channels are defined as all of the Walsh codes except Walsh 0,1,32. A traffic channel is active if its coding power is greater than the active threshold parameter which you have selected.		
	8. Maximum inactive traffic power is a floating point number with units of dB. It is the maximum relative power of an inactive traffic channel with respect to the carrier power. Traffic channels are defined as all of the Walsh codes except Walsh 0,1,32. A traffic channel is inactive if its coding power is less than the active threshold parameter which you have selected.		
•	9. Average inactive traffic power is a floating point number with units of dB. It is the average relative power of the inactive traffic channels with respect to the carrier power. Traffic channels are defined as all of the Walsh codes except Walsh 0,1,32. A traffic channel is inactive if its coding power is less than the active threshold parameter which you have selected.		
	10. Marker Values The last 16 measurement results are the current values for all four available markers. The values are zero for any marker that is not active.		
	10. Marker 1 position (code number) 11, Marker 1 power level 12. Marker 1 time value 13. Marker 1 phase value		
	25. Marker 4 phase value		

n	Results Returned
n=1 (or not specified) cdma2000 mode	Returns the following scalar results:
	1. RMS symbol EVM is a floating point number (in percent) of the EVM over the entire measurement area.
	2. Peak symbol EVM is a floating point number (in percent) of the peak EVM in the measurement area.
	3. Symbol magnitude error is a floating point number (in percent) of the average magnitude error over the entire measurement area.
	4. Symbol phase error is a floating point number (in degrees) of the average phase error over the entire measurement area.
	5. Total power is a floating point number (in dBm) of the total RF power over the measurement interval.
	6. Channel power is a floating point number (in dBc or dBm depending on the measurement type, see below) of the power in the entire slot, for the selected code, averaged over the measurement interval.
	NOTE: When measurement type = rel, then the value displayed is in units of dBc, and the relative power is calculated as the ratio of the Channel Power to the Total Power (parameter 5 above).
	7. Total active power is a floating point number (in dB or dBm depending on the measurement type) of the sum of the active power.
	8. Pilot power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the Pilot code.
	9. Sync power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the Sync code. In the MS mode, the value returned is – 999.
	10. Maximum active traffic power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the active code. If no active code is detected the value returned is – 999. In the MS mode, the value returned is – 999.
	11. Average active traffic power is a floating point number (in dB or dBm depending on the measurement type) of the average power of all the active traffic channels. If no active code is detected the value returned is – 999. In the MS mode, the value returned is – 999.
	12. Maximum inactive traffic power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive traffic channels. In the MS mode, the value returned is – 999.
	13. Average inactive traffic power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the inactive traffic channels. In the MS mode, the value returned is – 999.
	14. Number of active channel In the MS mode, the value returned is – 999.

n	Results Returned
n=1 (or not specified) cdma2000 mode (continued)	15. I channel average active power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the active I channels. In the BS mode, the value returned is – 999.
	16. I channel maximum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive I channels. In the BS mode, the value returned is – 999.
	17. Q channel average active power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the active Q channels. In the BS mode, the value returned is – 999.
	18. Q channel maximum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive Q channels. In the BS mode, the value returned is – 999.
	19. Time between trigger to PN Offset is a floating point number (in μs) of the time from the trigger point to the PN Offset. In the MS mode, the value returned is – 999.
	20. Mod Scheme is available when 1xEV-DV demod enable is set to ON. It is an integer number that indicates the modulation type used in the specified channel and measurement time period. In the MS mode, the value returned is – 999. In BTS the returned values represent:
	0, is QPSK +1, is 8PSK +2, is 16QAM – 999, is returned if:
	 1xEV-DV license is not installed 1xEV-DV demod enable is set Off Walsh code length is not 32 not measuring forward link (Radio Device is MS)

n	Results Returned
n=1 (or not specified) W-CDMA mode	Returns the following scalar results:
	1. RMS symbol EVM is a floating point number (in percent) of the EVM over the entire measurement area.
	2. Peak symbol EVM is a floating point number (in percent) of the peak EVM in the measurement area.
	3. Symbol magnitude error is a floating point number (in percent) of the average magnitude error over the entire measurement area.
	4. Symbol phase error is a floating point number (in degrees) of the average phase error over the entire measurement area.
	5. Total power is a floating point number (in dBm) of the total RF power over the measurement interval.
	6. Channel power is a floating point number (in dBc or dBm depending on the measurement type, see below) of the power in the entire slot, for the selected code, averaged over the measurement interval.
	NOTE: When measurement type = rel, then the value displayed is in units of dBc, and the relative power is calculated as the ratio of the Channel Power to the Total Power (parameter 5 above).
	7. tDPCH is an integer number (in 256 chips) of dedicated physical channel (DPCH) delay time from the reference. (tDPCH equals $T_{\rm n}$)
	NOTE: Downlink HS-PDSCH has a fixed tHS-PDSCH (= $2\times T_{slot}$ = 5120 chips). The offset is aligned with the slot boundary. The measurement cannot detect the offset and it returns -999.
	NOTE: Downlink HS-SCCH does not have time offset (by definition), so the measurement returns – 999.
	NOTE: For all uplink cahnnels, the measurement does not detect the offset and returns – 999.
	8. Total power over a slot is a floating point number (in dBm) of total RF power over the measurement interval. (SCH is excluded.)
	9. Total active power is a floating point number (in dB or dBm depending on the measurement type) of the sum of the active power. (SCH is excluded.)
	10. Pilot power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the CPICH code relative to the total slot power. In the MS mode, the value returned is – 999. (SCH is excluded.)
	11. Maximum active traffic power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the active traffic channels. If no active code is detected the value returned is – 999. In the MS mode, the value returned is – 999. (SCH is excluded.)

n	Results Returned
n=1 (or not specified) W-CDMA mode (continued)	12. Average active traffic power is a floating point number (in dB or dBm depending on the measurement type) of the average power of all the active traffic channels. If no active code is detected the value returned is – 999. In the MS mode, the value returned is – 999. (SCH is excluded.)
	13. Maximum inactive traffic power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive traffic channels. The slot timing is determined by Perch. In the MS mode, the value returned is – 999. (SCH is excluded.)
	14. Average inactive traffic power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the inactive traffic channels. In the MS mode, the value returned is – 999. (SCH is excluded.)
	15. Number of active channel In the MS mode, the value returned is – 999.
	16. P-SCH is a floating point number (in dBm) of the primary synchronization channel power. In the MS mode, the value returned is – 999.
	17. S-SCH is a floating point number (in dBm) of the secondary synchronization channel power. In the MS mode, the value returned is – 999.
	18. DPCCH Power is a floating point number (in dB or dBm depending on the measurement type) of the average power of dedicated physical control channel (DPCCH). In the BS mode, the value returned is – 999. When PRACH is measured, this returns control part power.
	19. DPCCH Beta Nominal is a floating point number of the nominal beta value of DPCCH Beta factor. In the BS mode, the value returned is – 999. When PRACH is measured, this returns control part Beta nominal.
	20. DPCCH Beta Measured is a floating point number of the measured value of the DPCCH Beta factor. In the BS mode, the value returned is – 999. When PRACH is measured, this returns control part Beta measured.
	21. DPDCH Beta Nominal is a floating point number of the nominal beta value of the dedicated physical data channel (DPDCH) Beta factor. In the BS mode, the value returned is – 999. When PRACH is measured, this returns data part Beta nominal.
	22. DPDCH Beta 1 Measured is a floating point number of the measured value of the DPDCH (C1) Beta factor. In the BS mode, the value returned is –999. When PRACH is measured, this returns data part Beta measured.
	23. DPDCH Beta 2 Measured is a floating point number of the measured value of the DPDCH (C2) Beta factor. In the BS mode, the value returned is – 999. When PRACH is measured, this returns – 999.

n	Results Returned
n=1 (or not specified) W-CDMA mode (continued)	24. DPDCH Beta 3 Measured is a floating point number of the measured value of the DPDCH (C3) Beta factor. In the BS mode, the value returned is – 999. When PRACH is measured, this returns – 999.
	25. DPDCH Beta 4 Measured is a floating point number of the measured value of the DPDCH (C4) Beta factor. In the BS mode, the value returned is – 999. When PRACH is measured, this returns – 999.
	26. DPDCH Beta 5 Measured is a floating point number of the measured value of the DPDCH (C5) Beta factor. In the BS mode, the value returned is – 999. When PRACH is measured, this returns – 999.
	27. DPDCH Beta 6 Measured is a floating point number of the measured value of the DPDCH (C6) Beta factor. In the BS mode, the value returned is – 999. When PRACH is measured, this returns – 999.
	28. I channel average active power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the active I channels. In the BS mode, the value returned is – 999.
	29. I channel maximum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive I channels. In the BS mode, the value returned is – 999.
	30. Q channel average active power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the active Q channels. In the BS mode, the value returned is – 999.
	31. Q channel maximum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive Q channels. In the BS mode, the value returned is – 999.
	32. Nominal ratio between HS-DPCCH and DPCCH is a floating point number. It's an amplitude ratio of the nominal value based on the measured value of the uplink HS-DPCCH beta factor and the uplink DPCCH beta factor. In the base station mode, the value returned is – 999.0. When PRACH is measured this returns – 999.0.
	33. HS-DPCCH beta measured is a floating point number that is the measured value of the HS-DPCCH beta factor. In the BS mode, the value returned is – 999.0. When PRACH is measured this returns – 999.0.
	34. Modulation scheme is an integer number representing the modulation scheme for the specified channel and measurement time period.
	0, is QPSK 2, is 16QAM -999 is returned an any of the following cases:
	 — HSDPA Option 210 license key is not installed — HSPDA Enable setting is OFF — Radio Device setting is MS

n	Results Returned
n=1 (or not specified) 1xEV-DO mode	Returns the following comma-delimited scalar results, in the following order:
	1. Total power is a floating point number (in dBm) of the total RF power over the measurement interval.
	NOTE: The following power results are computed by the CDP measurement. The unit used in the computation, either dB or dBm, is determined by the setting of the CALCulate:CDPower:TYPE command. When the selection is ABSolute, the unit used is dBm. When the selection is RELative, the unit used is dB relative to Total Power (above).
	2. Total active power is a floating point number (in dB or dBm depending on the measurement type) of the sum of the active powers (– 999.0 when no active channel is detected).
	3. Maximum active power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the active code (– 999.0 when no active channel is detected in I/Q Combined=On mode. Always – 999.0 in I/Q Combined=Off mode)
	4. Average active power is a floating point number (in dB or dBm depending on the measurement type) of the average power of all the active traffic channels (– 999.0 when no active channel is detected in I/Q Combined=On mode. Always – 999.0 in I/Q Combined=Off mode).
	5. Maximum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive traffic channels. (– 999.0 in I/Q Combined=Off mode)
	6. Average inactive power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the inactive traffic channels. (– 999.0 in I/Q Combined=Off mode)
	7. Number of active channels
	8. I channel average active power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the active I channels. (– 999.0 when I/Q Combined=On mode or when no active channel is detected in I/Q Combined=Off mode).
	9. I channel maximum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive I channels. (– 999.0 when I/Q Combined=On mode)
	10. Q channel average active power is a floating point number (in dB or dBm depending on the measurement type) of the average power of the active Q channels. (– 999.0 when I/Q Combined=On mode or when no active channel is detected in I/Q Combined=Off mode).
	11. Q channel maximum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive Q channels. (– 999.0 when I/Q Combined=On mode)

n	Results Returned
n=1 (or not	12. Preamble Length is a floating point number (in chips).
specified)	13. Preamble MAC Index is an integer number of MAC index.
1xEV-DO mode (continued)	14. Minimum Active Power is a floating point number (in dB or dBm depending on the measurement type) of the minimum average power of the active code (– 999.0 when no active channel is detected in I/Q Combined=On mode. Always – 999.0 in I/Q Combined=Off mode)
	15. I channel maximum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive I channels. (– 999.0 when I/Q Combined=On mode)
	16. I channel minimum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the minimum average power of the inactive I channels. (– 999.0 when I/Q Combined=On mode)
	17. Q channel maximum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the maximum average power of the inactive Q channels. (– 999.0 when I/Q Combined=On mode)
	18. Q channel minimum inactive power is a floating point number (in dB or dBm depending on the measurement type) of the minimum average power of the inactive Q channels. (– 999.0 when I/Q Combined=On mode)
2 cdmaOne mode	Returns floating point numbers that are the trace data of the code domain <i>power</i> trace for all 64 Walsh codes. This series of 64 numbers represent the relative power levels (in dB) of all 64 walsh codes, with respect to the carrier power.

n	Results Returned
2 cdma2000 mode	Returns a series of floating point numbers (in dB or dBm depending on the measurement type) that represents all the code domain powers.
	With a device of BTS, there are 64 or 128 numbers depending on CALCulate:CDPower:WCODe:BASE. If the active channel occupies more than the max spreading factor (64 or 128 Walsh Code length depending on CALCulate:CDPower:WCODe:BASE) the power is duplicated (CALCulate:CDPower:WCODe:BASE / active Walsh code length) times.
	1st number = 1st code power over the slot 2nd number = 2nd code power over the slot
	Nth number = Nth code power over the slot
	With a device of MS, there are 256 I/Q pairs. If the active channel occupies more than the max spreading factor (C8) the power is duplicated (active Cx / $C8$) times.
	1st number = 1st in-phase code power over the slot 2nd number = 1st quad-phase code power over the slot
	$(2\times N-1)$ th number = Nth in-phase code power over the slot $(2\times N)$ th number = Nth quad-phase code power over a slot
	N= the number of codes detected. The total number of codes varies because of the different symbol rates of each code.
2 1xEV-DO mode	Returns a series of floating point numbers (in dB or dBm depending on the measurement type) that represents all the code domain powers.
TAE V-DO IIIoue	When I/Q Combined=On, total is 16 for Data, 32 for Pilot, and 64 for MAC. If the active channel occupies more than the max spreading factor (16 for Data, 32 for Pilot, and 64 for MAC) the power is duplicated.
	1st number = 1st code power over the slot 2nd number = 2nd code power over the slot
	Nth number = Nth code power over the slot
	When I/Q Combined=Off, results are returned alternatively. Total is 16 I/Q pairs for Data, 32 for Pilot, and 64 for MAC. If the active channel occupies more than the max spreading factor (16 for Data, 32 for Pilot, and 64 for MAC) the power is duplicated.
	1st number = 1st in-phase code power over the slot 2nd number = 1st quad-phase code power over the slot
	$(2\times N-1)$ th number = Nth in-phase code power over the slot $(2\times N)$ th number = Nth quad-phase code power over a slot
	N = the number of codes detected. The total number of codes varies because of the different symbol rates of each code.

n	Results Returned
2 W-CDMA.mode	Returns a series of floating point numbers (in dB or dBm depending on the measurement type) that represents all the code domain powers.
	With a device of BTS, there are 512 numbers. If the active channel occupies more than the max spreading factor (7.5 ksps) the power is duplicated (active symbol rate/7.5 ksps) times.
	1st number = 1st code power over the slot 2nd number = 2nd code power over the slot
	Nth number = Nth code power over the slot
	With a device of MS, there are 256 I/Q pairs. If the active channel occupies more than the max spreading factor (15 ksps) the power is duplicated (active symbol rate / 15 ksps) times.
	1st number = 1st in-phase code power over the slot 2nd number = 1st quad-phase code power over the slot
	$(2\times N-1)$ th number = Nth in-phase code power over the slot $(2\times N)$ th number = Nth quad-phase code power over a slot
	N = the number of codes detected. The total number of codes varies because of the different symbol rates of each code.
3 cdmaOne mode	Returns floating point numbers that are the trace data of the code domain <i>timing</i> trace for all 64 Walsh codes. This series of 64 numbers represent the relative timing estimations (in seconds) of the codes, relative to the pilot channel. Typical values are on the order of 1 ns.

n	Results Returned
3 cdma2000 mode	Returns a series of floating point numbers (in symbol rate) that represent all code domain symbol rates.
	With a device of BTS, there are 64 or 128 numbers depending on CALCulate:CDPower:WCODe:BASE. If the active channel occupies more than the max spreading factor (64 or 128 Walsh code length depending on CALCulate:CDPower:WCODe:BASE) the power is duplicated (CALCulate:CDPower:WCODe:BASE / active Walsh code length) times.
	1st number = 1st code symbol rate over the slot 2nd number = 2nd code symbol rate over the slot
	Nth number = Nth code symbol rate over the slot
	With a device of MS, there are 256 I/Q pairs. If the active channel occupies more than the max spreading factor (C8) the power is duplicated (active Cx / $C8$) times.
	1st number = 1st in-phase code symbol rate over the slot 2nd number = 1st quad-phase code symbol rate over the slot
	$(2\times N-1)$ th number = Nth in-phase code symbol rate over the slot $(2\times N)$ th number = Nth quad-phase code symbol rate over the slot
	N = the number of codes detected. The total number of codes varies because of the different symbol rates of each code.
3 1xEV-DO mode	Returns a series of floating point numbers (in dB or dBm depending on the measurement type) that represents all the code domain symbol rates.
TAE V-DO IIIoue	When I/Q Combined=On, total is 16 for Data, 32 for Pilot, and 64 for MAC. If the active channel occupies more than the max spreading factor (16 for Data, 32 for Pilot, and 64 for MAC) the power is duplicated.
	1st number = 1st code symbol rate over the slot 2nd number = 2nd code symbol rate over the slot
	Nth number = Nth code symbol rate over the slot
	When I/Q Combined=Off, results are returned alternatively. Total is 16 I/Q pairs for Data, 32 for Pilot, and 64 for MAC. If the active channel occupies more than the max spreading factor (16 for Data, 32 for Pilot, and 64 for MAC) the power is duplicated.
	1st number = 1st in-phase code symbol rate over the slot 2nd number = 1st quad-phase code symbol rate over the slot
	$(2\times N-1)$ th number = Nth in-phase code symbol rate over the slot $(2\times N)$ th number = Nth quad-phase code symbol rate over a slot
	N= the number of codes detected. The total number of codes varies because of the different symbol rates of each code.

n	Results Returned
3 W-CDMA mode	Returns a series of floating point numbers (in symbol rate) that represent all code domain symbol rates.
	With a device of BTS, there are 512 numbers. If the active channel occupies more than the max spreading factor (7.5 ksps) the power is duplicated (active symbol rate/7.5 ksps) times. For inactive code channels, 7.5ksps is returned.
	1st number = 1st code symbol rate over the slot 2nd number = 2nd code symbol rate over the slot
	Nth number = Nth code symbol rate over the slot
	With a device of MS, there are 256 I/Q pairs. If the active channel occupies more than the max spreading factor (15 ksps) the power is duplicated (active symbol rate/15 ksps) times. For inactive code channels, 7.5ksps is returned.
	1st number = 1st in-phase code symbol rate over the slot 2nd number = 1st quad-phase code symbol rate over the slot
	$(2\times N-1)$ th number = Nth in-phase code symbol rate over the slot $(2\times N)$ th number = Nth quad-phase code symbol rate over the slot
	N = the number of codes detected. The total number of codes varies because of the different symbol rates of each code.
4 cdmaOne mode	Returns floating point numbers that are the trace data of the code domain <i>phase</i> trace for all 64 Walsh codes. This series of 64 numbers represent the relative phase estimations (in radians) of the codes, relative to the pilot channel. Typical values are on the order of 1 mrad.
4 cdma2000 or W-CDMA mode	Returns a series of floating point numbers that show either active or inactive status for each of the code powers returned in n=2. (See above.) If a code is inactive, the value returned is 0.0, otherwise a value >0.0 is returned.
	1st number = active or inactive flag of the 1st code
	Nth number = active or inactive flag of the Nth code
	(where N= the number of codes identified)

n	Results Returned
4 1xEV-DO mode	Returns a series of floating point numbers that show either active or inactive status for each of the code powers returned in n=2 and 3. If a code is inactive, the value returned is 0.0, otherwise a value >0.0 is returned.
	When I/Q Combined=On, I/Q combined results are returned. 1st number = active or inactive flag of the 1st code
	Nth number = active or inactive flag of the Nth code
	When channel type=Pilot or MAC, results are returned alternatively. 1st number = 1st in-phase code active flag 2nd number = 1st Quad Phase code active flag
	$(2\times N-1)$ th number = Nth in-phase code active flag $(2\times N)$ th number = Nth Quad Phase code active flag
	N = the number of codes detected. The total number of codes varies because of the different symbol rates of each code. 2nd number = 1st quad-phase code symbol rate over the slot
5 cdma2000, or W-CDMA mode	Returns a series of floating point numbers (in percent) that represent each sample in the EVM trace. The first number is the symbol 0 decision point and there are X points per symbol. Therefore, the decision points are at 0, $1\times X$, $2\times X$, $3\times X$
	(where X = the number of points per chip)
5 1xEV-DO mode	Returns series of floating point numbers that alternately represent I and Q pairs of the <i>corrected measured</i> trace. The magnitude of each I and Q pair is normalized to 1.0. The first number is the in-phase (I) sample of symbol 0 decision point and the second is the quadrature-phase (Q) sample of symbol 0 decision point. As in the EVM, there are X points per symbol, so that:
	1st number is I of the symbol 0 decision point 2nd number is Q of the symbol 0 decision point
	$(2\times X)+1$ number is I of the symbol 1 decision point $(2\times X)+2$ number is Q of the symbol 1 decision point
	$(2\times X)\times N+1$ th number is I of the symbol N decision point $(2\times X)\times N+2$ th number is Q of the symbol N decision point
	where X = the number of points per symbol, and N = the number of symbols
6 cdma2000, or W-CDMA mode	Returns a series of floating point numbers (in percent) that represent each sample in the <i>magnitude error</i> trace. The first number is the symbol 0 decision point and there are X points per symbol. Therefore, the decision points are at $0, 1\times X, 2\times X, 3\times X$
	(where X = the number of points per chip)

n	Results Returned
6 1xEV-DO mode	Returns series of floating point numbers (in dBm) that represent the trace data of the chip power vs. time.
7 cdma2000, or W-CDMA mode	Returns a series of floating point numbers (in degrees) that represent each sample in the <i>phase error</i> trace. The first number is the symbol 0 decision point and there are X points per symbol. Therefore, the decision points are at $0, 1\times X, 2\times X, 3\times X.$.
	(where X = the number of points per chip)
8 cdma2000 mode	Returns series of floating point numbers that alternately represent I and Q pairs of the <i>corrected measured</i> trace. The magnitude of each I and Q pair is normalized to 1.0. The first number is the in-phase (I) sample of symbol 0 decision point and the second is the quadrature-phase (Q) sample of symbol 0 decision point. As in the EVM, there are X points per symbol, so that:
	1st number is I of the symbol 0 decision point 2nd number is $\mathbf Q$ of the symbol 0 decision point
	$(2\times X)+1$ number is I of the symbol 1 decision point $(2\times X)+2$ number is Q of the symbol 1 decision point
	$(2\times X)\times N+1$ th number is I of the symbol N decision point $(2\times X)\times N+2$ th number is Q of the symbol N decision point
	where X = the number of points per symbol, and N = the number of symbols
	NOTE: "Normalization" is done so that ideal reference decision points for I and Q pairs of the corrected measured trace are scaled as follows:
	 — QPSK: I and Q = +/-1.0/SQRT(2) Radius [distance from origin] = 1.0 — 8PSK: I and Q = +/-0.9239 (or=COS(pi/8)), +/-0.3827 Radius [distance from origin] = 1.0 — 16QAM: I and Q = +/-0.3162 (or=SQRT(0.1)), +/-0.9487 (or=SQRT(0.9)) Radius = 0.4472 (or=SQRT(0.2)), 1.0, 1.3416 (or=SQRT(1.8))

n	Results Returned
8 W-CDMA mode	Returns series of floating point numbers that alternately represent I and Q pairs of the <i>corrected measured</i> trace. The magnitude of each I and Q pair is normalized to 1.0. The first number is the in-phase (I) sample of symbol 0 decision point and the second is the quadrature-phase (Q) sample of symbol 0 decision point. As in the EVM, there are X points per symbol, so that:
	1st number is I of the symbol 0 decision point 2nd number is Q of the symbol 0 decision point
	$(2\times X)+1$ number is I of the symbol 1 decision point $(2\times X)+2$ number is Q of the symbol 1 decision point
	$(2\times X)\times N+1$ th number is I of the symbol N decision point $(2\times X)\times N+2$ th number is Q of the symbol N decision point
	where X = the number of points per symbol, and N = the number of symbols
	NOTE: "Normalization" is done so that ideal reference decision points for I and Q pairs of the corrected measured trace are scaled as follows:
	$ \begin{array}{lll} & - & QPSK: I \ and \ Q = +/-1.0 \\ & \text{in other words: Radius [distance from origin]} = 1.4142 \ (or \ SQRT(2.0)) \\ & - & 16QAM: I \ and \ Q = +/-0.4472 \ (or=SQRT(0.2)), \ +/-1.3416 \ (or=SQRT(1.8)) \\ & \text{in other words: Radius} = 0.6325 \ (or=SQRT(0.4)), \ 1.4142 \ (or=SQRT(2.0)), \ 1.8974 \ (or=SQRT(3.6)) \end{array} $
9	Returns series of floating point numbers (in dBm) that represent the trace
cdma2000, or W-CDMA mode	data of the symbol power vs. time.
10	Returns series of floating point numbers (in dBm) that represent the trace
cdma2000, or W-CDMA mode	data of the chip power vs. time.

n	Results Returned
11 cdma2000	Returns a series of floating point numbers $(0.0 \ or \ 1.0)$ of the symbol values (demodulated bits) for the selected spread code. The results are returned as alternating values of I,Q,I,Q for the entire measurement interval.
	When using 1xEV-DV with 8PSK or 16QAM, it returns a series of floating point numbers (0.0 or 1.0) of the symbol values for the selected code with the entire capture length.
	For 8PSK modulation the queried data represents alternating s0, s1 and s2 sequence as follows:
	1st number = s0 bit of the 1st symbol 2nd number = s1 bit of the 1st symbol 3rd number = s2 bit of the 1st symbol 4th number = s0 bit of the 2nd symbol 5th number = s1 bit of the 2nd symbol 6th number = s2 bit of the 2nd symbol (3×N-2) number = s0 bit of the Nth symbol (3×N-1) number = s1 bit of the Nth symbol (3×N) number = s2 bit of the Nth symbol where N is the number of the symbols in the capture length.
	For 16QAM modulation the queried data represents alternating s0, s1, s2 and s3 sequence as follows:
	1st number = s0 bit of the 1st symbol 2nd number = s1 bit of the 1st symbol 3rd number = s2 bit of the 1st symbol 4th number = s3 bit of the 1st symbol 5th number = s0 bit of the 2nd symbol 6th number = s1 bit of the 2nd symbol 7th number = s2 bit of the 2nd symbol 8th number = s3 bit of the 2nd symbol (4×N-3) number = s0 bit of the Nth symbol (4×N-2) number = s1 bit of the Nth symbol (4×N-1) number = s2 bit of the Nth symbol (4×N) number = s3 bit of the Nth symbol where N is the number of the symbols in the capture length.

n	Results Returned
11 W-CDMA mode	Returns series of floating point numbers (0.0 or 1.0) of symbol values for the selected code with the entire capture length, when :CALCulate:CDPower:DBITs[:FORMat] is set to BINary.
	Returns series of floating point numbers (0.0, 1.0 or – 1.0) of symbol values for the selected code with the entire capture length, when :CALCulate:CDPower:DBITs[:FORMat] is set to TRIState. "–1.0" represents DTX (Discontinuous Transmission) bit.
	If a channel's spreading has been done on only the I or ${\bf Q}$ branch, then the queried data represents the sequence of I or ${\bf Q}$ data.
	If a channel's spreading has been done on both I and Q branches, and its modulation scheme is QPSK, then the queried data rapresents alternating I and Q sequences as follows:
	1st number = in-phase bit of the 1st I/Q pair 2nd number = quad-phase bit of the 1st I/Q pair 3rd number = in-phase bit of the 2nd I/Q pair 4th number = quad-phase bit of the 2nd I/Q pair
	(2×N-1) number = in-phase bit of the Nth I/Q pair (2×N) number = quad-phase bit of the 2nd I/Q pair where N is the number of symbols in the entire capture length
	If a channel's modulation scheme is 16QAM, then the queried data represents alternating i_1 , q_1 , i_2 and q_2 sequences as follows:
	1st number = i_1 bit of the 1st symbol 2nd number = q_1 bit of the 1st symbol 3rd number = i_2 bit of the 1st symbol 4th number = q_2 bit of the 1st symbol 5th number = i_1 bit of the 2nd symbol 6th number = q_1 bit of the 2nd symbol
	$(4\times N-3) \ number = i_1 \ bit \ of \ the \ Nth \ symbol$ $(4\times N-2) \ number = q_1 \ bit \ of \ the \ Nth \ symbol$ $(4\times N-1) \ number = i_2 \ bit \ of \ the \ Nth \ symbol$ $(4\times N) \ number = q_2 \ bit \ of \ the \ Nth \ symbol$ where N is the number of symbols in the entire capture length

n	Results Returned
12 W-CDMA mode	Returns series of floating point numbers (0.0 or 1.0) of symbol values for the selected code with the period selected by Meas Interval, and Meas Offset and tDPCH, when :CALCulate:CDPower:DBITs[:FORMat] is set to BINary. Returns series of floating point numbers (0.0, 1.0 or -1.0) of symbol values for the selected code with the period selected by Meas Interval, and Meas Offset and tDPCH, when :CALCulate:CDPower:DBITs[:FORMat] is set to TRIState. "-1.0" represents DTX (Discontinuous Transmission) bit.
	(Note: tDPCH indicates the time offset in (x256 chips) from CPICH slot #0 start position to the DPCH slot #0 start position. (value range: 0 to 149) But for the demod bit stream in n=12, only (tDPCH mod 10) is considered. This is the offset from CPICH slot boundary to the slot boundary of the selected DPCH. For example, in the case of tDPCH=83, offset = 3 (tDPCH mod 10=3) is used to identify the slot boundary for the selected DPCH (code channel for symbol values to be analyzed). The demod bit stream in n=12 always returns all bits in the entire captured length without consideration for Meas Interval, Meas offset or tDPCH. User can select which is useful for their own application.)
	If a channel's spreading has been done on only the I or ${\bf Q}$ branch, then the queried data represents the sequence of I or ${\bf Q}$ data.
	If a channel's spreading has been done on both I and Q branches, and its modulation scheme is QPSK, then the queried data rapresents alternating I and Q sequences as follows:
	1st number = in-phase bit of the 1st I/Q pair 2nd number = quad-phase bit of the 1st I/Q pair 3rd number = in-phase bit of the 2nd I/Q pair 4th number = quad-phase bit of the 2nd I/Q pair
	(2×N-1) number = in-phase bit of the Nth I/Q pair (2×N) number = quad-phase bit of the 2nd I/Q pair where N is the number of symbols in the time selected by Meas Interval and Meas Offset
	If a channel's modulation scheme is 16QAM, then the queried data rapresents alternating i_1 , q_1 , i_2 and q_2 sequences as follows:
	1st number = i_1 bit of the 1st symbol 2nd number = q_1 bit of the 1st symbol 3rd number = i_2 bit of the 1st symbol 4th number = q_2 bit of the 1st symbol 5th number = i_1 bit of the 2nd symbol 6th number = q_1 bit of the 2nd symbol
	$(4\times N-3) \ number = i_1 \ bit \ of \ the \ Nth \ symbol$ $(4\times N-2) \ number = q_1 \ bit \ of \ the \ Nth \ symbol$ $(4\times N-1) \ number = i_2 \ bit \ of \ the \ Nth \ symbol$ $(4\times N) \ number = q_2 \ bit \ of \ the \ Nth \ symbol$ where N is the number of symbols in the time selected by Meas Interval and Meas Offset

Channel Power Measurement

For E4406A this measures the total rms power in a specified integration bandwidth. You must be in the Basic, cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use these commands. Use INSTrument:SELect to set the mode.

For PSA this measures the total rms power in a specified integration bandwidth. You must be in the cdmaOne, cdma2000, or W-CDMA, or 1xEV-DO mode to use these commands. Use INSTrument:SELect to set the mode.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:CHPower commands for more measurement related commands.

:CONFigure:CHPower

:INITiate:CHPower

:FETCh:CHPower[n]?

:READ:CHPower[n]?

:MEASure:CHPower[n]?

History: For E4406A:

Added to Basic mode, version A.03.00 or later

Front Panel

Access: Measure, Channel Power

After the measurement is selected, press Restore Meas

Defaults to restore factory defaults.

Measurement Results Available

n	Results Returned
0	Returns unprocessed I/Q trace data, as a series of trace point values, in volts. The I values are listed first in each pair, using the 0 through even-indexed values. The Q values are the odd-indexed values.
n=1 (or not	Returns scalar results:
specified)	1. Channel Power is a floating point number representing the total channel power in the specified integration bandwidth.
	2. PSD (Power Spectral Density) is the power (in dBm/Hz) in the specified integration bandwidth.
2	Returns floating point numbers that are the captured trace data of the power (in dBm/resolution BW) of the signal. The frequency span of the captured trace data is specified by the Span key.

QPSK Error Vector Magnitude Measurement

This measures the QPSK error vector magnitude of each symbol. You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use these commands. Use INSTrument:SELect to set the mode.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:EVMQpsk commands for more measurement related commands.

:CONFigure:EVMQpsk

:INITiate:EVMQpsk

:FETCh:EVMQpsk[n]?

:READ:EVMQpsk[n]?

:MEASure:EVMQpsk[n]?

History: Version A.03.00 or later

Front Panel

Access: Measure, QPSK EVM

After the measurement is selected, press Restore Meas

Defaults to restore factory defaults.

Measurement Results Available

n	Results Returned
0	Returns unprocessed I/Q trace data, as a data array of trace point values, in volts.

n	Results Returned
1 (default)	Returns scalar results, in the following order.
	 RMS EVM is a floating point number (in percent) of EVM over the entire measurement area. RMS EVM maximum is the maximum RMS EVM over the averaged
	counts 3. Peak EVM is a floating point number (in percent) of peak EVM in the measurement area.
	4. Peak EVM maximum is the maximum peak EVM over the averaged counts.
	5. Magnitude error is a floating point number (in percent) of average magnitude error over the entire measurement area.
	6. Magnitude error maximum is the maximum magnitude error over the averaged counts.
	7. Phase error is a floating point number (in degree) of average phase error over the entire measurement area.
	8. Phase error maximum is the maximum phase error over the averaged counts.
	9. Frequency error is a floating point number (in Hz) of the frequency error in the measured signal.
	10. Frequency error maximum is the maximum frequency error over the averaged counts.
	11. I/Q origin offset is a floating point number (in dB) of the I and Q error (magnitude squared) offset from the origin.
2	EVM trace – returns series of floating point numbers (in percent) that represent each sample in the EVM trace. The first number is the symbol 0 decision point. There are X points per symbol (X = points/chip). Therefore, the decision points are at 0 , $1 \times X$, $2 \times X$, $3 \times X$
3	Magnitude error trace – returns series of floating point numbers (in percent) that represent each sample in the magnitude error trace. The first number is the symbol 0 decision point. There are X points per symbol (X = points/chip). Therefore, the decision points are at 0 , $1 \times X$, $2 \times X$, $3 \times X$
4	Phase error trace – returns series of floating point numbers (in degree) that represent each sample in the phase error trace. There are X points per symbol (X = points/chip). Therefore, the decision points are at $0, 1 \times X, 2 \times X, 3 \times X$

n	Results Returned
5	Corrected measured trace — returns series of floating point numbers that alternately represent I and Q pairs of the corrected measured trace. The magnitude of each I and Q pair are normalized to 1.0. The first number is the in-phase (I) sample of symbol 0 decision point and the second is the quadrature-phase (Q) sample of symbol 0 decision point. There are X points per symbol (X = points/chip), so the series of numbers is:
	1st number = I of the symbol 0 decision point 2nd number = Q of the symbol 0 decision point $(2 \times X) + 1$, number = I of the symbol 1 decision point $(2 \times X) + 2$, number = Q of the symbol 1 decision point
	$(2 \times X) \times N$ th + 1 number = I of the symbol N decision point $(2 \times X) \times N$ th + 2 number = Q of the symbol N decision point

Intermodulation Measurement

This measures the third order and fifth order intermodulation products caused by the wanted signal and the interfering signal. You must be in cdma2000, W-CDMA, or 1xEV-DO mode to use these commands. Use INSTrument:SELect to set the mode.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:IM commands for more measurement related commands.

:CONFigure:IM

:INITiate:IM

:FETCh:IM[n]?

:READ:IM[n]?

:MEASure:IM[n]?

Front Panel

Access: Measure, Intermod

After the measurement is selected, press Restore Meas

Defaults to restore factory defaults.

Measurement Results Available

n	Results Returned
0	Returns unprocessed I/Q trace data that acquired in the last acquisition when multiple acquisition is performed, as a data array of trace point values, in volts.

n	Results Returned
1 (default)	Returns scalar results in the following order. 1. Absolute power of the reference (dBm) 2. Base lower frequency (Hz) 3. Base lower absolute power (dBm) 4. Base lower relative power to the reference (dBc) 5. Base upper frequency (Hz)
	6. Base upper absolute power (dBm) 7. Base upper relative power to the reference (dBc) 8. Third order lower frequency (Hz) 9. Third order lower absolute power (dBm) 10. Third order lower power spectrum density (dBm/Hz) 12. Third order upper frequency (Hz) 13. Third order upper absolute power (dBm) 14. Third order upper power spectrum density (dBm/Hz) 15. Third order upper power spectrum density (dBm/Hz) 16. Fifth order lower frequency (Hz) 17. Fifth order lower absolute power (dBm) 18. Fifth order lower relative power to the reference power (dBc) 19. Fifth order lower power spectrum density (dBm/Hz) 20. Fifth order upper frequency (Hz) 21. Fifth order upper absolute power (dBm) 22. Fifth order upper relative power to the reference power (dBc) 23. Fifth order upper relative power to the reference power (dBc) 15. Third order upper spectrum density (dBm/Hz) 16. Fifth order upper frequency (Hz) 17. Fifth order lower power spectrum density (dBm/Hz) 18. Fifth order upper frequency (Hz) 29. Fifth order upper spectrum density (dBm/Hz) 19. Fifth order upper relative power to the reference power (dBc) 20. Fifth order upper spectrum density (dBm/Hz) 21. Fifth order upper relative power to the reference power (dBc) 22. Fifth order upper relative power to the reference power (dBc) 23. Fifth order upper spectrum density (dBm/Hz)
2 cdma2000, 1xEV-DO mode	0.0 for the frequency results. Returns a series of floating point numbers that represent the frequency-domain spectrum trace for the entire frequency range being measured. In the default settings (SENSe:IM:FREQuency:SPAN 20 MHz; SENSe:IM:BANDwidth BWIDth[:RESolution] 140 kHz), there are 345 numbers.
2 W-CDMA mode	Returns a series of floating point numbers that represent the frequency-domain spectrum trace for the entire frequency range being measured. In the default settings (SENSe:IM:FREQuency:SPAN 50 MHz; SENSe:IM:BANDwidth BWIDth[:RESolution] 140 kHz), there are 872 numbers.

MEASure Group of Commands

n	Results Returned
3	Returns 2 scalar values of the measured mode determined by the Auto algorithm.
	1. Measurement Mode:
	1: Two-tone
	2: Transmit IM
	3: Auto (Two-tone)
	4: Auto (Transmit IM)
	5: Unknown
	2. Reference:
	1: Lower
	2: Upper
	3: Average
	4: Auto (Lower)
	5: Auto (Upper)

Occupied Bandwidth Measurement

This measures the bandwidth of the carrier signal in the occupied part of the channel. You must be in the PDC, iDEN (E4406A only), cdma2000, W-CDMA, or 1xEV-DO mode to use these commands. Use INSTrument:SELect to set the mode.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:OBW commands for more measurement related commands.

:CONFigure:OBW

:INITiate:OBW

:FETCh:OBW[n]?

:READ:OBW[n]?

:MEASure:OBW[n]?

History: E4406A:

Version A.02.00 or later

Front Panel

Access: Measure, Occupied BW

After the measurement is selected, press Restore Meas

Defaults to restore factory defaults.

Measurement results available

n	Results Returned
0	Returns unprocessed I/Q trace data, as a data array of trace point values, in volts.
1 (default)	Returns scalar results, in the following order:
cdma2000, W-CDMA mode	 Occupied bandwidth - Hz Absolute Carrier Power - dBm
1 (default)	Returns scalar results, in the following order:
PDC	 Occupied bandwidth - kHz Absolute Carrier Power - dBm
1 (default)	Returns scalar results, in the following order:
1xEV-DO mode	 Occupied bandwidth - Hz Absolute Carrier Power - dBm Span - Hz Spectrum Trace Points - points Res BW - Hz

MEASure Group of Commands

n	Results Returned
1 (default) iDEN mode E4406A	Returns the following scalar results, in order. 1. Absolute power of occupied bandwidth (dBm) 2. Relative power of occupied bandwidth (dB) 3. Bandwidth for specified power percentage 4. Power percentage 5. Measured carrier frequency 6. Frequency span 7. Average count
PDC, cdma2000, W-CDMA, 1xEV-DO mode	Returns the frequency-domain spectrum trace (data array) for the entire frequency range being measured.
2, spectrum display only iDEN mode E4406A	Returns the frequency-domain spectrum trace (data array) for the entire frequency range (9003 points) being measured.

Power Statistics CCDF Measurement

For E4406A this is a statistical power measurement of the complementary cumulative distribution function (CCDF). You must be in the Basic, cdma2000, W-CDMA, or 1xEV-DO mode to use these commands. Use INSTrument:SELect to set the mode.

For PSA this is a statistical power measurement of the complementary cumulative distribution function (CCDF). You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use these commands. Use INSTrument:SELect to set the mode.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:PSTat commands for more measurement related commands.

:CONFigure:PSTatistic

:INITiate:PSTatistic

:FETCh:PSTatistic[n]?

:READ:PSTatistic[n]?

:MEASure:PSTatistic[n]?

History: Version A.03.00 or later, added in Basic A.04.00

Front Panel

Access: Measure, Power Stat CCDF

After the measurement is selected, press Restore Meas

Defaults to restore factory defaults.

Measurement Results Available

n	Results Returned
0	Returns unprocessed I/Q trace data, as a series of trace point values, in volts. The I values are listed first in each pair, using the 0 through even-indexed values. The Q values are the odd-indexed values,
n=1 (or not specified)	Returns scalar results: 1. Average input power (in dBm) 2. Probability at the average input power level (in %) 3. Power level that has 10% of the power 4. Power level that has 1% of the power 5. Power level that has 0.1% of the power 6. Power level that has 0.01% of the power 7. Power level that has 0.001% of the power 8. Power level that has 0.0001% of the power 9. Peak power (in dB) 10. Count

n	Results Returned
2	Returns a series of 5001 floating point numbers (in percent) that represent the current measured power stat trace. This is the probability at particular power levels (average power), in the following order:
	 Probability at 0.0 dB power Probability at 0.01 dB power Probability at 0.02 dB power
	• • •
	 Probability at 49.9 dB power Probability at 50.0 dB power
3	Returns a series of 5001 floating point numbers (in percent) that represent the Gaussian trace. This is the probability at particular power levels (average power), in the following order:
	 Probability at 0.0 dB power Probability at 0.01 dB power Probability at 0.02 dB power
	• • •
	 Probability at 49.9 dB power Probability at 50.0 dB power
4	Returns a series of 5001 floating point numbers (in percent) that represent the user-definable reference trace. This is the probability at particular power levels (average power), in the following order:
	 Probability at 0.0 dB power Probability at 0.01 dB power Probability at 0.02 dB power
	• • •
	 Probability at 49.9 dB power Probability at 50.0 dB power

Modulation Accuracy (Rho) Measurement

This measures the modulation accuracy of the transmitter by checking the magnitude and phase error and the EVM (error vector magnitude). You must be in the cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use these commands. Use INSTrument:SELect to set the mode.

For 1xEV-DO: these commands will measure modulation accuracy on network access equipment (base transmitter stations). Use MEAS:TRHO to measure terminal transmitter modulation accuracy, after selecting mobile stations using SENSe:RADio:DEVice MS.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:RHO commands for more measurement related commands.

:CONFigure:RHO

:INITiate:RHO

:FETCh:RHO[n]?

:READ:RHO[n]?

:MEASure:RHO[n]?

Front Panel

Access: Measure, Mod Accuracy (Rho) for cdmaOne

Measure, Mod Accuracy (Composite Rho) for cdma2000,

1xEV-DO, or W-CDMA (3GPP)

After the measurement is selected, press **Restore Meas**

Defaults to restore factory defaults.

Measurement Results Available

n	Results Returned
0 cdmaOne mode	Returns unprocessed I/Q trace data, as a series of trace point values. The I values are listed first in each pair, using the 0 through even-indexed values. The Q values are the odd-indexed values.
	The standard sample rate is 7.5 MHz and the trace length is determined by the current measurement interval.
0 cdma2000 or W-CDMA mode	Returns unprocessed I/Q trace data, as a series of trace point values. The I values are listed first in each pair, using the 0 through even-indexed values. The Q values are the odd-indexed values.

n	Results Returned
n=1 (or not specified) cdmaOne mode	 Returns floating point numbers, in the following order: Rho (no units) represents the correlation of the measured power compared to the ideal pilot channel. The calculation is performed after the complementary filter, so it is IS95 compliant. It is performed at the decision points in the pilot waveform. If averaging is on, this is the average of the individual rms measurements. Time offset (with units of seconds) is the time delay of the even second clock with respect to the start of the short code PN sequences, at offsets from the 15 zeros in the characteristic phase of the sequence. Frequency error of the measured signal, with units of Hz. This is based on the linear best fit of the uncorrected measured phase. Carrier feedthrough has units of dB and is the dc error offset of I and Q, from the origin. EVM has units of percent. The calculation is based on the composite of the phase error and magnitude error, between the measured signal and the ideal pilot channel. It is performed after the complementary filter which removes the inter-symbol interference in the modulated data. If averaging is on, this is the average of the individual rms measurements. Magnitude error (with units of percent) is the rms error between the measured (compensated) magnitude and the ideal magnitude. This is performed after the complementary filter which removes the inter-symbol interference in the modulated data. If averaging is on, this is the average of the individual rms measurements. Phase error (with units in percent) is the rms phase error between the measured phase and the ideal phase. The calculation is performed after the complementary filter which removes the inter-symbol interference in the modulated data. If averaging is on, this is the average of the individual rms measurements.

n	Results Returned
n=1 (or not specified)	Returns scalar results, in the following order. 1. RMS EVM is a floating point number (in percent) of EVM over the
cdma2000	entire measurement area 2. Peak EVM is a floating point number (in percent) of peak EVM in the measurement area
	3. Magnitude error is a floating point number (in percent) of average magnitude error over the entire measurement area
	 4. Phase error is a floating point number (in degree) of average phase error over the entire measurement area 5. I/Q origin offset is a floating point number (in dB) of the I and Q error
	(magnitude squared) offset from the origin 6. Frequency error is a floating point number (in Hz) of the frequency
	error in the measured signal 7. Rho is a floating point number of Rho
	8. Peak code domain error is a floating point number (in dB) of the Peak Code Domain Error relative to the mean power
	9. Peak code domain error channel number is the channel number in which the peak code domain error is detected at the max spreading factor.
	NOTE: For MS measurements of Q channel numbers, subtract 32 from the number returned by SCPI query to obtain the actual channel number. For example, if the front panel displayed result is "W32 (15) :Q", then the SCPI query result will be "47". As $47-32=15$, 15 is the actual Peak CDE channel number result.
	For I channel MS measurements, as well as both I and Q channel BTS measurements, the returned number is the actual Peak CDE channel number.
	10. Number of active channels.11. Time offset is a floating point number (in second) PN offset from the trigger point.

Results Returned
Returns following scalar results, in the following order.
Returns following scalar results, in the following order. 1. RMS EVM is a floating point number (in percent) of EVM over the entire measurement area 2. Peak EVM error is a floating point number (in percent) of peak EVM in the measurement area 3. Magnitude error is a floating point number (in percent) of average magnitude error over the entire measurement area 4. Phase error is a floating point number (in degree) of average phase error over the entire measurement area 5. I/Q origin offset is a floating point number (in dB) of the I and Q error (magnitude squared) offset from the origin 6. Frequency error is a floating point number (in Hz) of the frequency error in the measured signal 7. Rho is a floating point number of Rho 8. Peak Code Domain Error is a floating point number (in dB) of the Peak Code Domain Error relative to the mean power 9. Peak Code Domain Error Channel Number is the channel number in which the peak code domain error is detected at the max spreading factor.
10. Number of active channels.11. Time offset is a floating point number (in chip) of the pilot phase
timing from the acquisition trigger point. 12. CPICH power over a slot is a floating point number in dB of CPICH power over a measurement slot. In the MS mode the value returned is –999. 13. Average total power over a slot is a floating point number in dBm of total RF power over a measurement slot. 14. Slot number is an integer number of the slot being measured. This result is not averaged even if averaging is On. It is always the last cycle

n	Results Returned
n=1 (or not specified)	Returns the following comma-separated scalar results, in the following order:
1xEV-DO mode For base stations: SENS:RAD:DEV BTS For meas type: CALC:RHO:TYPE DATA MAC PILot PREamble	 (NOTE: Returns ONLY the following 9 comma-separated scalar results, in the following order, for base transmitter station measurements when the type is NOT set to ALL.) RMS EVM – a floating point number (in percent) of EVM over the entire measurement area. Peak EVM error – a floating point number (in percent) of peak EVM in the measurement area. Magnitude error – a floating point number (in percent) of average magnitude error over the entire measurement area. Phase error – a floating point number (in degree) of average phase error over the entire measurement area. I/Q Origin Offset – a floating point number (in dB) of the I and Q error (magnitude squared) offset from the origin. Frequency error – a floating point number (in Hz) of the frequency error in the measured signal. Rho – a floating point number of Rho. Number of active channels. Time offset is the time from the trigger to the PN offset – a floating point number (in micro seconds) of PN offset from the trigger point.

	D I D I
n	Results Returned
n=1 (or not specified)	Returns the following scalar results for base transmitter station measurements when the type is set to ALL.
1xEV-DO mode For base stations: SENS:RAD:DEV BTS	Rho Overall-1 and Rho Overall-2 specified in 3GPP2 TSG-C4.1 Recommended Minimum Performance Standard for cdma2000 High Rate Data Packet Access Network, 11.4.2 Waveform Quality Measurement section.
For meas type ALL: CALC:RHO:TYPE ALL	10. RMS EVM (Overall-1) – a floating point number (in percent) of EVM over the entire measurement area. 11. Peak EVM error (Overall-1) – a floating point number (in percent) of peak EVM in the measurement area. 12. Magnitude error (Overall-1) – a floating point number (in percent) of average magnitude error over the entire measurement area. 13. Phase error (Overall-1) – a floating point number (in degree) of average phase error over the entire measurement area. 14. I/Q Origin Offset (Overall-1) – a floating point number (in dB) of the I and Q error (magnitude squared) offset from the origin. 15. Frequency error (Overall-1) – a floating point number (in Hz) of the frequency error in the measured signal. 16. Rho (Overall-1) – a floating point number of Rho. 17. RMS EVM (Overall-2) – a floating point number (in percent) of EVM over the entire measurement area. 18. Peak EVM error (Overall-2) – a floating point number (in percent) of peak EVM in the measurement area. 19. Magnitude error (Overall-2) – a floating point number (in percent) of average magnitude error over the entire measurement area. 20. Phase error (Overall-2) – a floating point number (in degree) of average phase error over the entire measurement area. 21. I/Q Origin Offset (Overall-2) – a floating point number (in dB) of the I and Q error (magnitude squared) offset from the origin. 22. Frequency error (overall-2) – a floating point number (in dB) of the I and Q error (magnitude squared) offset from the origin. 23. Rho (Overall-2) – a floating point number of Rho. 24. Number of active channels in Pilot 25. Number of active channels in Pilot 26. Number of active channels in Data 27. Preamble Length 28. MAC Index 29. Number of Max MAC Inactive channel Power – a floating point number (in dB) of Maximum Data Active Channel Power channels in Data 30. Max Data Active Channel Power – a floating point number (in dB) of Minimum Data Active Channel Power

n	Results Returned
2 cdmaOne mode	EVM trace – returns error vector magnitude (EVM) data, as trace point values in percent. The first value is the chip 0 decision point. The trace is interpolated for the currently selected points/chips displayed on the front panel. The number of trace points depends on the current measurement interval setting.
2 cdma2000 or W-CDMA mode	EVM trace – returns series of floating point numbers (in percent) that represent each sample in the EVM trace. The first number is the symbol 0 decision point. There are X points per symbol (X = points/chip). Therefore, the decision points are at 0 , $1 \times X$, $2 \times X$, $3 \times X$
2 1xEV-DO mode	Returns series of floating point numbers (in percent) that represent each sample in the EVM trace. The first number is the symbol 0 decision point and there are X points per symbol. Therefore, the decision points are at 0, 1xX, 2xX, 3xX
	(X = the number of points per chip)
	This traces is available when the Measurement Channel Type Selection is Pilot, MAC or Data (CALCulate:RHO:TYPE = PILot MAC DATA) In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0
3 cdmaOne mode	Magnitude error trace – returns magnitude error data, as trace point values, in percent. The first value is the chip 0 decision point. The trace is interpolated for the currently selected points/chips displayed on the front panel. The number of trace points depends on the current measurement interval setting.
3 cdma2000, W-CDMA, or 1xEV-DO mode	Magnitude error trace – returns series of floating point numbers (in percent) that represent each sample in the magnitude error trace. The first number is the symbol 0 decision point. There are X points per symbol (X = points/chip). Therefore, the decision points are at 0, $1 \times X$, $2 \times X$, $3 \times X$
	For 1xEV-DO: this traces is available when the Measurement Channel Type Selection is Pilot, MAC or Data (CALCulate:RHO:TYPE = PILot MAC DATA) In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0
4 cdmaOne mode	Phase error trace – returns phase error data, as trace point values, in degrees. The first value is the symbol 0 decision point. The trace is interpolated for the currently selected chips/symbol displayed on the front panel. The number of trace points depends on the current measurement interval setting.

n	Results Returned
d cdma2000, W-CDMA, or 1xEV-DO mode	Phase error trace – returns series of floating point numbers (in degrees) that represent each sample in the phase error trace. There are X points per symbol (X = points/ chip). Therefore, the decision points are at 0 , $1 \times X$, $2 \times X$, $3 \times X$
	For 1xEV-DO: this traces is available when the Measurement Channel Type Selection is Pilot, MAC or Data (CALCulate:RHO:TYPE = PILot MAC DATA) In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0
5 cdmaOne mode	Corrected measured data – returns a series of floating point numbers that alternately represent I and Q pairs of the corrected measured trace data. The magnitude of each I and Q pair are normalized to 1.0 .
	The number of trace points depends on the current measurement interval setting.
	The numbers are sent in the following order:
	In-phase (I) sample, of symbol 0 decision point Quadrature-phase (Q) sample, of symbol 0 decision point
	In-phase (I) sample, of symbol 1 decision point Quadrature-phase (Q) sample, of symbol 1 decision point
	The trace can be interpolated to 2,4, 8 points/chip selected with the display Points/Chip softkey. This will change the number of points between decision points in the trace, changing the number of I/Q pairs sent for each decision point.
5 cdma2000, W-CDMA, 1xEV-DO mode	Corrected measured trace – returns series of floating point numbers that alternately represent I and Q pairs of the corrected measured trace. The magnitude of each I and Q pair are normalized to 1.0. The first number is the in-phase (I) sample of symbol 0 decision point and the second is the quadrature-phase (Q) sample of symbol 0 decision point. There are X points per symbol (X = points/chip), so the series of numbers is:
	1st number = I of the symbol 0 decision point 2nd number = Q of the symbol 0 decision point
	$(2 \times X) + 1$, number = I of the symbol 1 decision point $(2 \times X) + 2$, number = Q of the symbol 1 decision point
	$(2 \times X) \times Nth + 1$ number = I of the symbol N decision point $(2 \times X) \times Nth + 2$ number = Q of the symbol N decision point
	For 1xEV-DO: this traces is available when the Measurement Channel Type Selection is Pilot, MAC or Data (CALCulate:RHO:TYPE = PILot MAC DATA) In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0

n	Results Returned			
6 cdmaOne mode	Reference IQ data – returns a series of floating point numbers that alternately represent I and Q pairs of the reference trace data.			
	The number of trace points depends on the current measurement interval and points per chip settings.			
	The numbers are sent in the following order:			
	$\begin{array}{c} \text{In-phase} \ (I) \ sample, \ of \ symbol \ 0 \ decision \ point \\ Quadrature-phase \ (Q) \ sample, \ of \ symbol \ 0 \ decision \ point \end{array}$			
	In-phase (I) sample, of symbol 1 decision point Quadrature-phase (Q) sample, of symbol 1 decision point			
	The trace can be interpolated to 2,4,8 points/chip selected with the display Points/Chip softkey.			
6 cdma2000 mode	Returns scalar values of the pass/fail (0=passed, or 1=failed) results determined by testing the EVM and peak EVM.			
	 Test result of EVM Test result of Peak EVM Test result of Rho Test result of Peak Code Domain Error Test result of Time Offset Test result of Phase Error 			
6	The same as n=2. (Overall-1)			
1xEV-DO mode	This trace is available when the Measurement Channel Type Selection is All			
	(CALCulate:RHO:TYPE = ALL)			
	(Rho Overall-1 and Rho Overall-2 as specified in 3GPP2 TSG-C4.1 Recommended Minimum Performance Standard for cdma2000 High Rate Data Packet Access Network, 11.4.2 Waveform Quality Measurement section.)			
	n=6, 7, 8, 9 are for Overall-1 data trace			
	n=10, 11, 12, 13 are for Overall-2 data trace			
	In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0			
6 W-CDMA mode	Returns comma-separated scalar values of the pass/fail (0.0 = passed, or 1.0 = failed) results determined by testing the EVM and peak EVM.			
	 Test result of EVM Test result of Peak EVM Test result of Rho Test result of Peak Code Domain Error Test result of Frequency Error Test result of CPICH power over a frame (If MS is selected, this always returns 0.0.) 			

n	Results Returned		
7 cdmaOne mode	complementary filtered measured data – returns a series of floating point numbers that alternately represent I and Q pairs of the complementary filtered measured data. This is inverse filtered data of the inter-symbol interference in CDMA signals due to the digital transmission filters defined in the standard as well as the base station phase equalization filter.		
	The number of trace points depends on the current measurement interval setting.		
	The numbers are sent in the following order:		
	$\begin{array}{c} \text{In-phase (I) sample, of symbol 0 decision point} \\ \text{Quadrature-phase (Q) sample, of symbol 0 decision point} \end{array}$		
	In-phase (I) sample, of symbol 1 decision point Quadrature-phase (Q) sample, of symbol 1 decision point		
	The trace can be interpolated to 2,4,8 points/chip selected with the display Points/Chip softkey. This will change the number of points between decision points in the trace, changing the number of I/Q pairs sent for each decision point.		
7 cdma2000 mode	Returns series of floating point numbers of code level, code index, power (in dB), time offset (in ns), phase offset (in rad), and code domain error (in dB). The total number of results are six times of "number of active channels". The number of active channels can be obtained by the 10th result of FETCh:RHOO command.		
7	The same as n=3. (Overall-1)		
1xEV-DO mode	This trace is available when the Measurement Channel Type Selection is All		
	(CALCulate:RHO:TYPE = ALL)		
	(Rho Overall-1 and Rho Overall-2 as specified in 3GPP2 TSG-C4.1 Recommended Minimum Performance Standard for cdma2000 High Rate Data Packet Access Network, 11.4.2 Waveform Quality Measurement section.)		
	n=6, 7, 8, 9 are for Overall-1 data trace		
	n=10, 11, 12, 13 are for Overall-2 data trace		
	In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0		

n	Results Returned		
7 W-CDMA mode	With a device of BTS, it returns a series of floating point numbers: symbol rate (ex. 7.5 ksps), OVSF code number, a dummy value, power level and code domain error for the active channels.		
	With a device of MS, it returns a series of floating point numbers: symbol rate (ex. 15 ksps), OVSF code number, $1.0~(I)~or~-1.0~(Q)$, power level and code domain error for the active channels. The results would look like the following:		
	1st number = Symbol Rate for 1st Active Channel 2nd number = OVSF Code number for 1st Active Channel 3rd number = (in BTS) – 999, or (in MS) either +1 (I) or –1 (Q) for 1st Active Channel 4th number = Power Level (in dB) for 1st Active Channel 5th number = Code Domain Error for 1st Active Channel		
	(N-1)*5+1 number = Symbol Rate for Nth Active Channel (N-1)*5+2 number = OVSF Code number for Nth Active Channel (N-1)*5+3 number = -999 (in BTS), or either +1 (I) or -1 (Q) (in MS) for Nth Active Channel (N-1)*5+4 number = Power Level (in dB) for Nth Active Channel N*5 number = Code Domain Error for Nth Active Channel		
	Number of active channel is given by 10th parameter of :MEASure:RHO[1].		
8 cdmaOne mode	complementary filtered reference data – returns a series of floating poin numbers that alternately represent I and Q pairs of the complementary filtered reference data. This is inverse filtered data of the inter-symbol interference in CDMA signals due to the digital transmission filters defined in the standard as well as the base station phase equalization filter.		
	The number of trace points depends on the current measurement interval setting.		
	The numbers are sent in the following order:		
	$\begin{array}{c} \text{In-phase} \ (I) \ sample, \ of \ symbol \ 0 \ decision \ point \\ Quadrature-phase \ (Q) \ sample, \ of \ symbol \ 0 \ decision \ point \end{array}$		
	In-phase (I) sample, of symbol 1 decision point Quadrature-phase (Q) sample, of symbol 1 decision point		
	The trace can be interpolated to 2,4,8 points/chip selected with the display Points/Chip softkey. This will change the number of points between decision points in the trace, changing the number of I/Q pairs sent for each decision point.		

n	Results Returned		
8 W-CDMA mode	Returns a series of floating point numbers (in dB) that represents all the code domain powers.		
W OBJAIT MOUC	With a device of BTS, there are 512 numbers. If the active channel occupies more than the max spreading factor (7.5 ksps) the power is duplicated (active symbol rate/7.5 ksps) times.		
	1st number = 1st code power over the slot 2nd number = 2nd code power over the slot		
	 Nth number = Nth code power over the slot		
	With a device of MS, there are 256 I/Q pairs. If the active channel occupies more than the max spreading factor (15 ksps) the power is duplicated (active symbol rate / 15 ksps) times.		
	1st number = 1st in-phase code power over the slot 2nd number = 1st quad-phase code power over the slot		
	(2*N-1) number = Nth in-phase code power over the slot $(2*N)$ number = Nth quad-phase code power over a slot		
	N = the number of codes detected. The total number of codes varies because of the different symbol rates of each code.		
8	The same as n=4. (Overall-1)		
1xEV-DO mode	This trace is available when the Measurement Channel Type Selection is All		
	(CALCulate:RHO:TYPE = ALL)		
	(Rho Overall-1 and Rho Overall-2 as specified in 3GPP2 TSG-C4.1 Recommended Minimum Performance Standard for cdma2000 High Rate Data Packet Access Network, 11.4.2 Waveform Quality Measurement section.)		
	n=6, 7, 8, 9 are for Overall-1 data trace		
	n=10, 11, 12, 13 are for Overall-2 data trace		
	In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0		

n	Results Returned	
9	The same as n=5. (Overall-1)	
1xEV-DO mode	This trace is available when the Measurement Channel Type Selection is All	
	(CALCulate:RHO:TYPE = ALL)	
	(Rho Overall-1 and Rho Overall-2 as specified in 3GPP2 TSG-C4.1 Recommended Minimum Performance Standard for cdma2000 High Rate Data Packet Access Network, 11.4.2 Waveform Quality Measurement section.)	
	n=6, 7, 8, 9 are for Overall-1 data trace	
	n=10, 11, 12, 13 are for Overall-2 data trace	
	In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0	
10	The same as n=2. (Overall-2)	
1xEV-DO mode	This trace is available when the Measurement Channel Type Selection is All	
	(CALCulate:RHO:TYPE = ALL)	
	(Rho Overall-1 and Rho Overall-2 as specified in 3GPP2 TSG-C4.1 Recommended Minimum Performance Standard for cdma2000 High Rate Data Packet Access Network, 11.4.2 Waveform Quality Measurement section.)	
	n=6, 7, 8, 9 are for Overall-1 data trace	
	n=10, 11, 12, 13 are for Overall-2 data trace	
	In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0	
11 cdmaOne mode	Corrected measured data – returns a series of floating point numbers that alternately represent I and Q pairs of the corrected measured trace data. The magnitude of each I and Q pair are normalized to 1.0.	
	The number of trace points depends on the current setting for the number of displayed I/Q points in the I/Q display.	
	The numbers are sent in the following order:	
	In-phase (I) sample, of symbol 0 decision point Quadrature-phase (Q) sample, of symbol 0 decision point	
	In-phase (I) sample, of symbol 1 decision point Quadrature-phase (Q) sample, of symbol 1 decision point	
	The trace can be interpolated to 2,4,8 points/chip selected with the display Points/Chip softkey. This will change the number of points between decision points in the trace, changing the number of I/Q pairs sent for each decision point.	

n	Results Returned		
11	The same as n=2. (Overall-2)		
1xEV-DO mode	This trace is available when the Measurement Channel Type Selection is All		
	(CALCulate:RHO:TYPE = ALL)		
	(Rho Overall-1 and Rho Overall-2 as specified in 3GPP2 TSG-C4.1 Recommended Minimum Performance Standard for cdma2000 High Rate Data Packet Access Network, 11.4.2 Waveform Quality Measurement section.)		
	n=6, 7, 8, 9 are for Overall-1 data trace		
	n=10, 11, 12, 13 are for Overall-2 data trace		
	In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0		
12	The same as n=4. (Overall-2)		
1xEV-DO mode	This trace is available when the Measurement Channel Type Selection is All		
	(CALCulate:RHO:TYPE = ALL)		
	(Rho Overall-1 and Rho Overall-2 as specified in 3GPP2 TSG-C4.1 Recommended Minimum Performance Standard for cdma2000 High Rate Data Packet Access Network, 11.4.2 Waveform Quality Measurement section.)		
	n=6, 7, 8, 9 are for Overall-1 data trace		
	n=10, 11, 12, 13 are for Overall-2 data trace		
	In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0		

n	Results Returned		
13 cdmaOne mode	complementary filtered measured data – returns a series of floating point numbers that alternately represent I and Q pairs of the complementary filtered measured data. This is inverse filtered data of the inter-symbol interference in CDMA signals due to the digital transmission filters defined in the standard as well as the base station phase equalization filter.		
	The number of trace points depends on the current setting for the number of displayed I/Q points in the I/Q display.		
	The numbers are sent in the following order:		
	In-phase (I) sample, of symbol 0 decision point Quadrature-phase (Q) sample, of symbol 0 decision point		
	In-phase (I) sample, of symbol 1 decision point Quadrature-phase (Q) sample, of symbol 1 decision point		
	The trace can be interpolated to 2,4,8 points/chip selected with the display Points/Chip softkey. This will change the number of points between decision points in the trace, changing the number of I/Q pairs sent for each decision point.		
13	The same as n=5. (Overall-2)		
1xEV-DO mode	This trace is available when the Measurement Channel Type Selection is All		
	(CALCulate:RHO:TYPE = ALL)		
	(Rho Overall-1 and Rho Overall-2 as specified in 3GPP2 TSG-C4.1 Recommended Minimum Performance Standard for cdma2000 High Rate Data Packet Access Network, 11.4.2 Waveform Quality Measurement section.)		
	n=6, 7, 8, 9 are for Overall-1 data trace		
	n=10, 11, 12, 13 are for Overall-2 data trace		
	In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0		

n	Results Returned		
14	The same as n=5. (Overall-2) I/Q trace data is descrambled.		
1xEV-DO mode	This trace is available when the Measurement Channel Type Selection is All		
	(CALCulate:RHO:TYPE = ALL)		
	(Rho Overall-1 and Rho Overall-2 as specified in 3GPP2 TSG-C4.1 Recommended Minimum Performance Standard for cdma2000 High Rate Data Packet Access Network, 11.4.2 Waveform Quality Measurement section.)		
	n=6, 7, 8, 9 are for Overall-1 data trace		
	n=10, 11, 12, 13 are for Overall-2 data trace		
	In all cases, returns one full slot data points, but only portion of EVM computation is performed are valid. All other portion is 0.0		
15 1xEV-DO mode	Returns comma-separated scalar values of the pass/fail (0.0=passed, or 1.0=failed) results determined by testing the EVM, Peak EVM:		
TALLY DO INOUE	 Test result of EVM Test result of Peak EVM Test result of Rho Test result of Frequency Error 		
	The following Timing and Phase results are valid only if Multichannel Estimater is On and with the existence of multiple codes. When the measurement is not valid, the results are 0.0		
	5. Test result of Timing6. Test result of Phase		
	The following Pilot Offset result is valid only if external trigger is selected. When the measurement is not valid, the result is 0.0		
	7. Test result of Pilot Offset		
	The following three results are valid exclusively. When the measurement is not valid, the result is 0.0		
	8. Test result of Max MAC Inactive Channel Power 9. Test result of Max Data Active Channel Power 10. Test result of Min Data Active Channel Power		

Spurious Emissions Measurement

This measures spurious emissions levels up to five pairs of offset/region frequencies and relates them to the carrier power. You must be in the cdma2000, W-CDMA or 1xEV-DO mode to use these commands. Use INSTrument:SELect to set the mode. For 1xEV-DO mode, this command will return spurious emissions measurements or adjacent channel power measurements, depending on which setting is selected using SENSe:SEMask:SEGMent:TYPE ACPr|SEMask.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:SEMask commands for more measurement related commands.

:CONFigure:SEMask

:INITiate:SEMask

:FETCh:SEMask[n]?

:READ:SEMask[n]?

:MEASure:SEMask[n]?

Front Panel

Access: Measure, Spectrum Emission Mask

After the measurement is selected, press Restore Meas

Defaults to restore factory defaults.

Measurement Results Available

Measurement Type	n	Results Returned
	0	Returns unprocessed I/Q trace data, as a series of trace point values, in volts.

Measurement Type	n	Results Returned
Total power reference	n=1 (or not specified)	Returns 60 scalar results, in the following order: 1. Reserved for future use, returns – 999.0 2. Absolute power at the center frequency (reference) area (dBm) 3. Reserved for future use, returns – 999.0 4. Reserved for future use, returns – 999.0 5. Peak frequency in the center frequency (reference) area (Hz) 6. Reserved for future use, returns – 999.0 7. Reserved for future use, returns – 999.0 8. Reserved for future use, returns – 999.0 9. Reserved for future use, returns – 999.0 10. Reserved for future use, returns – 999.0 11. Relative power on the negative offset A (dBc) 12. Absolute power on the negative offset A (dBm) 13. Relative peak power on the negative offset A (dBm) 15. Peak frequency in the negative offset A (dBm) 15. Peak frequency in the positive offset A (dBm) 16. Relative power on the positive offset A (dBm) 17. Absolute peak power on the positive offset A (dBm) 18. Relative peak power on the positive offset A (dBm) 20. Peak frequency in the positive offset A (dBm) 21. Relative power on the negative offset B (dBc) 12. Absolute peak power on the positive offset A (dBm) 22. Peak frequency in the positive offset E (Hz) When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.

Measurement Type	n	Results Returned
Power spectral density reference	n=1 (or not specified)	Returns 60 scalar results, in the following order: 1. Reserved for future use, returns – 999.0 2. Absolute power at the center frequency (reference) area (dBm) 3. Reserved for future use, returns – 999.0 4. Reserved for future use, returns – 999.0 5. Peak frequency in the center frequency (reference) area (Hz) 6. Reserved for future use, returns – 999.0 7. Reserved for future use, returns – 999.0 8. Reserved for future use, returns – 999.0 9. Reserved for future use, returns – 999.0 10. Reserved for future use, returns – 999.0 11. Relative power on the negative offset A (dB) 12. Absolute power on the negative offset A (dBm/Hz) 13. Relative peak power on the negative offset A (dBm/Hz) 15. Peak frequency in the negative offset A (dB) 16. Relative power on the positive offset A (dBm/Hz) 17. Absolute power on the positive offset A (dBm/Hz) 18. Relative peak power on the positive offset A (dBm/Hz) 19. Absolute peak power on the positive offset A (dBm/Hz) 20. Peak frequency in the positive offset B (dB) 1. Absolute peak power on the positive offset B (dBm/Hz)
		2. Peak frequency in the positive offset E (Hz) When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.
	2	Returns the displayed frequency domain spectrum trace data separated by comma. The number of data is 2001 when DISPlay:SEMask:VIEW is set to ALL.
	3	Returns the displayed frequency domain absolute limit trace data separated by comma. The number of data is 2001 when DISPlay:SEMask:VIEW is set to ALL.
	4	Returns the displayed frequency domain relative limit trace data separated by comma. The number of data is 2001 when DISPlay:SEMask:VIEW is set to ALL.

Measurement Type	n	Results Returned
Total power reference	5	Returns 12 scalar values (in dBm) of the absolute power of the segment frequencies:
		 Total power reference (dBm), for cdma2000 and W-CDMA Reserved for future use, returns – 999.0, for 1xEV-DO Reserved for future use, returns – 999.0 Negative offset frequency (A) or region (A) Positive offset frequency (A)
		• • •
		 Negative offset frequency (E) or region (E) Positive offset frequency (E)
		When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.
Power spectral density	5	Returns 12 scalar values (in dBm/Hz) of the absolute power of the segment frequencies:
reference		 Power spectral density reference (dBm/Hz), for cdma2000 and W-CDMA Reserved for future use, returns – 999.0, for 1xEV-DO Reserved for future use, returns – 999.0 Negative offset frequency (A) or region (A) Positive offset frequency (A)
		•••
		 Negative offset frequency (E) or region (E) Positive offset frequency (E)
		When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.
Total power reference	6	Returns 12 scalar values (in dBc) of the power relative to the carrier at the segment frequencies:
		 Reserved for future use, returns – 999.0 Reserved for future use, returns – 999.0 Negative offset frequency (A) or region (A) Positive offset frequency (A)
		• • • •
		 Negative offset frequency (E) or region (E) Positive offset frequency (E)
		When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.

Measurement Type	n	Results Returned
Power spectral density	6	Returns 12 scalar values (in dBc) of the power relative to the carrier at the segment frequencies:
reference		 Reserved for future use, returns – 999.0 Reserved for future use, returns – 999.0 Negative offset frequency (A) or region (A) Positive offset frequency (A)
		• • •
		 Negative offset frequency (E) or region (E) Positive offset frequency (E)
		When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.
	7	Returns 12 pass/fail test results (0 = passed, or 1 = failed) determined by testing the absolute power of the segment frequencies:
		 Reserved for future use, returns – 999.0 Reserved for future use, returns – 999.0 Negative offset frequency (A) or region (A) Positive offset frequency (A)
		 Negative offset frequency (E) or region (E) Positive offset frequency (E)
		When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.
	8	Returns 12 scalar values of the pass/fail (0=passed, or 1=failed) results determined by testing the power relative to the segment frequencies:
		 Reserved for future use, returns – 999.0 Reserved for future use, returns – 999.0 Negative offset frequency (A) or region (A) Positive offset frequency (A)
		Negative offset frequency (E) or region (E)
		2. Positive offset frequency (E)
		When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.

Measurement Type	n	Results Returned
	9	Returns 12 scalar values of frequency (in Hz) that have peak power in each offset/region:
		 Reserved for future use, returns – 999.0 Reserved for future use, returns – 999.0 Negative offset frequency (A) or region (A) Positive offset frequency (A)
		•••
		 Negative offset frequency (E) or region (E) Positive offset frequency (E)
		When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.
	10	Returns 12 scalar values (in dBm) of the absolute peak power of the segment frequencies:
		 Reserved for future use, returns – 999.0 Reserved for future use, returns – 999.0 Negative offset frequency (A) or region (A) Positive offset frequency (A)
		 Negative offset frequency (E) or region (E) Positive offset frequency (E)
		When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.
	11	Returns 12 scalar values (in dBc) of the peak power relative to the carrier at the segment frequencies:
		 Reserved for future use, returns – 999.0 Reserved for future use, returns – 999.0 Negative offset frequency (A) or region (A) Positive offset frequency (A)
		 Negative offset frequency (E) or region (E) Positive offset frequency (E)
		When [:SENSe]:SEMask:SEGMent is set to REGion, the positive offsets are not available and return – 999.0.

Spectrum (Frequency Domain) Measurement

For E4406A this measures the amplitude of your input signal with respect to the frequency. It provides spectrum analysis capability using FFT (fast Fourier transform) measurement techniques. You must select the appropriate mode using INSTrument:SELect, to use these commands.

For PSA this measures the amplitude of your input signal with respect to the frequency. It provides spectrum analysis capability using FFT (fast Fourier transform) measurement techniques. You must be in the Basic, cdmaOne, cdma2000, 1xEV-DO, W-CDMA, GSM (w/EDGE), NADC, or PDC mode to use these commands. Use INSTrument:SELect, to select the mode.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:SPECtrum commands for more measurement related commands.

:CONFigure:SPECtrum

:INITiate:SPECtrum

:FETCh:SPECtrum[n]?

:READ:SPECtrum[n]?

:MEASure:SPECtrum[n]?

Front Panel

Access: Measure, Spectrum (Freq Domain)

After the measurement is selected, press Restore Meas

Defaults to restore factory defaults.

Measurement Results Available

n	Results Returned
0	Returns unprocessed I/Q trace data, as a series of trace point values, in volts. The I values are listed first in each pair, using the 0 through even-indexed values. The Q values are the odd-indexed values.

n	Results Returned						
n=1 (or not	Returns the following scalar results:						
specified)	1. FFT peak is the FFT peak amplitude.						
	2. FFT frequency is the FFT frequency of the peak amplitude.						
	3. FFT points is the Number of points in the FFT spectrum.						
	4. First FFT frequency is the frequency of the first FFT point of the spectrum.						
	5. FFT spacing is the frequency spacing between the FFT points of the spectrum.						
	6. Time domain points is the number of points in the time domain trace used for the FFT. The number of points doubles if the data is complex instead of real. See the time domain scaler description below.						
	7. First time point is the time of the first time domain point, where time zero is the trigger event.						
	8. Time spacing is the time spacing between the time domain points. The time spacing value doubles if the data is complex instead of real. See the time domain scaler description below.						
	9. Time domain returns a 1 if time domain is complex (I/Q) and complex data will be returned. It returns a 0 if the data is real. (raw ADC samples) When this value is 1 rather than 0 (complex vs. real data), the time domain points and the time spacing scalers both increase by a factor of two.						
	10. Scan time is the total scan time of the time domain trace used for the FFT. The total scan time = (time spacing) X (time domain points -1)						
	11. Current average count is the current number of data measurements that have already been combined, in the averaging calculation.						
2, Service mode only	Returns the trace data of the log-magnitude versus time. (That is, the RF envelope.)						
3	Returns the I and Q trace data. It is represented by I and Q pairs (in volts) versus time.						
4	Returns spectrum trace data. That is, the trace of log-magnitude versus frequency. (The trace is computed using a FFT.)						
5, Service mode only	Returns the averaged trace data of log-magnitude versus time. (That is, the RF envelope.)						
6	Not used.						
7	Returns the averaged spectrum trace data. That is, the trace of the averaged log-magnitude versus frequency.						
8	Not used.						
9, Service mode only	Returns a trace containing the shape of the FFT window.						

n	Results Returned
10, Service mode only	Returns trace data of the phase of the FFT versus frequency.
11, cdma2000, 1xEV-DO, W-CDMA, Basic modes only	Returns linear spectrum trace data values in Volts RMS.
12, cdma2000, 1xEV-DO, W-CDMA, Basic modes only	Returns averaged linear spectrum trace data values in Volts RMS.

Waveform (Time Domain) Measurement

For E4406A this measures the amplitude of your input signal with respect to the frequency. It provides spectrum analysis capability using FFT (fast Fourier transform) measurement techniques. You must select the appropriate mode using INSTrument:SELect, to use these commands.

For PSA this measures the amplitude of your input signal with respect to the frequency. It provides spectrum analysis capability using FFT (fast Fourier transform) measurement techniques. You must be in the Basic, cdmaOne, cdma2000, 1xEV-DO, W-CDMA, GSM (w/EDGE), NADC, or PDC mode to use these commands. Use INSTrument:SELect, to select the mode.

The general functionality of CONFigure, FETCh, MEASure, and READ are described at the beginning of this section. See the SENSe:WAVeform commands for more measurement related commands.

:CONFigure:WAVeform

:INITiate:WAVeform

:FETCh:WAVeform[n]?

:READ:WAVeform[n]?

:MEASure:WAVeform[n]?

Front Panel

Access: Measure, Waveform (Time Domain)

After the measurement is selected, press Restore Meas

Defaults to restore factory defaults.

Measurement Results Available

n	Results Returned					
0 (see also 5)	Returns unprocessed I/Q trace data, as a series of trace point values, in volts. The I values are listed first in each pair, using the 0 through even-indexed values. The Q values are the odd-indexed values.					
n=1 (or not	Returns the following scalar results:					
specified)	1. Sample time is a floating point number representing the time between samples when using the trace queries (n=0,2,etc).					
	2. Mean power is the mean power (in dBm). This is either the power across the entire trace, or the power between markers if the markers are enabled. If averaging is on, the power is for the latest acquisition.					
	3. Mean power averaged is the power (in dBm) for N averages, if averaging is on. This is either the power across the entire trace, or the power between markers if the markers are enabled. If averaging is on, the power is for the latest acquisition. If averaging is off, the value of the mean power averaged is the same as the value of the mean power.					
	4. Number of samples is the number of data points in the captured signal. This number is useful when performing a query on the signal (i.e. when n=0,2,etc.).					
	5. Peak-to-mean ratio has units of dB. This is the ratio of the maximum signal level to the mean power. Valid values are only obtained with averaging turned off. If averaging is on, the peak-to-mean ratio is calculated using the highest peak value, rather than the displayed average peak value.					
	6. Maximum value is the maximum of the most recently acquired data (in dBm).					
	7. Minimum value is the minimum of the most recently acquired data (in dBm).					
2	Returns trace point values of the entire captured signal envelope trace data. These data points are floating point numbers representing the power of the signal (in dBm). There are N data points, where N is the number of samples . The period between the samples is defined by the sample time .					
3, Option B7C with cdma2000, W-CDMA, Basic modes only (E4406A only)	Returns magnitude values of the time data in Volts peak.					
4, Option B7C with cdma2000, W-CDMA, Basic modes only (E4406A only)	Returns values of phase data in degrees.					

READ Subsystem

The READ? commands are used with several other commands and are documented in the section on the "MEASure Group of Commands" on page 311.

Initiate and Read Measurement Data

:READ:<measurement>[n]?

A READ? query must specify the desired measurement. It will cause a measurement to occur without changing any of the current settings and will return any valid results. The code number n selects the kind of results that will be returned. The available measurements and data results are described in the "MEASure Group of Commands" on page 311.

SENSe Subsystem

These commands are used to set the instrument state parameters so that you can measure a particular input signal. Some SENSe commands are only for use with specific measurements found under the MEASURE key menu or the "MEASure Group of Commands" on page 311. The measurement must be active before you can use these commands.

The SCPI default for the format of any data output is ASCII. The format can be changed to binary with FORMat:DATA which transports faster over the bus.

Adjacent Channel Power Measurement

Commands for querying the adjacent channel power measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after the ACP or ACPR measurement has been selected from the MEASURE key menu.

Adjacent Channel Power—Average Count

[:SENSe]:ACP:AVERage:COUNt <integer>

[:SENSe]:ACP:AVERage:COUNt?

Set the number of data acquisitions that will be platform averaged. After the specified number of average counts, the average mode (termination control) setting determines the average action.

Factory Preset: 10 for cdma2000, W-CDMA

20 for Basic, cdmaOne, iDEN (E4406A)

Range: 1 to 10,000

Remarks: Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup

Adjacent Channel Power—Averaging State

[:SENSe]:ACP:AVERage[:STATe] OFF ON 0 1

[:SENSe]:ACP:AVERage[:STATe]?

Turn the averaging function On or Off.

Factory Preset: On

Off for iDEN mode (E4406A)

Remarks: Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup

Adjacent Channel Power—Averaging Termination Control

```
[:SENSe]:ACP:AVERage:TCONtrol EXPonential | REPeat
```

```
[:SENSe]:ACP:AVERage:TCONtrol?
```

Select the type of termination control used for averaging. This determines the averaging action after the specified number of data acquisitions (average count) is reached.

EXPonential – Each successive data acquisition after the average count is reached, is exponentially weighted and combined with the existing average.

REPeat – After reaching the average count, the averaging is reset and a new average is started.

Factory Preset: REPeat for PSA cdmaOne, cdma2000, W-CDMA

REPeat for E4406A Basic, cdmaOne, cdma2000,

W-CDMA

EXPonential for E4406A iDEN

EXPonential for NADC, PDC

Remarks: Use INSTrument:SELect to set the mode.

Adjacent Channel Power—Carrier Channel BW

Basic, iDEN mode (E4406A)

```
[:SENSe]:ACP:BANDwidth|BWIDth:INTegration <freq>
```

[:SENSe]:ACP:BANDwidth|BWIDth:INTegration?

cdma2000, W-CDMA mode

[:SENSe]:ACP:BANDwidth[n] | BWIDth[n]:INTegration < freq>

[:SENSe]:ACP:BANDwidth[n] | BWIDth[n]:INTegration?

cdmaOne mode

[:SENSe]:ACP:BANDwidth[n] | BWIDth[n]:INTegration[m] < freq>

[:SENSe]:ACP:BANDwidth[n] | BWIDth[n]:INTegration[m]?

Set the Integration bandwidth that will be used for the main (carrier) channel.

BANDwidth[n] | BWIDth[n]: m=1 is base station and 2 is mobiles. The default is base station (1).

INTegration[n]: m=1 is cellular bands and 2 is pcs bands. The default is cellular.

Factory Preset:

Mode	Format (Modulation Standard)				
Basic (E4406A)	1.23 MHz				
cdmaOne	1.23 MHz				
iDEN (E4406A)	18 kHz				
cdma2000	1.23 MHz				
W-CDMA	3.84 MHz				

Range: 300 Hz to 20 MHz for Basic (E4406A), cdmaOne,

cdma2000, or W-CDMA mode

1 kHz to 5 MHz for iDEN (E4406A)

Default Unit: Hz

Remarks: With measurement type set at (TPR) total power

reference, 1.40 MHz is sometimes used. Using

1.23 MHz will give a power that is very nearly identical to the 1.40 MHz value, and using 1.23 MHz will also

yield the correct power spectral density with

measurement type set at (PSD) reference. However, a setting of 1.40 MHz will not give the correct results

with measurement type set at PSD reference.

For PSA you must be in cdmaOne, cdma2000, or

W-CDMA mode to use this command. Use INSTrument:SELect to set the mode.

For E4406A you must be in Basic, cdmaOne, cdma2000, W-CDMA, or iDEN mode to use this command. Use

INSTrument: SELect to set the mode.

Adjacent Channel Power—Absolute Amplitude Limits

iDEN mode (E4406A)

[:SENSe]:ACP:OFFSet:ABSolute <power>

[:SENSe]:ACP:OFFSet:ABSolute?

Basic (E4406A), cdmaOne mode

[:SENSe]:ACP:OFFSet:LIST:ABSolute

<power>,<power>,<power>,<power>,<power>

[:SENSe]:ACP:OFFSet:LIST:ABSolute?

cdma2000, W-CDMA mode

[:SENSe]:ACP:OFFSet[n]:LIST:ABSolute
<power>,<power>,<power>,<power>,<power>,<power>,

[:SENSe]:ACP:OFFSet[n]:LIST:ABSolute?

Sets the absolute amplitude levels to test against for each of the custom offsets. The list must contain five (5) entries. If there is more than one offset, the offset closest to the carrier channel is the first one in the list. [:SENSe]:ACP:OFFSet[n]:LIST[m]:TEST selects the type of testing to be done at each offset.

You can turn off (not use) specific offsets with the [:SENSe]:ACP:OFFSet[n]:LIST:STATe command.

The query returns the five (5) sets of the real numbers that are the current absolute amplitude test limits.

Offset[n] n=1 is base station and 2 is mobiles. The default is base

station (1).

List[n] m=1 is cellular bands and 2 is pcs bands. The default is

cellular.

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
Basic (E4406A)		0 dBm				
cdmaOne	BS cellular	0 dBm				
	BS pcs	0 dBm	– 13 dBm	– 13 dBm	0 dBm	0 dBm
	MS cellular	0 dBm				
	MS pcs	0 dBm	– 13 dBm	– 13 dBm	0 dBm	0 dBm
cdma2000		50 dBm				
W-CDMA		50 dBm				
iDEN (E4406A)		0 dBm	n/a	n/a	n/a	n/a

Range: -200.0 dBm to 50.0 dBm

Default Unit: dBm

Remarks: For PSA you must be in cdmaOne, cdma2000, or

W-CDMA mode to use this command. Use

INSTrument:SELect to set the mode.

For E4406A you must be in Basic, cdmaOne, cdma2000, W-CDMA, or iDEN mode to use this command. Use INSTrument:SELect to set the mode.

Adjacent Channel Power-Define Resolution Bandwidth List

iDEN mode (E4406A)

[:SENSe]:ACP:OFFSet:BANDwidth|BWIDth <res_bw>

[:SENSe]:ACP:OFFSet:BANDwidth | BWIDth?

Basic mode (E4406A)

[:SENSe]:ACP:OFFSet:LIST:BANDwidth|BWIDth
<res bw>,<res bw>,<res bw>,<res bw>,

[:SENSe]:ACP:OFFSet:LIST:BANDwidth | BWIDth?

cdma2000, W-CDMA mode

[:SENSe]:ACP:OFFSet[n]:LIST:BANDwidth | BWIDth
<res bw>,<res bw>,<res bw>,<res bw>,

[:SENSe]:ACP:OFFSet[n]:LIST:BANDwidth|BWIDth?

cdmaOne mode

[:SENSe]:ACP:OFFSet[n]:LIST[n]:BANDwidth|BWIDth
<res_bw>,<res_bw>,<res_bw>,<res_bw>,

[:SENSe]:ACP:OFFSet[n]:LIST[n]:BANDwidth|BWIDth?

Define the custom resolution bandwidth(s) for the adjacent channel power testing. If there is more than one bandwidth, the list must contain five (5) entries. Each resolution bandwidth in the list corresponds to an offset frequency in the list defined by [:SENSe]:ACP:OFFSet[n]:LIST[n][:FREQuency]. You can turn off (not use) specific offsets with the [:SENSe]:ACP:OFFSet[n]:LIST[n]:STATe command.

Offset[n] n=1 is base station and 2 is mobiles. The default is base

station (1).

List[n] n=1 is cellular bands and 2 is pcs bands. The default is

cellular.

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
iDEN (E4406A)		10 kHz	n/a	n/a	n/a	n/a

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
Basic (E4406A)		30 kHz				
cdmaOne	BS cellular	30 kHz				
	BS pcs	30 kHz	12.5 kHz	1 MHz	30 kHz	30 kHz
	MS cellular	30 kHz				
	MS pcs	30 kHz	12.5 kHz	1 MHz	30 kHz	30 kHz
cdma2000		30 kHz				
W-CDMA		3.84 MHz				

Range: 300 Hz to 20 MHz for cdmaOne, Basic, cdma2000,

W-CDMA mode

1 kHz to 5 MHz for iDEN mode (E4406A)

Default Unit: Hz

Remarks: For PSA you must be in cdmaOne, cdma2000, or

W-CDMA mode to use this command. Use INSTrument:SELect to set the mode.

For E4406A you must be in Basic, cdmaOne, cdma2000, W-CDMA, or iDEN mode to use this command. Use

INSTrument:SELect to set the mode.

Adjacent Channel Power—Define Offset Frequency List

```
iDEN mode (E4406A)
```

```
[:SENSe]:ACP:OFFSet[:FREQuency] <f offset>
```

[:SENSe]:ACP:OFFSet[:FREQuency]?

Basic mode (E4406A)

```
[:SENSe]:ACP:OFFSet:LIST[:FREQuency]
```

<f_offset>,<f_offset>,<f_offset>,<f_offset>

[:SENSe]:ACP:OFFSet:LIST[:FREQuency]?

cdma2000, W-CDMA mode

[:SENSe]:ACP:OFFSet[n]:LIST[:FREQuency]

<f_offset>,<f_offset>,<f_offset>,<f_offset>,<f_offset>

[:SENSe]:ACP:OFFSet[n]:LIST[:FREQuency]?

cdmaOne mode

[:SENSe]:ACP:OFFSet[n]:LIST[n][:FREQuency]

<f_offset>,<f_offset>,<f_offset>,<f_offset>

[:SENSe]:ACP:OFFSet[n]:LIST[n][:FREQuency]?

Define the custom set of offset frequencies at which the switching transient spectrum part of the ACP measurement will be made. The list contains five (5) entries for offset frequencies. Each offset frequency in the list corresponds to a reference bandwidth in the bandwidth list.

An offset frequency of zero turns the display of the measurement for that offset off, but the measurement is still made and reported. You can turn off (not use) specific offsets with the [:SENSe]:ACP:OFFSet:LIST:STATe command.

Offset[n] n=1 is base station and 2 is mobiles. The default is base

station (1).

List[n] n=1 is cellular bands and 2 is pcs bands. The default is

cellular.

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
iDEN (E4406A)		25 kHz	n/a	n/a	n/a	n/a
Basic (E4406A)		750 kHz	1.98 MHz	0 Hz	0 Hz	0 Hz
cdmaOne	BS cellular	750 kHz	1.98 MHz	0 Hz	0 Hz	0 Hz
	BS pcs	885 kHz	1.25625 MHz	2.75 MHz	0 Hz	0 Hz
	MS cellular	885 kHz	1.98 MHz	0 Hz	0 Hz	0 Hz
	MS pcs	1.265 MHz	0 Hz	0 Hz	0 Hz	0 Hz
cdma2000	BTS	750 kHz	1.98 MHz	0 Hz	0 Hz	0 Hz
	MS	885 kHz	1.98 MHz	0 Hz	0 Hz	0 Hz
W-CDMA		5 MHz	10 MHz	15 MHz	20 MHz	25 MHz

Range: 0 Hz to 45 MHz for cdmaOne

0 Hz to 20 MHz for iDEN, Basic (E4406A)

0 Hz to 100 MHz for cdma2000, W-CDMA

Default Unit: Hz

Remarks: For PSA you must be in cdmaOne, cdma2000, or

W-CDMA mode to use this command. Use

INSTrument:SELect to set the mode.

For E4406A you must be in Basic, cdmaOne, cdma2000, W-CDMA, or iDEN mode to use this command. Use

INSTrument:SELect to set the mode.

Adjacent Channel Power—Amplitude Limits Relative to the Carrier

```
iDEN mode (E4406A)
[:SENSe]:ACP:OFFSet:RCARrier <rel_power>
[:SENSe]:ACP:OFFSet:RCARrier?

Basic mode (E4406A)
[:SENSe]:ACP:OFFSet:LIST:RCARrier
<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>
[:SENSe]:ACP:OFFSet:LIST:RCARrier?

cdma2000, W-CDMA mode
[:SENSe]:ACP:OFFSet[n]:LIST:RCARrier
<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>
[:SENSe]:ACP:OFFSet[n]:LIST:RCARrier?

cdmaOne mode
[:SENSe]:ACP:OFFSet[n]:LIST[n]:RCARrier
<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>,
```

Sets the amplitude levels to test against for any custom offsets. This amplitude level is relative to the carrier amplitude. If multiple offsets are available, the list contains five (5) entries. The offset closest to the carrier channel is the first one in the list.

[:SENSe]:ACP:OFFSet[n]:LIST[n]:TEST selects the type of testing to be done at each offset.

You can turn off (not use) specific offsets with the [:SENSe]:ACP:OFFSet[n]:LIST[n]:STATe command.

The query returns the five (5) sets of the real numbers that are the current amplitude test limits, relative to the carrier, for each offset.

Offset[n] n=1 is base station and 2 is mobiles. The default is base

station (1).

List[n] n=1 is cellular bands and 2 is pcs bands. The default is

cellular.

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
iDEN (E4406A)		0 dBc	n/a	n/a	n/a	n/a
Basic (E4406A)		– 45 dBc	- 60 dBc	0 dBc	0 dBc	0 dBc
cdmaOne	BS cellular	– 45 dBc	- 60 dBc	0 dBc	0 dBc	0 dBc
	BS pcs	– 45 dBc	0 dBc	0 dBc	0 dBc	0 dBc
	MS cellular	- 42 dBc	- 54 dBc	0 dBc	0 dBc	0 dBc
	MS pcs	- 42 dBc	0 dBc	0 dBc	0 dBc	0 dBc
cdma2000		0 dBc				
W-CDMA	BTS	– 44.2 dBc	- 49.2 dBc	– 49.2 dBc	– 49.2 dBc	- 49.2 dBc
	MS	- 32.2 dBc	- 42.2 dBc	- 42.2 dBc	- 42.2 dBc	- 42.2 dBc

Range: - 150.0 dB to 50.0 dB for cdmaOne, cdma2000,

W-CDMA, Basic (E4406A)

- 200.0 dB to 50.0 dB for iDEN (E4406A)

Default Unit: dB

Remarks: For PSA you must be in cdmaOne, cdma2000, or

W-CDMA mode to use this command. Use INSTrument:SELect to set the mode.

For E4406A you must be in Basic, cdmaOne, cdma2000, W-CDMA, or iDEN mode to use this command. Use

INSTrument:SELect to set the mode.

Adjacent Channel Power—Amplitude Limits Relative to the Power Spectral Density

iDEN mode (E4406A)

[:SENSe]:ACP:OFFSet:RPSDensity <rel power>

[:SENSe]:ACP:OFFSet:RPSDensity?

Basic mode (E4406A)

[:SENSe]:ACP:OFFSet:LIST:RPSDensity

<rel power>,<rel power>,<rel power>,<rel power>,<rel power>

[:SENSe]:ACP:OFFSet:LIST:RPSDensity?

cdma2000, W-CDMA mode

[:SENSe]:ACP:OFFSet[n]:LIST:RPSDensity

<rel_power>,<rel_power>,<rel_power>,<rel_power>,<rel_power>

[:SENSe]:ACP:OFFSet[n]:LIST:RPSDensity?

cdmaOne mode

[:SENSe]:ACP:OFFSet[n]:LIST[n]:RPSDensity

<rel power>,<rel power>,<rel power>,<rel power>,<rel power>

[:SENSe]:ACP:OFFSet[n]:LIST[n]:RPSDensity?

Sets the amplitude levels to test against for any custom offsets. This amplitude level is relative to the power spectral density. If multiple offsets are available, the list contains five (5) entries. The offset closest to the carrier channel is the first one in the list.

[:SENSe]:ACP:OFFSet[n]:LIST[n]:TEST selects the type of testing to be done at each offset.

You can turn off (not use) specific offsets with the [:SENSe]:ACP:OFFSet[n]:LIST:STATe command.

The query returns the five (5) sets of the real numbers that are the current amplitude test limits, relative to the power spectral density, for each offset.

Offset[n] n=1 is base station and 2 is mobiles. The default is base

station (1).

List[n] n=1 is cellular bands and 2 is pcs bands. The default is

cellular.

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
iDEN (E4406A)		0 dB	n/a	n/a	n/a	n/a
Basic (E4406A)		- 28.87 dB	- 43.87 dB	0 dB	0 dB	0 dB
cdmaOne	BS cellular	- 28.87 dB	- 43.87 dB	0 dB	0 dB	0 dB
	BS pcs	- 28.87 dB	0 dB	0 dB	0 dB	0 dB
	MS cellular	– 25.87 dB	- 37.87 dB	0 dB	0 dB	0 dB
	MS pcs	- 25.87 dB	0 dB	0 dB	0 dB	0 dB
cdma2000		0 dB	0 dB	0 dB	0 dB	0 dB
W-CDMA	BTS	- 44.2 dBc	- 49.2 dBc	- 49.2 dBc	- 49.2 dBc	– 49.2 dBc
	MS	- 32.2 dBc	- 42.2 dBc	- 42.2 dBc	- 42.2 dBc	– 42.2 dBc

Range: - 150.0 dB to 50.0 dB for cdmaOne, Basic, cdma2000,

W-CDMA

- 200.0 dB to 50.0 dB for iDEN (E4406A)

Default Unit: dB

Remarks: For PSA you must be in cdmaOne, cdma2000, or

W-CDMA mode to use this command. Use INSTrument:SELect to set the mode.

For E4406A you must be in Basic, cdmaOne, cdma2000, W-CDMA, or iDEN mode to use this command. Use

INSTrument:SELect to set the mode.

Adjacent Channel Power—Control Offset Frequency List

Basic mode (E4406A)

```
[:SENSe]:ACP:OFFSet:LIST:STATE OFF |ON|0|1, OFF |ON|0|1, OFF |ON|0|1, OFF |ON|0|1, OFF |ON|0|1 [:SENSe]:ACP:OFFSet:LIST:STATE?
```

cdma2000, W-CDMA mode

```
[:SENSe]:ACP:OFFSet[n]:LIST:STATe OFF|ON|0|1, OFF|ON|0|1, OFF|ON|0|1, OFF|ON|0|1, OFF|ON|0|1
```

```
[:SENSe]:ACP:OFFSet[n]:LIST:STATe?
```

 $cdmaOne\ mode$

```
[:SENSe]:ACP:OFFSet[n]:LIST[n]:STATe OFF|ON|0|1, OFF|ON|0|1, OFF|ON|0|1, OFF|ON|0|1, OFF|ON|0|1
```

```
[:SENSe]:ACP:OFFSet[n]:LIST[n]:STATe?
```

Selects whether testing is to be done at the custom offset frequencies. The measured powers are tested against the absolute values defined with [:SENSe]:ACP:OFFSet:LIST:ABSolute, or the relative values defined with [:SENSe]:ACP:OFFSet:LIST:RPSDensity and [:SENSe]:ACP:OFFSet:LIST:RCARier.

Offset[n] n=1 is base station and 2 is mobiles. The default is base

station (1).

List[n] n=1 is cellular bands and 2 is pcs bands. The default is

cellular.

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
Basic (E4406A)		On	On	On	On	On
cdmaOne	BS cellular	On	On	On	On	On
	BS pcs	On	On	On	On	On
	MS cellular	On	On	On	On	On
	MS pcs	On	On	On	On	On
cdma2000		On	On	Off	Off	Off
W-CDMA		On	On	Off	Off	Off

Remarks: For PSA and E4406A you must be in Basic (E4406A),

cdmaOne, cdma2000, or W-CDMA mode to use this command. Use INSTrument:SELect to set the mode.

Adjacent Channel Power—Define Type of Offset Frequency List

```
iDEN mode (E4406A)
```

```
[:SENSe]:ACP:OFFSet:TEST ABSolute AND OR RELative
```

[:SENSe]:ACP:OFFSet:TEST?

Basic mode (E4406A)

```
[:SENSe]:ACP:OFFSet:LIST:TEST ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative
```

[:SENSe]:ACP:OFFSet:LIST:TEST?

cdma2000, W-CDMA mode

```
\label{eq:constraints} \begin{tabular}{ll} $[:SENSe]: ACP: OFFSet $[n]: LIST: TEST $$ ABSolute $|AND|OR|RELative, $$ ABSOL
```

[:SENSe]:ACP:OFFSet[n]:LIST:TEST?

cdmaOne mode

```
[:SENSe]:ACP:OFFSet[n]:LIST[n]:TEST,
```

ABSolute AND OR RELative,

ABSolute AND OR RELative, ABSolute AND OR RELative,

ABSolute AND OR RELative

[:SENSe]:ACP:OFFSet[n]:LIST[n]:TEST?

Defines the type of testing to be done at any custom offset frequencies.

The measured powers are tested against the absolute values defined with [:SENSe]:ACP:OFFSet[n]:LIST:ABSolute, or the relative values defined with [:SENSe]:ACP:OFFSet:LIST:RPSDensity and [:SENSe]:ACP:OFFSet:LIST:RCARrier.

You can turn off (not use) specific offsets with the [:SENS]:ACP:OFFSet:LIST:STATe command.

Offset[n] n=1 is base station and 2 is mobiles. The default is base

station (1).

List[n] n=1 is cellular bands and 2 is pcs bands. The default is

cellular.

The types of testing that can be done for each offset include:

• Absolute - Test the absolute power measurement. If it fails, then return a failure for the measurement at this offset.

- And Test both the absolute power measurement and the power relative to the carrier. If they both fail, then return a failure for the measurement at this offset.
- Or Test both the absolute power measurement and the power relative to the carrier. If either one fails, then return a failure for the measurement at this offset.
- Relative Test the power relative to the carrier. If it fails, then return a failure for the measurement at this offset.
- OFF Turns the power test off.

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
iDEN (E4406A)		REL	n/a	n/a	n/a	n/a
Basic (E4406A)		REL	REL	REL	REL	REL
cdmaOne	BS cellular	REL	REL	REL	REL	REL
	BS pcs	REL	ABS	ABS	REL	REL
	MS cellular	REL	REL	REL	REL	REL
	MS pcs	REL	ABS	ABS	REL	REL
cdma2000		REL	REL	REL	REL	REL
W-CDMA		REL	REL	REL	REL	REL

Remarks: For PSA you must be in cdmaOne, cdma2000, or

W-CDMA mode to use this command. Use

INSTrument:SELect to set the mode.

For E4406A you must be in Basic, cdmaOne, cdma2000,

W-CDMA, or iDEN mode to use this command. Use INSTrument:SELect to set the mode.

Adjacent Channel Power—Sweep Mode Resolution Bandwidth

[:SENSe]:ACP:SWEep:BANDwidth|BWIDth[:RESolution] <freq>

[:SENSe]:ACP:SWEep:BANDwidth|BWIDth[:RESolution]?

Sets the resolution bandwidth when using the spectrum analyzer type sweep mode. See [:SENSe]:ACP:SWEep:TYPE.

Factory Preset: Auto coupled.

Range: 1.0 kHz to 1.0 MHz

Resolution: 1.0 kHz Step Size: 1.0 kHz

Default Unit: Hz

Remarks: You must be in the cdmaOne cdma2000, or W-CDMA

mode to use this command. Use INSTrument:SELect to

set the mode.

Adjacent Channel Power—Sweep Mode Resolution BW Control

[:SENSe]:ACP:SWEep:BANDwidth|BWIDth[:RESolution]:AUTO OFF|ON|0|1

[:SENSe]:ACP:SWEep:BANDwidth|BWIDth[:RESolution]:AUTO?

Sets the resolution bandwidth to automatic, when using the spectrum analyzer type sweep mode. See [:SENSe]:ACP:SWEep:TYPE.

Factory Preset: ON

Remarks: You must be in the cdmaOne cdma2000, or W-CDMA

mode to use this command. Use INSTrument:SELect to

set the mode.

Adjacent Channel Power—Sweep Mode Detection

[:SENSe]:ACP:SWEep:DETector[:FUNCtion] AAVerage POSitive

[:SENSe]:ACP:SWEep:DETector[:FUNCtion]?

Selects the detector type when using the sweep mode. See

[:SENSe]:ACP:SWEep:TYPE.

Absolute average (AAVerage) - the absolute average power in each frequency is measured across the spectrum

Positive - the positive peak power in each frequency is measured across the spectrum

Factory Preset: POSitive

Remarks: You must be in the cdma2000, or W-CDMA mode to use

this command. Use INSTrument:SELect to set the

mode.

Adjacent Channel Power—Sweep Time

[:SENSe]:ACP:SWEep:TIME <seconds>

[:SENSe]:ACP:SWEep:TIME?

Selects a specific sweep time used to measure the reference (carrier) channel. If you increase the sweep time, you increase the length of the time data captured and the number of points measured. You might need to specify a specific sweep speed to accommodate a specific condition in your transmitter. For example, you may have a burst signal and need to measure an exact portion of the burst.

Selecting a specific sweep time may result in a long measurement time since the resulting number of data points my not be the optimum 2^n . Use [:SENSe]:ACP:OFFSet:LIST:SWEEP:TIME to set the number of points used for measuring the offset channels for Basic and cdmaOne.

For cdma2000 and W-CDMA, this command sets the sweep time when using the sweep mode. See [:SENSe]:ACP:SWEep:TYPE.

Factory Preset: 625 µs (1 slot) for W-CDMA

1.25 ms for cdma2000

11.20 ms for Basic, cdmaOne

Range: 500 µs to 10 ms for W-CDMA, cdma2000

1 µs to 50 ms for Basic (E4406A), cdmaOne

Default Unit: seconds

Remarks: You must be in the Basic (E4406A), cdmaOne,

cdma2000, or W-CDMA mode to use this command. Use

INSTrument:SELect to set the mode.

History: E4406A:

Added to Basic revision A.03.00, to cdmaOne revision

A.04.00

Adjacent Channel Power—Sweep Type

W-CDMA mode

[:SENSe]:ACP:SWEep:TYPE FAST | FFT | SWEep

[:SENSe]:ACP:SWEep:TYPE?

 $cdma2000 \ mode$

[:SENSe]:ACP:SWEep:TYPE FFT | SWEep

[:SENSe]:ACP:SWEep:TYPE?

Selects the type of sweeping.

Fast (W-CDMA mode only) - the data acquisition is made with the wide channel integration bandwidth and the time-domain data is divided into the narrow data to apply FFT. This mode is faster than the FFT mode but less accurate in power levels.

FFT - the data acquisition is made with the narrow channel integration bandwidth and apply fast Fourier transform (FFT) to convert to the frequency domain data.

Sweep - the measurement is made by the swept spectrum method like the traditional swept frequency spectrum analysis to have better correlation to the input signal with a high crest factor (peak/average ratio). This mode may take a longer time than the FFT mode. See [:SENSe]:ACP:SWEEp:DETector[:FUNCtion].

Factory Preset: FFT

Remarks: You must be in the cdma2000, or W-CDMA mode to use

this command. Use INSTrument: SELect to set the

mode.

Adjacent Channel Power—Power Reference

[:SENSe]:ACP:TYPE PSDRef | TPRef

[:SENSe]:ACP:TYPE?

Selects the measurement type. This allows you to make absolute and relative power measurements of either total power or the power normalized to the measurement bandwidth.

Power Spectral Density Reference (PSDRef) - the power spectral density is used as the power reference

Total Power Reference (TPRef) - the total power is used as the power reference

Factory Preset: Total power reference (TPRef)

Remarks:

For E4406A you must be in the Basic, cdmaOne, cdma2000, W-CDMA, NADC, or PDC mode to use this command. Use INSTrument:SELect to set the mode.

For PSA you must be in the cdmaOne, cdma2000, W-CDMA, NADC, or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Baseband I/Q Commands (E4406A only)

Baseband I/Q - Select I/Q Power Range

[:SENSe]:POWer:IQ:RANGe[:UPPer] <power> [DBM] | DBMV | W

[:SENSe]:POWer:IQ:RANGe[:UPPer]?

Selects maximum total power expected from unit under test at test port when I or Q port is selected.

Range: For 50 Ohms:

13.0, 7.0. 1.0, or – 5.1 dBm 60.0, 54.0, 48.0, or 41.9 dBmV 0.02, 0.005, 0.0013, or 0.00031 W

For 600 Ohms:

2.2, -3.8. -9.8, or -15.8 dBm 60.0, 54.0, 48.0, or 41.9 dBmV

0.0017, 0.00042, 0.0001, or 0.000026 W

For 1 M Ohm:

Values for 1 M Ohm vary according to selected

reference impedance.

Default Units: DBM

Remarks: You must be in the Basic, W-CDMA, cdma2000, or

EDGE with GSM mode to use this command. Use

INSTrument:SELect to set the mode.

History: Added revision A.05.00 for B, WC, C2

Added revision A.06.00 for E

Baseband I/Q - Select I/Q Voltage Range

[:SENSe]:VOLTage:IQ:RANGe[:UPPer] <level>

[:SENSe]:VOLTage:IQ:RANGe[:UPPer]?

Selects upper voltage range when I or Q port is selected. This setting helps set the gain which is generated in the variable gain block of the baseband IQ board to improve dynamic range.

Range: 1.0, 0.5, .025, or 0.125 volts

Default Units: V

Remarks: You must be in the Basic, W-CDMA, cdma2000, or

EDGE with GSM mode to use this command. Use

INSTrument:SELect to set the mode.

History: Added revision A.05.00 for B, WC, C2

Added revision A.06.00 for E

Code Domain Measurement

Commands for querying the code domain power measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after the Code Domain measurement has been selected from the MEASURE key menu.

Code Domain — Active Data Channels

For cdma2000/1xEV-DV:

[:SENSe]:CDPower:ACODe AUTO GATed COMBination

For 1xEV-DO:

[:SENSe]:CDPower:ACODe AUTO PREDefined

[:SENSe]:CDPower:ACODe?

Select the Active Channel ID detection mode. This command is not available in the cdma2000 mode unless you have a license for 1xEV-DV option.

AUTO - detects the active channels automatically by checking power levels over the entire capture interval.

AUTO (Gated) - automatically detects active channels that are in the slots defined by the measurement offset and measurement interval commands CALCulate:CDPower:SWEep:OFFSet, CALCulate:CDPower:SWEep:TIME.

COMBination - sets predefined channels as active and also automatically detects other active channels by checking channel power levels. This affects the F-PDCH channel in forward link (BTS). (Channels can have unstable power levels which make them difficult to detect automatically, especially when 16QAM is being used.)

Note that even if a channel is predefined to be Off using SENSe:CDPower:<channel type>:STATe, if an active power level is detected on a channel by the automatic routine, it will be treated as an active channel.

PREDefined - sets predefined data channels as the active channels (from the Active Channel setting).

Example: CDP:ACOD COMB

Factory Preset: AUTO

Remarks: You must be in the 1xEV-DO, cdma2000 mode to use

this command. Use INSTrument:SELect to set the

mode.

Front Panel

Access: Meas Setup

Code Domain—Data Capture Time

[:SENSe]:CDPower:CAPTure:TIME <numeric>

[:SENSe]:CDPower:CAPTure:TIME?

Set the data capture length in Power Control Groups (PCG; 1 PCG equals 1.25 ms) for cdma2000 and 1xEV-DO, or frames (1 frame equals 10 ms) for W-CDMA that will be used in the acquisition.

For cdma2000 Set the data capture length in Power Control Groups

(PCG; 1 PCG equals 1.25 ms) that will be used in the

acquisition.

For 1xEV-DO Set the data capture length in units of slots (1 slot

equals 1.667 ms) that will be used in the acquisition.

For W-CDMA Set the data capture length in frames (1 frame equals

10 ms) for that will be used in the acquisition.

Factory Preset: 5 for cdma2000, 1xEV-DO

2.0 for W-CDMA

Range: 2 to 32 PCGs (2.5 to 40 ms) for cdma2000; 2 to 32 slots

for 1xEV-DO

0.067 (any value below 1 is set to 0.067), 1.0, 2.0, 3.0, 4.0, and 8.0 frames (0.67 to 80 ms; 1/15 frame equals 1 slot) for W-CDMA. Other numeric values between 1 and 8 are rounded to the nearest integer; entries between integers are rounded up, excepting for entries above 8

which are rounded down to 8.

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Code Domain—Chip Rate

[:SENSe]:CDPower:CRATe <freq>

[:SENSe]:CDPower:CRATe?

Enter a frequency value to set the chip rate.

Factory Preset: 1.2288 MHz for cdma2000, 1xEV-DO

3.84 MHz for W-CDMA

Range: 1.10592 to 1.35168 MHz for cdma2000, 1xEV-DO

3.456 to 4.224 MHz for W-CDMA

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Code Domain — Walsh Code Column Index

[:SENSe]:CDPower:INDex <integer>

[:SENSe]:CDPower:INDex?

Inputs the Walsh code column index as defined by the standard C.S0003. This information is used to set the predefined active channels that will be measured. To completely define the active channels, you should also enter the Walsh Mask value, the F-PDCH0 number/modulation type, and the F-PDCH1 number/modulation type. This command is not available unless the 1xEV-DV option is licensed and enabled.

Example: CDP: IND 2

Factory Preset: 0

Range: 0 to 3 (this is equivalent to: 000, 010, 011, 011)

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, 1xEV-DV Predefined Active Chan

Code Domain — Walsh Code Mask

[:SENSe]:CDPower:MASK <integer>

[:SENSe]:CDPower:MASK?

Inputs the Walsh Mask which is a 13-bit binary pattern. This information is used to set the predefined active channels that will be measured. To completely define the active channels, you should also enter the Walsh code column index, the F-PDCH0 number & modulation type, and the F-PDCH1 number & modulation type. This command is not available unless the 1xEV-DV option is licensed and

enabled.

Example: CDP:MASK 5120 (equivalent to 1010000000000)

Factory Preset: 0

Range: 0 to FFFh (equivalent to: 0000000000000 to

1111111111111)

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, 1xEV-DV Predefined Active Chan

Code Domain — Walsh Code Mask

[:SENSe]:CDPower:MASK:STATe OFF|ON|0|1

[:SENSe]:CDPower:MASK:STATe?

Turns on/off the Walsh Mask. The Walsh code is used to set the predefined active channels that will be measured. To completely define the active channels, you should also enter the Walsh code column index, the F-PDCH0 number & modulation type, and the F-PDCH1 number & modulation type. This command is not available unless the 1xEV-DV option is licensed and enabled.

Example: CDP:MASK:STAT ON

Factory Preset: Off

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, 1xEV-DV Predefined Active Chan

Code Domain — F-PDCH Modulation Type

[:SENSe]:CDPower:PDCH[0] | 1:MTYPe QPSK | QPSK | QAM16

[:SENSe]:CDPower:PDCH[0] |1:MTYPe?

Selects the modulation format of all the allowed subpackets in the active F-PDCH channels for QPSK, 8PSK, or 16QAM modulation. This information is used to set the predefined active channels that will be measured. To completely define the active channels, you should also enter the Walsh code column index, the Walsh Mask value, and the F-PDCH0/1 numbers. This command is not available unless the 1xEV-DV option is licensed and enabled.

Example: CDP:PDCH:MTYP QPSK

CDP:PDCH1:MTYP QPSK

Factory Preset: F-PDCH0 = QAM16

F-PDCH1 = QAM16

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, 1xEV-DV Predefined Active Chan

Code Domain — F-PDCH Number

[:SENSe]:CDPower:PDCH[0] | 1:NUMBer <integer>

[:SENSe]:CDPower:PDCH[0] | 1:NUMBer?

Inputs F-PDCH0 number, or F-PDCH1 number (number of possible assigned Walsh code row indexes, see standard C.S0003). This information is used to set the predefined active channels that will be measured. To completely define the active channels, you should also enter the Walsh code column index, the Walsh Mask value, and the F-PDCH0/1 modulation types. This command is not available unless the 1xEV-DV option is licensed and enabled.

Example: CDP:PDCH:NUMB 7 F-PDCH0 is assigned to one of the

first 7 column indexes, i.e. 0 to 6.

CDP: PDCH1: NUMB 4 F-PDCH1 is assigned to one of the

next 4 column indexes, i.e. 7 to 10.

Factory Preset: F-PDCH0 = 1

F-PDCH1 = 0 (not active)

Range: 0 to 27

Where 0 means the F-PDCH is not active.

The sum of F-PDCH0 + F-PDCH1 must be ≤ 28 .

Remarks: F-PDCH0 must be available before F-PDCH1 can be

used.

You must be in the cdma2000 mode to use this command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, 1xEV-DV Predefined Active Chan

Code Domain—Quasi-Orthogonal Function

[:SENSe]:CDPower:QOF 0|1|2|3

[:SENSe]:CDPower:QOF?

Set the Walsh code quasi-orthogonal function for expanding the number of downlink channels (subscribers).

Factory Preset: 0

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Code Domain—Spectrum Normal/Invert

[:SENSe]:CDPower:SPECtrum INVert | NORMal

[:SENSe]:CDPower:SPECtrum?

Set a spectrum either to normal or inverted for the demodulation related measurements. If set to INVert, the upper and lower spectrums are swapped.

Factory Preset: NORMal

Remarks You must be in the cdmaOne, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Code Domain—Long Code Mask

[:SENSe]:CDPower:SYNC:LCMask <integer>

[:SENSe]:CDPower:SYNC:LCMask?

Set the long code mask for MS measurement.

Factory Preset: 2000000000

Range: 0000000000 or 2000000000 (Any other integer value

entered will be rounded down to either 0,000,000,000 or

2,000,000,000.)

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Code Domain—Trigger Source

[:SENSe]:CDPower:TRIGger:SOURce EXTernal[1] | External2

|FRAMe|IF|IMMediate|RFBurst

[:SENSe]:CDPower:TRIGger:SOURce?

Select one of the trigger sources used to control the data acquisitions.

EXTernal 1 – front panel external trigger input

EXTernal 2 – rear panel external trigger input

FRAMe – internal frame trigger

IF – internal IF envelope (video) trigger

IMMediate – the next data acquisition is immediately taken, capturing the signal asynchronously (also called free run).

RFBurst – internal wideband RF burst envelope trigger that has automatic level control for periodic burst signals.

Factory Preset: IMMediate

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Front Panel

Access: Meas Setup, Trig Source

Channel Power Measurement

Commands for querying the channel power measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after the Channel Power measurement has been selected from the MEASURE key menu.

Channel Power—Average Count

[:SENSe]:CHPower:AVERage:COUNt <integer>

[:SENSe]:CHPower:AVERage:COUNt?

Set the number of data acquisitions that will be averaged. After the specified number of average counts, the averaging mode (terminal control) setting determines the averaging action.

Factory Preset: 20

200, for W-CDMA

Range: 1 to 10,000

Remarks: For PSA you must be in the cdmaOne, cdma2000,

W-CDMA, or 1xEV-DO mode to use this command. Use

INSTrument:SELect to set the mode.

For E4406A you must be in the Basic, cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Channel Power—Averaging State

[:SENSe]:CHPower:AVERage[:STATe] OFF ON 0 1

[:SENSe]:CHPower:AVERage[:STATe]?

Turn averaging on or off.

Factory Preset: ON

Remarks: For PSA you must be in the cdmaOne, cdma2000,

W-CDMA, or 1xEV-DO mode to use this command. Use

INSTrument:SELect to set the mode.

For E4406A you must be in the Basic, cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Channel Power—Averaging Termination Control

[:SENSe]:CHPower:AVERage:TCONtrol EXPonential REPeat

[:SENSe]:CHPower:AVERage:TCONtrol?

Select the type of termination control used for the averaging function. This determines the averaging action after the specified number of data acquisitions (average count) is reached.

EXPonential - Each successive data acquisition after the average count is reached, is exponentially weighted and combined with the existing average.

REPeat - After reaching the average count, the averaging is reset and a new average is started.

Factory Preset: REPeat

Remarks: For PSA you must be in the cdmaOne, cdma2000,

W-CDMA, or 1xEV-DO mode to use this command. Use

INSTrument:SELect to set the mode.

For E4406A you must be in the Basic, cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Channel Power—Integration BW

[:SENSe]:CHPower:BANDwidth|BWIDth:INTegration <freq>

[:SENSe]:CHPower:BANDwidth|BWIDth:INTegration?

Set the Integration BW (IBW) that will be used.

Factory Preset: 1.23 MHz for Basic (E4406A), cdmaOne, cdma2000,

1xEV-DO

5.0 MHz for W-CDMA

Range: 1 kHz to 10 MHz

Default Unit: Hz

Remarks: For PSA you must be in the cdmaOne, cdma2000,

W-CDMA, or 1xEV-DO mode to use this command. Use

INSTrument:SELect to set the mode.

For E4406A you must be in the Basic, cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Channel Power—Span

[:SENSe]:CHPower:FREQuency:SPAN <freq>

[:SENSe]:CHPower:FREQuency:SPAN?

Set the frequency span that will be used.

Factory Preset: 2.0 MHz for Basic, cdmaOne, cdma2000, 1xEV-DO

6.0 MHz for W-CDMA

Range: Dependent on the current setting of the channel power

integration bandwidth

Default Unit: Hz

Remarks: For PSA you must be in the cdmaOne, cdma2000,

W-CDMA, or 1xEV-DO mode to use this command. Use

INSTrument: SELect to set the mode.

For E4406A you must be in the Basic, cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Channel Power—Data Points

[:SENSe]:CHPower:POINts <integer>

[:SENSe]:CHPower:POINts?

Set the number of data points that will be used. Changing this will change the time record length and resolution BW that are used.

Factory Preset: 512

Range: 64 to 32768, in a 2^n sequence

Remarks: For PSA you must be in the cdmaOne, cdma2000,

W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

For E4406A you must be in the Basic, cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Channel Power—Data Points Auto

[:SENSe]:CHPower:POINts:AUTO OFF ON 0 1

[:SENSe]:CHPower:POINts:AUTO?

Select auto or manual control of the data points. This is an advanced control that normally does not need to be changed. Setting this to a value other than the factory default, may cause invalid measurement results.

OFF - the Data Points is uncoupled from the Integration BW.

ON - couples the Data Points to the Integration BW.

Factory Preset: ON

Remarks: You must be in the Basic (E4406A), cdmaOne,

cdma2000, W-CDMA, 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Channel Power—Sweep Time

[:SENSe]:CHPower:SWEep:TIME <time>

[:SENSe]:CHPower:SWEep:TIME?

Sets the sweep time when using the sweep mode.

Factory Preset: 68.27 µs

17.07 µs for W-CDMA

Range: 1 µs to 50 ms

Default Unit: seconds

Remarks: You must be in the Basic (E4406A), cdmaOne,

cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Version A.03.00 and later

Channel Power—Sweep Time

[:SENSe]:CHPower:SWEep:TIME:AUTO OFF ON 0 1

[:SENSe]:CHPower:SWEep:TIME:AUTO?

Selects the automatic sweep time, optimizing the measurement.

Factory Preset: ON

Remarks: You must be in the Basic (E4406A), cdmaOne,

cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Version A.03.00 and later

Channel Power—Trigger Source

[:SENSe]:CHPower:TRIGger:SOURce EXTernal[1]|EXTernal2|IMMediate

[:SENSe]:CHPower:TRIGger:SOURce?

Select the trigger source used to control the data acquisitions. This is an Advanced control that normally does not need to be changed.

EXTernal 1 - front panel external trigger input

EXTernal 2 - rear panel external trigger input

IMMediate - the next data acquisition is immediately taken (also called Free Run).

Factory Preset: IMMediate

Remarks: For PSA you must be in the cdmaOne, cdma2000,

W-CDMA, or 1xEV-DO mode to use this command. Use

INSTrument:SELect to set the mode.

For E4406A you must be in the Basic, cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Signal Corrections Commands

Correction for BTS RF Port External Attenuation

[:SENSe]:CORRection:BTS[:RF]:LOSS <rel power>

[:SENSe]:CORRection:BTS[:RF]:LOSS?

Set equal to the external attenuation used when measuring base transmission stations.

Factory Preset: 0.0 dB

Range: -50 to 100.0 dB for GSM, EDGE

-100.0 to 100.0 dB for cdma2000, W-CDMA, 1xEV-DO

Default Unit: dB

Remarks: Global to the current mode.

You must be in the GSM, EDGE, cdma2000, W-CDMA,

or 1xEV-DO mode to use this command. Use

INSTrument:SELect to set the mode.

Correction for MS RF Port External Attenuation

[:SENSe]:CORRection:MS[:RF]:LOSS <rel_power>

[:SENSe]:CORRection:MS[:RF]:LOSS?

Set the correction equal to the external attenuation used when measuring mobile stations.

Factory Preset: 0.0 dB

Range: - 50 to 100.0 dB for cdmaOne, GSM, EDGE, iDEN

- 100.0 to 100.0 dB for cdma2000, W-CDMA, 1xEV-DO

- 50.0 to 50.0 dB for NADC, PDC

Default Unit: dB

Remarks: For E4406A you must be in the cdmaOne, GSM, EDGE

(w/GSM), cdma2000, W-CDMA, iDEN, NADC, PDC, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

For PSA you must be in the cdmaOne, GSM (w/EDGE), cdma2000, W-CDMA, NADC, PDC, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set

the mode.

Value is global to the current mode.

QPSK Error Vector Magnitude Measurement

Commands for querying the QPSK error vector magnitude measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after the QPSK EVM measurement has been selected from the MEASURE key menu.

QPSK Error Vector Magnitude—Average Count

[:SENSe]:EVMQpsk:AVERage:COUNt <integer>

[:SENSe]:EVMQpsk:AVERage:COUNt?

Set the number of data acquisitions that will be averaged. After the specified number of average counts, the average mode (termination control) setting determines the average action.

Factory Preset: 10

Range: 1 to 10,000

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

QPSK Error Vector Magnitude—Averaging State

[:SENSe]:EVMQpsk:AVERage[:STATe] OFF ON 0 1

[:SENSe]:EVMQpsk:AVERage[:STATe]?

Turn the averaging function on or off.

Factory Preset: ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

QPSK Error Vector Magnitude—Averaging Termination Control

[:SENSe]:EVMQpsk:AVERage:TCONtrol EXPonential REPeat

[:SENSe]:EVMQpsk:AVERage:TCONtrol?

Select the type of termination control used to averaging. This determines the averaging action after the specified number of data acquisitions (average count) is reached.

EXPonential – Each successive data acquisition after the average count is reached, is exponentially weighted and combined with the existing average.

REPeat – After reaching the average count, the averaging is reset and a new average is started.

Factory Preset: REPeat

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

QPSK Error Vector Magnitude—Chip Rate

[:SENSe]:EVMQpsk:CRATe <freq>

[:SENSe]:EVMQpsk:CRATe?

Enter a frequency value to set the chip rate.

Factory Preset: 1.2288 MHz for cdma2000, 1xEV-DO

3.84 MHz for W-CDMA

Range: 1.10592 to 1.35168 MHz for cdma2000, 1xEV-DO

3.456 to 4.224 MHz for W-CDMA

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

QPSK Error Vector Magnitude—RF Carrier Mode

[:SENSe]:EVMQpsk:RFCarrier MULTiple | SINGle

[:SENSe]:EVMQpsk:RFCarrier?

Select either the single carrier mode or the multiple carrier mode.

MULTiple – The measurement assumes that the input signal is the multiple carriers with adjacent channel signals. The filter is used to cut the adjacent channel signals. (The filter may affect the measurement result.)

SINGle – The measurement assumes that the input signal is the single carrier without adjacent channel signals. No filter is used for better measurement.

Factory Preset: SINGle

Remarks: You must be in the cdma2000 or 1xEV-DO mode to use

this command. Use INSTrument:SELect to set the

mode.

QPSK Error Vector Magnitude—Measurement Interval

[:SENSe]:EVMQpsk:SWEep:POINts <integer>

[:SENSe]:EVMQpsk:SWEep:POINts?

Set the number of data points that will be used as the measurement interval.

Factory Preset: 256 chips

96 chips for 1xEV-DO

2560 chips (1 slot) for W-CDMA

Range: 128 to 1536 chips for cdma2000

 $128\ {\rm to}\ 5120\ {\rm chips}\ {\rm for}\ {\rm W\text{-}CDMA}$

32 to 2048 chips for 1xeV-DO

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

QPSK Error Vector Magnitude—Trigger Source

[:SENSe]:EVMQpsk:TRIGger:SOURce EXTernal[1] | EXTernal2

| FRAMe | IF | IMMediate | RFBurst

[:SENSe]:EVMQpsk:TRIGger:SOURce?

Select one of the trigger sources used to control the data acquisitions.

EXTernal 1 – front panel external trigger input

EXTernal 2 – rear panel external trigger input

FRAMe – internal frame trigger

IF – internal IF envelope (video) trigger

IMMediate – the next data acquisition is immediately taken, capturing the signal asynchronously (also called free run)

RFBurst – wideband RF burst envelope trigger that has automatic level control for periodic burst signals

Factory Preset: IMMediate

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

RF Input Signal Alignments

Select the Input Signal

(PSA)

[:SENSe]:FEED RF | AREFerence | IFAlign

(E4406A)

[:SENSe]:FEED RF | IQ | IONLY | QONLY | AREFerence | IFALign

[:SENSe]:FEED?

Selects the input signal. The default input signal is taken from the front panel RF input port. For calibration and testing purposes the input signal can be taken from an internal 321.4 MHz IF alignment signal or an internal 50 MHz amplitude reference source.

For E4406A if the baseband IQ option (Option B7C) is installed, I and Q input ports are added to the front panel. The I and Q ports accept the in-phase and quadrature components of the IQ signal, respectively. The input signal can be taken from either or both ports.

RF selects the signal from the front panel RF INPUT port.

IQ selects the combined signals from the front panel optional I and Q input ports. (E4406A with Option B7C in Basic, W-CDMA, cdma2000, EDGE(w/GSM) modes)

IONLy selects the signal from the front panel optional I input port. (E4406A with Option B7C in Basic mode)

QONLy selects the signal from the front panel optional Q input port. (E4406A with Option B7C in Basic mode)

AREFerence selects the internal 50 MHz amplitude reference signal.

IFALign selects the internal, 321.4 MHz, IF alignment signal.

Factory Preset: RF

Front Panel

Access: Input, Input Port

History: E4406A:

modified in version A.05.00

Frequency Commands

Center Frequency

[:SENSe]:FREQuency:CENTer <freq>

[:SENSe]:FREQuency:CENTer?

Set the center frequency.

Factory Preset: PSA

E4443A: 3.35 GHz for SA E4445A: 6.5 GHz for SA E4440A: 13.25 GHz for SA

1.0 GHz for Basic, cdmaOne, cdma2000, W-CDMA,

NADC, PDC modes

935.2 MHz for GSM, EDGE modes

Factory Preset: 1.0 GHz

942.6 MHz for GSM, EDGE

806.0 MHz for iDEN

Range: PSA

E4443A: 3 Hz to 6.7 GHz for SA

E4445A: 3 Hz to 13.2 GHz for SA

E4440A: 3 Hz to 26.5 GHz for SA

3 Hz to 1.5 GHz for Basic, cdmaOne, cdma2000, W-CDMA, GSM, EDGE, NADC, PDC modes

(Measurement specifications are only applicable up

to 3 GHz.)

Range: 1.0 kHz to 4.3214 GHz

Default Unit: Hz

Front Panel

Access: FREQUENCY/Channel, Center Freq

Center Frequency Step Size

[:SENSe]:FREQuency:CENTer:STEP[:INCRement] <freq>

[:SENSe]:FREQuency:CENTer:STEP[:INCRement]?

Specifies the center frequency step size.

Factory Preset: 5.0 MHz (E4406A)

1.25 MHz for cdma2000 (E4406A)

Range: 1.0 kHz to 1.0 GHz, in 10 kHz steps (E4406A)

Default Unit: Hz

History: E4406A:

Version A.03.00 or later

Front Panel

Access: FREQUENCY/Channel, CF Step

Intermodulation Measurement

Commands for querying the intermodultaion measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after the Intermod measurement has been selected from the MEASURE key menu.

History: E4406A:

Added version A.04.00 and later

Intermodulation—Average Count

[:SENSe]:IM:AVERage:COUNt <number>

[:SENSe]:IM:AVERage:COUNt?

Set the number of data acquisitions that will be averaged. After the specified number of average counts, the average mode (termination control) setting determines the average action.

Factory Preset: 10

Range: 1 to 10,000

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Averaging State

[:SENSe]:IM:AVERage[:STATe] OFF|ON|0|1

[:SENSe]:IM:AVERage[:STATe]?

Turn the averaging function on or off.

Factory Preset: ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Averaging Termination Control

[:SENSe]:IM:AVERage:TCONtrol EXPonential | REPeat

[:SENSe]:IM:AVERage:TCONtrol?

Select the type of termination control used for averaging. This determines the averaging action after the specified number of data acquisitions (average count) is reached.

EXPonential – Each successive data acquisition after the average count is reached, is exponentially weighted and combined with the existing average.

REPeat – After reaching the average count, the averaging is reset and a new average is started.

Factory Preset: REPeat

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Integration Bandwidth

[:SENSe]:IM:BANDwidth|BWIDth:INTegration <freq>

[:SENSe]:IM:BANDwidth|BWIDth:INTegration?

Set the Integration Bandwidth (IBW) that will be used.

Factory Preset: 1.23 MHz for cdma2000, 1xEV-DO

3.84 MHz for W-CDMA

Range: 100.0 kHz to 5.0 MHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Resolution Bandwidth

[:SENSe]:IM:BANDwidth|BWIDth[:RESolution] <freq>

[:SENSe]:IM:BANDwidth | BWIDth [:RESolution]?

Set the resolution bandwidth that will be used for the Transmitter IM measurement mode. If span is set to a value greater than 5 MHz, minimum resolution bandwidth is limited to 1 kHz.

Factory Preset: Auto coupled.

Range: 100 Hz to 300.0 kHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Resolution Bandwidth State

 $\hbox{\tt [:SENSe]:IM:BANDwidth} \, | \, \hbox{\tt BWIDth} \, \hbox{\tt [:RESolution]:AUTO OFF} \, | \, \hbox{\tt ON} \, | \, \hbox{\tt 0} \, | \, \hbox{\tt 1}$

[:SENSe]:IM:BANDwidth | BWIDth [:RESolution]:AUTO?

Select auto (default value) or manual (user entered value) to set the resolution bandwidth.

Factory Preset: ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Base Frequency Auto Search

[:SENSe]:IM:FREQuency:AUTO OFF ON 0 1

[:SENSe]:IM:FREQuency:AUTO?

Turn the base frequency auto search function on or off.

OFF – the frequencies set by the [:SENSe]:IM:FREQuency are used.

ON – automatically determined by searching the entire span.

Factory Preset: ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Base Frequencies Delta

[:SENSe]:IM:FREQuency[:BASE]:DELTa <freq>

[:SENSe]:IM:FREQuency[:BASE]:DELTa?

lower frequency).

Set the delta frequency which is (the base upper frequency – the base

Factory Preset: Auto coupled.

Range: E4406A

-4.3214 GHz to 4.3214 GHz

PSA

-3.0000 GHz to 3.0000 GHz

Default Unit: Hz

Remarks: Frequency step value is set by

[:SENSe]:FREQuency:CENTer:STEP[:INCRement]

You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Base Lower Frequency

[:SENSe]:IM:FREQuency[:BASE]:LOWer <freq>

[:SENSe]:IM:FREQuency[:BASE]:LOWer?

Set the frequency value of the base lower frequency. The available lower limit value is dependent on the Resolution Bandwidth setting.

Factory Preset: Auto coupled.

Range: E4406A

1 kHz to 4.3214 GHz

PSA

1 kHz to 3.0 GHz

Default Unit: Hz

Remarks: Frequency step value is set by

[:SENSe]:FREQuency:CENTer:STEP[:INCRement]

You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Base Upper Frequency

[:SENSe]:IM:FREQuency[:BASE]:UPPer <freq>

[:SENSe]:IM:FREQuency[:BASE]:UPPer?

Set the frequency value of the base upper frequency. The available lower limit value is dependent on the Resolution Bandwidth setting.

Factory Preset: Auto coupled.

Range: E4406A

1 kHz to 4.3214 GHz

PSA

1 kHz to 3.0 GHz

Default Unit: Hz

Remarks: Frequency step value is set by

[:SENSe]:FREQuency:CENTer:STEP[:INCRement]

You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Span

[:SENSe]:IM:FREQuency:SPAN <freq>

[:SENSe]:IM:FREQuency:SPAN?

Set the span.

Factory Preset: 20.0 MHz for cdma2000, 1xEV-DO

50.0 MHz for W-CDMA

Range: 100.0 kHz to 100.0 MHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Intermodulation—Measurement Mode

[:SENSe]:IM:MODE AUTO TWOTONE TXIM

[:SENSe]:IM:MODE?

Select the measurement mode of the intermodulation measurement.

AUTO – Automatically identifies the intermodulation caused by the two-tone or transmit intermodulation signals.

 $\label{two-tone} \mbox{Two-tone} \mbox{ (TWOTone)- Measures the two-tone intermodulation products.}$

Transmit (TXIM) – Measures the transmit intermodulation products.

Factory Preset: AUTO

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to set the mode.

Intermodulation—Measurement Reference

[:SENSe]:IM:REFerence AUTO | AVERage | LOWer | UPPer

[:SENSe]:IM:REFerence?

Select the measurement reference of the intermodulation measurement.

AUTO – Automatically sets the highest level signal in two base signals as measurement reference.

AVERage – Sets the average level of the base lower carrier and upper carrier frequency as measurement reference.

LOWer – Sets the base lower carrier as measurement reference.

UPPer – Sets the base upper carrier as measurement reference.

Factory Preset: AUTO

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Occupied Bandwidth Measurement

Commands for querying the occupied bandwidth measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after the Occupied BW measurement has been selected from the MEASURE key menu.

Occupied Bandwidth—Average Count

[:SENSe]:OBW:AVERage:COUNt <integer>

[:SENSe]:OBW:AVERage:COUNt?

Set the number of data acquisitions that will be averaged. After the specified number of average counts, the average mode (termination control) setting determines the average action.

Factory Preset: 10

Range: 1 to 10,000

Remarks: This command is used for measurements in the

MEASURE menu.

You must be in the PDC, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Version A.02.00 or later

Front Panel

Access: Meas Setup, Avg Number

Occupied Bandwidth—Averaging State

[:SENSe]:OBW:AVERage[:STATe] OFF | ON | 0 | 1

[:SENSe]:OBW:AVERage[:STATe]?

Turn the averaging function on or off.

Factory Preset: ON

Remarks: You must be in the PDC, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Version A.02.00 or later

Front Panel

Access: Meas Setup, Avg Number

Occupied Bandwidth—Averaging Termination Control

[:SENSe]:OBW:AVERage:TCONtrol EXPonential | REPeat

[:SENSe]:OBW:AVERage:TCONtrol?

Select the type of termination control used for the averaging function. This determines the averaging action after the specified number of data acquisitions (average count) is reached.

EXPonential - After the average count is reached, each successive data acquisition is exponentially weighted and combined with the existing average.

REPeat - After reaching the average count, the averaging is reset and a new average is started.

Factory Preset: EXPonential for PDC

REPeat for cdma2000, W-CDMA, 1xEV-DO

Remarks: You must be in the PDC, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Version A.02.00 or later

Front Panel

Access: Meas Setup, Avg Mode

Occupied Bandwidth—Resolution Bandwidth

[:SENSe]:OBW:BANDwidth|BWIDth[:RESolution] <freq>

[:SENSe]:OBW:BANDwidth|BWIDth[:RESolution]?

Set the resolution bandwidth that will be used.

Factory Preset: 30.0 kHz

Range: 1.0 kHz to 1.0 MHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Occupied Bandwidth—FFT Window

[:SENSe]:OBW:FFT:WINDow[:TYPE] BH4Tap BLACkman FLATtop

|GAUSsian|HAMMing|HANNing|KB70|KB90|KB110|UNIForm

[:SENSe]:OBW:FFT:WINDow[:TYPE]?

Select the FFT window type.

BH4Tap - Blackman Harris with 4 taps

BLACkman - Blackman

FLATtop - flat top, set to the default (for high amplitude accuracy)

GAUSsian - Gaussian with alpha of 3.5

HAMMing - Hamming

HANNing - Hanning

KB70, 90, and 110 - Kaiser Bessel with sidelobes at – 70, – 90, or – 110 dBc

UNIForm - no window is used. (This is the unity response.)

Factory Preset: GAUSsian

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Occupied Bandwidth—Span

[:SENSe]:OBW:FREQuency:SPAN <freq>

[:SENSe]:OBW:FREQuency:SPAN?

Set the occupied bandwidth span. The analyzer span will retain this value throughout the measurement.

Factory Preset: 10.0 MHz

3.75 MHz for cdma2000, 1xEV-DO

Range: 10.0 kHz to 10.0 MHz

Default Unit: Hz

Remarks: You must be in the PDC, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Occupied Bandwidth—Trigger Source

iDEN mode (E4406A)

[:SENSe]:OBW:TRIGger:SOURce

EXTernal[1] | EXTernal2 | IF | IMMediate | RFBurst

[:SENSe]:OBW:TRIGger:SOURce?

PDC mode

[:SENSe]:OBW:TRIGger:SOURce

EXTernal[1] | EXTernal2 | IF | IMMediate | RFBurst

[:SENSe]:OBW:TRIGger:SOURce?

cdma2000, W-CDMA, 1xEV-DO mode

[:SENSe]:OBW:TRIGger:SOURce EXTernal[1] | EXTernal2

| FRAMe | IF | IMMediate | LINE | RFBurst

[:SENSe]:OBW:TRIGger:SOURce?

Select one of the trigger sources used to control the data acquisitions for the occupied bandwidth measurement.

EXTernal1 – rear panel external trigger input

EXTernal2 – front panel external trigger input

FRAMe – internal frame trigger (cdma2000, W-CDMA, 1xEV-DO mode only)

IF – internal IF envelope (video) trigger

IMMediate – the next data acquisition is immediately taken, capturing the signal asynchronously (also called free run)

LINE – power line (cdma2000, W-CDMA, 1xEV-DO mode only)

RFBurst – wideband RF burst envelope trigger that has automatic level control for periodic burst signals

Factory Preset: IMMediate for BS in PDC, cdma2000, W-CDMA,

1xEV-DO mode

RFBurst for MS in PDC, iDEN (E4406A) mode

RFBurst for iDEN (E4406A)

Remarks:

You must be in the PDC, iDEN (E4406A), cdmaOne, cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Version A.02.00 or later

Select I/Q Power Range (E4406A only)

[:SENSe]:POWer:IQ:RANGe[:UPPer]<Float 64>{DBM] | DBMV | W

[:SENSe]:POWer:IQ:RANGe[:UPPer]?

Selects maximum total power expected from unit under test at test port when I or Q port is selected.

Range: For 50 Ohms:

13.0, 7.0. 1.0, -5.1 [DBM] 60.0, 54.0, 48.0, 41.9 [DBMV] .02, .005, .0013, .00031 [W]

For 600 Ohms:

2.2, -3.8. -9.8, -15.8 [DBM] 60.0, 54.0, 48.0, 41.9 [DBMV] .0017, .00042, .0001, .000026 [W]

Values for 1 M Ohm vary according to selected

reference impedance.

Remarks: Implemented for BASIC and W-CDMA modes.

History: Version A.05.00 or later

Select I/Q Voltage Range (E4406A only)

[:SENSe]:VOLTage:IQ:RANGe[:UPPer]<Float 64> [V]

[:SENSe]:VOLTage:IQ:RANGe[:UPPer]?

Selects upper voltage range when I or Q port is selected. This setting helps set the gain which is generated in the variable gain block of the BbIQ board to improve dynamic range.

Range: 1.0, 0.5, .025, 0.125[V]

Remarks: Implemented for BASIC and W-CDMA modes.

History: Version A.05.00 or later

RF Power Commands

RF Port Input Attenuation

[:SENSe]:POWer[:RF]:ATTenuation <rel power>

[:SENSe]:POWer[:RF]:ATTenuation?

Set the RF input attenuator. This value is set at its auto value if RF input attenuation is set to auto.

Factory Preset: 0 dB

12 dB for iDEN (E4406A)

Range: 0 to 40 dB

Default Unit: dB

Front Panel

Access: Input, Input Atten

Internal RF Preamplifier Control

[:SENSe]:POWer[:RF]:GAIN[:STATe] OFF ON 0 1

[:SENSe]:POWer[:RF]:GAIN[:STATe]?

Turns the internal preamp on or off for the currently selected measurement. Requires Option 1DS.

Factory Preset: OFF

Front Panel

Access: Input/Output, More (1 of 2), Int Preamp for Optional

Personalities.

AMPLITUDE/Y Scale, More (1 of 3), Int Preamp for SA

mode

Remarks: For PSA you must be in W-CDMA, cdma2000, or

1xEV-DO mode to use this command. Use

INSTrument:SELect to set the mode. BEFORE you can turn on the preamp using the :SENSe command, you

must also send the following command: :CONFigure:RHO|EVMQpsk|CDPower.

Internal RF Preamplifier Attenuation

[:SENSe]:POWer[:RF]:GAIN:ATTenuation <rel power>

[:SENSe]:POWer[:RF]:GAIN:ATTenuation?

Specifies the internal mechanical attenuator setting when the internal preamp is on. Requires Option 1DS. This not the same attenuator used when the preamp is OFF.

Factory Preset: 0 [dB]

Front Panel

Access: Input/Output, More (1 of 2), Int Preamp for Optional

Personalities.

AMPLITUDE/Y Scale, More (1 of 3), Int Preamp for SA

mode

Range: 0,10, or 20 [dB]

Other numbers between 0 and 20 are rounded to the nearest number; entries between numbers are rounded

up. Entries above 20 are rounded down to 20.

Remarks: You must be in W-CDMA, cdma2000, or 1xEV-DO mode

with the preamp ON to use this command. Use

INSTrument:SELect to set the mode. BEFORE you can turn on the preamp using the :SENSe command, you

must also send the following command::CONFigure:RHO|EVMQpsk|CDPower.

Key Path: Input/Output, More (1 of 2), Attenuation

State Saved: Saved in Instrument State

RF Port Power Range Auto

[:SENSe]:POWer[:RF]:RANGe:AUTO OFF ON 0 1

[:SENSe]:POWer[:RF]:RANGe:AUTO?

Select the RF port power range to be set either automatically or manually.

ON - power range is automatically set as determined by the actual measured power level at the start of a measurement.

OFF - power range is manually set

Factory Preset: ON

Remarks: You must be in the cdmaOne, GSM, EDGE, NADC,

PDC, cdma2000, W-CDMA, mode to use this command.

Use INSTrument:SELect to set the mode.

Front Panel

Access: Input, Max Total Pwr (at UUT)

RF Port Power Range Maximum Total Power

[:SENSe]:POWer[:RF]:RANGe[:UPPer] <power>

[:SENSe]:POWer[:RF]:RANGe[:UPPer]?

Set the maximum expected total power level at the radio unit under test. This value is ignored if RF port power range is set to auto. External attenuation required above 30 dBm.

Factory Preset: -15.0 dBm

Range: - 100.0 to 80.0 dBm for EDGE, GSM

- 100.0 to 27.7 dBm for cdmaOne, iDEN (E4406A)

- 200.0 to 50.0 dBm for NADC, PDC

-200.0 to 100.0 dBm for cdma2000, W-CDMA

Default Unit: dBm

Remarks: Global to the current mode. This is coupled to the RF

input attenuation

For E4406A you must be in the Service, cdmaOne, EDGE(w/GSM), GSM, iDEN, NADC, PDC, cdma2000,

or W-CDMA mode to use this command. Use

INSTrument:SELect to set the mode.

For PSA you must be in the cdmaOne, GSM, EDGE, NADC, PDC, cdma2000, or W-CDMA mode to use this command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Input, Max Total Pwr (at UUT)

Power Statistics CCDF Measurement

Commands for querying the statistical power measurement of the complementary cumulative distribution function (CCDF) measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after the Power Stat CCDF measurement has been selected from the MEASURE key menu.

History: E4406A:

Added PSTatistic to Basic Mode version A.04.00

Power Statistics CCDF—Channel Bandwidth

[:SENSe]:PSTatistic:BANDwidth|BWIDth <freq>

[:SENSe]:PSTatistic:BANDwidth | BWIDth?

Enter a frequency value to set the channel bandwidth that will be used for data acquisition.

Factory Preset: 5.0 MHz

Range: 10.0 kHz to 6.7 MHz

Default Unit: Hz

Remarks: You must be in the Basic (E4406A), cdma2000,

W-CDMA, or 1xEV-DO mode to use this command. Use

INSTrument:SELect to set the mode.

Power Statistics CCDF—Sample Counts

[:SENSe]:PSTatistic:COUNts <integer>

[:SENSe]:PSTatistic:COUNts?

Enter a value to set the sample counts. Measurement stops when the sample counts reach this value.

Factory Preset: 10,000,000

Range: 1,000 to 2,000,000,000

Unit: counts

Remarks: You must be in the Basic E4406A), cdma2000,

W-CDMA, or 1xEV-DO mode to use this command. Use

INSTrument:SELect to set the mode.

Power Statistics CCDF—Sweep Time

[:SENSe]:PSTatistic:SWEep:TIME <time>

[:SENSe]:PSTatistic:SWEep:TIME?

Enter a value to set the measurement interval that will be used to make measurements.

Factory Preset: 1.0 ms

Range: 0.1 ms to 10 ms

Remarks: You must be in the Basic, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Power Statistics CCDF—Trigger Source

[:SENSe]:PSTatistic:TRIGger:SOURce EXTernal[1] | EXTernal2

| FRAMe | IF | IMMediate | RFBurst

[:SENSe]:PSTatistic:TRIGger:SOURce?

Select one of the trigger sources used to control the data acquisitions.

EXTernal 1 - front panel external trigger input

EXTernal 2 - rear panel external trigger input

FRAMe - uses the internal frame timer, which has been synchronized to the selected burst sync.

IF - internal IF envelope (video) trigger

IMMediate - the next data acquisition is immediately taken, capturing the signal asynchronously (also called Free Run).

RFBurst - wideband RF burst envelope trigger that has automatic level control for periodic burst signals.

Factory Preset: IMMediate

Remarks: You must be in the Basic (E4406A), cdma2000,

W-CDMA, or 1xEV-DO mode to use this command. Use

INSTrument:SELect to set the mode.

Radio Standards Commands

Radio Carrier Multiple

[:SENSe]:RADio:CARRier:NUMBer SINGle | MULTiple

[:SENSe]:RADio:CARRier:NUMBer?

Select if single or multiple carriers are present on the output of the base station under test. This enables/disables a software filter for the rho and code domain power measurements.

SINGle – disable software filter.

MULTiple – enable software filter to mitigate the adjacent carrier effects.

Factory Preset: SINGle

Remarks: You must be in the cdmaOne, cdma2000, 1xEV-DO, or

iDEN (E4406A) mode to use this command. Use

INSTrument:SELect to set the mode.

Front Panel

Access: Mode Setup, Demod, RF Carrier

Enable 1xEV-DV

[:SENSe]:RADio:CONFigure:EVDV[:STATe] OFF|ON|0|1

[:SENSe]:RADio:CONFigure:EVDV[:STATe]?

Sets the measurement default settings to the values needed for making 1xEV-DV measurements. This supports the F-PDCH (forward packet data channel) and the 8PSK and 16QAM demodulation schemes that are needed for making code domain and modulation accuracy measurements.

To use this function you must have a license for 1xEV-DV Option 214.

Factory Preset: On

Saved State: Saved in instrument state

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Global to the current mode.

Front Panel

Access: Mode Setup, Demod

Radio Device Under Test

[:SENSe]:RADio:DEVice BTS MS

[:SENSe]:RADio:DEVice?

Select the type of radio device to be tested.

BTS - Base station transmitter test

MS - Mobile station transmitter test

Factory Preset: BTS

Remarks: Global to the current mode.

You must be in cdma2000, GSM, EDGE, W-CDMA or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Version A.03.00 or later

Front Panel

Access: Mode Setup, Radio, Device

Modulation Accuracy (Rho) Measurement

Commands for querying the rho measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after the Mod Accuracy (Rho) or Mod Accuracy (Composite Rho) measurement has been selected from the MEASURE key menu.

Modulation Accuracy - Active Data Channel

For cdma2000/1xEV-DV:

[:SENSe]:RHO:ACODe AUTO | COMBination

For 1xEV-DO:

[:SENSe]:RHO:ACODe AUTO | PREDefined

[:SENSe]:RHO:ACODe?

Select the Active Channel ID detection mode. This command is not available in the cdma2000 mode unless you have a license for 1xEV-DV option.

AUTO - detects the active channels automatically by checking power levels.

COMBination - sets predefined channels as active and also automatically detects other active channels by checking channel power levels. This affects the F-PDCH channel in forward link (BTS). (Channels can have unstable power levels which make them difficult to detect automatically, especially when 16QAM is being used.)

Note that even if a channel is predefined to be Off using SENSe:CDPower:<channel type>:STATe, if an active power level is detected on a channel by the automatic routine, it will be treated as an active channel.

PREDefined - sets predefined data channels as the active channels (from the Active Channel setting).

Factory Preset: AUTO

Remarks: You must be in the 1xEV-DO, cdma2000 mode to use

this command. Use INSTrument:SELect to set the

mode.

Front Panel

Access: Meas Setup

Modulation Accuracy (Rho)—ADC Range

12-bit ADC E4406A

[:SENSe]:RHO:ADC:RANGe

AUTO | APEak | APLock | NONE | M6 | P0 | P6 | P12 | P18 | P24

PSA and 14-bit ADC E4406A

[:SENSe]:RHO:ADC:RANGe AUTO APEak APLock NONE P0 P6 P12 P18

[:SENSe]:RHO:ADC:RANGe?

Select a ranging function for the ADC gain control. This is an advanced control that normally does not need to be changed. If you are measuring a CW signal, see the following description:

• AUTO - automatic ranging

For FFT spectrums, the auto ranging should not be used. An exception to this would be if you know that your signal is "bursty". Then you might use auto to maximize the time domain dynamic range as long as you are not very interested in the FFT data.

• APEak (Auto Peak) - automatic ranging to the peak signal level

For CW signals, the default of auto-peak ranging can be used, but a better FFT measurement of the signal can be made by selecting one of the manual ranges that is available by specifying M6, or P0 through P24.

Auto peaking can cause the ADC gain to monotonically track the ranges down during the data capture. This tracking effect should be negligible for the FFT spectrum, but selecting a manual range solves this possibility. Note that if the CW signal being measured is close to the auto-ranging threshold, the noise floor may shift as much as 6 dB every sweep.

• APLock (Auto Peak Lock) - automatic ranging locked to the peak signal level

For CW signals, auto-peak lock ranging may be used. It will find the ADC gain most appropriate for this particular signal and will not track the ranges as auto-peak can. Note that if the CW signal being measured is close to the auto-ranging threshold, the noise floor may shift as much as 6 dB every sweep.

SENSe Subsystem

For "bursty" signals, auto-peak lock ranging should not be used. Since the ADC range can often be locked to the wrong one resulting in overloading the ADC, the measurement will fail.

- NONE turns off any auto-ranging without making any changes to the current setting.
- M6 manually selects an ADC range that subtracts 6 dB from the fixed gain across the range. Manual ranging is best for CW signals.
- P0 thru P24 manually selects one of the ADC ranges that add 0 dB to 24 dB to the fixed gain across the range. Manual ranging is best for CW signals.

Factory Preset: M6

Remarks: You must be in the 1xEV-DO mode to use this

command. Use INSTrument:SELect to set the mode.

Modulation Accuracy (Rho)—Average Count

[:SENSe]:RHO:AVERage:COUNt <integer>

[:SENSe]:RHO:AVERage:COUNt?

Set the number of data acquisitions that will be averaged. After the specified number of averaging counts, the averaging mode (termination control) setting determines the averaging action.

Factory Preset: 10

Range: 1 to 10,000

Remarks: You must be in the cdmaOne, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Modulation Accuracy (Rho)—Averaging State

[:SENSe]:RHO:AVERage[:STATe] OFF ON |0|1

[:SENSe]:RHO:AVERage[:STATe]?

Turn the modulation accuracy averaging function on or off.

Factory Preset: OFF

ON for cdma2000, W-CDMA, 1xEV-DO

Remarks: You must be in the cdmaOne, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Modulation Accuracy (Rho)—Averaging Termination Control

[:SENSe]:RHO:AVERage:TCONtrol EXPonential | REPeat

[:SENSe]:RHO:AVERage:TCONtrol?

Select the type of termination control used for the averaging function. This determines the averaging action after the specified number of frames (average count) is reached.

EXPonential - Each successive data acquisition after the average count is reached, is exponentially weighted and combined with the existing average.

REPeat - After reaching the average count, the averaging is reset and a new average is started.

Factory Preset: REPeat for cdmaOne, cdma2000, W-CDMA, 1xEV-DO

Remarks: You must be in the cdmaOne, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Modulation Accuracy (Rho)—Chip Rate

[:SENSe]:RHO:CRATe <freq>

[:SENSe]:RHO:CRATe?

Enter a frequency value to set the chip rate.

Factory Preset: 1.2288 MHz for cdma2000, 1xEV-DO

3.84 MHz for W-CDMA

Range: 1.10592 to 1.35168 MHz for cdma2000, 1xEV-DO

3.456 to 4.224 MHz for W-CDMA

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Modulation Accuracy (Rho)— Walsh Code Column Index

[:SENSe]:RHO:INDex <integer>

[:SENSe]:RHO:INDex?

Inputs the Walsh code column index as defined by the standard C.S0003. This information is used to set the predefined active channels

SENSe Subsystem

that will be measured. To completely define the active channels, you should also enter the Walsh Mask value, the F-PDCH0 number/modulation type, and the F-PDCH1 number/modulation type. This command is not available unless the 1xEV-DV option is licensed and enabled.

Example: RHO: IND 2

Factory Preset: 0

Range: 0 to 3 (this is: 000, 010, 011, 011)

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, 1xEV-DV Predefined Active Chan

Modulation Accuracy (Rho)— Walsh Code Mask

[:SENSe]:RHO:MASK <integer>

[:SENSe]:RHO:MASK?

Inputs the Walsh Mask which is a 13-bit binary pattern. This information is used to set the predefined active channels that will be measured. To completely define the active channels, you should also enter the Walsh code column index, the F-PDCH0 number & modulation type, and the F-PDCH1 number & modulation type. This command is not available unless the 1xEV-DV option is licensed and enabled.

Example: RHO:MASK 5120 (equivalent to 1010000000000)

Factory Preset: 0

Range: 0 to FFFh (this is: 000000000000 to 1111111111111)

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, 1xEV-DV Predefined Active Chan

Modulation Accuracy (Rho)—Walsh Code Mask State

[:SENSe]:RHO:MASK:STATe OFF ON 0 1

[:SENSe]:RHO:MASK:STATe?

Turns on/off the Walsh Mask. The Walsh code is used to set the predefined active channels that will be measured. To completely define the active channels, you should also enter the Walsh code column index,

the F-PDCH0 number & modulation type, and the F-PDCH1 number & modulation type. This command is not available unless the 1xEV-DV option is licensed and enabled.

Example: RHO:MASK:STAT ON

Factory Preset: Off

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, 1xEV-DV Predefined Active Chan

Modulation Accuracy (Rho)—Multi Carrier Estimator

[:SENSe]:RHO:MCEStimator OFF ON 0 1

[:SENSe]:RHO:MCEStimator?

Turns the multi carrier estimator on or off.

OFF - computes the phase information only from one coded signal assuming that each code phase is perfectly aligned.

ON - aligns the code phases to be orthogonal before computing the phase information.

Factory Preset: OFF

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Modulation Accuracy (Rho)— F-PDCH Modulation Type

[:SENSe]:RHO:PDCH[0] | 1:MTYPe QPSK | QPSK | QAM16

[:SENSe]:RHO:PDCH[0] | 1:MTYPe?

Selects the modulation format of all the allowed subpackets in the active F-PDCH channels for QPSK, 8PSK, or 16QAM modulation. This information is used to set the predefined active channels that will be measured. To completely define the active channels, you should also enter the Walsh code column index, the Walsh Mask value, and the F-PDCH0/1 numbers. This command is not available unless the 1xEV-DV option is licensed and enabled.

Example: CDP:PDCH:MTYP QPSK

CDP:PDCH1:MTYP OPSK

Factory Preset: F-PDCH0 = QAM16

F-PDCH1 = QAM16

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, 1xEV-DV Predefined Active Chan

Modulation Accuracy (Rho)—F-PDCH Number

[:SENSe]:RHO:PDCH[0] | 1:NUMBer <integer>

[:SENSe]:RHO:PDCH[0] | 1:NUMBer?

Inputs F-PDCH0 number, or F-PDCH1 number (number of possible assigned Walsh code row indexes, see standard C.S0003). This information is used to set the predefined active channels that will be measured. To completely define the active channels, you should also enter the Walsh code column index, the Walsh Mask value, and the F-PDCH0/1 modulation types. This command is not available unless the 1xEV-DV option is licensed and enabled.

Example: RHO: PDCH: NUMB 7 F-PDCH0 is assigned to one of the

first 7 column indexes, i.e. 0 through 6.

RHO: PDCH1: NUMB 4 F-PDCH1 is assigned to one of the

next 4 column indexes, i.e. 7 through 10.

Factory Preset: F-PDCH0 = 1

F-PDCH1 = 0 (not active)

Range: 0 to 27

Where 0 means the F-PDCH is not active. The sum of F-PDCH0 + F-PDCH1 must be ≤ 28 .

Remarks: F-PDCH0 must be available before F-PDCH1 can be

used.

You must be in the cdma2000 mode to use this command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, 1xEV-DV Predefined Active Chan

Modulation Accuracy (Rho)—Spectrum Normal/Invert

[:SENSe]:RHO:SPECtrum INVert | NORMal

[:SENSe]:RHO:SPECtrum?

Set a spectrum either to normal or inverted for the demodulation related measurements. If set to INVert, the upper and lower spectrums

are swapped.

Factory Preset: NORMal

Remarks You must be in the cdmaOne, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Modulation Accuracy (Rho)—Long Code Mask

[:SENSe]:RHO:SYNC:LCMask <integer>

[:SENSe]:RHO:SYNC:LCMask?

Set the long code mask for MS measurement.

Factory Preset: 2,199,023,255,552 (20,000,000,000h)

Range: 0 to 4,398,046,511,103 (0h to 3F,FFF,FFF,FFFh)

Remarks: You must be in the cdma2000 mode to use this

command. Use INSTrument:SELect to set the mode.

Modulation Accuracy (Rho)—Trigger Source

[:SENSe]:RHO:TRIGger:SOURce

EXTernal[1] | External2 | FRAMe | IF | IMMediate | RFBurst

[:SENSe]:RHO:TRIGger:SOURce?

Select the trigger source used to control the data acquisitions.

EXTernal 1 – front panel external trigger input

EXTernal 2 – rear panel external trigger input

FRAMe – internal frame trigger

IF – internal IF envelope (video) trigger

IMMediate – the next data acquisition is immediately taken, capturing the signal asynchronously (also called free run).

RFBurst – internal wideband RF burst envelope trigger that has automatic level control for periodic burst signals.

Factory Preset: IMMediate

Remarks: You must be in the cdmaOne, cdma2000, W-CDMA, or

1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Meas Setup, Trig Source

Reference Oscillator Commands

Reference Oscillator External Frequency

[:SENSe]:ROSCillator:EXTernal:FREQuency <frequency>

[:SENSe]:ROSCillator:EXTernal:FREQuency?

Specify to the frequency of the external reference being supplied to the instrument. Switch to the external reference with ROSC:SOUR.

Preset

and *RST: Value remains at last user selected value (persistent)

Factory default, 10 MHz

Range: 1 MHz to 30 MHz, with 1 Hz steps

Default Unit: Hz

Remarks: Global to system

Front Panel

Access: System, Reference, Ref Oscillator

Reference Oscillator Rear Panel Output

[:SENSe]:ROSCillator:OUTPut[:STATe] OFF ON 0 1

[:SENSe]:ROSCillator:OUTPut?

Turn on and off the 10 MHz frequency reference signal going to the rear panel.

Preset

and *RST: Persistent State with factory default of On Remarks: Global to system. Was SENS:ROSC:REAR

Front Panel

Access: System, Reference, 10 MHz Out

Reference Oscillator Source

[:SENSe]:ROSCillator:SOURce INTernal EXTernal

[:SENSe]:ROSCillator:SOURce?

Select the reference oscillator (time base) source. Use ROSC: EXT: FREQ to tell the instrument the frequency of the external reference.

INTernal - uses internally generated 10 MHz reference signal

EXTernal - uses the signal at the rear panel external reference input port.

Preset

and *RST: Persistent State with factory default of Internal

Remarks: Global to system.

Front Panel

Access: System, Reference, Ref Oscillator

Spectrum Emission Mask Measurement (Spurious Emissions)

Commands for querying the Spectrum Emission Mask measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after selecting the measurement from the MEASURE key menu. Select the Spectrum Emission Mask measurement (for W-CDMA, cdma2000) or the Spurious Emissions and ACP measurement (for 1xEV-DO).

History: E4406A:

Added version A.04.00 and later

Spectrum Emission Mask—Average Count

[:SENSe]:SEMask:AVERage:COUNt <integer>

[:SENSe]:SEMask:AVERage:COUNt?

Set the number of data acquisitions that will be averaged. After the specified number of average count, the average mode (termination control) setting determines the average action.

Factory Preset: 10

Range: 1 to 10,000

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Averaging State

[:SENSe]:SEMask:AVERage[:STATe] OFF ON 0 1

[:SENSe]:SEMask:AVERage[:STATe]?

Turn the averaging function On or Off.

Factory Preset: OFF

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum Emission Mask—Reference Channel Integration Bandwidth

cdma2000, W-CDMA mode

[:SENSe]:SEMask:BANDwidth[n] | BWIDth[n]:INTegration <freq>

[:SENSe]:SEMask:BANDwidth[n] | BWIDth[n]:INTegration?

1xEV-DO mode

[:SENSe]:SEMask:BANDwidth|BWIDth:INTegration[m] <freq>

[:SENSe]:SEMask:BANDwidth|BWIDth:INTegration[m]?

Set the integration bandwidth that will be used for the reference channel.

 $BANDwidth[n] \mid BWIDth[n]$

n=1 is the base station test and n=2 is the mobile station test. The default is the base station test (1).

(cdma2000, W-CDMA mode only)

INTegration[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset: 1.23 MHz for cdma2000, 1xEV-DO

3.84 MHz for W-CDMA

Range: 100.0 kHz to 1.250 MHz

Default Unit: Hz

Default Offit. 112

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Reference Channel Resolution Bandwidth

cdma2000, W-CDMA mode

[:SENSe]:SEMask:BANDwidth[n] | BWIDth[n]:RESolution < freq>

[:SENSe]:SEMask:BANDwidth[n] | BWIDth[n]:RESolution?

1xEV-DO mode

[:SENSe]:SEMask:BANDwidth|BWIDth:RESolution[m] <freq>

[:SENSe]:SEMask:BANDwidth | BWIDth:RESolution [m]?

Set the resolution bandwidth for the reference channel.

BANDwidth[n] | BWIDth[n]

n=1 is the base station test and n=2 is the mobile station test. The default is the base station test (1).

(cdma2000, W-CDMA mode only)

RESolution[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset: No valid value as the default is set to Auto. See

[:SENS]:SEM:BAND[n]|BWID[n]:RES[m]:AUTO.

Range: 1.0 kHz to 7.5 MHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Auto Mode for Reference Channel Resolution Bandwidth

cdma2000, W-CDMA mode

[:SENSe]:SEMask:BANDwidth[n] | BWIDth[n]:RESolution:AUTO

OFF ON 0 1

[:SENSe]:SEMask:BANDwidth[n] | BWIDth[n]:RESolution:AUTO?

1xEV-DO mode

[:SENSe]:SEMask:BANDwidth | BWIDth:RESolution[m]:AUTO

OFF ON 0 1

[:SENSe]:SEMask:BANDwidth|BWIDth:RESolution[m]:AUTO?

Set the auto mode to determine the resolution bandwidth to On or Off. If set to Off, enter a frequency value referring to

[:SENS]:SEM:BAND[n]|BWID[n]:RES[m].

BANDwidth[n] | BWIDth[n]

n=1 is the base station test and n=2 is the mobile station test. The default is the base station test (1).

(cdma2000, W-CDMA mode only)

RESolution[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset: ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Detector Mode

[:SENSe]:SEMask:DETector[:FUNCtion] AAVerage POSitive

[:SENSe]:SEMask:DETector[:FUNCtion]?

Select one of the detector modes for spectrum measurements.

AAVerage (absolute average) - the absolute average power in each frequency is measured across the spectrum

POSitive - the positive peak power in each frequency is measured across the spectrum

Factory Preset: AAVerage (absolute average)

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Channel Frequency Span

[:SENSe]:SEMask:FREQuency[n]:SPAN[m] <freq>

[:SENSe]:SEMask:FREQuency[n]:SPAN[m]?

Enter a frequency value to set the channel frequency span for the reference channel integration.

FREQuency[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

SPAN[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset: 1.25 MHz for cdma2000, 1xEV-DO

5.0 MHz for W-CDMA

Range: 100.0 kHz to 10.0 MHz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Reference Channel Step Frequency

cdma2000, W-CDMA mode

[:SENSe]:SEMask:FREQuency[n]:STEP <freq>

[:SENSe]:SEMask:FREQuency[n]:STEP?

1xEV-DO mode

[:SENSe]:SEMask:FREQuency:STEP[m] <freq>

[:SENSe]:SEMask:FREQuency:STEP[m]?

Enter a frequency value to set the step frequency for the reference channel integration.

FREQuency[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

STEP[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset: No valid value as the default is set to Auto. See

[:SENS]:SEM:FREQ[n]:STEP[m]:AUTO.

Range: 100 Hz to 7.5 MHz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Auto Mode for Reference Channel Step Frequency

cdma2000, W-CDMA mode

 $\hbox{\tt [:SENSe]:SEMask:FREQuency[n]:STEP:AUTO\ OFF\,|\,ON\,|\,0\,|\,1}\\$

[:SENSe]:SEMask:FREQuency[n]:STEP:AUTO?

1xEV-DO mode

[:SENSe]:SEMask:FREQuency:STEP[m]:AUTO OFF ON 0 1

[:SENSe]:SEMask:FREQuency:STEP[m]:AUTO?

Set the auto mode to determine the step frequency to On or Off.

OFF - enter a value to set the step frequency for the reference channel integration, referring to [:SENS]:SEM:FREQ[n]:STEP[m].

ON - the step frequency for the reference channel integration is set to a half of the resolution bandwidth.

FREQuency[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

STEP[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset: ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Resolution Bandwidth

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth | BWIDth
<res bw>,<res bw>,<res bw>,<res bw>,

[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth|BWIDth?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth | BWIDth
<res bw>,<res bw>,<res bw>,<res bw>,

[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth|BWIDth?

Define the offset resolution bandwidth for Spectrum Emission Mask measurements. The list must contain five (5) entries. You can turn off (not use) specific offsets with [:SENS]:SEM:OFFS[n]:LIST[m]:STAT.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	3.00 kHz	30.00 kHz	30.0 kHz	6.25 kHz	1.000 MHz
	MS	30.00 kHz	30.00 kHz	6.25 kHz	1.000 MHz	1.000 MHz
W-CDMA	BTS	30.00 kHz	30.00 kHz	30.00 kHz	50.00 kHz	1.000 MHz
	MS	30.00 kHz	1.000 MHz	1.000 MHz	1.000 MHz	1.000 MHz
1xEV-DO	SEM	3.000 kHz	30.00 kHz	30.00 kHz	$6.250~\mathrm{kHz}$	1.000 MHz
	ACP	3.000 kHz	30.00 kHz	30.00 kHz	30.00 kHz	30.00 kHz

Range: 300 Hz to 7.5 MHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Auto Offset Resolution Bandwidth

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth|BWIDth:AUTO?

1xEV-DO mode

 $\begin{tabular}{ll} [:SENSe] : SEMask: OFFSet: LIST [m] : BANDwidth | BWIDth: AUTO OFF | ON | 0 | 1, OFF | ON | 0 | 1, OFF | ON | 0 | 1, OFF | ON | 0 | 1 \\ \hline \end{tabular}$

[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth|BWIDth:AUTO?

Set the auto mode to determine the offset resolution bandwidth to On or Off.

OFF - enter a value to set the resolution bandwidth for an offset channel, referring to [:SENS]:SEM:OFFS[n]:LIST[m]BAND|BWID.

ON - the resolution bandwidth for an offset channel is automatically set according to the offset start and stop frequencies.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000.

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset and *RST:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000		OFF	OFF	OFF	OFF	OFF
W-CDMA		OFF	OFF	OFF	OFF	OFF
1xEV-DO	SEM	OFF	OFF	OFF	OFF	OFF
	ACP	OFF	OFF	OFF	OFF	OFF

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Resolution Bandwidth Multiplier

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth|BWIDth:IMULti

<integer>,<integer>,<integer>,<integer>

[:SENSe]:SEMask:OFFSet[n]:LIST:BANDwidth|BWIDth:IMULti?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth|BWIDth:IMULti

<integer>,<integer>,<integer>,<integer>

[:SENSe]:SEMask:OFFSet:LIST[m]:BANDwidth|BWIDth:IMULti?

Specify a multiplier of the offset resolution bandwidth for the offset measurement integration bandwidth.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	10	1	1	1	1
	MS	1	1	1	1	1
W-CDMA	BTS	1	1	1	20	1
	MS	1	1	1	1	1
1xEV-DO	SEM	10	1	1	1	1
	ACP	10	1	1	1	1

Range: $1 \text{ to } ((Stop frequency} - Start frequency}) / Resolution$

bandwidth)

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Start Frequency

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STARt

<f offset>,<f offset>,<f offset>,<f offset>

[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STARt?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STARt

<f offset>,<f offset>,<f offset>,<f offset>,<f

[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STARt?

Set the five (5) sets of the offset start frequencies.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	765.0 kHz	795.0 kHz	1.195 MHz	3.2531 MHz	7.500 MHz
	MS	900.0 kHz	1.995 MHz	2.2531 MHz	8.500 MHz	12.50 MHz
W-CDMA	BTS	2.515 MHz	2.715 MHz	3.515 MHz	4.000 MHz	8.000 MHz
	MS	2.515 MHz	4.000 MHz	7.500 MHz	8.5 00MHz	12.50 MHz
1xEV-DO	SEM	765.0 kHz	795.0 kHz	1.995 MHz	3.2531 MHz	7.500 MHz
	ACP	765.0 kHz	1.995 MHz	3.125 MHz	4.000 MHz	7.500 MHz

Range: 10.0 kHz to 100.0 MHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Step Frequency

cdma2000, W-CDMA mode

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset: No valid value as the default is set to Auto. See

W-CDMA mode only)

[:SENS]:SEM:OFF[n]:LIST[m]:FREQ:STEP:AUTO.

Range: 100 Hz to 7.5 MHz

The minimum value is determined to be equal to or greater than one 2000th (1/2000) of the frequency difference derived from (Stop Freq – Start Freq).

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Auto Offset Step Frequency

cdma2000, W-CDMA mode

```
 \begin{tabular}{ll} [:SENSe] : SEMask:OFFSet [n] : LIST:FREQuency:STEP:AUTO \\ OFF | ON | 0 | 1,OFF | ON | 0 | 1,OFF | ON | 0 | 1,OFF | ON | 0 | 1 \\ \hline \end{tabular}
```

[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STEP:AUTO?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STEP:AUTO OFF \mid ON \mid 0 \mid 1, OFF \mid ON \mid 0 \mid 1

[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STEP:AUTO?

Set the auto mode to determine the offset step frequency to On or Off.

OFF - enter a value to set the step frequency for an offset channel, referring to [:SENS]:SEM:OFFS[n]:LIST[m]:FREQ:STEP.

ON - the step frequency for an offset channel is automatically set according to the offset start and stop frequencies.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000		ON	ON	ON	ON	ON
W-CDMA		ON	ON	ON	ON	ON
1xEV-DO	SEM	ON	ON	ON	ON	ON
	ACP	ON	ON	ON	ON	ON

Remarks: You must be in cdma2000, W-CDMA, or 1xEV-DO mode

to use this command. Use INSTrument:SELect to set

the mode.

Spectrum Emission Mask—Offset Stop Frequency

cdma2000, W-CDMA mode

```
[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STOP
<f offset>,<f offset>,<f offset>,<f offset>,<f</pre>
```

[:SENSe]:SEMask:OFFSet[n]:LIST:FREQuency:STOP?

1xEV-DO mode

```
[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STOP
<f offset>,<f offset>,<f offset>,<f offset>
```

[:SENSe]:SEMask:OFFSet:LIST[m]:FREQuency:STOP?

Sets the five (5) sets of the offset stop frequencies.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	795.0 kHz	1.195 MHz	4.015 MHz	4.0031 MHz	12.50 MHz
	MS	1.995 MHz	4.015 MHz	4.0031 MHz	12.00 MHz	15.00 MHz
W-CDMA	BTS	2.715 MHz	3.515 MHz	4.000 MHz	8.000 MHz	12.50 MHz
	MS	3.485 MHz	7.500 MHz	8.500 MHz	12.00 MHz	15.00 MHz
1xEV-DO	SEM	795.0 kHz	1.995 MHz	4.015 MHz	4.0031 MHz	12.50 MHz
	ACP	765.0 kHz	1.995 MHz	3.125 MHz	4.000 MHz	7.500 MHz

Range: 10.0 kHz to 100.0 MHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Relative Attenuation

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:RATTenuation

<rel power>,<rel power>,<rel power>,<rel power>,<rel power>

[:SENSe]:SEMask:OFFSet[n]:LIST:RATTenuation?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:RATTenuation

<rel power>,<rel power>,<rel power>,<rel power>,<rel power>

[:SENSe]:SEMask:OFFSet:LIST[m]:RATTenuation?

Set a relative amount of attenuation for the measurements made at an offset channel. The amount is specified relative to the attenuation required to measure the carrier channel. Since the offset channel power is lower than the carrier channel power, less attenuation is required to measure the offset channel and you get wider dynamic range for the measurement.

You can turn off (not use) specific offset channels with [:SENS]:SEM:OFFS[n]:LIST[m]:STAT.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	0.00 dB				
W-CDMA	0.00 dB				
1xEV-DO	0.00 dB				

Range: -40.00 to 0.00 dB, but this relative attenuation cannot

exceed the absolute attenuation ranging from 0 to 40

dB.

Default Unit: dB

Remarks: Remember that the attenuation that you specify is

always relative to the amount of attenuation used for the carrier channel. Selecting negative attenuation means that you want less attenuation used. For example, if the measurement must use 20 dB of

attenuation for the carrier measurement and you want to use 12 dB less attenuation for the first offset, you

would send the value - 12 dB.

You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Frequency Side

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:SIDE BOTH | NEGative | POSitive,

BOTH | NEGative | POSitive, BOTH | NEGative | POSitive, BOTH | NEGative | POSitive, BOTH | NEGative | POSitive

[:SENSe]:SEMask:OFFSet[n]:LIST:SIDE?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:SIDE BOTH NEGative POSitive,

BOTH | NEGative | POSitive, BOTH | NEGative | POSitive, BOTH | NEGative | POSitive, BOTH | NEGative | POSitive

[:SENSe]:SEMask:OFFSet:LIST[m]:SIDE?

Specify which sideband will be measured. You can turn off (not use)

specific offsets with [:SENS]:SEM:OFFS[n]:LIST[m]:STAT.

BOTH - both of the negative (lower) and positive (upper) sidebands

NEGative - negative (lower) sideband only

POSitive - positive (upper) sideband only

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000		вотн	ВОТН	ВОТН	ВОТН	ВОТН
W-CDMA		вотн	ВОТН	ВОТН	ВОТН	вотн
1xEV-DO	SEM	вотн	ВОТН	ВОТН	ВОТН	вотн
	ACP	вотн	ВОТН	ВОТН	ВОТН	ВОТН

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Start Absolute Power Limit

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:STARt:ABSolute

<abs_power>,<abs_power>,<abs_power>,<abs_power>,<abs_power>

[:SENSe]:SEMask:OFFSet[n]:LIST:STARt:ABSolute?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:STARt:ABSolute

<abs power>,<abs power>,<abs power>,<abs power>,<abs power>

[:SENSe]:SEMask:OFFSet:LIST[M]:STARt:ABSolute?

Sets an absolute power level for each offset start limit. The list must contain five (5) entries. If there is more than one offset, the offset closest to the carrier channel comes first in the list.

The fail condition for each offset channel is set by [:SENS]:SEM:OFFS[n]:LIST[m]:TEST.

You can turn off (not use) specific offset channels with

[:SENS]:SEM:OFFS[n]:LIST[m]:STAT.

The query returns the five (5) sets of the real values currently set to the absolute power test limits.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	– 27.00 dBm	- 27.00 dBm	- 27.00 dBm	- 46.00 dBm	- 13.00 dBm
	MS	– 70.13 dBm	- 70.13 dBm	- 35.00 dBm	- 13.00 dBm	- 13.00 dBm
W-CDMA	BTS	- 12.50 dBm	- 12.50 dBm	- 24.50 dBm	- 11.50 dBm	- 11.50 dBm
	MS	- 69.57 dBm	- 54.34 dBm	- 54.34 dBm	- 54.34 dBm	- 54.34 dBm
1xEV-DO	SEM	- 27.00 dBm	- 27.00 dBm	- 27.00 dBm	- 46.00 dBm	- 13.00 dBm
	ACP	- 27.00 dBm	- 27.00 dBm	- 13.00 dBm	- 13.00 dBm	- 13.00 dBm

Range: -200.0 dBm to 50.0 dBm

Default Unit: dBm

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Start Relative Power Limit

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:STARt:RCARrier

<rel power>,<rel power>,<rel power>,<rel power>

[:SENSe]:SEMask:OFFSet[n]:LIST:STARt:RCARrier?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:STARt:RCARrier

<rel power>,<rel power>,<rel power>,<rel power>,

[:SENSe]:SEMask:OFFSet:LIST[m]:STARt:RCARrier?

Set a relative power level for each offset start limit. The list must contain five (5) entries. If there is more than one offset, the offset closest to the carrier channel comes first in the list.

The fail condition is set by [:SENS]:SEM:OFFS[n]:LIST[m]:TEST for each offset channel test.

You can turn off (not use) specific offset channels with [:SENS]:SEM:OFFS[n]:LIST[m]:STAT.

The query returns the five (5) sets of the real values currently set to the relative power test limits.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	- 45.00 dB	- 45.00 dB	- 55.00 dB	- 55.00 dB	- 55.00 dB
	MS	- 42.00 dB	- 54.00 dB	- 54.00 dB	- 54.00 dB	- 54.00 dB
W-CDMA	BTS	- 30.00 dB				
	MS	- 33.73 dB	- 34.00 dB	– 37.50 dB	- 47.50 dB	- 47.50 dB
1xEV-DO	SEM	- 45.00 dB	-45.00 dB	- 55.00 dB	- 55.00 dB	- 55.00 dB
	ACP	- 45.00 dB	- 55.00 dB	- 55.00 dB	- 55.00 dB	- 55.00 dB

Range: - 150.0 dBm to 50.0 dB

Default Unit: dB

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Measurement State

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:STATe

OFF | ON | 0 | 1, OFF | ON | 0 | 1

[:SENSe]:SEMask:OFFSet[n]:LIST:STATe?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:STATe

OFF | ON | 0 | 1, OFF | ON | 0 | 1

[:SENSe]:SEMask:OFFSet:LIST[m]:STATe?

Define whether or not to execute pass/fail tests at the offset channels. The pass/fail conditions are set by [:SENS]:SEM:OFFS[n]:LIST[m]:ABS or [:SENS]:SEM:OFFS[n]:LIST[m]:RCAR for each offset channel.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	ON	ON	ON	OFF	OFF
	MS	ON	ON	OFF	OFF	OFF
W-CDMA	BTS	ON	ON	ON	ON	ON
	MS	ON	ON	ON	ON	OFF
1xEV-DO	SEM	ON	ON	ON	OFF	OFF
	ACP	ON	ON	OFF	OFF	OFF

Remarks:

You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum Emission Mask—Offset Stop Absolute Power Limit

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:ABSolute

<abs power>,<abs power>,<abs power>,<abs power>,<abs power>

[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:ABSolute?

1xEV-DO. mode

[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:ABSolute

<abs power>,<abs power>,<abs power>,<abs power>,<abs power>

[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:ABSolute?

SENSe Subsystem

Set an absolute power level to for each offset stop limit. The list must contain five (5) entries. If there is more than one offset, the offset closest to the carrier channel comes first in the list.

The fail condition is set by [:SENS]:SEM:OFFS[n]:LIST[m]:TEST for each offset channel test.

You can turn off (not use) specific offset channels with [:SENS]:SEM:OFFS[n]:LIST[m]:STAT.

The query returns the five (5) sets of the real values currently set to the offset stop absolute power limits.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	- 27.00 dBm	- 27.00 dBm	- 27.00 dBm	- 46.00 dBm	- 13.00 dBm
	MS	- 70.13 dBm	- 70.13 dBm	- 35.00 dBm	- 13.00 dBm	- 13.00 dBm
W-CDMA	BTS	- 12.50 dBm	- 24.50 dBm	- 24.50 dBm	- 11.50 dBm	- 11.50 dBm
	MS	- 69.57 dBm	– 54.34 dBm	– 54.34 dBm	- 54.34 dBm	– 54.34 dBm
1xEV-DO	SEM	- 27.00 dBm	- 27.00 dBm	- 27.00 dBm	- 46.00 dBm	- 13.00 dBm
	ACP	- 27.00 dBm	- 27.00 dBm	- 13.00 dBm	- 13.00 dBm	- 13.00 dBm

Range: -200.0 dBm to 50.0 dBm

Default Unit: dBm

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Couple Offset Stop Absolute Power Limit

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:ABSolute:COUPle?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:ABSolute:COUPle?

Define whether or not to couple the offset stop absolute power limit to the offset start absolute power limit for each offset channel.

You can turn off (not use) specific offset channels with [:SENS]:SEM:OFFS[n]:LIST[m]:STAT.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	ON	ON	ON	ON	ON
	MS	ON	ON	ON	ON	ON
W-CDMA	BTS	ON	OFF	ON	ON	ON
	MS	ON	ON	ON	ON	ON
1xEV-DO	SEM	ON	ON	ON	ON	ON
	ACP	ON	ON	ON	ON	ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Stop Relative Power Limit

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:RCARrier

<rel_power>,<rel_power>,<rel_power>,<rel_power>

[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:RCARrier?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:RCARrier

<rel power>,<rel power>,<rel power>,<rel power>,<rel power>

[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:RCARrier?

Set a relative power level for each offset stop limit. The list must contain five (5) entries. If there is more than one offset, the offset closest to the carrier channel comes first in the list.

The fail condition is set by [:SENS]:SEM:OFFS[n]:LIST[m]:TEST for each offset channel.

You can turn off (not use) specific offset channels with [:SENS]:SEM:OFFS[n]:LIST[m]:STAT.

The query returns the five (5) sets of the real values currently set to the offset stop relative power limits.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	- 45.00 dB	-45.00 dB	- 55.00 dB	- 55.00 dB	- 55.00 dB
	MS	- 42.00 dB	- 54.00 dB	– 54.00 dB	- 54.00 dB	- 54.00 dB
W-CDMA	BTS	- 30.00 dB				
	MS	- 48.28 dB	- 37.50 dB	– 47.50 dB	-47.50 dB	- 47.50 dB
1xEV-DO	SEM	- 45.00 dB	-45.00 dB	– 55.00 dB	- 55.00 dB	– 55.00 dB
	ACP	- 45.00 dB	- 55.00 dB	– 55.00 dB	- 55.00 dB	- 55.00 dB

Range: - 150.0 dBm to 50.0 dB

Default Unit: dB

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Couple Offset Stop Relative Power Limit

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:STOP:RCARrier:COUPle?

1xEV-DO mode

 $\begin{tabular}{ll} [:SENSe]: SEMask: OFFSet: LIST [m]: STOP: RCARrier: COUPle \\ OFF | ON | 0 | 1, OFF | ON | 0 | 1, OFF | ON | 0 | 1, OFF | ON | 0 | 1 \\ \hline \end{tabular}$

[:SENSe]:SEMask:OFFSet:LIST[m]:STOP:RCARrier:COUPle?

Define whether or not to couple the offset stop relative power limit to the offset start relative power limit for each offset channel.

You can turn off (not use) specific offset channels with [:SENS]:SEM:OFFS[n]:LIST[m]:STAT.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	ON	ON	ON	ON	ON
	MS	ON	ON	ON	ON	ON
W-CDMA	BTS	ON	ON	ON	ON	ON
	MS	OFF	OFF	OFF	ON	ON
1xEV-DO	SEM	ON	ON	ON	ON	ON
	ACP	ON	ON	ON	ON	ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Offset Channel Fail Condition

cdma2000, W-CDMA mode

[:SENSe]:SEMask:OFFSet[n]:LIST:TEST

ABSolute AND OR RELative, ABSolute AND OR RELative,

ABSolute AND OR RELative, ABSolute AND OR RELative,

ABSolute AND OR RELative

[:SENSe]:SEMask:OFFSet[n]:LIST:TEST?

1xEV-DO mode

[:SENSe]:SEMask:OFFSet:LIST[m]:TEST

ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative,

ABSolute AND OR RELative

[:SENSe]:SEMask:OFFSet:LIST[m]:TEST?

Define one of the fail conditions for each offset channel limit test to be done. The absolute or relative power limit value for each offset channel is set by [:SENS]:SEM:OFFS[n]:LIST[m]:ABS or [:SENS]:SEM:OFFS[n]:LIST[m]:RCAR.

You can turn off (not use) specific offset channels with [:SENS]:SEM:OFFS[n]:LIST[m]:STAT.

OFFSet[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

LIST[m] m=1 is the spectrum emission mask (SEM) mode and

m=2 is the adjacent channel power (ACP) mode. The default is the SEM mode (1). (1xEV-DO mode only)

The fail condition that can be set for each offset channel include:

- AND Tests the measurement result for an offset channel against both the absolute power limit and the relative power limit. If it fails, then returns a failure for that measurement test.
- ABSolute Tests the measurement result for an offset channel against the absolute power limit. If it fails, then returns a failure for that measurement test.
- OR Tests the measurement result for an offset channel against the absolute power limit OR the relative power limit. If either test fails, then returns a failure for that measurement test.
- RELative Tests the measurement result for an offset channel against the relative power limit. If it fails, then returns a failure for that measurement test.

Factory Preset:

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
cdma2000	BTS	REL	REL	REL	ABS	REL
	MS	AND	AND	ABS	REL	REL
W-CDMA	BTS	ABS	ABS	ABS	ABS	ABS
	MS	AND	AND	AND	AND	AND

Mode	Variant	Offset A	Offset B	Offset C	Offset D	Offset E
1xEV-DO	SEM	REL	REL	REL	ABS	REL
	ACP	REL	REL	ABS	REL	REL

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Region Resolution Bandwidth

cdma2000, W-CDMA mode

[:SENSe]:SEMask:REGion[n]:LIST:BANDwidth|BWIDth
<res bw>,<res bw>,<res bw>,<res bw>,

[:SENSe]:SEMask:REGion[n]:LIST:BANDwidth | BWIDth?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:BANDwidth|BWIDth
<res_bw>,<res_bw>,<res_bw>,<res_bw>

[:SENSe]:SEMask:REGion:LIST:BANDwidth | BWIDth?

Define the region resolution bandwidth(s) for spectrum emission measurements. The list must contain five (5) entries. You can turn off (not use) specific regions with [:SENS]:SEM:REG[n]:LIST:STAT.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset

and *RST: Auto coupled, except cdma2000, see below.

Mode	Variant	Region A	Region B	Region C	Region D	Region E
cdma200 0	BTS	1.000 MHz	300.0 kHz	100.0 kHz	100.0 kHz	4.000 MHz
	MS	300.0 kHz	100.0 kHz	100.0 kHz	100.0 kHz	12.00 MHz

Range: 300 Hz to 7.5 MHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Auto Region Resolution Bandwidth

cdma2000, W-CDMA mode

 $\begin{tabular}{ll} [:SENSe]: SEMask: REGion [n]: LIST: BANDwidth & | BWIDth: AUTO OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 1, OFF & | ON & | 0 & | 0 & | 1, OFF & | ON & | 0 & | 0 & | 1, OFF & | ON & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0 & | 0$

 $\verb|[:SENSe]:SEMask:REGion[n]:LIST:BANDwidth | BWIDth:AUTO?$

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:BANDwidth|BWIDth:AUTO OFF|ON|0|1,OFF|ON|0|1,OFF|ON|0|1,OFF|ON|0|1

[:SENSe]:SEMask:REGion:LIST:BANDwidth|BWIDth:AUTO?

Set the auto mode of the region step frequency.

Set the auto mode to determine the region resolution bandwidth to On or Off.

OFF - enter a value to set the resolution bandwidth for a region channel, referring to [:SENS]:SEM:REG[n]:LIST:BAND | BWID.

ON - the resolution bandwidth for a region channel is automatically set according to the region start and stop frequencies.

REGion[n]

n=1 is the base station test and n=2 is the mobile test. The default is the base station test (1). (cdma2000, W-CDMA mode only)

Factory Preset and *RST:

Mode	Region A	Region B	Region C	Region D	Region E
cdma2000	OFF	OFF	OFF	OFF	OFF
W-CDMA	ON	ON	ON	ON	ON
1xEV-DO	ON	ON	ON	ON	ON

Remarks:

You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum Emission Mask—Region Start Frequency

cdma2000, W-CDMA mode

[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STARt
<f region>,<f region>,<f region>,<f region>

[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STARt?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:FREQuency:STARt

<f region>,<f region>,<f region>,<f region>

[:SENSe]:SEMask:REGion:LIST:FREQuency:STARt?

Set the five (5) sets of the region start frequencies.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset and *RST:

Mode	Variant	Region A	Region B	Region C	Region D	Region E
cdma2000	BTS	1920.5 MHz	1893.65 MHz	876.05 MHz	921.05 MHz	800.0 MHz
	MS	1920.5 MHz	925.05 MHz	935.05 MHz	1805.05 MHz	800.0 MHz
W-CDMA	n/a	1920.0 MHz	1893.5 MHz	2100.0 MHz	2175.0 MHz	800.0 MHz
1xEV-DO	n/a	1920.0 MHz	1893.5 MHz	2100.0 MHz	2175.0 MHz	800.0 MHz

Range: 329.0 MHz to 3.678 GHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Region Step Frequency

cdma2000, W-CDMA mode

[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STEP

<f region>,<f region>,<f region>,<f region>

[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STEP?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:FREQuency:STEP

<f_region>,<f_region>,<f_region>,<f_region>,

[:SENSe]:SEMask:REGion:LIST:FREQuency:STEP?

Sets the five (5) sets of the region step frequencies.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset: No valid value as the default is set to Auto. See

[:SENS]:SEM:REG[n]:LIST:FREQ:STEP:AUTO.

Range: 100 Hz to 7.5 MHz

The minimum value is determined to be equal to or greater than one 2000th (1/2000) of the frequency difference derived from (Stop Freq – Start Freq).

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Auto Region Step Frequency

cdma2000, W-CDMA mode

 $\begin{tabular}{ll} [:SENSe]: SEMask: REGion [n]: LIST: FREQuency: STEP: AUTO \\ OFF | ON | 0 | 1, OFF | ON | 0 | 1, OFF | ON | 0 | 1, OFF | ON | 0 | 1 \\ \hline \end{tabular}$

[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STEP:AUTO?

1xEV-DO mode

 $\begin{tabular}{ll} [:SENSe] : SEMask: REGion: LIST: FREQuency: STEP: AUTO \\ OFF | ON | 0 | 1, OFF | ON | 0 | 1, OFF | ON | 0 | 1, OFF | ON | 0 | 1 \\ \hline \end{tabular}$

[:SENSe]:SEMask:REGion:LIST:FREQuency:STEP:AUTO?

Set the auto mode to determine the region step frequency to On or Off.

OFF - enter a value to set the step frequency for a region channel, referring to [:SENS]:SEM:REG[n]:LIST:FREQ:STEP.

ON - the step frequency for a region channel is automatically set according to the region start and stop frequencies.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset:

Mode	Region A	Region B	Region C	Region D	Region E
cdma2000	ON	ON	ON	ON	ON
W-CDMA	ON	ON	ON	ON	ON
1xEV-DO	ON	ON	ON	ON	ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument: SELect to

set the mode.

Spectrum Emission Mask—Region Stop Frequency

cdma2000, W-CDMA mode

[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STOP

<f_region>,<f_region>,<f_region>,<f_region>

[:SENSe]:SEMask:REGion[n]:LIST:FREQuency:STOP?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:FREQuency:STOP

<f_region>,<f_region>,<f_region>,<f_region>,<f_region>

[:SENSe]:SEMask:REGion:LIST:FREQuency:STOP?

Sets the five (5) sets of the region stop frequencies.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset and *RST:

Mode	Variant	Region A	Region B	Region C	Region D	Region E
cdma2000	BTS	1980.5 MHz	1919.75 MHz	915.05 MHz	960.05 MHz	1000.0 MHz
	MS	1980.5 MHz	935.05 MHz	960.05 MHz	1880.05 MHz	1000.0 MHz
W-CDMA	n/a	1980.0 MHz	1919.6 MHz	2105.0 MHz	2180.0 MHz	1000.0 MHz
1xEV-DO	n/a	1980.0 MHz	1919.6 MHz	2105.0 MHz	2180.0 MHz	1000.0 MHz

Range: 329.0 MHz to 3.678 MHz

Default Unit: Hz

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Region Relative Attenuation

cdma2000, W-CDMA mode

[:SENSe]:SEMask:REGion[n]:LIST:RATTenuation

<rel_power>,<rel_power>,<rel_power>,<rel_power>

[:SENSe]:SEMask:REGion[n]:LIST:RATTenuation?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:RATTenuation

<rel power>,<rel power>,<rel power>,<rel power>,<rel power>

[:SENSe]:SEMask:REGion:LIST:RATTenuation?

Set a relative amount of attenuation for measurements made at a region. The amount is specified relative to the attenuation required to measure the carrier channel power. Since the region channel power is lower than the carrier channel power, less attenuation is required to measure the region channel and you get wider dynamic range for the measurement.

You can turn off (not use) specific regions with [:SENS]:SEM:REG[n]:LIST:STAT.

REGion[n]

n=1 is the base station test and n=2 is the mobile test. The default is the base station test (1). (cdma2000, W-CDMA mode only)

Factory Preset:

Mode	Variant	Region A	Region B	Region C	Region D	Region E
cdma2000	BTS	0.00 dB				
	MS	0.00 dB				
W-CDMA	n/a	0.00 dB				
1xEV-DO	n/a	0.00 dB				

Range: -40.00 to 0.00 dB, but this relative attenuation cannot

exceed the absolute attenuation ranging from 0.00 to

40.00 dB.

Remarks: Remember that the attenuation that you specify is

always relative to the amount of attenuation used for the carrier channel. Selecting negative attenuation means that you want less attenuation used. For example, if the measurement must use 20 dB of

attenuation for the carrier measurement and you want to use 12 dB less attenuation for the first region, you

would send the value -12 dB.

You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument: SELect to

set the mode.

Spectrum Emission Mask—Region Start Absolute Power Limit

cdma2000, W-CDMA (3GPP) mode

[:SENSe]:SEMask:REGion[n]:LIST:STARt:ABSolute

<abs power>,<abs_power>,<abs_power>,<abs_power>,<abs_power>

[:SENSe]:SEMask:REGion[n]:LIST:STARt:ABSolute?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:STARt:ABSolute

<abs power>,<abs_power>,<abs_power>,<abs_power>,<abs_power>

[:SENSe]:SEMask:REGion:LIST:STARt:ABSolute?

Set an absolute power level for each region start limit. The list must contain five (5) entries. If there is more than one region, the region closest to the carrier channel comes first in the list.

The fail condition for each region channel is set by [:SENS]:SEM:REG[n]:LIST:TEST.

You can turn off (not use) specific regions with [:SENS]:SEM:REG[n]:LIST:STAT.

The query returns the five (5) sets of the real values currently set to the absolute power test limits.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset:

Mode	Variant	Region A	Region B	Region C	Region D	Region E
cdma2000	BTS	- 86.00 dBm	- 41.00 dBm	- 98.00 dBm	- 57.00 dBm	- 50.00 dBm
	MS	- 41.00 dBm	- 67.00 dBm	- 79.00 dBm	- 71.00 dBm	- 50.00 dBm
W-CDMA		- 50.00 dBm				
1xEV-DO		- 50.00 dBm				

Range: -200.00 dBm to 50.00 dBm

Default Unit: dBm

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Region Start Relative Power Limit cdma2000, W-CDMA mode

[:SENSe]:SEMask:REGion[n]:LIST:STARt:RCARrier

<rel power>,<rel power>,<rel power>,<rel power>,<rel power>

[:SENSe]:SEMask:REGion[n]:LIST:STARt:RCARrier?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:STARt:RCARrier

<rel power>,<rel power>,<rel power>,<rel power>,<rel power>

[:SENSe]:SEMask:REGion:LIST:STARt:RCARrier?

Set a relative power level for each region start limit. The list must contain five (5) entries. If there is more than one region, the region closest to the carrier channel comes first in the list.

The fail condition is set by [:SENS]:SEM:REG[n]:LIST:TEST for each region test.

You can turn off (not use) specific regions with [:SENS]:SEM:REG[n]:LIST:STAT.

The query returns the five (5) sets of the real values currently set to the relative power test limits.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset:

Mode	Region A	Region B	Region C	Region D	Region E
cdma2000	- 30.00 dB				
W-CDMA	- 30.00 dB				
1xEV-DO	- 30.00 dB				

Range: - 150.00 dBm to 50.00 dB

Default Unit: dB

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Control Region List State

cdma2000, W-CDMA mode

[:SENSe]:SEMask:REGion[n]:LIST:STATe

 $\texttt{OFF} \, | \, \texttt{ON} \, | \, \texttt{0} \, | \, \texttt{1,OFF} \, | \, \texttt{ON} \, | \, \texttt{0} \, | \, \texttt{1,OFF} \, | \, \texttt{ON} \, | \, \texttt{0} \, | \, \texttt{1,OFF} \, | \, \texttt{ON} \, | \, \texttt{0} \, | \, \texttt{1}$

[:SENSe]:SEMask:REGion[n]:LIST:STATe?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:STATe

OFF | ON | 0 | 1, OFF | ON | 0 | 1

[:SENSe]:SEMask:REGion:LIST:STATe?

Define whether or not to execute pass/fail tests at custom region frequencies. The pass/fail conditions are set by [:SENS]:SEM:REG[n]:LIST:ABS or [:SENS]:SEM:REG[n]:LIST:RCAR for each region.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset and *RST:

Mode	Region A	Region B	Region C	Region D	Region E
cdma2000	ON	ON	OFF	OFF	OFF
W-CDMA	ON	ON	ON	OFF	OFF
1xEV-DO	ON	ON	ON	OFF	OFF

Remarks:

You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum Emission Mask—Region Stop Absolute Power Limit

cdma2000, W-CDMA mode

[:SENSe]:SEMask:REGion[n]:LIST:STOP:ABSolute

<abs_power>,<abs_power>,<abs_power>,<abs_power>,<abs_power>

[:SENSe]:SEMask:REGion[n]:LIST:STOP:ABSolute?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:STOP:ABSolute

<abs power>,<abs power>,<abs power>,<abs power>,<abs power>

[:SENSe]:SEMask:REGion:LIST:STOP:ABSolute?

Set an absolute power level for each region stop limit. The list must contain five (5) entries. If there is more than one region, the region closest to the carrier channel comes first in the list.

The fail condition is set by [:SENS]:SEM:REG[n]:LIST:TEST for each region test.

You can turn off (not use) specific regions with [:SENS]:SEM:REG[n]:LIST:STAT.

SENSe Subsystem

The query returns the five (5) sets of the real values currently set to the region stop absolute power limits.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset and *RST:

Mode	Variant	Region A	Region B	Region C	Region D	Region E
cdma2000	BTS	- 86.00 dBm	- 41.00 dBm	- 98.00 dBm	- 57.00 dBm	- 50.00 dBm
	MS	- 41.00 dBm	- 67.00 dBm	- 79.00 dBm	- 71.00 dBm	- 50.00 dBm
W-CDMA	n/a	- 50.00 dBm				
1xEV-DO	n/a	- 50.00 dBm				

Range: -200.00 dBm to 50.00 dBm

Unit: dBm

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Couple Region Stop Absolute Power Limit

[:SENSe]:SEMask:REGion[n]:LIST:STOP:ABSolute:COUPle OFF |ON|0|1{,OFF |ON|0|1}

[:SENSe]:SEMask:REGion[n]:LIST:STOP:ABSolute:COUPle?

Define whether or not to couple the region stop absolute power limit to the region start absolute power limit for each region.

You can turn off (not use) specific regions with [:SENS]:SEM:REG[n]:LIST:STAT.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset:

Mode	Region A	Region B	Region C	Region D	Region E
cdma2000	ON	ON	ON	ON	ON

Mode	Region A	Region B	Region C	Region D	Region E
W-CDMA	ON	ON	ON	ON	ON
1xEV-DO	ON	ON	ON	ON	ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Region Stop Relative Power Limit

cdma2000, W-CDMA mode

[:SENSe]:SEMask:REGion[n]:LIST:STOP:RCARrier

<rel_power>,<rel_power>,<rel_power>,<rel_power>

[:SENSe]:SEMask:REGion[n]:LIST:STOP:RCARrier?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:STOP:RCARrier

<rel_power>,<rel_power>,<rel_power>,<rel_power>

[:SENSe]:SEMask:REGion:LIST:STOP:RCARrier?

Set a relative power level for each region stop limit. The list must contain five (5) entries. If there is more than one region, the region closest to the carrier channel comes first in the list.

The fail condition is set by [:SENS]:SEM:REG[n]:LIST[m]:TEST for each region.

You can turn off (not use) specific regions with [:SENS]:SEM:REG[n]:LIST:STAT.

The query returns the five (5) sets of the real values currently set to the region stop relative power limits.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset:

Mode	Region A	Region B	Region C	Region D	Region E
cdma2000	- 30.00 dB				
W-CDMA	- 30.00 dB				
1xEV-DO	- 30.00 dB				

Range: - 150.00 dBm to 50.00 dB

Default Unit: dB

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Couple Region Stop Relative Power Limit

cdma2000, W-CDMA mode

 $\begin{tabular}{ll} [:SENSe] : SEMask : REGion [n] : LIST : STOP : RCARrier : COUPle \\ OFF | ON | 0 | 1, OFF | ON | 0 | 1, OFF | ON | 0 | 1, OFF | ON | 0 | 1 \\ \hline \end{tabular}$

[:SENSe]:SEMask:REGion[n]:LIST:STOP:RCARrier:COUPle?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:STOP:RCARrier:COUPle

OFF | ON | 0 | 1, OFF | ON | 0 | 1

[:SENSe]:SEMask:REGion:LIST:STOP:RCARrier:COUPle?

Define whether or not to couple the region stop relative power limit to the region start relative power limit for each region.

You can turn off (not use) specific regions with [:SENS]:SEM:REG[n]:LIST:STAT.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

Factory Preset:

Mode	Region A	Region B	Region C	Region D	Region E
cdma2000	ON	ON	ON	ON	ON
W-CDMA	ON	ON	ON	ON	ON
1xEV-DO	ON	ON	ON	ON	ON

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Region Limit Test Fail Condition

cdma2000, W-CDMA mode

[:SENSe]:SEMask:REGion[n]:LIST:TEST

ABSolute | AND | OR | RELative,

ABSolute AND OR RELative, ABSolute AND OR RELative, ABSolute AND OR RELative

[:SENSe]:SEMask:REGion[n]:LIST:TEST?

1xEV-DO mode

[:SENSe]:SEMask:REGion:LIST:TEST ABSolute AND OR RELative,
ABSolute AND OR RELative, ABSolute AND OR RELative,
ABSolute AND OR RELative, ABSolute AND OR RELative

[:SENSe]:SEMask:REGion:LIST:TEST?

Define one of the fail conditions for each region limit test to be done. The absolute or relative test limit value for each region is set by [:SENS]:SEM:REG[n]:LIST:ABS or [:SENS]:SEM:REG[n]:LIST:RCAR.

You can turn off (not use) specific regions with [:SENS]:SEM:REG[n]:LIST[m]:STAT.

REGion[n] n=1 is the base station test and n=2 is the mobile test.

The default is the base station test (1). (cdma2000,

W-CDMA mode only)

The fail condition that can be set for each region test include:

- AND Tests the measurement result for a region against both the absolute power limit and the relative power limit. If it fails, then returns a failure for that measurement test.
- ABSolute Tests the measurement result for a region against the absolute power limit. If it fails, then returns a failure for that measurement test.
- OR Tests the measurement result for a region against the absolute power limit OR the relative power limit. If either test fails, then returns a failure for that measurement test.
- RELative Tests the measurement result for a region against the relative power limit. If it fails, then returns a failure for that measurement test.

Factory Preset:

Mode	Region A	Region B	Region C	Region D	Region E
cdma2000	ABS	ABS	ABS	ABS	ABS
W-CDMA	ABS	ABS	ABS	ABS	ABS
1xEV-DO	ABS	ABS	ABS	ABS	ABS

Remarks:

You must be in the cdma2000, W-CDMA, or 1xEV-DO mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum Emission Mask—Spectrum Segment

[:SENSe]:SEMask:SEGMent OFFSet REGion

[:SENSe]:SEMask:SEGMent?

Set the frequency spectrum measurement segment to either the offset channels with relative frequencies or the regions with absolute frequencies.

Factory Preset: OFFset

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Measurement Interval

[:SENSe]:SEMask:SWEep:TIME <time> | <no. of chips>

[:SENSe]:SEMask:SWEep:TIME?

Specify the time length in μs or number of chips, for the measurement interval that is the data acquisition time for each bin.

Factory Preset: 1 ms

182.3 μs or 224 chips (for 1xEV-DO)

Range: $100 \,\mu s$ to $10 \,ms$

10.0 µs to 10.0 ms or 12.3 to 12300 chips (for 1xEV-DO)

Default Unit: seconds

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Trigger Source

[:SENSe]:SEMask:TRIGger:SOURce

EXTernal[1] | EXTernal2 | FRAMe | IMMediate | LINE

[:SENSe]:SEMask:TRIGger:SOURce?

Select one of the trigger sources used to control the data acquisitions.

EXTernal 1 – front panel external trigger input

EXTernal 2 – rear panel external trigger input

FRAMe – internal frame trigger

IMMediate – the next data acquisition is immediately taken, capturing the signal asynchronously (also called free run).

LINE – power line

Factory Preset: IMMediate

Remarks: You must be in the cdma2000, W-CDMA, or 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum Emission Mask—Power Reference

[:SENSe]:SEMask:TYPE PSDRef | TPRef

[:SENSe]:SEMask:TYPE?

Set the power measurement reference type. This allows you to make absolute and relative power measurements of either total power or the power normalized to the measurement bandwidth.

PSDRef - the power spectral density is used as the power reference

TPRef - the total power is used as the power reference

Factory Preset: TPRef

Remarks: You must be in the cdma2000, W-CDMA, 1xEV-DO

mode to use this command. Use INSTrument:SELect to

set the mode.

Spectrum (Frequency-Domain) Measurement

Commands for querying the spectrum measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after the Spectrum (Freq Domain) measurement has been selected from the MEASURE key menu.

Spectrum—Data Acquisition Packing

[:SENSe]:SPECtrum:ACQuisition:PACKing

AUTO | LONG | MEDium | SHORt

[:SENSe]:SPECtrum:ACQuisition:PACKing?

Select the amount of data acquisition packing. This is an advanced control that normally does not need to be changed.

Factory Preset: AUTO

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—ADC Dither

[:SENSe]:SPECtrum:ADC:DITHer[:STATe] AUTO ON OFF 2 1 0

[:SENSe]:SPECtrum:ADC:DITHer[:STATe]?

Turn the ADC dither on or off. This is an advanced control that normally does not need to be changed.

Factory Preset: AUTO

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—ADC Range

E4406A

[:SENSe]:SPECtrum:ADC:RANGe

AUTO | APEak | APLock | M6 | P0 | P6 | P12 | P18 | P24

PSA

[:SENSe]:SPECtrum:ADC:RANGe

AUTO | APEak | APLock | NONE | P0 | P6 | P12 | P18

[:SENSe]:SPECtrum:ADC:RANGe?

Select the range for the gain-ranging that is done in front of the ADC. This is an advanced control that normally does not need to be changed. Auto peak ranging is the default for this measurement. If you are measuring a CW signal please see the description below.

AUTO - automatic range

For FFT spectrums - auto ranging should not be not be used. An exception to this would be if you know that your signal is "bursty". Then you might use auto to maximize the time domain dynamic range as long as you are not very interested in the FFT data.

Auto Peak (APEak) - automatically peak the range

For CW signals, the default of auto-peak ranging can be used, but a better FFT measurement of the signal can be made by selecting one of the manual ranges that are available: M6, P0 - P24. Auto peaking can cause the ADC range gain to move monotonically down during the data capture. This movement should have negligible effect on the FFT spectrum, but selecting a manual range removes this possibility. Note that if the CW signal being measured is close to the auto-ranging threshold, the noise floor may shift as much as 6 dB from sweep to sweep.

• Auto Peak Lock (APLock) - automatically peak lock the range

For CW signals, auto-peak lock ranging may be used. It will find the best ADC measurement range for this particular signal and will not move the range as auto-peak can. Note that if the CW signal being measured is close to the auto-ranging threshold, the noise floor may shift as much as 6 dB from sweep to sweep. For "bursty" signals, auto-peak lock ranging should not be used. The measurement will fail to operate, since the wrong (locked) ADC range will be chosen often and overloads will occur in the ADC.

- NONE (PSA) turns off any auto-ranging without making any changes to the current setting.
- M6 (E4406A) manually selects an ADC range that subtracts 6 dB of fixed gain across the range. Manual ranging is best for CW signals.
- P0 to P18 (PSA) manually selects ADC ranges that add 0 to 18 dB of fixed gain across the range. Manual ranging is best for CW signals.

SENSe Subsystem

• P0 to 24 - (E4406A) manually selects ADC ranges that add 0 to 24 dB of fixed gain across the range. Manual ranging is best for CW signals.

Factory Preset: APEak

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Average Clear

[:SENSe]:SPECtrum:AVERage:CLEar

The average data is cleared and the average counter is reset.

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Number of Averages

[:SENSe]:SPECtrum:AVERage:COUNt <integer>

[:SENSe]:SPECtrum:AVERage:COUNt?

Set the number of 'sweeps' that will be averaged. After the specified number of 'sweeps' (average counts), the averaging mode (terminal control) setting determines the averaging action.

Factory Preset: 25

Range: 1 to 10,000

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Averaging State

[:SENSe]:SPECtrum:AVERage[:STATe] OFF ON 0 1

[:SENSe]:SPECtrum:AVERage[:STATe]?

Turn averaging on or off.

Factory Preset: ON

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Averaging Mode

[:SENSe]:SPECtrum:AVERage:TCONtrol EXPonential REPeat

[:SENSe]:SPECtrum:AVERage:TCONtrol?

Select the type of termination control used for the averaging function. This determines the averaging action after the specified number of 'sweeps' (average count) is reached.

EXPonential - Each successive data acquisition after the average count is reached, is exponentially weighted and combined with the existing average.

REPeat - After reaching the average count, the averaging is reset and a new average is started.

Factory Preset: EXPonential

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Averaging Type

[:SENSe]:SPECtrum:AVERage:TYPE
LOG|MAXimum|MINimum|RMS|SCALar

[:SENSe]:SPECtrum:AVERage:TYPE?

Select the type of averaging.

SENSe Subsystem

LOG – The log of the power is averaged. (This is also known as video averaging.)

MAXimum - The maximum values are retained.

MINimum - The minimum values are retained.

RMS – The power is averaged, providing the rms of the voltage.

SCALar - The voltage is averaged.

Factory Preset: LOG

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Select Pre-FFT Bandwidth

 $\hbox{[:SENSe]:SPECtrum:BANDwidth} \ | \ BWIDth:IF:AUTO \ \ OFF \ | \ ON \ | \ 0 \ | \ 1$

[:SENSe]:SPECtrum:BANDwidth|BWIDth:IF:AUTO?

Select auto or manual control of the pre-FFT BW.

Factory Preset: AUTO, 1.55 MHz

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Measure, Spectrum, Meas Setup, More, Advanced, Pre-FFT

BW.

Spectrum — **IF Flatness Corrections**

[:SENSe]:SPECtrum:BANDwidth|BWIDth:IF:FLATness OFF|ON|0|1

[:SENSe]:SPECtrum:BANDwidth|BWIDth:IF:FLATness?

Turns IF flatness corrections on and off.

Factory Preset: ON

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Front Panel

Access: Measure, Spectrum, Meas Setup, More, Advanced, Pre-FFT

BW

Spectrum—Pre-ADC Bandpass Filter

[:SENSe]:SPECtrum:BANDwidth|BWIDth:PADC OFF|ON|0|1

[:SENSe]:SPECtrum:BANDwidth|BWIDth:PADC?

Turn the pre-ADC bandpass filter on or off. This is an advanced control that normally does not need to be changed.

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Pre-FFT BW

[:SENSe]:SPECtrum:BANDwidth|BWIDth:PFFT[:SIZE] <freq>

[:SENSe]:SPECtrum:BANDwidth|BWIDth:PFFT[:SIZE]?

Set the pre-FFT bandwidth. This is an advanced control that normally does not need to be changed.

Frequency span, resolution bandwidth, and the pre-FFT bandwidth settings are normally coupled. If you are not auto-coupled, there can be combinations of these settings that are not valid.

Factory Preset: 1.55 MHz

1.25 MHz for cdmaOne

155.0 kHz, for iDEN mode (E4406A)

Range: 1 Hz to 10.0 MHz

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use

INSTrument:SELect to set the mode.

Spectrum—Pre-FFT BW Filter Type

[:SENSe]:SPECtrum:BANDwidth|BWIDth:PFFT:TYPE FLAT|GAUSsian

[:SENSe]:SPECtrum:BANDwidth|BWIDth:PFFT:TYPE?

Select the type of pre-FFT filter that is used. This is an advanced control that normally does not need to be changed.

Flat top (FLAT)- a filter with a flat amplitude response, which provides the best amplitude accuracy.

GAUSsian - a filter with Gaussian characteristics, which provides the best pulse response.

Factory Preset: FLAT

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Resolution BW

[:SENSe]:SPECtrum:BANDwidth|BWIDth[:RESolution] <freq>

[:SENSe]:SPECtrum:BANDwidth|BWIDth[:RESolution]?

Set the resolution bandwidth for the FFT. This is the bandwidth used for resolving the FFT measurement. It is not the pre-FFT bandwidth. This value is ignored if the function is auto-coupled.

Frequency span, resolution bandwidth, and the pre-FFT bandwidth settings are normally coupled. If you are not auto-coupled, there can be combinations of these settings that are not valid.

Factory Preset: 20.0 kHz

250.0 Hz, for iDEN mode (E4406A)

Range: 0.10 Hz to 3.0 MHz

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Resolution BW Auto

 $\hbox{\tt [:SENSe]:SPECtrum:BANDwidth} \ | \ \hbox{\tt BWIDth} \ \hbox{\tt [:RESolution]:AUTO} \\ \hbox{\tt OFF} \ | \ \hbox{\tt ON} \ | \ \hbox{\tt 0} \ | \ \hbox{\tt 1} \\ \\ \hbox{\tt }$

[:SENSe]:SPECtrum:BANDwidth|BWIDth[:RESolution]:AUTO?

Select auto or manual control of the resolution BW. The automatic mode couples the resolution bandwidth setting to the frequency span.

Factory Preset: ON

OFF, for iDEN mode (E4406A)

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, W-CDMA, GSM, EDGE, NADC, or PDC mode to use this command. Use INSTrument:SELect to

set the mode.

Decimation of Spectrum Display

[:SENSe]:SPECtrum:DECimate[:FACTor] <integer>

[:SENSe]:SPECtrum:DECimate[:FACTor]?

Sets the amount of data decimation done by the hardware and/or the software. Decimation by n keeps every nth sample, throwing away each of the remaining samples in the group of n. For example, decimation by 3 keeps every third sample, throwing away the two in between. Similarly, decimation by 5 keeps every fifth sample, throwing away the four in between.

Using zero (0) decimation selects the automatic mode. The measurement will then automatically choose decimation by "1" or "2" as is appropriate for the bandwidth being used.

This is an advanced control that normally does not need to be changed.

Factory Preset: 0

Range: 0 to 1,000, where 0 sets the function to automatic

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Version A.02.00 or later

Spectrum—FFT Length

[:SENSe]:SPECtrum:FFT:LENGth <integer>

[:SENSe]:SPECtrum:FFT:LENGth?

Set the FFT length. This value is only used if length control is set to manual. The value must be greater than or equal to the window length value. Any amount greater than the window length is implemented by zero-padding. This is an advanced control that normally does not need to be changed.

Factory Preset: 706

Range: min, depends on the current setting of the spectrum

window length

max, 1,048,576

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Short form changed from LENgth to LENGth, A.03.00

Spectrum—FFT Length Auto

[:SENSe]:SPECtrum:FFT:LENGth:AUTO OFF ON 0 1

[:SENSe]:SPECtrum:FFT:LENGth:AUTO?

Select auto or manual control of the FFT and window lengths.

This is an advanced control that normally does not need to be changed.

On - the window lengths are coupled to resolution bandwidth, window type (FFT), pre-FFT bandwidth (sample rate) and SENSe:SPECtrum:FFT:RBWPoints.

 $Off \hbox{-lets you set $\tt SENSe:SPECtrum:FFT:LENGth and}\\$

SENSe: SPECtrum: FFT: WINDow: LENGth.

Factory Preset: ON

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Short form changed from LENgth to LENGth, A.03.00

Spectrum—FFT Minimum Points in Resolution BW

[:SENSe]:SPECtrum:FFT:RBWPoints <real>

[:SENSe]:SPECtrum:FFT:RBWPoints?

Set the minimum number of data points that will be used inside the resolution bandwidth. The value is ignored if length control is set to manual. This is an advanced control that normally does not need to be changed.

Factory Preset: 1.30

Range: 0.1 to 100

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Window Delay

[:SENSe]:SPECtrum:FFT:WINDow:DELay <real>

[:SENSe]:SPECtrum:FFT:WINDow:DELay?

Set the FFT window delay to move the FFT window from its nominal position of being centered within the time capture. This function is not available from the front panel. It is an advanced control that normally does not need to be changed.

Factory Preset: 0

Range: -10.0 to +10.0 s

Default Unit: seconds

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Window Length

[:SENSe]:SPECtrum:FFT:WINDow:LENGth <integer>

[:SENSe]:SPECtrum:FFT:WINDow:LENGth?

Set the FFT window length. This value is only used if length control is set to manual. This is an advanced control that normally does not need to be changed.

Factory Preset: 706

Range: 8 to 1,048,576

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

History: E4406A:

Short form changed from LENgth to LENGth, A.03.00

Spectrum—FFT Window

[:SENSe]:SPECtrum:FFT:WINDow[:TYPE] BH4Tap|BLACkman|FLATtop|GAUSsian|HAMMing|HANNing|KB70|KB90|KB110|UNIForm

[:SENSe]:SPECtrum:FFT:WINDow[:TYPE]?

Select the FFT window type.

BH4Tap - Blackman Harris with 4 taps

BLACkman - Blackman

FLATtop - flat top, the default (for high amplitude accuracy)

GAUSsian - Gaussian with alpha of 3.5

HAMMing - Hamming

HANNing - Hanning

KB70, 90, and 110 - Kaiser Bessel with sidelobes at -70, -90, or -110 dBc

UNIForm - no window is used. (This is the unity response.)

Factory Preset: FLATtop

Remarks: This selection affects the acquisition point quantity and

the FFT size, based on the resolution bandwidth

selected.

To use this command for E4406A, the appropriate mode

should be selected with INSTrument: SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Frequency Span

[:SENSe]:SPECtrum:FREQuency:SPAN <freq>

[:SENSe]:SPECtrum:FREQuency:SPAN?

Set the frequency span to be measured.

Factory Preset: 1.0 MHz

100.0 kHz for iDEN mode (E4406A)

Range: 10 Hz to 10.0 MHz (15 MHz when Service mode is

selected)

Default Unit: Hz

Remarks: The actual measured span will generally be slightly

wider due to the finite resolution of the FFT.

To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Sweep (Acquisition) Time

[:SENSe]:SPECtrum:SWEep:TIME[:VALue] <time>

[:SENSe]:SPECtrum:SWEep:TIME?

Set the sweep (measurement acquisition) time. It is used to specify the length of the time capture record. If the value you specify is less than the capture time required for the specified span and resolution bandwidth, the value is ignored. The value is set at its auto value when auto is selected. This is an advanced control that normally does not need to be changed.

Factory Preset: 188.0 µs

15.059 ms, for iDEN mode (E4406A)

Range: 100 ns to 10 s

Default Unit: seconds

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Sweep (Acquisition) Time Auto

[:SENSe]:SPECtrum:SWEep:TIME:AUTO OFF ON 0 1

[:SENSe]:SPECtrum:SWEep:TIME:AUTO

Select auto or manual control of the sweep (acquisition) time. This is an advanced control that normally does not need to be changed.

AUTO - couples the Sweep Time to the Frequency Span and Resolution BW

Manual - the Sweep Time is uncoupled from the Frequency Span and Resolution BW.

Factory Preset: AUTO

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Spectrum—Trigger Source

[:SENSe]:SPECtrum:TRIGger:SOURce EXTernal[1] | EXTernal2

| FRAMe | IF | LINE | IMMediate | RFBurst

[:SENSe]:SPECtrum:TRIGger:SOURce?

Select the trigger source used to control the data acquisitions.

EXTernal1 - front panel external trigger input

EXTernal2 - rear panel external trigger input

FRAMe - internal frame timer from front panel input

IF - internal IF envelope (video) trigger

LINE - internal line trigger

IMMediate - the next data acquisition is immediately taken (also called free run)

RFBurst - wideband RF burst envelope trigger that has automatic level control for periodic burst signals

Factory Preset: IMMediate (free run)

RFBurst, for GSM, iDEN mode

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform (Time-Domain) Measurement

Commands for querying the waveform measurement results and for setting to the default values are found in the "MEASure Group of Commands" on page 311. The equivalent front panel keys for the parameters described in the following commands, are found under the Meas Setup key, after the Waveform (Time Domain) measurement has been selected from the MEASURE key menu.

Waveform—Data Acquisition Packing

[:SENSe]:WAVeform:ACQuistion:PACKing AUTO LONG MEDium SHORt

[:SENSe]:WAVeform:ACQuistion:PACKing?

This is an advanced control that normally does not need to be changed.

Factory Preset: AUTO

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—ADC Dither State

[:SENSe]:WAVeform:ADC:DITHer[:STATe] OFF | ON | 0 | 1

[:SENSe]:WAVeform:ADC:DITHer[:STATe]?

This is an Advanced control that normally does not need to be changed.

Factory Preset: OFF

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—Pre-ADC Bandpass Filter

[:SENSe]:WAVeform:ADC:FILTer[:STATe] OFF ON 0 1

[:SENSe]:WAVeform:ADC:FILTer[:STATe]?

Turn the pre-ADC bandpass filter on or off. This is an Advanced control that normally does not need to be changed.

Preset: OFF

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—ADC Range

E4406A

 $\hbox{\tt [:SENSe]:WAVeform:ADC:RANGe\ AUTO\,|\ APEak\,|\ APLock\,|\ GROund}\\$

|M6|P0|P6|P12|P18|P24

PSA

[:SENSe]:WAVeform:ADC:RANGe AUTO APEak APLock GROund

| NONE | P0 | P6 | P12 | P18

[:SENSe]:WAVeform:ADC:RANGe?

Select the range for the gain-ranging that is done in front of the ADC. This is an Advanced control that normally does not need to be changed.

AUTO - automatic range

Auto Peak (APEak) - automatically peak the range

Auto Peak Lock (APLock)- automatically peak lock the range

GROund - ground

NONE - (PSA) turn off auto-ranging without making any changes to the current setting.

M6 - (E4406A) subtracts 6 dB of fixed gain across the range

P0 to P18 - (PSA) adds 0 to 18 dB of fixed gain across the range

P0 to P24 - (E4406A) adds 0 to 24 dB of fixed gain across the range

Factory Preset: AUTO

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform - Query Aperture Setting

[:SENSe]:WAVeform:APERture?

Returns the waveform sample period (aperture) based on current resolution bandwidth, filter type, and decimation factor. Sample rate is the reciprocal of period.

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—Number of Averages

[:SENSe]:WAVeform:AVERage:COUNt <integer>

[:SENSe]:WAVeform:AVERage:COUNt?

Set the number of sweeps that will be averaged. After the specified number of sweeps (average counts), the averaging mode (terminal control) setting determines the averaging action.

Factory Preset: 10

Range: 1 to 10,000

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—Averaging State

[:SENSe]:WAVeform:AVERage[:STATe] OFF |ON|0|1

[:SENSe]:WAVeform:AVERage[:STATe]?

Turn averaging on or off.

Factory Preset: OFF

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use

INSTrument:SELect to set the mode.

Waveform—Averaging Mode

[:SENSe]:WAVeform:AVERage:TCONtrol EXPonential | REPeat

[:SENSe]:WAVeform:AVERage:TCONtrol?

Select the type of termination control used for the averaging function. This determines the averaging action after the specified number of 'sweeps' (average count) is reached.

EXPonential - Each successive data acquisition after the average count is reached, is exponentially weighted and combined with the existing average.

REPeat - After reaching the average count, the averaging is reset and a new average is started.

Factory Preset: EXPonential

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—Averaging Type

[:SENSe]:WAVeform:AVERage:TYPE LOG|MAXimum|MINimum|RMS|SCALar

[:SENSe]:WAVeform:AVERage:TYPE?

Select the type of averaging.

LOG - The log of the power is averaged. (This is also known as video averaging.)

MAXimum - The maximum values are retained.

MINimum - The minimum values are retained.

RMS - The power is averaged, providing the rms of the voltage.

Factory Preset: RMS

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—Resolution BW

[:SENSe]:WAVeform:BANDwidth|BWIDth[:RESolution] <freq>

[:SENSe]:WAVeform:BANDwidth | BWIDth [:RESolution]?

Set the resolution bandwidth. This value is ignored if the function is auto-coupled.

Factory Preset: 100.0 kHz for NADC, PDC, cdma2000, W-CDMA,

Basic, Service (E4406A) 500.0 kHz for GSM 2.0 MHz for cdmaOne

Range: 1.0 kHz to 8.0 MHz when

[:SENSe]:WAVeform:BANDwidth|BWIDth

[:RESolution]:TYPE GAUSsian

1.0 kHz to 10.0 MHz when

[:SENSe]:WAVeform:BANDwidth|BWIDth

[:RESolution]:TYPE FLATtop

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Bandwidths > 6.7 MHz will require a slight increase in

measurement time.

Waveform - Query Actual Resolution Bandwidth

[:SENSe]:WAVeform:BANDwidth:RESolution]:ACTual?

Due to memory constraints the actual resolution bandwidth value may vary from the value entered by the user. For most applications the resulting difference in value is inconsequential but for some it is necessary to know the actual value; this query retrieves the actual resolution bandwidth value.

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use

INSTrument:SELect to set the mode.

History: E4406A:

Version A.05.00 or later

Waveform—Resolution BW Filter Type

[:SENSe]:WAVeform:BANDwidth|BWIDth[:RESolution]:TYPE FLATtop|GAUSsian

[:SENSe]:WAVeform:BANDwidth|BWIDth[:RESolution]:TYPE?

Select the type of Resolution BW filter that is used. This is an Advanced control that normally does not need to be changed.

FLATtop - a filter with a flat amplitude response, which provides the best amplitude accuracy.

GAUSsian - a filter with Gaussian characteristics, which provides the best pulse response.

Factory Preset: GAUSsian

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—Decimation of Waveform Display

[:SENSe]:WAVeform:DECimate[:FACTor] <integer>

[:SENSe]:WAVeform:DECimate[:FACTor]?

Set the amount of data decimation done on the IQ data stream. For example, if 4 is selected, three out of every four data points will be thrown away. So every 4th data point will be kept.

Factory Preset: 1

Range: 1 to 4

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—Control Decimation of Waveform Display

[:SENSe]:WAVeform:DECimate:STATe OFF ON 0 1

[:SENSe]:WAVeform:DECimate:STATe?

Set the amount of data decimation done by the hardware in order to decrease the number of acquired points in a long capture time. This is the amount of data that the measurement ignores.

Factory Preset: OFF

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—Sweep (Acquisition) Time

[:SENSe]:WAVeform:SWEep:TIME <time>

[:SENSe]:WAVeform:SWEep:TIME?

Set the measurement acquisition time. It is used to specify the length of the time capture record.

Factory Preset: 2.0 ms

10.0 ms, for NADC, PDC

15.0 ms, for iDEN mode (E4406A)

Range: 1 µs to 100 s

Default Unit: seconds

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

Waveform—Trigger Source

[:SENSe]:WAVeform:TRIGger:SOURce EXTernal[1] |
EXTernal2|FRAMe|IF|IMMediate|LINE|RFBurst

[:SENSe]:WAVeform:TRIGger:SOURce?

Select the trigger source used to control the data acquisitions.

EXTernal 1 - front panel external trigger input

EXTernal 2 - rear panel external trigger input

FRAMe - internal frame timer from front panel input

IF - internal IF envelope (video) trigger

IMMediate - the next data acquisition is immediately taken (also called free run)

LINE - internal line trigger

RFBurst - wideband RF burst envelope trigger that has automatic level control for periodic burst signals

Factory Preset: IMMediate (free run), for Basic, cdmaOne, NADC,

PDC mode

RFBurst, for GSM, iDEN (E4406A) modes

Remarks: To use this command for E4406A, the appropriate mode

should be selected with INSTrument:SELect.

For PSA you must be in the Basic, cdmaOne,

cdma2000, 1xEV-DO, W-CDMA, GSM, EDGE, NADC,

or PDC mode to use this command. Use INSTrument:SELect to set the mode.

TRIGger Subsystem

The Trigger Subsystem is used to set the controls and parameters associated with triggering the data acquisitions. Other trigger-related commands are found in the INITiate and ABORt subsystems.

The trigger parameters are global within a selected Mode. The commands in the TRIGger subsystem set up the way the triggers function, but selection of the trigger source is made from each measurement. There is a separate trigger source command in the SENSe:<meas> subsystem for each measurement. The equivalent front panel keys for the parameters described in the following commands, can be found under the **Mode Setup**, **Trigger** key.

Automatic Trigger Control

```
:TRIGger[:SEQuence]:AUTO:STATe OFF|ON|0|1
```

:TRIGger[:SEQuence]:AUTO:STATe?

Turns the automatic trigger function on and off. This function causes a trigger to occur if the designated time has elapsed and no trigger occurred. It can be used with unpredictable trigger sources, like external or burst, to make sure a measurement is initiated even if a trigger doesn't occur. Use TRIGger[:SEQuence]:AUTO[:TIME] to set the time limit.

Factory Preset

and *RST Off for cdma2000, W-CDMA, NADC, PDC, 1xEV-DO

Front Panel

Access Mode Setup, Trigger, Auto Trig

Automatic Trigger Time

```
:TRIGger[:SEQuence]:AUTO[:TIME] <time>
```

:TRIGger[:SEQuence]:AUTO[:TIME]?

After the measurement is activated the instrument will take a data acquisition immediately upon receiving a signal from the selected trigger source. If no trigger signal is received by the end of the time specified in this command, a data acquisition is taken anyway. TRIGger[:SEQuence]:AUTO:STATE must be on.

Factory Preset: 100.0 ms

Range: 1.0 ms to 1000.0 s

0.0 to 1000.0 s for cdma2000, W-CDMA, 1xEV-DO

Default Unit: seconds

Front Panel

Access Mode Setup, Trigger, Auto Trig

External Trigger Delay

```
:TRIGger[:SEQuence]:EXTernal[1] | 2:DELay <time>
```

:TRIGger[:SEQuence]:EXTernal[1] | 2:DELay?

Set the trigger delay when using an external trigger. Set the trigger value to zero (0) seconds to turn off the delay.

EXT or EXT1is the front panel trigger input.

EXT2 is the rear panel trigger input.

Factory Preset: 0.0 s

Range: -100.0 ms to 500.0 ms

Default Unit: seconds

Front Panel

Access: Mode Setup, Trigger, Ext Rear (or Ext Front), Delay

External Trigger Level

```
:TRIGger[:SEQuence]:EXTernal[1] | 2:LEVel <voltage>
```

:TRIGger[:SEQuence]:EXTernal[1] | 2:LEVel?

Set the trigger level when using an external trigger input.

EXT or EXT1is the front panel trigger input

EXT2 is the rear panel trigger input

Factory Preset: 2.0 V

Range: -5.0 to + 5.0 V

Default Unit: volts

Front Panel

Access: Mode Setup, Trigger, Ext Rear (or Ext Front), Level

External Trigger Slope

:TRIGger[:SEQuence]:EXTernal[1] | 2:SLOPe NEGative | POSitive

:TRIGger[:SEQuence]:EXTernal[1]|2:SLOPe?

Sets the trigger slope of an external trigger input to either NEGative or POSitive.

EXT or EXT1is the front panel trigger input.

EXT2 is the rear panel trigger input.

Factory Preset: Positive

Front Panel

Access: Mode Setup, Trigger, Ext Rear (or Ext Front), Slope

Frame Trigger Adjust

```
:TRIGger[:SEQuence]:FRAMe:ADJust <time>
```

Lets you advance the phase of the frame trigger by the specified amount. It does not change the period of the trigger waveform. If the command is sent multiple times, it advances the phase of the frame trigger more each time it is sent.

Factory Preset: 0.0 s

Range: 0.0 to 10.0 s

Default Unit: seconds

Front Panel

Access: None

Frame Trigger Period

```
:TRIGger[:SEQuence]:FRAMe:PERiod <time>
```

:TRIGger[:SEQuence]:FRAMe:PERiod?

Set the frame period that you want when using the external frame timer trigger. If the traffic rate is changed, the value of the frame period is initialized to the preset value.

Factory Preset: 250.0 µs for Basic, cdmaOne

4.615383 ms, for GSM

26.666667 ms for cdma2000 and 1xEV-DO

10.0 ms (1 radio frame) for W-CDMA

90.0 ms for iDEN (E4406A)

20.0 ms with rate=full for NADC, PDC

40.0 ms with rate=half for NADC, PDC

Range: 0.0 ms to 559.0 ms for Basic, cdmaOne, GSM,

cdma2000, W-CDMA, 1xEV-DO

1.0 ms to 559.0 ms for iDEN (E4406A), NADC, PDC

Default Unit: seconds

Front Panel

Access: Mode Setup, Trigger, Frame Timer, Period

Trigger Holdoff

:TRIGger[:SEQuence]:HOLDoff <time>

:TRIGger[:SEQuence]:HOLDoff?

Set a value of the holdoff time between triggers. After a trigger, another trigger will not be allowed until the holdoff time expires. This parameter affects all trigger sources.

Factory Preset: 0.0 s

20.0 ms for iDEN (E4406A)

10.0 ms for NADC or PDC

Range: 0.0 to 500.0 ms

Default Unit: seconds

Front Panel

Access: Mode Setup, Trigger, Trigger Holdoff

Video (IF) Trigger Delay

:TRIGger[:SEQuence]:IF:DELay <time>

:TRIGger[:SEQuence]:IF:DELay?

Set a value of the trigger delay of the IF (video) trigger (signal after the resolution BW filter).

Factory Preset: 0.0 s

Range: -100.0 ms to 500.0 ms

Default Unit: seconds

Front Panel

Access: Mode Setup, Trigger, Video (IF Envlp), Delay

Video (IF) Trigger Level

:TRIGger[:SEQuence]:IF:LEVel <ampl>

:TRIGger[:SEQuence]:IF:LEVel?

Set the trigger level when using the IF (video) trigger.

Factory Preset: - 6.0 dBm for cdmaOne, GSM, EDGE, Basic, Service

(E4406A), cdma2000, W-CDMA, 1xEV-DO

- 20.0 dBm for iDEN (E4406A)

- 30.0 dBm for NADC, PDC

Range: -200.0 to 50.0 dBm

Default Unit: dBm

Front Panel

Access: Mode Setup, Trigger, Video (IF Envlp), Level

Video (IF) Trigger Slope

:TRIGger[:SEQuence]:IF:SLOPe NEGative | POSitive

:TRIGger[:SEQuence]:IF:SLOPe?

Sets the trigger slope when using the IF (video) trigger, to either NEGative or POSitive.

Factory Preset: Positive

Front Panel

Access: Mode Setup, Trigger, Video (IF Envlp), Slope

RF Burst Trigger Delay

:TRIGger[:SEQuence]:RFBurst:DELay <time>

:TRIGger[:SEQuence]:RFBurst:DELay?

Set the trigger delay when using the RF burst (IF Wideband) trigger.

Factory Preset: 0.0 µs

Range: -100.0 ms to 500.0 ms

Default Unit: seconds

Front Panel

Access: Mode Setup, Trigger, RF Burst, Delay

RF Burst Trigger Level

:TRIGger[:SEQuence]:RFBurst:LEVel <rel power>

:TRIGger[:SEQuence]:RFBurst:LEVel?

Set the trigger level when using the RF Burst (IF Wideband) Trigger. The value is relative to the peak of the signal. RF Burst is also known as RF Envelope.

Factory Preset: - 6.0 dB

Range: -25.0 to 0.0 dB

- 200.0 to 0.0 dB for NADC, PDC

Default Unit: dB

Front Panel

Access: Mode Setup, Trigger, RF Burst, Peak Level

RF Burst Trigger Slope

:TRIGger[:SEQuence]:RFBurst:SLOPe NEGative POSitive

:TRIGger[:SEQuence]:RFBurst:SLOPe?

Set the trigger slope when using the RF Burst (IF Wideband) Trigger.

Factory Preset: Positive

Remarks: You must be in the cdmaOne, cdma2000, W-CDMA

mode to use this command. Use :INSTrument:SELect

to set the mode.

Front Panel

Access: Mode Setup, Trigger, RF Burst, Slope

Chapter 4 505

5 Concepts

This chapter provides details about the cdma2000 and 1xEV-DV communications systems, and explains how the various measurements are performed by the instrument. Suggestions for optimizing and troubleshooting your setup are provided, along with a list of related Agilent documents that are referenced for further information.

What Is the cdma2000 Communication System?

Introduction

Code Division Multiple Access 2000 (cdma2000) is a wideband CDMA standard that has been adopted by 3GPP2. It provides a wideband air interface for third generation global wireless communications systems. cdma2000 is a derivative of the IS-95-B CDMA system, also known as cdmaOne, and provides an upgrade path to support IMT-2000. This section will present the basics of cdma2000 as it differs from IS-95, and will assume the reader has some familiarity with IS-95 technology.

cdma2000 is defined in the following Telecommunications Industry Association (TIA) and Electronics Industry Alliance (EIA) document: TIA/EIA/IS-2000-1 through TIA/EIA/IS-2000-6.

cdma2000 relies on the Global Positioning System (GPS) for intercell synchronization. Both reverse and forward transmitter power controls are implemented with 1.25 ms intervals. cdma2000 is a direct sequence spread-spectrum digital communications technique that supports wider RF bandwidths from 1.25 to 15 MHz. The main advantages of cdma2000 over other types of digital communication schemes are:

- greater capacity
- immunity to signal loss and degradation due to high-level broadband interference, multipath, and fading
- strict minimization of power consumption for mobile stations by both base station and mobile controls
- support for variable data rates; up to 144 kbits/second for mobile (vehicular) data rate, up to 384 kbits/second for portable (pedestrian) data rate, and up to 2 Mbits/second for fixed installations
- increased security

cdma2000 uses correlative codes to distinguish one user from another. Frequency division is still used, as is done with Frequency Division Multiple Access (FDMA) and Time Division Multiple Access (TDMA), but in a much larger bandwidth such as 1.25 MHz or greater. cdma2000 realizes increased capacity from 1:1 frequency reuse and sectored cells. The capacity limit is soft. That is, capacity can be increased with some degradation of the error rate or voice quality.

In cdma2000, a single user's channel consists of a specific frequency combined with a unique Walsh code channel. Correlative Walsh codes allow each user to operate in the presence of substantial interference. The interference is the sum of all other users on the same cdma2000 frequency, both from within and outside of the home cell, and from delayed versions of these signals. It also includes the usual thermal noise and atmospheric disturbances. Delayed signals caused by

multipath are separately received and combined in cdma2000. One of the major differences in access is that any cdma2000 frequency can be used in all sectors of all cells. This is possible because cdma2000 is designed to decode the proper signal in the presence of high interference.

Also, cdma2000 offers a number of RF structures to accommodate almost any conceivable application. These options include direct spreading to support those applications where clear spectrum is available and multi-carrier arrangements using 1.25 MHz wide channels to allow overlays with TIA/EIA-95-B systems.

Spreading Rate

Spreading rate (SR) defines the final spread chip rate in terms of 1.2288 Mcps. The two spreading rates are SR1 and SR3. An SR1 signal has a chip rate of 1.2288 Mcps and occupies the same bandwidth as cdmaOne signals. The SR1 system doubles the system capacity, therefore, it can be considered an improved cdmaOne system.

There are two main differences between cdmaOne and cdma2000. The first is fast power control and quadrature phase shift keying (QPSK) modulation rather than dual binary phase shift keying (BPSK) in the forward link. The second difference is the presence of a pilot signal, to allow coherent demodulation, and hybrid phase shift keying (HPSK) spreading in the reverse link.

An SR3 cdma2000 signal has a rate of 3.6864 Mcps (3 x 1.2288 Mcps) and occupies three times the bandwidth of cdmaOne. Originally, the SR3 system appeared to be viable. Upon further investigation the SR3 cdma2000 system was determined to not be viable and is no longer receiving any commercial attention at this time. Therefore, we will not be covering SR3 in this section.

Radio Configuration

Radio configuration (RC) defines the physical channel configuration based upon a specific channel data rate. Each RC specifies a set of data rates based on either 9.6 or 14.4 kbps bit streams, the two existing data rates supported for cdmaOne. Each RC also specifies the spreading rate (either SR1 or SR3) and the physical coding. Currently there are nine radio configurations defined in the cdma2000 system for the forward link and six for the reverse link. Examples include:

- RC1 is the backwards-compatible mode of cdmaOne for 9600-bps voice traffic. It includes 9.6, 4.8, 2.4, and 1.2 kbps data rates and operates at SR1. It does not use any of the cdma2000 coding improvements.
- RC3 is a cdma2000-specific configuration based on 9.6 kbps that also supports 4.8, 2.7, and 1.5 kbps for voice, while supporting data at

19.2, 38.4, 76.8, and 153.6 kbps and operates at SR1. Each base transceiver station (BTS) or MS must be capable of transmitting using different RCs at the same SR. Refer to [2] for detailed information on the different RCs.

Forward Link Air Interface

The forward link air interface for a cdma2000 SR1 channel is very similar to that of cdmaOne. In order to preserve compatibility, cdma2000 uses the same structure as cdmaOne for the forward pilot (F-Pilot), forward sync (F-Sync), and forward paging (F-Paging) channels. In cdma2000, each user is assigned a forward traffic (F-Traffic) channel, which consists of

- zero to one forward fundamental channel (F-FCH)
- zero to seven forward supplemental code channels (F-SCCHs) for RC1 and RC2
- zero to two forward supplemental channels (F-SCHs) for RC3 to RC9
- zero to one forward dedicated control channels (F-DCCHs)
- The F-FCHs are used for voice and the F-FCCHs and F-SCHs are used for data. The BTS may also send zero or one F-DCCHs. An F-DCCH is associated with traffic channels (either FCH, SCH, or SCCH) and may carry signaling data and power control data.

One of the main differences between cdmaOne and cdma2000 is that the latter uses true quadrature phase shift keying (QPSK) modulation (as opposed to dual-BPSK) for all traffic channels from RC3 to RC9. As an example, "Coding and Air Interface for a cdma2000 RC4 F-FCH" on page 511 shows the forward link structure for an RC4 F-FCH. The coding is identical to cdmaOne up through the long code scrambling of the voice data. The F-FCH is optionally punctured with the reverse link power control data bits. The data is then converted from a serial bit stream into a two-bit wide parallel data stream to produce true QPSK modulation. This reduces the data rate of each stream by a factor of two. Each branch is spread with a 128 Walsh code to generate a spreading rate of 1.2288 Mcps. In this case, the processing gain is doubled for each channel relative to cdmaOne. Each channel is transmitted at one-half the power used before, but there are now two of them for no apparent gain. The actual processing gain for each channel depends on its data rate and RC. The outputs of the I and Q Walsh spreaders are then complex multiplied against the same I and Q channel short codes used in cdmaOne. Complex scrambling is used in the forward link instead of regular scrambling because it is a more robust scheme against interference.

Complex scrambling Add CRC Full rate and tail bits data bits control 9.6 ksps 8.6 ksps 1228.8 kcps puncture ĦR I short code 1/4 Rate conv Orthogonal bits encoder ▼ 1228.8 kcps spreading 1228.8 kcps 38.4 ksps 19.2 ksps Gain Interleaver 38.4 ksps ₩ 800 bps 1228.8 kcps 38.4 ksps User long Walsh 64 S-P Gain P.C. code mask generator Puncture 800 bps 1228.8 kcps Q 1228.8 kcps 1228.8 kcps 38.4 ksps timing Long code Long code P.C. Qshort code dec ĦR decimator generator 19.2 ksps 1228.8 kcps Decimate by

Figure 5-1 Coding and Air Interface for a cdma2000 RC4 F-FCH

Reverse link air interface — HPSK

Optional Can be carried by F-DCCH

Walsh length/ 2

The cdma2000 reverse link is very different from cdmaOne. The MS can transmit more than one code channel to accommodate the high data rates. The minimum configuration consists of a reverse pilot (R-Pilot) channel to allow the BTS to perform synchronous detection and a reverse fundamental channel (R-FCH) for voice. Additional channels, such as the reverse supplemental channels (R-SCHs) and the reverse dedicated control channel (R-DCCH) can be used to send data or signaling information, respectively.

1228.8 kcps

The different channels are assigned to either the I or Q path. For example, for RC3 to RC6, the R-Pilot is assigned to I and R-FCH is assigned to Q (see Figure 5-2 on page 512).

generator

Gain R-SCH2 Complex scrambling scale 1228.8 kcps 1228.8 kcps 1,1,-1,-1, or 1,1,-1,-1,-1,-1,1 I-channel Walsh 4/8 short code R-Pilot+ generator generator 1228.8 kcps power control Gain 1228.8 kcps R-DOCH scale 1228.8 kcps User long Long code Walsh 2 Walsh 16 code mask generator generator generator Gain R-SCH1 scale 1228.8 kcps 1,-1 or 1,1,-1,-1 1-Chip Deci by 2 delay 1228.8 kcps Σ Σ Q 1228.8 kcps Walsh 2/4/8 **Q**-channel short code generator generator 1228.8 kcps Gain R-FCH scale 1228.8 kcps **HPSK** 1,1,1,1,-1,-1,-1,1,1,1,1,-1,-1,-1 Walsh 16

Figure 5-2 Example of Channel Summing and HPSK spreading for cdma2000 reverse link (SR1)

Channels can be at different rates and different power levels. Complex scrambling facilitates this by continuously phase rotating the constellation and thus distributing the power evenly between the axes.

Without scrambling, unequal channel powers would result in a rectangular four-quadrature amplitude modulation (QAM) constellation (assuming that only R-Pilot and R-FCH are active). With complex scrambling, the constellation for two channels generally has eight points distributed around a circle, with the angular distribution determined by the relative powers of the two channels. For example, an amplitude difference of 6 dB between the two channels results in the constellation shown in Figure 5-3 on page 513, which is close to an 8-PSK (8-phase shift keying) constellation (an amplitude difference of 7.65 dB would result in a perfect 8-PSK constellation). If the amplitudes for the two channels are equal, then pairs of constellation points merge to give a QPSK-like constellation.

* Agilent cdma2000 Err Ch Freq 2.00000 GHz MS QPSK EVM Averages: 6 SR1 2.0000000000 GHz Center Freq RMS EVM: I/Q Measured Polar Vector 45.61 % 40.16% Pk EVM: 84.23% 104.61% Mag Error: Avg 8.04 % 6.80 % Phase Error: 26.09 ° Freq Error: 38368.30 Hz -4339.99 I/Q Origin Offset: -29.66 dB

Figure 5-3 Reverse Link cdma2000 SR1 Signal w/ R-Pilot and R-FCH

Basic complex scrambling applies a phase rotation of 0, $\pm\pi/2$, or π radians to each chip. HPSK takes this idea a stage further and defines the complex scrambling so that for every second chip, the phase rotation is restricted to $\pm\pi/2$. This constraint on the phase transitions entering the baseband pulse shaping filter reduces the peak-to-average ratio of the signal (about 1 to 1.5 dB) compared to regular complex scrambling (or regular QPSK). The HPSK technique continues to be advantageous even when the signal has more than two channels. For more information on HPSK see [3].

Forward link power control

A key improvement in cdma2000 is forward link power control. The MS sends power control data back to the BTS by time multiplexing it with the R-Pilot channel. Like the existing reverse link closed loop power control of cdmaOne, the cdma2000 forward link closed loop power control sends 800 power control bits each second. These bits indicate whether the BTS should raise or lower its power in 1 dB, 0.5 dB, or 0.25 dB. The finer steps allow tighter power control for low mobility or stationary phones. Tighter control (less power ripple) lowers the average power and thus raises the capacity of the system.

Differences between cdma2000 and W-CDMA

The Third-Generation Partnership Project (3GPP) W-CDMA is the other main wideband CDMA technology competing for the 3G cellular market. There has been much discussion about the need to harmonize W-CDMA and cdma2000 in an attempt to facilitate global use of 3G phones. However, even though both systems are based on a similar CDMA technology, they are significantly different. The main differences are:

- spreading rate (3.84 Mcps for W-CDMA versus 1.2288 Mcps for cdma2000 SR1)
- synchronization and BTS identification methodology W-CDMA does not use GPS, or Global Positioning System. For information on-CDMA user equipment (UE)¹ design and test issues, refer to [4].

^{1.} W-CDMA specifications use the term UE to refer to mobile phones or other computing devices that provide wireless access to the W-CDMA system.

What Is 1xEV-DV?

1xEV-DV and cdma2000

IxEV-DV enhances the data transmission capability of the cdma2000 DL by combining packet data and voice traffic on a single 1.25 MHz carrier. Alternatively, packet data may also be placed on a separate carrier. The format employs High Data Rate (HDR) technology on the forward link only. No higher data rates in the reverse link are currently supported.

The 1xEV-DV system is backwards compatible with previous versions of IS-95 and IS-2000, including existing channels and signal structure. The enhancements occur at the physical layer and are controlled by the upper layers. The reference specification is 3GPP2 C.S0002-C Version 1.0, dated May 28, 2002. This specification is sometimes referred to as the "1xEV-DV" specification – indicating a single carrier (1x), an evolution of cdma2000 (EV), and a data-voice (DV) system of wireless cellular communications.

A 1xEV-DV transmitter will configure a packet transmission utilizing forward packet data channels (F-PDCH) and forward packet data control channel (F-PDCCH) elements. The F-PDCCH contains data used by the MS mobile station receiver to demodulate and decode the F-PDCH and perform a CRC check. Packet transmissions can also be configured with variable data rates.

1xEV-DV Forward Data Channels


A packet transmission is capable of containing the following:

- CRC element (used for error correction)
- One or more F-PDCH, each with four subpackets
- up to two F-PDCCH, corresponding to one or more F-PDCH

A single packet transmission channel, therefore, can consist of up to 8 individual subpackets of F-PDCH along with up to 8 individual packets of F-PDCCH, which must be time-aligned with the subpackets. Up to 4 packet channels can sent simultaneously.

1xEV-DV uses the existing cdma2000 physical channels for Pilot, Synch, Power Control, and Paging functions. (See Figure 5-4)

Figure 5-4 1xEV-DV Data Only Mode Packet Channels



Forward Packet Data Channel (F-PDCH)

The Forward Packet Data Channel (F-PDCH) carries data packets shared by packet data users based on time-multiplexing. If the base station supports the F-PDCH with Radio Configuration 10, the base station will support one or two F-PDCHs.

The F-PDCH transmits 386, 770, 1538, 2306, 3074, or 3842 information bits. 16 packet frame quality indicator bits and 6 turbo encoder tail allowance bits are added to the information bits to form encoder packets. The subpackets of an encoder packet are then transmitted using 1-, 2-, or 4-slot durations, with each slot length equal to 1536chips, or 1.25ms.

The encoder packets are turbo encoded, interleaved, and then scrambled. Subpacket symbols are selected from the scrambler output sequence, then fed into a QPSK/8-PSK/16-QAM modulator. The modulated symbols are demultiplexed into N parallel streams, where N is the total number of 32-chip Walsh codes that are indicated in WCI_SET, a parameter transmitted in the Forward Packet Data Control Channel (F-PDCCH).

The number of Walsh channels can be from 1 to 28 on a single F-PDCH, with no more than 28 total on the two possible F-PDCHs in the same code space. Each stream is Walsh spread, and the spread symbols from the Walsh channels are summed to form a single sequence of (I,Q) symbols.

Forward Packet Data Control Channel (F-PDCCH)

The Forward Packet Data Control Channel (F-PDCCH) is used by the base station for transmitting control information for the associated F-PDCH or transmitting a Walsh mask to the mobile station. If the base station supports one F-PDCH with Radio Configuration 10, the base station will support one or two F-PDCCHs. If the base station supports two F-PDCHs, the base station must support two F-PDCCHs.

The F-PDCCH is transmitted at variable data rates of 29600, 14800, and 7400 bps depending on the frame duration. All F-PDCCHs and associated F-PDCHs transmitted simultaneously shall start their transmissions at the same time and have the same durations.

The channel bits are convolutionally encoded and symbol repetition is performed. The bit stream is then punctured, interleaved, and then spread by a Walsh function. The Walsh code which spreads the F-PDCCH is W64(n), where $1 \le n \le 63$. The value of n is specified by the base station.

Adjacent Channel Power Ratio (ACPR) Measurement Concepts

Purpose

Adjacent Channel Power Ratio (ACPR), as it applies to cdma2000, is the power contained in a specified frequency channel bandwidth relative to the total carrier power. It may also be expressed as a ratio of power spectral densities between the carrier and the specified offset frequency band.

As a composite measurement of out-of-channel emissions, ACPR combines both in-band and out-of-band specifications to provide useful figures-of-merit for spectral regrowth and emissions produced by components and circuit blocks without the rigor of performing a full spectrum emissions mask measurement.

To maintain a quality call by avoiding channel interference, it is important to measure and reduce any adjacent channel leakage power transmitted from a mobile phone. The characteristics of adjacent channel leakage power are mainly determined by the transmitter design, particularly the low-pass filter.

Measurement Method

This ACPR measurement analyzes the total power levels within the defined carrier bandwidth and at given frequency offsets on both sides of the carrier frequency. This measurement requires the user to specify measurement bandwidths of the carrier channel and each of the offset frequency pairs up to 5. Each pair may be defined with unique measurement bandwidths.

It uses an integration bandwidth (IBW) method that performs a time domain data acquisition and applies FFT to get a frequency domain trace. In this process, the channel integration bandwidth is analyzed using the automatically defined resolution bandwidth (RBW), which is much narrower than the channel bandwidth. The measurement computes an average power of the channel over a specified number of data acquisitions, automatically compensating for resolution bandwidth and noise bandwidth.

If **Total Pwr Ref** is selected as the measurement type, the results are displayed as relative power in dBc and as absolute power in dBm. If **PSD Ref** (Power Spectral Density Reference) is selected, the results are displayed as relative power in dB, and as absolute power in dBm/Hz.

Recommended Offset Frequencies and Reference Bandwidths

While the user sets the specific offsets and reference bandwidths, the

radio specifications recommend some common setups as shown in the following table. The offset frequency is titled as Offset to Edge in the measurement result window. For example, if the measurement bandwidth is set to 30 kHz, the first offset center frequency can be 765 kHz and the offset to edge frequency can be 750 kHz.

Table 5-1 ACPR Setup Recommendation

Band	Test Device	Offset Frequency	Integration Bandwidth	Result Reference
cdma2000	Mobile	±900.0 kHz	$30~\mathrm{kHz}$	Total Power
		±1.995 MHz	$30~\mathrm{kHz}$	in 1.230 MHz
	Base	±765.0 kHz	30 kHz	
		±1.995 MHz	30 kHz	

Channel Power Measurement Concepts

Purpose

The Channel Power measurement is a common test used in the wireless industry to measure the total transmitted power of a radio within a defined frequency channel. This procedure measures the total power within the defined channel for cdma2000. This measurement is applied to design, characterize, evaluate, and verify transmitters and their components or devices for base stations and mobile stations.

Measurement Method

The Channel Power measurement reports the total transmitted power within the channel bandwidth, 1.23000 MHz for the cdma2000 mode. The measurement acquires a number of points representing the input signal in the time domain. It transforms this information into the frequency domain using FFT and then calculates the channel power. The effective resolution bandwidth of the frequency domain trace is proportional to the number of points acquired for FFT. The fastest FFT process is achieved using a number of acquired points that is a power of 2 (for example: 64, 128, 512).

Since the measurement is optimized for speed and accuracy, you are permitted to change only the number of acquired data points in powers of 2, not the actual resolution bandwidth which is shown in gray. However, if absolute sweep time is required, it can be changed to the user's specific value at the expense of reduced speed. At no time will both sweep time and data points be set to manual because of conflicting parameter settings. This flexibility is available through the **Advanced** menu of the channel power measurement.

To improve repeatability, you can increase either the number of averages or the number of data points with longer time record length. The channel power graph is shown in the graph window, while the absolute channel power in dBm and the mean power spectral density in dBm/Hz are shown in the text window.

For E4406A Option B7C, this measurement is available for use with either the RF input or baseband I/Q inputs. For detailed operation, see the "Using Option B7C Baseband I/Q Inputs" section.

Code Domain Measurement Concepts

Purpose

Since the code domain measurements despread and descramble the cdma2000 signal into its physical channels, the number of active channels of various symbol rates (which are denoted by widths) can be observed. The width of the channel is inversely proportional to the Walsh code length in number of bits. In the code domain, there is a fixed amount of code space for a given chip rate. Therefore, by using the different Walsh codes, the system can dynamically allocate the code space for lower rate voice users versus high speed data users.

This code domain power composite view provides information about the in-channel characteristics of the cdma2000 signal. It directly informs the user of the active channels with their individual channel powers. The composite view also shows which data rates are active and the corresponding amount of code space used. The following are conditions under which a general unlock can occur: the Pilot signal is too low in power or no Pilot signal available, an incorrect long code is used for despreading, the frequency error is too large, or a frequency inversion is present.

When the level of the code domain noise floor is too high, relative to a reference or an expected level, one of the possible causes might be due to CW interference, like local oscillator feedthrough or spurs. I/Q modulation impairments can be another source of this uncorrelated noise. The I/Q demodulation measurements can reveal errors such as I/Q gain imbalance or I/Q quadrature error.

Measurement Method

This procedure measures the power levels of the spread channels in composite RF channels. **Measure** in the **Meas Control** menu default is **Single** for this measurement.

The code domain measurement displays the power for each of the spread channels, relative to the total power within the 1.230 MHz channel bandwidth centered at the center frequency. Each spread channel level is displayed as an individual vertical bar with a different width determined by a spread rate. Because this is a relative measurement, the unit of measure is dB (not dBm or watts). This allows a comparison of signal levels between the Pilot and Traffic channels.

For E4406A Option B7C, this measurement is available for use with either the RF input or Baseband I/Q inputs. For detailed operation, see "Baseband I/Q Inputs (Option B7C) Measurement Concepts" on page 537.

If **Device** is set to **MS**, the demodulated I and Q signals are individually shown in the code domain power graph window. Depending on the test equipment for MS, it is recommended that you use the trigger output signal from the instrument for synchronization.

The following displays are available for this measurement:

• Power Graph & Metrics - The transmitted energy associated with each of the symbol rates and Walsh codes is shown in the graph window. The following powers along with the total power are shown in the text window depending on the device selection:

Table 5-2 Code Domain Channel Power Metrics

For BTS	For MS
Total active channel power Pilot channel power Synch channel power Time offset Maximum active channel power Average active channel power Maximum inactive channel power Average inactive channel power Number of active channels	Total active channel power Pilot channel power I average active channel power I maximum inactive channel power Q average active channel power Q maximum inactive channel power

- I/Q Error (Quad View) The magnitude error, phase error, and EVM graphs are individually shown in the graph windows. The summary data for these parameters are also shown in the text window.
- Code Domain (Quad View) The graphs of the code domain power, the symbol power for the selected spread channel, and the I/Q symbol power polar vector for the symbol power range selected by the measurement interval and measurement offset parameters, are shown in the graph windows. The symbol EVM summary data is also shown in the text window.
- Demod Bits In addition to the graphs of the code domain power and the symbol power for the selected spread channel, the demodulated bit stream data can be shown for the selected slots of the symbol power in the text window.

Intermodulation Measurement Concepts

Purpose

The cdma2000 standard defines transmit intermodulation as a measure of transmitter quality. Intermodulation products are generated by non-linear components or devices in equipment where two signals, one desired and another undesired, are present. Transmit intermodulation is a measure of a transmitter's ability to inhibit the generation of the intermodulation products.

Measurement Method

The intermodulation measurement measures the third-order and fifthorder intermodulation products caused by the wanted signal and the interfering signal. These intermodulation products are generated by the nonlinear devices or circuits in a transmitter. The measured results are evaluated as a ratio, relative to the carrier power. There are two types of intermodulation:

- Two-tone Measurements are made assuming two CW signals to be the tone signals.
- Transmit IM Measurements are made assuming that one signal is the modulated transmitting signal and another is the CW signal.

This measurement automatically identifies either two-tone intermodulation mode or transmit intermodulation mode at the start of measurements. The fundamental signals, lower and upper, are automatically searched every sweep to calculate the proper results. When a measurement starts, the highest two peaks at frequency f0 and f1 are searched within a given span. Based on these frequencies, the frequencies associated with the possible third-order and fifth-order intermodulation products are calculated. The power bandwidth is checked to determine if the mode is two-tone intermodulation or transmit intermodulation.

The results are displayed both as relative power in dBc, and as absolute power in dBm. For transmit intermodulation products, the result is also shown as the power spectral density in dBm/MHz.

Modulation Accuracy (Composite Rho) Measurement Concepts

Purpose

Rho is one of the key modulation quality metrics, along with EVM and code domain power. Rho is the ratio of the correlated power in a single coded channel to the total signal power. This is a simplified case of code domain power since this measurement is made on a single coded channel. This measurement takes into account all possible error mechanisms in the entire transmission chain including baseband filtering, I/Q modulation anomalies, filter amplitude and phase non-linearities, and power amplifier distortion. This provides an overall indication of the performance level of the transmitter of the UUT.

Measurement Method

This procedure measures the performance of the transmitter's modulation circuitry.

In a digitally modulated signal, it is possible to predict what the ideal magnitude and phase of the carrier should be at any time, based on the transmitted data sequence. The transmitter's modulated signal is compared to an ideal signal vector. The difference between these two vectors is sampled and processed using DSP. Rho values are in the range of 0 to 1. A value of 1 indicates perfect correlation to the reference (high modulation quality). The cdma2000 base station standards require that transmitters have a Rho performance of 0.912 or greater.

For E4406A Option B7C, this measurement is available for use with either the RF input or Baseband I/Q inputs. For detailed operation, see "Baseband I/Q Inputs (Option B7C) Measurement Concepts" on page 537.

Depending on the test equipment for MS, it is recommended that you use the trigger output signal from the instrument for synchronization.

If the error code 604 "Can not correlate to input signal" is shown, it means that your measurement has failed to find any active channels due to the lack of correlation with the input signal. The input signal level, for example, may need to be adjusted to obtain correlation.

With the Rho measurement, the following data is provided:

- Rho modulation quality representing the ratio of the correlated power in a single coded channel to the total signal power
- EVM peak and rms error vector magnitude
- Peak CDE peak code domain error with that code number

- Magnitude Error rms magnitude error
- Phase Error rms phase error
- Freq Error the frequency difference between the transmitter's actual center frequency and the frequency (or channel) that you entered
- I/Q Origin Offset the origin offset for I/Q signals
- No. of Active Channels
- Time Offset the time offset between the I and Q signals

Occupied Bandwidth Measurement Concepts

Purpose

Occupied bandwidth measurements express the percentage of the transmitted power within a specified bandwidth. This percentage is typically 99%.

The spectrum shape of a cdma2000 signal can give useful qualitative insight into transmitter operation. Any distortion to the spectrum shape can indicate problems in transmitter performance.

Measurement Method

The instrument uses digital signal processing (DSP) to sample the input signal and convert it to the frequency domain. With the instrument tuned to a fixed center frequency, samples are digitized at a high rate with DSP hardware, and then converted to the frequency domain with FFT software.

The total power within the measurement frequency span is integrated for its 100% of power. The frequencies of 0.5% of the total power are then calculated to get 99.0% bandwidth.

For E4406A Option B7C, this measurement is available for use with either the RF input or Baseband I/Q inputs. For detailed operation, see "Baseband I/Q Inputs (Option B7C) Measurement Concepts" on page 537.

Power Statistics CCDF Measurement Concepts

Purpose

Many of the digitally modulated signals now look noise-like in the time and frequency domain. This means that statistical measurements of the signals can be a useful characterization. Power Complementary Cumulative Distribution Function (CCDF) curves characterize the higher-level power statistics of a digitally-modulated signal. The curves can be useful in determining design parameters for digital communications systems.

Long battery life is a key competitive advantage for the mobile phone. cdmaOne uses offset quadrature phase shift keying (OQPSK) as the modulation format for the reverse link. OQPSK minimizes the peak-to-average power ratio by avoiding signal envelope transitions through zero. Peak-to-average power ratio is the ratio of the peak envelope power to the average envelope power of a signal. If the peak-to-average power ratio is small, the headroom required in the amplifier to prevent compression of the signal and interference with the adjacent frequency channels is small. Thus, the amplifier can operate more efficiently.

In cdma2000 the handset can transmit multiple channels to accommodate the high data rates. Modulation schemes such as OQPSK or Gaussian minimum shift keying (GMSK) do not prevent zero-crossings for multiple channels and are no longer suitable. Instead, QPSK is used in combination with HPSK to minimize the peak-to-average power ratio. (For more information on HPSK see [3].) With this technique, the peak-to-average power ratio for the basic configuration (an R-Pilot channel and an R-FCH) is equal to or larger than 4 dB during 0.1 percent of the time (see Figure 6). Even though HPSK reduces the peak-to-average power ratio, it still increases as code channels are activated for higher data rates because the amplitude vectors of each code channel add to each other.

A severe case occurs if two supplemental channels at high data rates are required. In this case, the benefits of HPSK may be lost. This is rarely expected to happen since the forward link will carry most of the high data rate traffic.

The amplifier must be capable of handling the different peak-to-average power ratios the signal exhibits for the different channel configurations, while maintaining good adjacent channel power (ACP) performance. From the measurement perspective, the statistics of the signal may impact the result of the measurement, particularly in the case of adjacent channel power ratio (ACPR). Therefore, it is


(CCDF) does that for you.

important to choose the signal's channel configuration carefully. You need to cover the real-life worst cases, such as those with the most stressful signal configurations or highest peak-to-average power ratios. To do that, you need a way to define the statistics of cdma2000 reverse link signals. The complementary cumulative distribution function

CCDF measurement fully characterizes the power statistics of the signal [5]. It provides the distribution of particular peak-to-average power ratios versus probability. Figure 6 compares the CCDF curves for a signal with R-Pilot and R-FCH, and a signal with R-Pilot, R-FCH, R-SCH1 at 153.6 kbps, and R-SCH2 at

153.6 kbps. For a probability of 0.1 percent, the signal with two supplemental channels has a peak-to-average power ratio 2 dB higher than the signal with only an R-Pilot and an R-FCH. As mentioned earlier, adding code channels, in general, increases the peak-to-average power ratio of the signal [5].

Figure 5-5 CCDF curves for two cdma2000 SR1 reverse link signals with different channel configurations.



The power statistics CCDF measurement can be affected by many factors. For example, modulation filtering, modulation format, combining the multiple signals at different frequencies, number of active codes and correlation between symbols on different codes with spread spectrum systems. These factors are all related to modulation and signal parameters. External factors such as signal compression and expansion by non-linear components, group delay distortion from filtering, and power control within the observation interval also affect

the measurement.

CCDF curves can help you in several situations:

- To determine the headroom required when designing a component [15].
- To confirm the power statistics of a given signal or stimulus. CCDF curves allow you to verify if the stimulus signal provided by another design team is adequate. For example, RF designers can use CCDF curves to verify that the signal provided by the digital signal processing (DSP) section is realistic.
- To confirm that a component design is adequate or to troubleshoot your subsystem or system design, you can make CCDF measurements at several points of a system. For example, if the ACLR of a transmitter is too high, you can make CCDF measurements at the input and output of the PA. If the PA design is correct, the curves will coincide. If the PA compresses the signal, the PAR of the signal is lower at the output of the PA (Figure 5-5 on page 528).

Measurement Method

The power measured in power statistics CCDF curves is actually instantaneous envelope power defined by the equation:

$$P = (I^2 + Q^2)/Z_0$$

(where I and Q are the quadrature voltage components of the waveform and Z_0 is the characteristic impedance).

A CCDF curve is defined by how much time the waveform spends at or above a given power level. The percent of time the signal spends at or above the level defines the probability for that particular power level. To make the power statistics CCDF measurement, the instrument uses digital signal processing (DSP) to sample the input signal in the channel bandwidth.

The Gaussian distribution line as the band-limited gaussian noise CCDF reference line, the user-definable reference trace, and the currently measured trace can be displayed on a semi-log graph. If the currently measured trace is above the user reference trace, it means that the higher peak power levels against the average power are included in the input signal.

For E4406A Option B7C, this measurement is available for use with either the RF input or Baseband I/Q inputs. For detailed operation, see "Baseband I/Q Inputs (Option B7C) Measurement Concepts" on page 537.

QPSK EVM Measurement Concepts

Purpose


In constant amplitude modulation schemes, such as GMSK, the phase and frequency error are the metrics for modulation quality. However, these metrics are not very effective for non-constant amplitude modulation formats that can also have errors in amplitude.

Phase and frequency errors are measures of modulation quality for the cdma2000 system. This modulation quality is quantified through QPSK Error Vector Magnitude (EVM) measurements. Since the base stations in cdma2000 systems use Quadrature Phase Shift Keying (QPSK) modulation, the phase and frequency accuracies of the transmitter are critical to the communications system performance and ultimately affect range.

cdma2000 receivers rely on the phase and frequency quality of the QPSK modulation signal in order to achieve the expected carrier to noise ratio. A transmitter with high phase and frequency errors will often still be able to support phone calls during a functional test. However, it will tend to cause difficulty for mobiles trying to maintain service at the edge of the cell with low signal levels or under difficult fading and Doppler conditions.


The accuracy of non-constant amplitude modulation schemes, such as quadrature amplitude modulation (QAM), or quadrature phase shift keying (QPSK), can be assessed very effectively by looking at the constellation of the signal. Signal impairment can be objectively assessed by taking the displacement of each measured symbol from the reference position as an error phasor (or vector), as shown in Figure 5-6.

Figure 5-6 Error Vector and Related Parameters



The reference position is determined from a reference signal that is synthesized by demodulating the data bits from the received signal and then re-modulating these bits "perfectly" for a generic QPSK signal, as shown in Figure 5-7.

Figure 5-7 Process to Calculate EVM for a Generic QPSK Signal



The root mean square (RMS) of the error vectors is computed and expressed as a percentage of the square root of the mean power of the ideal signal¹. This is the error vector magnitude (EVM). EVM is a common modulation quality metric widely used in digital communication systems. (See [16] for more information on how to use EVM as a troubleshooting tool.)

For a regular QAM or a phase shift keying (PSK) signal the ideal symbol points always map onto a few specific locations in the I/Q plane. The cdma2000 reverse link signal can consist of multiple channels that are I/Q multiplexed. This means the one-bit symbols for each channel are BPSK encoded 2 for either the I or the Q path. Several channels can be added to the I and/or the Q paths. The resulting I and Q signals are then spread and HPSK scrambled (see Figure 3). The complex-valued chip sequence is then filtered and the result is applied to the QPSK modulator 3 . The cdma2000 MS transmitter in Figure 11 illustrates this process.

The resulting constellation depends on the physical channel configuration. The constellation typically does not look like QPSK or any other known constellation. Except for some very specific channel

^{1.} The actual calculation method of the percentage depends on the specific standard. The EVM may be normalized to the amplitude of the outermost symbol, the square root of the average symbol power, or the square root of the mean power of the ideal signal. In the case of cdma2000, the specifications require normalization to the square root of the mean power of the ideal signal (see section on Composite EVM).

^{2.} BPSK encoding, in this case, refers to the process of mapping the one-bit symbols for a channel onto the I (or the Q) path in serial. This means the symbols for a channel are directly converted into I (or Q) levels. For example, 1001 would be converted to 1-1-11.

^{3.} QPSK modulation, in this case, refers to the upconversion process (the process of modulating the radio frequency (RF) carrier with the I/Q baseband signal.

configurations, for example, a signal with a single R-Pilot (or a single R-FCH) does map onto a QPSK constellation. A signal with both a R-Pilot and a R-FCH at the same amplitude level maps onto a 45°-rotated QPSK constellation [3]. Since the receiver does not care about the absolute phase rotation, it effectively sees a QPSK constellation.


You can use a regular QPSK EVM measurement to evaluate the modulation quality of the transmitter for a single R-Pilot, a single R-FCH, or a signal with both at the same amplitude level. More complex signals cannot be analyzed with this measurement.

The signal analyzer may use either of the following methodologies to make a QPSK EVM measurement:

- Measure QPSK EVM on the received signal. Filter the recovered I/Q signal with the equalizer and complementary receiver filters and compare it with a reference signal calculated by filtering the demodulated signal with the transmitter, equalizer, and receiver filters See (a) in Figure 5-8 on page 533.
- Measure QPSK EVM on the transmitted signal. Compare the I/Q recovered signal directly with a reference signal calculated by filtering the ideal chips with the transmitter filter. See (b) in Figure 5-8 on page 533.

Both methods yield similar EVM results and you can use either of them to make valid modulation quality measurements of the MS transmitter; however, the resulting constellation looks different. The first method results in four discrete constellation points. The second method results in a fuzzy constellation, as shown in Figure 12a. The constellations for both methods are correct. The reason for the difference is that, for the first method, the constellation displays what the receiver sees after filtering, while the second method displays the constellation of the transmitted signal before applying any receiver filtering.

Figure 5-8 Process to Calculate QPSK EVM for a cdma2000 Forward Link Signal.



Measurement Method

The input signal needs to be a single coded signal, such as a pilot channel.

The phase error of the unit under test is measured by computing the difference between the phase of the transmitted signal and the phase of a theoretically perfect signal. The instrument samples the transmitter output in order to capture the actual phase trajectory. This is then demodulated and the ideal phase trajectory is mathematically derived using detected bits and channel filtering. Subtracting one from the other results in a phase error signal.

This measurement allows you to display these errors numerically and graphically on the instrument display. There are graphs for EVM, Phase Error and Mag Error in the graph windows. In the text window, there are both maximum and average data for Evm: in % rms, in % peak, RMS Mag Error: in %, Phase Error: in degrees, Freq Error: in Hz, and IQ Offset: in dB.

For E4406A Option B7C, this measurement is available for use with either the RF input or Baseband I/Q inputs. For detailed operation, see "Using Option B7C Baseband I/Q Inputs" on page 97.

Spectrum (Frequency Domain) Measurement Concepts

Purpose

The spectrum measurement provides spectrum analysis capability for the instrument. The control of the measurement was designed to be familiar to those who are accustomed to using swept spectrum analyzers.

This measurement is FFT (Fast Fourier Transform) based. The FFT-specific parameters are located in the **Advanced** menu. Also available under basic mode spectrum measurements is an I/Q window, which shows the I and Q signal waveforms in parameters of voltage versus time. The advantage of having an I/Q view available while in the spectrum measurement is that it allows you to view complex components of the same signal without changing settings or measurements.

Measurement Method

The measurement uses digital signal processing to sample the input signal and convert it to the frequency domain. With the instrument tuned to a fixed center frequency, samples are digitized at a high rate, converted to I and Q components with DSP hardware, and then converted to the frequency domain with FFT software.

For E4406A Option B7C, this measurement is available for both the RF input and baseband I/Q inputs. For details on Baseband I/Q operation see the section on "Using Option B7C Baseband I/Q Inputs".

Troubleshooting Hints

Changes made by the user to advanced spectrum settings, particularly to ADC range settings, can inadvertently result in spectrum measurements that are invalid and cause error messages to appear. Care needs to be taken when using advanced features.

Spectrum Emission Mask Measurement Concepts

Purpose

Spectrum Emission Mask measurements include the in-band and out-of-band spurious emissions. As it applies to cdma2000, it is the power contained in a specified frequency bandwidth at certain offsets relative to the total carrier power. It may also be expressed as a ratio of power spectral densities between the carrier and the specified offset frequency band.

As a composite measurement of out-of-channel emissions, the spectrum emission mask measurement combines both in-band and out-of-band specifications to provide useful figures-of-merit for spectral regrowth and emissions produced by components and circuit blocks without the rigor of performing a full spectrum emissions mask measurement.

Measurement Method

The spectrum emission mask measurement measures spurious signal levels in up to five pairs of offset/region frequencies and relates them to the carrier power. The reference channel integration bandwidth method is used to measure the carrier channel power and offset/region powers. When "Offset" is selected, spectrum emission mask measurements are made, relative to the carrier channel frequency bandwidth. When "Region" is selected, spurious emission absolute measurements are made, set by specifying start and stop RF frequencies. The upper frequency range limit is 3.678 GHz. The measurement screen is titled Spurious Emission.

This integration bandwidth method performs a time domain data acquisition. In this process, the reference channel integration bandwidth (Meas BW) is analyzed using the automatically defined resolution bandwidth (Res BW), which is much narrower than the channel bandwidth. The measurement computes an average power of the channel or offset/region over a specified number of data acquisitions, automatically compensating for resolution bandwidth and noise bandwidth.

This measurement requires the user to specify measurement bandwidths of the carrier channel and each of the offset/region frequency pairs up to 5. Each pair may be defined with unique measurement bandwidths. The results are displayed both as relative power in dBc, and as absolute power in dBm. Refer to Table 3-12 on page 209, Table 3-13 on page 209, Table 3-14 on page 211, and Table 3-15 on page 211 for the default values of offset and region frequencies, resolution bandwidths, and limits.

Waveform (Time Domain) Measurement Concepts

Purpose

The waveform measurement is a generic measurement for viewing the input signal waveforms in the time domain. This measurement is how the instrument performs the zero span functionality found in traditional spectrum analyzers.

Basic mode waveform measurement data may be displayed using either a Signal Envelope window, or an I/Q window which shows the I and Q signal waveforms in parameters of voltage versus time. The advantage of having an I/Q view available while making a waveform measurement is that it allows you to view complex components of the same signal without changing settings or measurements.

For E4406A, an I/Q Polar display is also available to view the I and Q waveforms in a polar plot. This display shows the instantaneous relationship between the I and Q waveform voltages.

The waveform measurement can be used to perform general purpose power measurements in the time domain with excellent accuracy.

Measurement Method

The instrument makes repeated power measurements at a set frequency, similar to the way a swept-tuned spectrum analyzer makes zero span measurements. The input analog signal is converted to a digital signal, which then is processed into a representation of a waveform measurement. The measurement relies on a high rate of sampling to create an accurate representation of a time domain signal.

For E4406A with Option B7C, this measurement is available for use with both the RF input and baseband I/Q inputs. For details on Baseband I/Q operation see the section on "Using Option B7C Baseband I/Q Inputs".

Baseband I/Q Inputs (Option B7C) Measurement Concepts

The E4406A VSA Option B7C Baseband I/Q Inputs provides the ability to analyze baseband I/Q signal characteristics of mobile and base station transmitters. This option may be used only in conjunction with the following personalities:

- Basic mode (available in all VSA Series Transmitter Testers)
- Option BAF W-CDMA Measurement Personality
- Option B78 cdma2000 Measurement Personality
- Option 202 GSM with EDGE
- Option 252 GSM to GSM with EDGE upgrade

What are Baseband I/Q Inputs?

Option B7C consists of a Baseband Input module, four $50~\Omega$ BNC connectors, and internal cabling. The four BNC connectors are grouped into pairs at the upper left corner of the front panel. The upper two connectors labeled "I" and "Q" are the "unbalanced" inputs.

In practice, an unbalanced or "single-ended" baseband measurement of an I or Q signal is made using a probe connected to the I or Q connector. A simultaneous I/Q unbalanced single-ended measurement may be made using two probes connected to the I and Q input connectors.

If "balanced" signals are available, they may be used to make a more accurate measurement. Balanced signals are signals present in two separate conductors, are symmetrical about ground, and are opposite in polarity, or out of phase by 180 degrees.

Measurements using balanced signals can have a higher signal to noise ratio resulting in improving accuracy. Noise coupled into each conductor equally in a "common mode" to both signals may be separated from the signal. The measure of this separation is "common-mode rejection".

To make a balanced measurement, the lower two connectors labeled " \overline{I} " and " \overline{Q} " are used in conjunction with the I and Q inputs. The terms "I-bar" and "Q-bar" may be applied to the signals, as well as the inputs themselves. Probes (customer provided) must be used to input balanced baseband I/Q signals. This may be referred to as a balanced measurement.

Balanced baseband measurements are made using the I and \overline{I} connectors for I only signal measurements, while the Q and \overline{Q} connectors are used for a Q only signal measurement. Balanced

measurements of I/Q require differential probe connections to all four input connectors. For details of probe selection and use, refer to "Selecting Input Probes for Baseband Measurements" on page 538.

What are Baseband I/Q Signals?

In transmitters, the term baseband I/Q refers to signals that are the fundamental products of individual I/Q modulators, before the I and Q component signals are combined, and before upconversion to IF or RF frequencies.

In receivers, baseband I/Q analysis may be used to test the I and Q products of I/Q demodulators, after an RF signal has been downconverted and demodulated.

Why Make Measurements at Baseband?

Baseband I/Q measurements are a valuable means of making qualitative analyses of the following operating characteristics:

- I/Q signal layer access for performing format-specific demodulation measurements (e.g. CDMA, GSM, W-CDMA):
- Modulation accuracy i.e. I/Q plane metrics
 - rho
 - error vector magnitude; rms, peak, or 95%
 - carrier feed-through
 - frequency error
 - magnitude and phase errors
- Code-domain analysis (including code-specific metrics)
- CCDF of $I^2 + Q^2$
- Single sideband (SSB) metrics for assessing output quality
- Basic analysis of I and Q signals in isolation including: DC content, rms and peak to peak levels, CCDF of each channel

Comparisons of measurements made at baseband and RF frequencies produced by the same device are especially revealing. Once signal integrity is verified at baseband, impairments can be traced to specific stages of upconversion, amplification, or filtering by RF analysis. Likewise, impairments to signal quality that are apparent at RF frequencies may be traceable to baseband using baseband analysis.

Selecting Input Probes for Baseband Measurements

The selection of baseband measurement probe(s) and measurement

method is primarily dependent on the location of the measurement point in the circuit. The probe must sample voltages without imposing an inappropriate load on the circuit.

The following measurement methods may be used with baseband I/Q inputs:

• 50 Ω Unbalanced - This is the measurement method of choice if single-ended or unbalanced baseband I and/or Q signals are available in 50 Ω coaxial transmission lines and are terminated in a coaxial connectors. Adapters necessary to convert to a 50 Ω BNC-type male connector must be of 50 Ω impedance.

The methods are as follows:

- I only measurement using one single-ended probe connected to the I input connector (available in the Basic mode)
- Q only measurement using one single-ended probe connected to the Q input connector (available in the Basic mode)
- I/Q measurement using two single-ended probes connected to the I and Q input connectors
- 600 Ω Balanced This is the measurement method of choice if balanced baseband signals having a 600 Ω impedance are available. The methods are as follows:
 - I only measurement using one differential probe or two single-ended probes connected to the I and \bar{I} inputs (available in the Basic mode)
 - Q only measurement using one differential <u>probe</u> or two single-ended probes connected to the Q and \overline{Q} inputs (available in the Basic mode)
 - I/Q measurement using two differential probes or four single-ended probes connected to the I, Q, \overline{I} , and \overline{Q} input connectors
- 1 M Ω Unbalanced High input impedance is the measurement method of choice if single-ended or unbalanced baseband signals to be measured lie in a trace on a circuit board and are sensitive to loading by the probe. This is the default input connector setting.

When making 1 M Ω measurements, the reference input impedance may be adjusted. For details refer to "I/Q Setup Key Menu" on page 2. 1 M Ω unbalanced measurements may be made as follows:

- I only measurement using one single-ended probe connected to the I input connector (available in the Basic mode)
- Q only measurement using one single-ended probe connected to the Q input connector (available in the Basic mode)

Baseband I/Q Inputs (Option B7C) Measurement Concepts

- I/Q measurement using two single-ended probes connected to the I and Q input connectors
- 1 $M\Omega$ Balanced High input impedance measurements may also be made if differential or balanced signals are available. 1 $M\Omega$ balanced measurements may be made as follows:
 - I only measurement using one differential probe or two single-ended probes connected to the I and \bar{I} inputs (available in the Basic mode)
 - Q only measurement using one differential probe or two single-ended probes connected to the Q and \overline{Q} inputs (available in the Basic mode)
 - I/Q measurement using two differential probes or four single-ended probes connected to the I, Q, \overline{I} , and \overline{Q} input connectors

This is the measurement method of choice if differential or balanced baseband signals to be measured lie in a trace on a circuit board and are sensitive to loading by the probe. When making $1~M\Omega$ measurements, the reference input impedance may be adjusted. For details refer to "I/Q Setup Key Menu" on page 2.

The following table lists the probes currently available from Agilent, which are suitable for use under various measurement conditions:

Table 5-3 Agilent Probes - Balanced and Unbalanced

Probe Type	Description
Unbalanced (single-ended)	1144A 800 MHz Active Probe ^{abc} 54701A 2.5 GHz Active Probe ^{bcd} 1145A 750 MHz 2-Channel Active Probe ^{abc} 85024A High Frequency Probe ^{be} 41800A Active Probe ^{bf} 10020A Resistive Divider Probe ^{bc} 54006A 6 GHz Passive Divider Probe ^g
Balanced (differential)	1141A 200 MHz Active Differential Probe ^{abc} N1025A 1 GHz Active Differential Probe ^{bh}

- a. Not compatible with 3-wire power interface. Needs 1142A power supply. For two channels, you will need either two 1142A power supplies or one 1142A power supply and one 01144-61604 1-input, two-output adapter cable.
- b. Two probes needed to cover both I and Q inputs.
- c. Output connector is BNC-type.
- d. Not compatible with 3-wire power interface. Requires use of 1143A power supply that can power two 54701A probes.
- e. 85024A bandwidth is 300 kHz to 3 GHz. Output connector is N-type. Power is 3-wire connector (+15 V, -12.6 V, ground).
- f. 41800A bandwidth is 5 Hz to 500 MHz. Output connector is N-type. Power is 3-wire connector (+15 V, -12.6 V, ground).
- g. 54006A output connector is 3.5 mm
- h. 3.5 mm output connector, requires ± 15 V supply.

Refer to the current Agilent data sheet for each probe for specific information regarding frequency of operation and power supply requirements.

The E4406A Transmitter Tester provides one "three-wire" probe power connector on the front panel. Typically, it can energize one probe. If you plan on operating more than one probe, make sure you provide sufficient external power sources as required.

Baseband I/Q Measurement Views

Measurement result views made in the Basic mode, or by other compatible optional personalities, are available for baseband signals if they relate to the nature of the signal itself. Many measurements which relate to the characteristics baseband I and Q signals have when mixed and upconverted to signals in the RF spectrum can be made as well. However, measurements which relate to the characteristics of an

Chapter 5 541

upconverted signal that lie beyond the bandwidth available to the Baseband I/Q Input circuits can not be measured (the limits are up to

Baseband I/Q Input circuits can not be measured (the limits are up to 5 MHz bandwidth for individual I and Q signals, and up to 10 MHz for composite I/Q signals).

Some measurement views are appropriate for use with both RF and baseband I/Q signals without any modification, while other views must be altered. Some examples of measurements with identical results views are QPSK EVM, Code Domain, and CCDF. For Spectrum measurements, identical views include the I and Q Waveform view and the I/Q Polar view. For Waveform measurements, identical views include the I/Q Waveform view, the Signal Envelope view, and the I/Q Polar view.

At RF frequencies, power measurements are conventionally displayed on a logarithmic vertical scale in dBm units, whereas measurements of baseband signals using Baseband I/Q inputs may be conveniently displayed as voltage using a linear vertical scale as well as a log scale.

Spectrum Views and 0 Hz Center Frequency

Some views must be altered to account for the fundamental difference between RF and baseband I/Q signals. For Spectrum measurements of I/Q signals this includes using a center frequency of 0 Hz for Spectrum views and the Spectrum Linear view. Occupied Bandwidth and Channel Power results are also displayed using a center frequency of 0 Hz.

The center frequency of baseband I/Q Spectrum displays is 0 Hz. Frequencies higher than 0 Hz are displayed as "positive" and those below 0 Hz are "negative". The "negative" portion of a multi-channel baseband signal below 0 Hz corresponds to the portion of the signal that would lie below the carrier center frequency when it is upconverted, if no spectral inversion occurs. As 0 Hz is a fixed center frequency, the **FREQUENCY Channel** front-panel key has no active menu for baseband I/Q Spectrum measurements.

To view the Spectrum display of I only or Q only signals, use the Spectrum measurement capability in Basic Mode.

I only and Q only Spectrum views are conventional, displayed with 0 Hz at the left margin of the vertical axis. When upconverted or multiplied, an I only or Q only signal could ultimately lie above or below the carrier center frequency, but in either case it will only occupy half the bandwidth. As 0 Hz is a fixed start frequency, the **FREQUENCY Channel** front panel key has no active menu keys. Use **Span** to change horizontal scale. The center frequency is displayed as half the current **Span**.

Waveform Views for Baseband I/Q Inputs

For Waveform measurements, two new displays are available exclusively for baseband I/Q input signals; the I and Q Waveform view, which separates the individual I and Q traces, and the I/Q Polar view.

Since the horizontal axis for Waveform measurements is Time, the **FREQUENCY Channel** front-panel key has no active menu for baseband I/Q Waveform measurements. Use **Span** to change horizontal scale. A **Linear Envelope** view is also available to display baseband signals that employs linear voltage units on the vertical axis.

Waveform Signal Envelope Views of I only or Q only

To view the Signal Envelope display of I only or Q only signals, use the Waveform measurement capability in Basic Mode.

The I and Q Waveform of an I/Q signal is very different from the complex signal displayed in the Waveform Signal Envelope view. That is because the Signal Envelope is a product of both the I and Q modulation waveforms.

However, an I and Q Waveform measurement of an I only or Q only signal is exactly the same signal displayed in the Waveform Signal Envelope view. That is because an I only or Q only waveform determines the I only or Q only signal envelope. Thus, the Waveform Signal Envelope view can be used to measure an I only or Q only waveform directly.

Comparing RF and Baseband I/Q Measurement Views

The following table compares the measurement views for RF inputs and baseband I/Q inputs.

Table 5-4 RF vs. Baseband I/Q Input Measurement Views by Measurement

Measurement	Views for RF Input Measurements	Views for Baseband I/Q Inputs Measurements	Mods to RF View for Baseband I/Q Inputs
Channel Power	Channel Power	Channel Power	Center Freq = 0 Hz
ACPR	FFT, Fast Bar Graph, Spectrum	Measurement Not Available	n/a
Itermodulation	IMD Spectrum	Measurement Not Available	n/a
Spectrum Emission Mask	Spectrum Views by Offset	Measurement Not Available	n/a
Occupied BW	Occupied BW	Occupied BW	Center Freq = 0 Hz
Code Domain	Power Graph & Metrics I/Q Error (Quad View) Code Domain (Quad View) Demod Bits table	Power Graph & Metrics I/Q Error (Quad View) Code Domain (Quad View) Demod Bits table	none
Mod Accuracy (Composite RHO)	I/Q Measured Polar Vector I/Q Measured Polar Constln I/Q Error (Quad View) Power Timing and Phase	I/Q Measured Polar Vector I/Q Measured Polar Constln I/Q Error (Quad View) Power Timing and Phase	none

Chapter 5 543

Table 5-4 RF vs. Baseband I/Q Input Measurement Views by Measurement

Measurement	Views for RF Input Measurements	Views for Baseband I/Q Inputs Measurements	Mods to RF View for Baseband I/Q Inputs
QPSK EVM	I/Q Measured Polar Vector I/Q Measured Polar Constln I/Q Error (Quad View)	I/Q Measured Polar Vector I/Q Measured Polar Constln I/Q Error (Quad View)	none
Power Stat CCDF	CCDF	CCDF	none
Spectrum (Freq Domain)	Spectrum Spectrum Linear I and Q Waveform I/Q Polar	Spectrum Spectrum Linear I and Q Waveform I/Q Polar	Center Freq = 0 Hz (Spectrum Views) Y axis = V, dBm (Spectrum Linear)
Waveform (Time Domain)	Signal Envelope I/Q Waveform I/Q Polar	Signal Envelope I/Q Waveform I/Q Polar Linear Envelope I and Q Waveform	Y axis = V, dBm (Linear Envelope)

Results screens for the above measurements unique to baseband I/Q inputs are shown in the section "Baseband I/Q Measurement Result Examples" on page 2.

Other Sources of Measurement Information

Additional measurement application information is available through your local Agilent Technologies sales and service office. The following application notes treat digital communications measurements in much greater detail than discussed in this measurement guide.

Application Note 1298

Digital Modulation in Communications Systems - An Introduction Agilent part number 5965-7160E

Application Note 1311

Understanding CDMA Measurements for Base Stations and Their Components
Agilent part number 5968-0953E

• Application Note 1335

HPSK Spreading for 3G Agilent part number 5968-8438E

• Application Note 1357

Designing and Testing cdma2000 Base Stations Agilent part number 5980-1303E

Application Note 1358

Designing and Testing cdma2000 Mobile Stations Agilent part number 5980-1237E

Application Note

Characterizing Digitally Modulated Signals with CCDF Curves Agilent part number 5968-5858E

Instrument Updates at www.agilent.com

These web locations can be used to access the latest information about the instrument, including the latest firmware version.

http://www.agilent.com/find/psa

http://www.agilent.com/find/vsa

Chapter 5 545

References

- [1] Understanding CDMA Measurements for Base Stations and Their Components, Application Note 1311, literature number 5968-0953E.
- [2] Ken Thompson, "Concepts of cdma2000," Wireless Symposium, 999.
- [3] HPSK Spreading for 3G, Application Note 1335, literature number 5968-8438E.
- [4] Designing and Testing W-CDMA Base Stations, Application Note 1355, literature number 5980-1239E.

6 Menu Maps

These menu maps are in alphabetical order by the front panel key label or oval cross-reference label. You can locate detailed information about each key/function at the page number listed in the figure title for each menu.

cdma2000 Measurement Key Flow

The key flow diagrams, shown in a hierarchical manner on the following pages, will help you grasp the overall functional relationships for the front-panel keys and the keys displayed at the extreme right side of the screen. The diagrams are:

```
"MODE Selection Key Flow" on page 549
```

Use these flow diagrams as follows:

• There are some basic conventions:

Meas Setup An oval represents one of the front-panel keys.

QPSK EVM This box represents one of the keys displayed.

<for EVM> This represents an explanatory description on its specific key.

Avg Number 10 On|Off This box shows how the key default condition is displayed. Default

parameters or values are underlined wherever possible.

- Start from the upper left corner of each measurement diagram. Go to the right, and go from the top to the bottom.
- When changing a key from auto (with underline) to manual, just press that key one time.
- When entering a numeric value of FREQUENCY Channel, for example,

[&]quot;Mode Setup/FREQUENCY Channel Key Flow (1 of 2)" on page 550

[&]quot;Measurement Selection Key Flow" on page 552

[&]quot;Channel Power Measurement Key Flow" on page 553

[&]quot;ACPR Measurement Key Flow" on page 554

[&]quot;Intermodulation Measurement Key Flow" on page 555

[&]quot;Spectrum Emission Mask Measurement Key Flow (3 of 3)" on page 558

[&]quot;Occupied Bandwidth Measurement Key Flow" on page 559

[&]quot;Code Domain Measurement Key Flow (1 of 7)" on page 560

[&]quot;Modulation Accuracy Measurement Key Flow (1 of 4)" on page 567

[&]quot;QPSK EVM Measurement Key Flow (1 of 2)" on page 571

[&]quot;Power Statistics CCDF Measurement Key Flow" on page 573

[&]quot;Spectrum (Freq Domain) Measurement Key Flow (1 of 4)" on page 574

[&]quot;Waveform (Time Domain) Measurement Key Flow (1 of 3)" on page 578

- use the numeric keypad and terminate the entry with the appropriate unit selection from the softkeys displayed.
- When entering a numeric value for a unit-less value, like Avg
 Number, use the numeric keypad and terminate the entry with the Enter front-panel key.
- Instead of using the numeric keypad to enter a value, it may be easier to use the RPG knob or **Up/Down** keys.

Figure 6-1 MODE Selection Key Flow




Figure 6-2 Mode Setup/FREQUENCY Channel Key Flow (1 of 2)




Figure 6-3 Mode Setup/FREQUENCY Channel Key Flow (2 of 2)





Figure 6-4 Measurement Selection Key Flow



Menu Maps

Figure 6-5 Channel Power Measurement Key Flow





Figure 6-6 ACPR Measurement Key Flow



Menu Maps

Figure 6-7 Intermodulation Measurement Key Flow





Figure 6-8 Spectrum Emission Mask Measurement Key Flow (1 of 3)



Menu Map

Figure 6-9 Spectrum Emission Mask Measurement Key Flow (2 of 3)





Figure 6-10 Spectrum Emission Mask Measurement Key Flow (3 of 3)



Menu Maps






Figure 6-12 Code Domain Measurement Key Flow (1 of 7)




Figure 6-13 Code Domain Measurement Key Flow (2 of 7)




Figure 6-14 Code Domain Measurement Key Flow (3 of 7)




Figure 6-15 Code Domain Measurement Key Flow (4 of 7)




Figure 6-16 Code Domain Measurement Key Flow (5 of 7)






Figure 6-17 Code Domain Measurement Key Flow (6 of 7)




Menu Maps

Figure 6-18 Code Domain Measurement Key Flow (7 of 7)



<2k_modacc1_setup>



QPSK 8PSK

16QAM

(a) (b)

Figure 6-19 Modulation Accuracy Measurement Key Flow (1 of 4)

Figure 6-20 Modulation Accuracy Measurement Key Flow (2 of 4)





Figure 6-21 Modulation Accuracy Measurement Key Flow (3 of 4)



Figure 6-22 Modulation Accuracy Measurement Key Flow (4 of 4)



Menu Maps

Figure 6-23 QPSK EVM Measurement Key Flow (1 of 2)





Figure 6-24 QPSK EVM Measurement Key Flow (2 of 2)



Menu Maps

Figure 6-25 Power Statistics CCDF Measurement Key Flow




Figure 6-26 Spectrum (Freq Domain) Measurement Key Flow (1 of 4)




Figure 6-27 Spectrum (Freq Domain) Measurement Key Flow (2 of 4)






Figure 6-28 Spectrum (Freq Domain) Measurement Key Flow (3 of 4)




Menu Maps

Figure 6-29 Spectrum (Freq Domain) Measurement Key Flow (4 of 4)




Chapter 6 577

Figure 6-30 Waveform (Time Domain) Measurement Key Flow (1 of 3)




578 Chapter 6

Figure 6-31 Waveform (Time Domain) Measurement Key Flow (2 of 3)



Chapter 6 579

Figure 6-32 Waveform (Time Domain) Measurement Key Flow (3 of 3)



580 Chapter 6

Numerics	ADC Corr key, 184, 218	amplitude y scale
1 Mohm balanced, 120	ADC Dither key	reference position, 137, 141,
1 Mohm unbalanced, 120	spectrum measurement, 189	159, 169, 170
1xEV-DO measurement, 441	ADC dithering	reference value, 137, 141, 159
1xEV-DV on/off, 431	SPECtrum, 478	169, 170
50 ohm unbalanced, 120	WAVeform, 492	scale coupling, 137, 141, 160,
600 ohm balanced, 120	ADC filter	169, 170
ooo omm balanced, 120	WAVeform, 492	scale per division, 137, 141,
A	ADC range	159, 169
A	automatic control, 176	Analog Filter key, 184, 218
ACP	automatic peak control, 176	applications
offset frequencies, 385	automatic peak lock, 176	currently available, 307
offset sideband choice, 453		applications, selecting, 307, 309
setting amplitude levels, 384	modulation accuracy (rho), 433	
testing, 392, 453	SPECtrum, 479	ASCII data format, 303
view of data, 292	WAVeform, 493	attenuation
ACPR	ADC Range key	setting, 426
	spectrum measurement, 188	average count
amplitude levels, 388, 390	ADC ranging function	intermodulation, 415
changing display, 137, 138	automatic control, 145, 164, 221	averaging
channel integration bandwidth,	automatic control to peak, 146,	ACP, 381, 382
125	164	ACPR, 381, 382
detector type, 394	automatic lock to peak, 164	CHPower, 404, 405, 421, 422
FFT sweep, 395	automatic peak control, 221	modulation accuracy (rho), 434
measurement reference type,	automatic peak lock, 221	435
130	manual control, 146, 164, 176,	OBW, 421
offset frequencies, 386	221	QPSK EVM, 410
offsets & limits, 126		SPECtrum, 480, 481
resolution bandwidths, 385	adjacent channel power	
spectrum graph	measurement, 381	traces, 423
amplitude Y scale, 137	adjacent channel power ratio	transmit band spurs, 397, 425
display, 138	measurement, 315, 381	494
	See also ACPR	WAVeform, 494, 495
sweep mode detection, 394	Advanced menu	averaging count
sweep time, 395	Active Set Th (threshold) key,	spectrum emission mask, 441
sweep type, 395	145	averaging state
swept mode res BW, 394	spectrum, 187	intermodulation, 415
testing choices, 391, 396, 453	waveform	spectrum emission mask, 441
view/trace selection, 134	waveform	averaging termination control
acpr	advanced set-	intermodulation, 416
sweep resolution bandwidth,		,
131	tings, 220	В
sweep type	advanced menu	
FFT, 131	active set threshold, 163	bandwidth
acquisition packing	ADC dither, 221	ACPR, 382
WAVeform, 492	ADC range, 176	CHPower, 405
activate 1xEV-DV, 431	ADC ranging function, 145, 164,	occupied bandwidth, 422
active data channel	221	SPECtrum, 484, 485
code domain power, 398		spectrum emission mask, 442
RHO, 432	chip rate, 145	WAVeform, 496, 497
active license key, 43	decimation, 222	base code length, 292
	FFT window, 171	base frequencies delta
how to locate, 43	number of data points, 139	intermodulation, 417
Active Set Th (threshold) key	pre-ADC bandpass filter, 221	base frequency auto search
Advanced menu, 145	resolution bandwidth, 139	intermodulation, 417
active set threshold	resolution bandwidth filter, 221	
CDP, 256	sweep time, 139	base lower frequency
modulation accuracy (rho), 286	trigger source, 139, 140	intermodulation, 418
active set threshold mode	amplitude	base station testing, 431
CDP, 256	input range, 427	base transmit station
modulation accuracy (rho), 286	maximizing input signal, 428	loss correction, 409

base upper frequency	Walsh code order, 261	I/Q modulation impairments,
intermodulation, 418	CDPower	521
Baseband I/Q inputs	chip rate, 400	I/Q quadrature error, 521
key access table, 246	data capture time, 399	in-channel characteristics, 521
key entries, 246	long code mask, 403	marker function, 156
key path, 246	QOF, 403	marker function, delta reading,
Baseband IQ measurements, 97	quasi-orthogonal function, 403	156
basic mode, 106	selecting spectrum type, 403	marker function, despread, 157
binary data order, 303	trigger source, 403	marker function, marker
Block Size key, 218	center frequency setting, 414	selection, 156
burst carriers, 431	center frequency step size, 414	marker function,markers off,
burst trigger	changing	156
level, 505	instrument settings, 381	marker function,normal
byte order of data, 303	channel power	reading, 156
by the order or data, 500	advanced menu, 520	marker function, off, 156
C	amplitude Y scale, 141	marker function, shape
	changing display, 141	selection, 156
captured data block size		
(wideband IF), 218	channel bandwidth, 520	marker function, trace with
captured data sample rate	power spectral density, 520	marker, 156
(wideband IF), 218	time record length, 520	marker key menu, 156
carrier	channel power measurement	meas setup
type, 431	See also CHPower	sync type F-PCICH, 143
carrier selection, 430	channel power measurement,	sync type TxDiv F-PCICH, 143
CCDF measurement, 351	342, 404	measure setup
CDMA measurement, 342, 381,	chip rate	1xEV-DV Active Channel, 143,
398, 404, 432	CDPower, 400	162
cdma2000	modulation accuracy (rho), 435	advanced menu, 145
ACP measurement, 384	QPSK EVM, 411	capture interval, 145
averaging, 410	Choose Option key, 42	long code mask, 143
offset frequencies, 446, 462,	CHPower	measure type, 141
463, 474	number of points, 406, 407	measurement interval, 142
offset frequencies auto mode,	sweep time, 407, 408	measurement offset, 142, 143
447, 448, 464	trigger source, 408	spectrum, 145
spectrum emission mask	code domain	sync type, 143
measurement, 454, 456,	amplitude Y scale, reference	Walsh code number, 142
457, 459, 460, 461, 469,	value, 153	measure setup Walsh code
470, 471, 472, 473, 474	amplitude Y scale, scale per	length, 141
trigger source, 412, 439, 476	division, 153	OVSF channels, 521
cdma2000 measurement, 315,	code domain with quad view, 522	paging channel, 521
343, 346, 349, 351, 353, 369,		pilot channel, 521
381, 410, 415, 421, 429, 441	demodulated bit stream, 522	sync channel, 521
cdmaOne	demodulated bits window, 152	traffic channel, 521
ACP measurement, 384, 392	display, 151	power composite view, 521
trigger source, 439	chip dots, 151 display, code order, bit reverse,	power graph & metrics, 522
cdmaOne measurement, 315,	151	span X scale, expand, 153 span X scale, reference position,
322, 353	display,base code length, 151	152, 153
CDP	display,code order, 151	span X scale, reference value,
active set threshold, 256	display,composite chip power,	152
active set threshold mode, 256	152	span X scale, scale coupling, 153
base code length, 292	display,consolidated marker,	span X scale, scale per division,
computation type, 260	151	152, 153
decode axis, 257	display,Walsh Code Length, 151	symbol power graph, 152
sweep offset, 258	I/Q error graphs, amplitude Y	view/trace, 148
sweep time, 259	scale, 155	view/trace, amplitude Y scale,
Walsh code base length, 260	I/Q error with quad view, 522	153
Walsh code length, 261	I/Q gain imbalance, 521	
Walsh code number, 261	• 6	

view/trace,code domain with	wideband ADC corrections, 184,	spectrum window, 294, 295,
quad view, 149	218	300, 301
view/trace,demodulated bit	current measurement, 291	tiling, 292
stream view, 150	curve fit the data, 273	trace, 295
view/trace,IQ error (quad view),		window tile, 292
148	D	zoom, 293
view/trace,power graph &	data	display ACP data, 292
metrics, 148		display commands, 292
width of channel, 521	querying, 262, 273	display rho data, 293
code domain error limit	data block size, 218	dithering of ADC
modulation accuracy (rho)	data capture time	WAVeform, 492
(BTS), 287	CDPower, 399	dithering the ADC, 478
code domain error limit (BTS)	data decimation, 485	dittiering the ADC, 476
	WAVeform, 497, 498	Б
cdma2000, 287	data format, 303	E
W-CDMA (3GPP), 287	data from measurements, 311	enable 1xEV-DV, 431
code domain measurement	Data Packing	external reference, 440
using print function, 156	spectrum measurement, 189,	external trigger
code domain power	221	delay, 501
active data channel, 398	data sample rate, 218	level, 501
column index, 400	Decimation	slope, 502
F-PDCH number, 401, 402	spectrum measurement, 189	51000, 502
Walsh mask, 400, 401	decimation	F
code domain power measurement,		
322, 398	SPECtrum, 485	fail conditions
See also CDPower	decimation of data	absolute AND relative, 127
code, programming	WAVeform, 497, 498	absolute level, 127
compatibility across PSA modes,	default states, 49	absolute OR relative, 127
251, 253	default values, setting remotely,	relative level, 127
compatibility, PSA series versus	313	fail mask condition
VSA, 254	deleting an	absolute limit, 208, 211
	application/personality, 37	absolute limit AND relative
column index	delta markers, 278	limit, 208, 211
code domain power, 400	demodulated bits window	absolute limit OR relative limit,
rho, 435	display	209, 211
commands	first page, 152, 168	relative limit, 208, 211
compatibility across PSA modes,	last page, 152, 168	
251, 253	next page, 168	FETCh command use, 311
CONFigure, 313	previous page, 168	FETCh commands, 313
FETCh, 313	scroll down, 152, 168	FFT
INITiate, 314	scroll up, 168	SPECtrum, 486, 487, 488
MEASure, 312	display,next page, 152	FFT bandwidth, SPECtrum, 482,
PSA series versus VSA	display, previous page, 152	483, 484
compatibility, 254	display,scroll up, 152	FFT Length key, 185, 188
READ, 314	display, seron up, 102	FFT Size menu, 184, 188
compatibility, programming	+45 degrees rotation, 168	FFT window
across PSA modes, 251		Blackman filter, 172
PSA series versus VSA, 254	absolute peak power levels &	Blackman-Harris filter, 172
CONFigure command use, 311	frequencies, 215	flat top filter, 171
CONFigure commands, 313	chip dots, 179	Gaussian filter with alpha 3.5,
continuous carriers, 431	chip interval, 168	172
continuous vs. single	chip offset, 167	Hamming filter, 172
measurement mode, 305	full vector background display,	Kaiser-Bessel 110 dB filter, 172
control measurement commands,	168	Kaiser-Bessel 70 dB filter, 172
305	I/Q points, 179	Kaiser-Bessel 90 dB filter, 172
correction	I/Q polar vector and/or	occupied bandwidth, 423
	constellation, 167	uniform filter, 172
base transmit station loss, 409	integrated power levels, 215	FFT Window key., 184, 187
mobile station loss, 409	relative peak power levels &	filter
corrections	frequencies, 215	gain setup (wideband), 183, 217
	·	Sam secup (wideband), 100, 211

setup (wideband), 183, 217	I/Q data output, 106	advanced spectrum feature, 189
type (wideband), 217	I/Q data results, 375, 379	IF path filter
Filter Alpha key, 183, 217	I/Q error graphs	alpha, 183, 217
Filter BW key, 183, 218	amplitude Y scale, 180	bandwidth, 183, 218
Filter Type key, 183, 217	phase error graph,amplitude Y	setup, 183
Flat Top key, 183, 217	scale	type, 183
format, data, 303	, 181	IF Path key, 187, 220
F-PDCH number	phase error,amplitude Y scale,	IF setup, 183, 217
code domain power, 401, 402	155	IF trigger delay, 503
rho, 437, 438	span X scale	IF trigger level, 504
frame trigger adjustment, 502	reference position, 154, 169,	IF trigger slope, 504
frame trigger period, 502	180	index
frequencies offset	reference value, 154, 168, 180	code domain power, 400
ACP, 385	scale coupling, 154, 169, 180	rho, 435
frequency	scale per division, 154, 168,	initial signal connection, 49
carrier setting, 430	179	INITiate commands, 314
center, 414	I/Q input impedance, 120	initiate measurement, 305, 306
step size, 414	I/Q marker query, 290	input
	I/Q Polar view	= -
frequency channel		external attenuator, 122
center frequency, 113	waveform measurement, 234,	attenuation for BTS tests, 122
center frequency step, 113	237	attenuation for MS tests, 122
frequency channel key menu, 113	I/Q polar view	I/Q impedance reference for 1
frequency span	I/Q polar window, 203, 204,	Mohm input impedance,
CHPower, 406	234, 237	120
SPECtrum, 489	I/Q polar window	IF alignment signal, 123
spectrum emission mask, 444	amplitude Y scale, 204	signal amplitude, 123
FT window	I/Q scale per division, 203, 204	signal rate, 123
Hanning filter, 172	Q Origin, 203, 204	signal type, 123
	I origin, 234, 237	input attenuator, 121, 122, 123
\mathbf{G}	I/Q scale per division, 234, 237	input port, 119
Gaussian key, 183, 217	Q origin, 234, 237	50 MHz reference, 120
Gaassian Roj, 100, 211	span X scale, 203, 204	Baseband Align Signal, 120
I	I Origin, 203, 204	rf, 119
	I/Q scale per division	max total power, 121
I and Q waveform view	I/Q polar window, 234, 237	maximum total power, 121
I or Q waveform window, 203	I/Q Scale/Div key, 203, 204	RF input range, 120
I waveform window, 236	I/Q setup, 120	input attenuation, 426
Q waveform window, 236	I/Q waveform view	input key menu, 116, 119
I offset, 120	I/Q waveform window, 236	input port
I or Q waveform window	I/Q waveform window, 233, 234	50 MHz reference, 120
amplitude Y scale, 203	amplitude Y scale, 236	I only, 119
reference position, 204	reference position, 237	I/Q, 119
reference value, 204	reference value, 236	IF align, 120
scale coupling, 204	scale coupling, 237	Q only, 119
scale per division, 204	scale per division, 236	input port selection, 413
span X scale	iDEN	input power
reference position, 202, 234	ACP measurement, 384	maximum, 428
reference value, 202, 234	trigger source, 424	range, 427
scale coupling, 202, 234	iDEN measurement, 349, 421	Install Now key, 42
scale per division, 202, 233	iDEN offset frequencies, 385	Installing and Obtaining a license
I origin	IF BW key, 217	key, 41
I/Q polar window, 234, 237	IF filter	installing measurement
I Origin key, 203, 204	gain setup, 183, 217	personalities, 37
I waveform window	setup, 217	instrument configuration, 307
amplitude Y scale, 236		integration bandwidth
reference position, 237	type, 217	intermedulation 416
scale coupling, 237	IF Flat Corr key, 184, 218 IF Flatness	intermodulation, 416
scale per division, 236	ir riamess	intermodulation
scare per arvision, 200		

amplitude Y scale, 159	obtaining and installing, 41	RF carrier, 119
average count, 415	limit line testing, 262	root-raised cosine filter, 158
averaging state, 415	limit testing	automatic search for base
averaging termination control,	OBW, 285	frequency signal, 158
416	limits	base frequency setting, 158
base frequencies delta, 417	fail mask condition, 208, 210	delta frequency (f1-f0), 158
base frequency auto search, 417	linear envelope view	lower frequency (f0), 158
base lower frequency, 418	linear envelope window, 235	upper frequency (f1), 158
base lower signal, 67	phase window, 236	detection type
base upper frequency, 418	linear envelope window, 233, 234	average power, 212
display	amplitude \dot{Y} scale, $\frac{235}{}$	peak power, 212
IM products lines, 160	reference position, 235	frequency span, 158
integration bandwidth, 416	reference value, 235	limits, 162
intermodulation graph, 67	scale coupling, 236	composite peak EVM, 162
measurement mode, 419	scale per division, 235	composite rho, 162
measurement reference, 420	linear spectrum window	composite rms EVM, 162
resolution bandwidth, 416	amplitude Y scale	peak code domain error, 162
resolution bandwidth, 417	reference position, 203	long code mask, 163
span, 419 transmit IM, 157, 158, 205, 206	reference value, 203	measurement bandwidth, 173
	scale coupling, 203	measurement interval, 173, 176
transmit intermodulation	scale per division, 203	measurement mode, 157
products, 523	span, 202	automatic search mode, 157
two-tone intermodulation	loading an	transmit IM mode, 157
products, 523	application/personality, 37	two-tone mode, 157
view/trace, 159	long code mask	number of counts, 173
intermodulation measurement,	CDPower, 403	PN offset, 163
346, 415	modulation accuracy (rho), 439	reference signal, 157
See also IM		resolution bandwidth, 158
internal reference, 440	M	automatic mode, 158
internal reference selection, 413	major functional keys, 110	manual mode, 158
Internal RF Preamplifier, 122	making measurements, 311	restore measurement defaults,
IQ port selection, 413	marker	131, 139, 145, 158, 163,
	I/Q query, 290	171, 174, 176, 187, 212, 220
K		spectrum, 163
kov flow diagram	markers, 274	spectrum segment
key flow diagram	assigning them to traces, 279	offset, offsets and limits, 206
acpr, 548	maximum, 278	spectrum segment, offset, 206
channel power, 548	minimum, 278	spectrum segment, region, 206
code domain, 548	off, 279	Walsh code quasi-orthogonal
intermodulation, 548	trace assignment, 284	factor, 145
mode setup / frequency channel,	turn off, 277	measure type
548	type, 278	absolute power, 141
modulation accuracy (composite	valid measurement, 274	relative power, 141
EVM), 548	value, 285	measurement
occupied bandwidth, 548	value of, 277	adjacent channel power, 381
power statistic CCDF, 548	x-axis location, 284	
QPSK EVM, 548	y-axis, 285	adjacent channel power ratio,
spectrum (frequency domain),	maximum value of trace data, 273	381
548	mean value of trace data, 273	channel power, 138, 404, 520
spectrum emission mask, 548	Meas Time key, 217	code domain, 141, 521
waveform (time domain), 548	MEASure command use, 311	code domain power, 398
	MEASure commands, 312	intermodulation, 415
L	measure setup	intermodulation products, 157,
	advanced menu, 158, 163, 171,	523
length	176	transmit intermodulation, 523
QPSK EVM, 412	chip rate, 164, 176	markers, 274
Length Ctrl key, 184, 188	integration bandwidth, 158	modulation accuracy (composite
Length key, 184, 188	multi channel estimator, 164	rho), 161, 524
license key		

correlated power, 524	measurement selection	missing options, 37
error vector magnitude, 524	adjacent channel power ratio,	mobile station
frequency error, 525	113, 114	loss correction, 409
I/Q origin offset, 525	channel power, 113	mobile station testing, 431
magnitude error, 525	modulation accuracy (composite	mod accuracy
modulation quality, 524	rho), 114	meas setup
number of active channels,	power stat CCDF, 115	sync type F-PCICH, 163
525	QPSK EVM, 115	sync type TxDiv F-PCICH, 163
peak code domain error, 524	spectrum (frequency domain),	Mod Scheme selection, 142
phase error, 525	115	modulation accuracy (rho)
rho, 524	waveform (time domain), 115	active set threshold, 286
time offset, 525	measurement setup	active set threshold mode, 286
modulation accuracy (rho), 432	advanced menu, 139	long code mask, 439
occupied bandwidth, 171, 526	averaging mode, 125, 138, 161, 185, 218	phase error limit, 288
spectrum shape, 526	exponential, 125, 138, 161,	rho result I/Q offset, 287 time offset limit, 288
transmitter operation, 526 occupied BW, 421	185, 219	
power stat CCDF	averaging number, 125, 138,	modulation accuracy (rho) (BTS) code domain error limit (BTS),
marker, 175	161, 185, 218	287
power statistics CCDF, 173, 527	averaging type, 185, 219	peak EVM limit, 287
Gaussian distribution curve,	log power average (video), 186,	rho limit, 288
529	219	RMS EVM limit, 288
power statistics CCDF	maximum voltage average,	modulation accuracy (rho)
measurement, 429	186, 219	measurement, 432
QPSK error vector magnitude,	minimum voltage average,	See also RHO
410	186, 219	modulation accuracy
QPSK EVM, 176, 530	power average (rms), 185, 219	measurement, 353
phase and frequency quality,	voltage average, 186, 219	meas setup
530	channel power span, 139	sync type, 57, 163
QPSK EVM phase trajectory,	integration bandwidth, 138	multi carrier estimator
533	time averaging number, 186	modulation accuracy (rho), 437
query current, 291	measurements	• • • • • • • • • • • • • • • • • • • •
spectrum (frequency domain),	adjacent channel power ratio,	N
478	315	NADC
spectrum emission mask, 205,	CCDF, 351	offset frequencies, 385
441, 535	channel power, 342	NADC measurement, 381
spurious emissions and ACP,	code domain power, 322	normal marker, 278
441	CONF/FETC/MEAS/READ	
waveform (time domain), 492	commands, 311	0
measurement control	control of, 305	OBW
measure, 116	getting results, 311	limit testing, 285
pause, 116	intermodulation, 346	trigger source, 424
restart, 116	modulation accuracy, 353	OBW averaging, 421
measurement key flow, 548 measurement mode	occupied BW, 349 power stat, 351	occupied bandwidth
intermodulation, 419	QPSK error vector magnitude,	99.0% bandwidth, 526
measurement modes	343	amplitude Y scale, 172
currently available, 307	setting default values remotely,	reference position, 173
selecting, 307, 309	313	reference value, 172
measurement reference	single/continuous, 305	scale coupling, 173
intermodulation, 420	spectrum (frequency domain),	scale per division, 172
measurement reference type	375	FFT window, 423
power spectral density	spectrum emission mask, 369	measure setup
reference, 212	waveform (time domain), 378	frequency span, 171
spectral power density	measuring I/Q data, 375, 379	limit frequency value, 171
reference, 130	Min Pts in RBW key, 184, 188	limit test, 171
total power reference, 130, 212	minimum value of trace data, 273	resolution bandwidth, 171
		view/trace, 172

occupied BW measurement, 349,	currently available, 307	factory defaults, 49
421	selecting, 307, 309	preset states, 49
See also OBW	personality options not in	print setup
offset for pseudo-random noise,	instrument, 37	print demodulated bits data,
258, 289	phase error limit	156
offset frequencies, 392	cdma2000, 288	programming
ACP, 385	modulation accuracy (rho), 288	compatibility among PSA
	phase inversion, 403	modes, 251, 253
spectrum emission mask, 446,		
462, 463, 474	phase window, 233, 234	compatibility, PSA series versus
offset frequencies auto mode	amplitude Y scale, 236	VSA, 254
spectrum emission mask, 447,	reference position, 236	PSA series versus VSA
448, 464	reference value, 236	(programming compatibility)
offsets & limits	scale per division, 236	254
absolute limits, 127	points/measurement	pseudo-random noise offset, 258,
fail conditions, 127	CHPower, 406, 407	289
offset channel memory, 126	power stat CCDF	
offset frequency, 126	display	\mathbf{Q}
offset side, 208	Gaussian line display, 174	•
reference bandwidth, 127	reference trace display, 174	Q offset, 120
relative attenuation, 208	store reference trace, 174	Q origin
relative limit (carrier level), 127	marker	I/Q Polar window, 234, 237
relative limit (PSD level), 128	delta, 175	I/Q polar window, 234, 237
offsets and limits	function, 175	Q Origin key, 203, 204
		Q waveform window
limits, 208	marker all off, 175	amplitude Y scale, 236
absolute start level, 208	normal, 175	reference position, 237
absolute stop level, 208	off, 175	reference value, 236
relative start level, 208	select, 175	scale coupling, 237
relative stop level, 208	shape, 175	scale per division, 236
measurement bandwidth, 208	trace, 175	QOF
offset, 207	span X scale	CDPower, 403
resolution bandwidth, 207	scale per division, 174	
start frequency, 207	power statistic CCDF	QPSK error vector magnitude
step frequency, 207	cdma2000, 286	measurement, 343, 410
stop frequency, 207	store reference, 286	QPSK error vector measurement
Option 122 wideband selection,	W-CDMA (3GPP), 286	See also EVMQpsk
187, 220	power statistics CCDF	QPSK EVM
options	measurement, 429	averaging, 410
		chip rate, 411
loading/deleting, 37	See also PSTat	length, 412
options not in instrument	pre-ADC bandpass filter	quadrature phase shift keying
memory, 37	SPECtrum, 483	modulation, 530
_	Pre-ADC BPF key	RF carrier mode, 411
P	spectrum measurement, 187	trigger source, 412
packing	Preamplifier	quasi-orthogonal function
SPECtrum, 478	Setting the internal	CDPower, 403
pass/fail test, 262	preamplifier, 122	query data, 262, 273
PDC	pre-amplifier	query uata, 202, 210
offset frequencies, 385	attenuator, 426	D
	on/off, 426	R
trigger source, 424	predefined active data channel	radio
PDC measurement, 349, 381, 421	code domain power, 400, 401,	device, 116
PDCH number, 401, 402, 437,	402	radio key menu, 116
438	rho, 435, 436, 437, 438	Raised Cosine Key, 183, 217
peak EVM limit		READ command use, 311
cdma2000 (BTS), 287	pre-FFT bandwidth, SPECtrum,	READ commands, 314
modulation accuracy (rho)	482, 483, 484	real number data format, 303
(BTS), 287	Pre-FFT BW key, 187	rear panel external trigger
W-CDMA (3GPP) (BTS), 287	Pre-FFT Fltr key, 187	=
personalities	preset, 49	delay, 501
•		slope, 502

reference external, 440 internal, 440	F-PDCH number, 437, 438 Walsh mask, 436 rho limit	averaged trace, 202, 233 changing views, 192 current trace, 202, 233
reference channel resolution bandwidth spectrum emission mask, 443	cdma2000 (BTS), 288 modulation accuracy (rho) (BTS), 288	I signal trace, 202, 233 next window selection, 192 Q signal trace, 202, 233
reference channel resolution bandwidth auto mode spectrum emission mask, 443	W-CDMA (3GPP) (BTS), 288 rho result I/Q offset modulation accuracy (rho), 287	span X scale, 202 trace display, 202, 233 view/trace, 192
reference channel step frequency spectrum emission mask, 445	RMS EVM limit cdma2000 (BTS), 288	zoom a window, 192 Spectrum (Frequency Domain)
reference channel step frequency auto mode list	modulation accuracy (rho) (BTS), 288	key, 183, 534 spectrum (frequency domain)
spectrum emission mask, 445	W-CDMA (3GPP) (BTS), 288	measurement, 375, 478
reference signal automatic setting, 157	RMS of trace data, 273 Root Nyquist key, 183, 217	See also SPECtrum spectrum emission mask
setting to the lower frequency, 158	RRC (root raised cosine) key, 183, 217	amplitude Y scale, 215 reference position, 215
setting to the upper frequency, 158	S	reference value, 215 scale coupling, 215
reference, selecting internal, 413	Sample Rate key, 218	scale per division, 215
region advanced menu relative attenuation, 210	sampling trace data, 273 select 1xEV-DV, 431	detector mode, 444 display
regions and limits	selecting the	limit lines, 215
limits, 210 absolute start level, 210	wideband/narrowband path,	display key, 215 measure setup
relative start level, 210	187, 220 set up the wideband IF, 183, 217	detection type, 212
relative stop level, 210	signal envelope view	measurement interval, 205
limits absolute stop level, 210	signal envelope window, 235	measurement reference type,
region, 209	signal envelope window, 233, 234	212
resolution bandwidth, 210	amplitude Y scale, 235	reference channel, 205
start frequency, 210 step frequency, 210	reference position, 235	trigger source, 174, 212 measure setup,spectrum
stop frequency, 210	reference value, 235	segment, 206
Res BW key	scale coupling, 235	measurement interval, 476
spectrum measurement, 183	scale per division, 235	offset frequencies, 446, 463
waveform measurement, 217	single vs. continuous measurement mode, 305	offset frequencies auto mode,
resolution bandwidth	span	447, 448, 464
intermodulation, 416	CHPower, 406	offset start frequency, 449, 465
resolution bandwidth state	intermodulation, 419	offset stop frequency, 450, 451,
intermodulation, 417	selecting IF path, 187, 220	465, 467
restart measurement, 306 results, waveform measurement,	SPECtrum, 489 Span key	offset stop frequency auto mode, 450, 466
536	spectrum measurement, 183	power reference, 477
return data, 262, 273 RF carrier mode	SPECtrum	reference channel integration bandwidth
QPSK EVM, 411	acquisition packing, 478	method, 535
RF input port gain setting when	ADC range, 479	reference channel,channel
pre-amplifier is on, 426	data decimation, 485	integration bandwidth, 205
RF input port power gain, 426	FFT length, 486 FFT resolution BW, 487	reference channel, channel span,
RF input, selection, 413	FFT window, 488	205
RHO	FFT window delay, 487	reference channel, resolution
active data channel, 432	frequency span, 489	bandwidth, 206
spectrum type, 438	sweep time, 489, 490	reference channel, step
view of data, 293 rho	trigger source, 490	frequency, 205 relative attenuation, 452, 468
column index, 435	spectrum all traces, 202, 233	relative attenuation, 402, 400

setting amplitude levels, 454, 456, 457, 459, 460, 461, 469, 470, 471, 472, 473, 474 spectral regrowth, 535 spectrum segment,regions and limits, 209 spurious emission, 535 testing choices, 457, 471 trigger source, 476 using markers, 215 view/trace, 214 spectrum emission mask measurement, 369, 441	scale per division, 154 T test limit OBW, 285 test limits, 262 tile the display, 292 time averaging, 186 time domain measurement, 378, 492 time domain measurements, 217, 536 time offset limit	timeout, 500 trigger holdoff, 117 trigger source, 186, 220 external front input, 186, 220 external rear input, 187, 220 frame clock, 187, 220 free run (immediate), 186, 220 line, 187, 220 RF burst (wideband), 186, 220 video (IF envelope), 186, 220 video (envelope) signal, 117 WAVeform, 498 trigger measurement, 305, 306
See also SEM	cdma2000, 288	trigger source
spectrum graph display	modulation accuracy (rho), 288	cdma2000, 403 OBW, 424
reference bandwidth markers,	trace averaging, 423 trace data	QPSK EVM, 412
138	processing, 273	Rho, 439
spectrum measurement basic mode, 106	trace display, 295	spectrum emission mask, 476 W-CDMA, 403
method, 534	trace format, 303 trace names for markers, 279	triggering
results, 192	trace/view selection	CHPower, 408
spectrum measurement display, 294, 295, 300, 301	magnitude & phase graph view,	turn on 1xEV-DV, 431
spectrum phase	transmit band spurs - averaging	U
CDPower, 403 spectrum segment, 215	state, 397, 425, 494	Uninstall Now, 44
spectrum emission mask, 475	transmit diversity	uninstalling measurement
view/trace,all offsets, 214	synchronization code domain measurement	personalities, 37
view/trace,all regions, 214	sync type, 143	v
view/trace, offset A to E, 214	modulation accuracy	view ACP data, 292
view/trace,offset side, 214 view/trace,region A to E, 214	measurement, 57, 163	view rich data, 202 view commands, 292
view/trace,spectrum segment	trigger	view rh data, 293
offset, 214	auto time, 500 automatic trigger, 117	view/trace
view/trace,spectrum segment	burst level, 505	I/Q error with quad view, 166,
region, 214	commands, 500	167, 178 I/Q measured polar
spectrum type RHO, 438	delay, 117, 501	constellation, 177
spurious emissions and ACP	delay, IF, 503	I/Q measured polar vector, 177
measurement, 441	external, 501, 502	I/Q measured polar vector
standard deviation of trace data,	external front input, 117 external rear input, 117	graph, 166
273	frame adjustment, 502	I/Q waveforms, 197 linear spectrum and phase
start measurement, 305, 306 state	frame period, 502	graphs, 195
changing, 381	frame timer, 117	spectrum graph, 192
store reference	offset, 117 period, 117	view/trace selection
power statistic CCDF, 286	reset offset display, 118	I and Q Waveform view, 231
sweep time	synchronizing source, 118	I and Q waveform view, 203 I/Q polar waveform view, 232
SPECtrum, 489, 490 WAVeform, 498	holdoff, 503	I/Q waveform graph window,
Sweep Time key, 217	level, 117, 501	195
symbol power graph	level, IF, 504 on/off, 500	I/Q Waveform view, 229
amplitude Y scale	RF burst signal, 117	linear envelope and phase view,
reference position, 154	slope, 117, 502	227 Spectrum I/Q Waveform view,
reference value, 154 scale coupling, 154	slope, IF, 504	195
scare coupling, 104	SPECtrum, 490	spectrum linear

linear spectrum window, 202,	W-CDMA (3GPP) measurement,
203	315, 322, 343, 346, 349, 351,
VSA versus PSA series	353, 369, 410, 415, 421, 429,
(programming compatibility),	441
254	W-CDMA (Trial & ARIB)
	averaging, 410
\mathbf{W}	trigger source, 412
Walsh mask	W-CDMA (Trial & ARIB)
code domain power, 400, 401	measurement, 315 , 322 , 343 ,
rho, 436	351, 353, 410, 429
WAVeform	W-CDMA measurement, 381
acquisition packing, 492	Wideband Advanced key, 183,
ADC dithering, 492	218
ADC filter, 492	wideband filter alpha, 183, 217
ADC range, 493	wideband filter bandwidth, 183,
data decimation, 497, 498	218
sweep time, 498	wideband filter type, 217
trigger source, 498	Wideband Filtering key, 183, 217
waveform	wideband IF
changing displays, 233	advanced settings, 184, 218
I and Q waveform view, 236	wideband IF data block size, 218
I/Q waveform view, 236	wideband IF data sample rate,
linear envelope view, 236	218
method, 536	wideband IF filter type, 183
resolution bandwidth, 217	Wideband IF Gain key, 183, 217
span X scale, 233	Wideband IF Setup key, 183, 217
sweep time, 233	wideband path selection, 187, 220
using markers, 160, 237	Window Length key, 184, 188
Waveform (Time Domain) key,	7
536	${f Z}$
Waveform (Time Domain) Key	zero span measurement, 378, 492
Menus, 217	zoom the display, 293
waveform (time domain)	
measurement, 378, 492	
See also WAVeform	
waveform measurement, 217	
basic mode, 106	
display, 237	
I/Q Polar view, 234, 237	
WB ADC Dither key, 184, 218	
W-CDMA	
ACP measurement, 384	
trigger source, 439	
W-CDMA (3GPP)	
averaging, 410	
offset frequencies, 446, 462, 463, 474	
offset frequencies auto mode,	
447, 448, 464	
spectrum emission mask	
measurement, 454, 456,	
457, 459, 460, 461, 469,	
470, 471, 472, 473, 474	
trigger source, 412, 476	