

Annex to declaration of accreditation (scope of accreditation)
Normative document: EN ISO/IEC 17025:2005
Registration number: **K 009**

of **KEMA B.V.**
High-Voltage Laboratory

This annex is valid from: **18-12-2018** to **30-11-2020**

Replaces annex dated: **24-05-2018**

Location(s) where activities are performed under accreditation

Head Office

Utrechtseweg 310, Building no. R11
6812 AR
Arnhem
The Netherlands

Location	Abbreviation/ location code
Utrechtseweg 310, Building no. R11 6812 AR Arnhem The Netherlands	ARN

HCS code	Measured quantity, Range	Frequency	CMC ¹	Remarks	Location
LF 0 0	DC/LF ELECTRICITY				
LF 1 0	Direct Voltage				
LF 1 3	Direct High Voltage				ARN
	(5 – 200) kV		$3.5 \cdot 10^{-3} \cdot U$	¹⁾	

If there is no reference to a code and no date or version number is mentioned for a normative document, the accreditation concerns the most current version of the document.
¹ Calibration and Measurement Capability (CMC): Demonstrated measurement uncertainty, with coverage probability of 95%, in a given measurement point or measurement range. Measurement uncertainty, *U*, is calculated according to EA-4/02 "Evaluation of the Uncertainty of Measurement in Calibration".

This annex has been approved by the Board of the
Dutch Accreditation Council, on its behalf,

J.A.W.M. de Haas
Director of Operations

of **KEMA B.V.**
High-Voltage Laboratory

This annex is valid from: **18-12-2018 to 30-11-2020**

Replaces annex dated: **24-05-2018**

HCS code	Measured quantity, Range	Frequency	CMC ¹	Remarks	Location
	Lightning Impulse			full wave	
	(15 – 500) kV		$8 \cdot 10^{-3} \cdot U_t$ $4 \cdot 10^{-2} \cdot T_1$ $2 \cdot 10^{-2} \cdot T_2$	¹⁾ ; T ₁ /T ₂ : 0.84/60 μs	
	(15 – 500) kV		$8 \cdot 10^{-3} \cdot U_t$ $4 \cdot 10^{-2} \cdot T_1$ $2 \cdot 10^{-2} \cdot T_2$	¹⁾ ; T ₁ /T ₂ : 5/60 μs	
	Lightning Impulse			chopped wave	
	(15 – 500) kV		$1.2 \cdot 10^{-2} \cdot U_t$ $5 \cdot 10^{-2} \cdot T_c$ $5 \cdot 10^{-2} \cdot T_1$	¹⁾ ; T _c = 2.5 μs T ₁ = 1.2 μs	
LF 3 0	Alternating Voltage				
LF 3 2	Alternating Voltage Ratio			Voltage Transformers	ARN
	Primary: (2 – 48) kV	50 Hz	$3.0 \cdot 10^{-4} \cdot U_i / U_u$ 0.4 mrad	¹⁾	
	Secondary: (100 or 110) V	60 Hz	$3.0 \cdot 10^{-4} \cdot U_i / U_u$ 0.36 mrad	¹⁾	
	Primary: (12 – 277) kV	50 Hz	$4.0 \cdot 10^{-4} \cdot U_i / U_u$ 0.4 mrad		
	Secondary: (100 / √3) V	60 Hz	$6.0 \cdot 10^{-4} \cdot U_i / U_u$ 0.5 mrad		
LF 3 3	Alternating High Voltage			RMS and $\hat{U}/\sqrt{2}$	ARN
	(12 – 277) kV	50 Hz 60 Hz	$1.2 \cdot 10^{-3} \cdot U$ $1.2 \cdot 10^{-3} \cdot U$		
	(2 – 48) kV	50 Hz 60 Hz	$2.0 \cdot 10^{-3} \cdot U$ $2.0 \cdot 10^{-3} \cdot U$	¹⁾ ¹⁾	
	(5 – 100) kV	25 – 500 Hz	$0.8 \cdot 10^{-2} \cdot U$	¹⁾	
	(20 – 260) kV	20 – 300 Hz	$0.8 \cdot 10^{-2} \cdot U$	¹⁾	

of **KEMA B.V.**
High-Voltage Laboratory

This annex is valid from: **18-12-2018 to 30-11-2020**

Replaces annex dated: **24-05-2018**

HCS code	Measured quantity, Range	Frequency	CMC ¹	Remarks	Location
LF 4 0	Alternating Current				
LF 4 3	Alternating High Current			RMS	ARN
	(0.25 – 60) kA	50 Hz	$2.0 \cdot 10^{-3} \cdot I$	¹⁾	
	(0.25 – 60) kA	60 Hz	$2.0 \cdot 10^{-3} \cdot I$	¹⁾	
	(0.05 – 12) kA	50 Hz	$2.0 \cdot 10^{-3} \cdot I$	¹⁾	
LF 4 2	Alternating Current Ratio			Current Transformers	ARN
	Primary:(0.05 – 12) kA Secondary: 1 A or 5 A	50 Hz	$1.3 \cdot 10^{-4} \cdot I_i / I_u$ 0.24 mrad	^{1) 2)}	
	Primary: (0.25 – 60) kA Secondary: 1 A or 5 A	50 Hz 60 Hz	$1.5 \cdot 10^{-4} \cdot I_i / I_u$ 0.22 mrad $1.5 \cdot 10^{-4} \cdot I_i / I_u$ 0.22 mrad	^{1) 2)} ^{1) 2)}	
	Primary: (0.05 – 3) kA Secondary: 1 A or 5 A	50 Hz 60 Hz	$1.6 \cdot 10^{-4} \cdot I_i / I_u$ 0.28 mrad $1.6 \cdot 10^{-4} \cdot I_i / I_u$ 0.30 mrad	^{1) 2)} ^{1) 2)}	
LF 4 3	Alternating High Current			Voltage Transformers	ARN
	(0.25 – 60) kA	50 Hz	$2.0 \cdot 10^{-3} \cdot I$	¹⁾	
	(0.25 – 60) kA	60 Hz	$2.0 \cdot 10^{-3} \cdot I$	¹⁾	
	(0.05 – 12) kA	50 Hz	$2.0 \cdot 10^{-3} \cdot I$	¹⁾	

Remarks:

The nominal ambient temperature during calibration is (20 ± 5) °C.
 Calibrations are performed inside the laboratory, unless specified otherwise.

¹⁾ Calibrations are also performed on-site.

²⁾ At $I/I_n < 20\%$ an additional contribution to the CMC might be applicable (possible poor signal-to-noise ratio)