

Bureau Veritas Consumer Products Services Germany GmbH

Businesspark A96 86842 Türkheim Germany + 49 (0) 40 740 41 – 0 cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH Accredited according to EN 45011 -ISO / IEC Guide 65

Certificate of compliance

Applicant:

SMA Solar Technology AG

Sonnenallee 1 34266 Niestetal **Germany**

Product:

Photovoltaic (PV) inverter

Model:

SB 1300TL-10, SB 1600TL-10, SB 2100TL

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with IEC 61727:2004 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Applied rules and standards:

NRS 097-2-1:2010 ed1.0

Grid interconnection of embedded generation Part 2: Small-scale embedded generation Section 1: Utility interface

IEC 61727:2004 ed2.0

Photovoltaic (PV) systems - Characteristics of the utility interface

IEC 62116:2008 ed1.0

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

DIN V VDE V 0126-1-1:2006-02

Automatic disconnection device between a generator and parallel to the public low voltage network

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number:

11TH0026-NRS 097-2-1

Certificate number:

U12-0820

Date of issue:

2012-09-11

Valid until:

2015-09-10

Certification body

Achim Hänchen