

## WHY5690

### WHY5640 Thermoelectric Temperature Controller Evaluation Board

#### GENERAL DESCRIPTION:


Quickly interface a WHY5640 temperature controller to your thermoelectric or resistive heater load without having to design a printed circuit board. Connect a WHY5640 Thermoelectric Temperature Controller to the easy-to-configure evaluation board to control temperature using thermistor temperature sensors. Adjust temperature using the onboard trimpot. Other adjustable trimpots configure heat and cool current limits, proportional gain, and integrator time constant. The removable input cable set allows easy connection to your power supply and monitoring equipment while the output cable set quickly connects to your thermal load and temperature sensor. For higher current and/or voltage operation use the onboard fan connector to power a WXC303 or WXC304 (+5 V or +12 V) DC fan attached to a WHS302 heatsink.




#### FEATURES:

- Control temperature using thermistors
- Adjustable Heat and Cool Current Limits
- Adjustable Proportional Gain
- Adjustable Integrator Time Constant
- Enable/Disable Switch and LED
- Includes Input/Output Cable Set
- Includes Fan Connections

**Figure 1**  
Top View




**Figure 2**  
WHY5690 Schematic



**Figure 3**

Assembling the WHY5640 Thermoelectric Controller to the WHY5690 Evaluation Board



## INPUT / OUTPUT CONNECTOR CONFIGURATION

**Table 1 - INPUT CABLE**

PIN #	Color	Function
1	BLUE	PGND
2	ORANGE	VS
3	RED	VDD
4	BLACK	COM
5	WHITE	VM1
6	GREEN	VM2

**Table 2 - OUTPUT CABLE**

PIN #	Color	Function
1	RED	OUTPUT B
2	GREEN	SENSOR +
3	WHITE	SENSOR -
4	BLACK	OUTPUT A

## WHY5690 SETUP AND OPERATION

Follow the next nine steps sequentially to safely operate the WHY5690. Complete steps 1 through 4 before applying power to the board. For online Safe Operating Area Calculators (SOA) see:

<http://www.teamwavelength.com/tools/calculator/soa/defaulttc.htm>.

### STEP 1: ATTACHING HEATSINK AND FAN

The WHY5640 is designed to handle currents as high as 2.0 Amps. Refer to the WHY5640 data sheet to determine the SOA and proper thermal solution for your application. Refer to the WHS302 and WXC303/WXC304 data sheets for proper assembly instructions. (WEV300, WEV301, and WEV302 Thermal Solutions Kits include: heatsink, thermal washer, fan, and screw fasteners).

### STEP 2: CONFIGURING THE HEAT AND COOL CURRENT LIMITS

The evaluation board's LIMA and LIMB trimpots independently adjust the heat and cool current limits from zero to a full 2.0 Amps. Use Table 3 to adjust the heat and cool current limits. Do not exceed SOA limits.

**Table 3 - LIMA and LIMB Current Limit Trimpot Configuration**

Sensor Type	Load Type	LIMA Trimpot	LIMB Trimpot
Thermistor	Thermoelectric	Cool Current Limit	Heat Current Limit
Thermistor	Resistive Heater	Turn Fully CCW	Heat Current Limit

## OPERATING THE EVALUATION BOARD

### STEP 3: CONNECTING YOUR THERMAL LOAD

Use Table 4 to determine how to connect the WHY5640 outputs (OUTA or OUTB) to your thermoelectric or resistive heater.

**Table 4 - Output Configuration**

Sensor Type	Load Type	Output A	Output B
Thermistor	Thermoelectric	Negative TE Terminal	Positive TE Terminal
Thermistor	Resistive Heater	<b>Quick Connection:</b> Simply connect the resistive heater to OUTA and OUTB. Adjust the cooling current limit to zero by turning the LIMA trimpot fully counterclockwise. <b>Maximum Voltage Connection:</b> Connect one side of the resistive heater to OUTB and the other side to the voltage source $V_S$ .	
RTD	Resistive Heater	<b>Maximum Voltage Connection:</b> Connect one side of the resistive heater to OUTA and the other side to the voltage source $V_S$ . NOTE: Adjust the cooling current limit to zero by turning the LIMB trimpot fully counterclockwise.	

### STEP 4: CONNECTING YOUR TEMPERATURE SENSOR

The default configuration of the WHY5690 allows for operation of the board with NTC thermistors in the range of 0-20k $\Omega$ . Connect the temperature sensor to the Sensor+ and Sensor- leads on the 4-wire output cable.

Contact Wavelength Electronics to use the WHY5690 with other sensors or ranges.

### STEP 5: ATTACHING THE $V_{DD}$ AND $V_S$ POWER SUPPLIES

The  $V_{DD}$  power supply is used to power the WHY5640 internal control electronics and must be capable of supplying 100 mA of current. The  $V_S$  power supply is used to power the WHY5640 output H-Bridge and must be capable of supplying a current greater than the LIMA and LIMB current limit settings. For simple operation tie  $V_{DD}$  to  $V_S$ . A separate  $V_S$  power supply allows the H-Bridge to operate at a voltage different from the 4.5 volts required by the  $V_{DD}$  supply. Select  $V_S$  approximately 2.5 volts above the maximum voltage drop across OUTA and OUTB to reduce the power dissipation in the WHY5640 component and minimize your heatsinking requirements. Connect both power supplies via the PGND line in the input connector. For high impedance resistance loads, a higher voltage  $V_S$  power supply may be required.

### STEP 6: ADJUSTING THE LOOP COMPENSATION PROPORTIONAL GAIN AND INTEGRATOR TIME CONSTANT

These two trimpots adjust the proportional gain and integrator time constant for the control loop and can be adjusted to optimize the control parameters of your system. The "I Term" adjustment affects both the proportional and integrator parameters while the proportional setting affects only the proportional gain.


For a better explanation of how the I Term and P Term trimpots affect the parameters of the control system see page 12 of the WHY5640 manual. The I Term adjusts  $R_G$  in the equations on page 12, while P Term adjusts  $R_L$ .

## OPERATING THE EVALUATION BOARD

### STEP 7: ADJUSTING THE SETPOINT TEMPERATURE

With the Run/Set switch in the “Set” position, measure the resistance between the two test points next to the RSET trimpot. Adjust the RSET trimpot to change this resistance to the resistance value of the thermistor at the desired operating temperature. Once the RSET resistance is set to the desired level, return the Run/Set switch to the “Run” position. Figure 3 shows the location of the Run/Set switch and test points.

**Figure 3**  
Run / Set Switch and Test Points



### STEP 8: ENABLING AND DISABLING THE OUTPUT CURRENT

The WHY5640 output current can be enabled and disabled using the onboard toggle switch. The output is enabled when the green ON LED indicator is lit.



**CAUTION:** Before enabling the output make sure the Run/Set switch is set to the “Run” position. When enabled with this switch in the “set” position the controller will run at the cooling current limit regardless of the temperature setpoint, which can cause damage to the controller or your thermal load.

### STEP 9: MONITORING THE TEMPERATURE SETPOINT VOLTAGE AND ACTUAL TEMPERATURE SENSOR VOLTAGE

The input connector includes three lines for externally monitoring the WHY5640 setpoint resistance and the actual temperature sensor resistance levels by monitoring voltages produced by the sensor bridge circuit. Both the VM1 and VM2 monitor voltages are referenced to the COMMON terminal. By monitoring VM1 and VM2 you can calculate the thermistor resistance using the following equation.

$$R_T = \left( \frac{VM2 - VM1}{VM1} \right) R_{SET}$$

# MECHANICAL SPECIFICATIONS\*



\*All Tolerances are +/- 5%

**CERTIFICATION:**

Wavelength Electronics (WEI) certifies that this product met its published specifications at the time of shipment. Wavelength further certifies that its calibration measurements are traceable to the United States National Institute of Standards and Technology, to the extent allowed by that organization's calibration facilities, and to the calibration facilities of other International Standards Organization members.

**WARRANTY:**

This Wavelength product is warranted against defects in materials and workmanship for a period of 90 days from date of shipment. During the warranty period, Wavelength will, at its option, either repair or replace products which prove to be defective.

**WARRANTY SERVICE:**

For warranty service or repair, this product must be returned to the factory. An RMA is required for products returned to Wavelength for warranty service. The Buyer shall prepay shipping charges to Wavelength and Wavelength shall pay shipping charges to return the product to the Buyer. However, the Buyer shall pay all shipping charges, duties, and taxes for products returned to Wavelength from another country.

**LIMITATIONS OF WARRANTY:**

The warranty shall not apply to defects resulting from improper use or misuse of the instrument or operation outside published specifications.

No other warranty is expressed or implied. Wavelength specifically disclaims the implied warranties of merchantability and fitness for a particular purpose.

**EXCLUSIVE REMEDIES:**

The remedies provided herein are the Buyer's sole and exclusive remedies. Wavelength shall not be liable for any direct, indirect, special, incidental, or consequential damages, whether based on contract, tort, or any other legal theory.

**NOTICE:**


The information contained in this document is subject to change without notice. Wavelength will not be liable for errors contained herein or for incidental or consequential damages in connection with the furnishing, performance, or use of this material. No part of this document may be photocopied, reproduced, or translated to another language without the prior written consent of Wavelength.

**SAFETY:**

There are no user serviceable parts inside this product. Return the product to Wavelength Electronics for service and repair to ensure that safety features are maintained.

**LIFE SUPPORT POLICY:**

As a general policy, Wavelength Electronics, Inc. does not recommend the use of any of its products in life support applications where the failure or malfunction of the Wavelength Electronics, Inc. product can be reasonably expected to cause failure of the life support device or to significantly affect its safety or effectiveness. Wavelength Electronics, Inc. will not knowingly sell its products for use in such applications unless it receives written assurances satisfactory to Wavelength Electronics, Inc. that the risks of injury or damage have been minimized, the customer assumes all such risks, and there is no product liability for Wavelength Electronics, Inc. Examples of devices considered to be life support devices are neonatal oxygen analyzers, nerve stimulators (for any use), auto transfusion devices, blood pumps, defibrillators, arrhythmia detectors and alarms, pacemakers, hemodialysis systems, peritoneal dialysis systems, ventilators of all types, and infusion pumps as well as other devices designated as "critical" by the FDA. The above are representative examples only and are not intended to be conclusive or exclusive of any other life support device.

**WAVELENGTH ELECTRONICS, INC.****51 Evergreen Drive  
Bozeman, Montana, 59715****phone: (406) 587-4910 Sales and Technical Support****fax: (406) 587-4911****e-mail: [sales@teamwavelength.com](mailto:sales@teamwavelength.com)****web: [www.teamwavelength.com](http://www.teamwavelength.com)**