

# Summary of electrical test results for valve-regulated lead-acid (VRLA) batteries<sup>☆</sup>

J. Crow<sup>\*</sup>, I. Francis, P. Butler

*Sandia National Laboratories, Albuquerque, NM 87185-0613, USA*

## Abstract

Under the auspices of the US Department of Energy, Energy Storage Systems (ESS) Program at Sandia National Laboratories, electrical tests were performed on two valve-regulated lead-acid (VRLA) batteries to compare the effects of several design improvements, evaluate their applicability to stationary applications, and determine their service lives. One battery represented a baseline design, and the other an improved design resulting from a development project. The two nine-cell, 1050–1200 A h, C<sub>8</sub>/8 batteries were tested over a 7-year period using primarily a 100% depth of discharge and approximately a C<sub>8</sub>/8 discharge regime. A variety of charge profiles were investigated and characterized. Both batteries reached end-of-life after several hundred cycles. This paper will describe these results and overall life data, and comparison information will be summarized. © 2001 Elsevier Science B.V. All rights reserved.

*Keywords:* Valve-regulated lead-acid batteries; Battery testing; Battery life and performance; Battery charging

## 1. Introduction

Energy storage systems for electric utilities, telecommunication systems, and other stationary applications must have high reliability and long life times [1,2]. It is also desirable that the batteries used in these systems require little maintenance [3]. In general, valve-regulated lead-acid (VRLA) batteries require low maintenance, but VRLA-based systems have experienced field failures and questions regarding their reliability being raised [4].

In 1991, the US Department of Energy (DOE) Energy Storage Systems Program at Sandia National Laboratories (SNL) began a competitively placed, multi-year, cost-shared contract with GNB Industrial Battery Corporation to enhance VRLA battery designs, improve performance, and reduce costs for utility applications [5]. This paper describes electrical test results on ABSOLYTE II and ABSOLYTE IIP batteries delivered to SNL during this contract. The testing methodologies and preliminary results were described in another paper [6]. The tests included different charge regimes and specialized discharges for various applications. A future paper will describe an analysis of the results and end-of-life observations.

## 2. Experimental

The ABSOLYTE II modules are designated Type 85A-25, and the ABSOLYTE IIP modules are Type 100A-25. In each case, three modules, each with three cells, were stacked to make a nine-cell battery. The two batteries are externally identical in size and configuration (the ABSOLYTE IIP cell cases are light gray and the ABSOLYTE II cell cases are dark gray). The cells, as installed for use, measure approximately 6 in. tall, 9 in. wide, and 24 in. deep, and are mounted side-by-side in the modules. The terminals are mounted on the 6 × 9 side. There are four terminals per cell; two positives are connected in parallel and two negatives are in parallel. Each cell has a vent centrally located on the terminal side. The assembly weighs approximately 1850 lb. A photograph of the ABSOLYTE IIP battery is shown in Fig. 1. The nominal fully-charged open circuit voltage of the batteries is 20 V. The rated capacity of the ABSOLYTE II is 1040 A h discharged at 25°C at a C<sub>8</sub>/8 (all subsequent relative capacity values are referred to the 8 h rate) rate to an average of 1.75 V per cell (V<sub>pc</sub>), or 15.75 V for nine cells in series. The ABSOLYTE IIP has a rated C/8 capacity of 1200 A h at 25°C with a C/8 discharge rate to 1.75 V<sub>pc</sub>.

The test equipment is described in a previous report [7] and uses PC-based controllers and data acquisition systems along with electronic loads and power supplies to cycle the batteries under test. Evaluations were conducted in temperature controlled laboratories. Data were stored in an Access data base for analysis.

<sup>☆</sup> Sandia is a multi-program laboratory operated by Sandia Corporation, a Lockheed Martin Company, for the United States Department of Energy under contract DE-AC04-94AL85000.

<sup>\*</sup> Corresponding author.




Fig. 1. ABSOLYTE IIP battery.

### 3. Results

#### 3.1. Initial evaluation and testing of ABSOLYTE IIP battery

In 1994, a test plan was written to evaluate the performance of the ABSOLYTE IIP battery. The testing objectives that were pursued in 1995 included the following.

1. Confirming the electrical performance ratings under various constant-current loads.
2. Evaluating the battery's capability to meet frequency regulation and spinning reserve requirements for utility energy storage (UES) applications.
3. Determining the service life of the battery.

Table 1  
ABSOLYTE II and ABSOLYTE IIP charge regimes

Charge regime	Sequence <sup>a</sup>	ABSOLYTE II cycles	ABSOLYTE IIP cycles
A	CI (300 A) to 21.15 V (2.35 Vpc); CV (21.15 V) to 107% charge return; OC for 2 h		1–40
B	CI (300 A) to 21.15 V (2.35 Vpc); CV (21.15 V) to 24 A; CI (24 A) for 2 h; OC for 2 h		41–45
C	CI (300 A) to 21.15 V (2.35 Vpc); CV (21.15 V) to 107% charge return; OC for 8 h		46–55, 75–85
D	CI (300 A) to 21.15 V (2.35 Vpc); CV (21.15 V) to 24 A; CI (24 A) to 107% charge return; OC for 8 h	1–59	56–74
E	CI (300 A) to 21.60 V (2.40 Vpc); CV (21.60 V) to 24 A; CI (24 A) to 107% charge return; OC for 8 h	60–76, 89–446 (float tests 77–88)	86–128
F	CI (300 A) to 21.6 V (2.4 Vpc); CV (21.6 V) to 24 A; cool below 40°C; CV (21.6 V) to 24 A; CI (24 A) to 107% charge return; OC for 8 h	118–139 (cycle 140, see text)	171–305 (after frequency regulation and PV test cycles 129–170)
G (8-cell)	CI (300 A) to 19.2 V (2.4 Vpc, 8 cells); CV (19.2 V) to 24 A; cool below 40°C; CV (19.2 V) to 24 A; CI (24 A) to 107% charge return; OC for 8 h		306–395
H	CI (300 A) to 21.6 V (2.4 Vpc); wait 1 min; CV (21.6 V) to 24 A; wait 1 min; CI (24 A) to 107% charge return; OC for 8 h	141–445	
H (8-cell)	CI (300 A) to 19.2 V (2.4 Vpc, 8 cells); wait 1 min; CV (19.2 V) to 24 A; wait 1 min; CI (24 A) to 107% charge return; OC for 8 h	445–507 (EOL)	396–699 (EOL)

<sup>a</sup> CI: constant current; CV: constant voltage; OC: open circuit.

A series of capacity measurement cycles were begun using the A-recharge regime shown in Table 1. As shown in Fig. 2 (cycles 1–128), capacity was initially measured at C/2, C/8, and C/18 discharge rates. Capacity was initially as-rated at these discharge rates, but tended to decline over a few cycles, calling into question the recharge regime. The manufacturer recommended several recharge sequences as part of a study to determine the appropriate recharge regime. Beginning with cycle 27, a series of capacity discharge cycles was performed at C/8 with various recharge sequences as shown (Table 1), with varying results. All recharge regimes, except recharge regime B, had a 7% ampere hour return limit in common, that is charge returned was limited to 7% more than the ampere hour removed in the previous discharge. In general, capacity continued to decline slowly. At cycle 86, the E-recharge sequence was implemented, with somewhat declining capacity at a C/8 discharge rate, and relatively stable capacity at a C/2 discharge rate. The E-recharge was continued until the beginning of the frequency regulation and spinning reserve testing.

#### 3.2. Frequency regulation and spinning reserve testing of ABSOLYTE IIP battery

The frequency regulation and spinning reserve tests were designed to be similar to a test performed in the SNL evaluation of the C&D Charter Power Systems Inc. flooded lead-acid battery in 1993 and 1994 for the Puerto Rico Electric Power Authority (PREPA) [8]. The frequency regulation part of the tests consisted of a succession of 160 min subcycles of constant power charge and discharge. These cycles begin with the battery state of charge (SOC) at 90% (at the beginning of the test, the battery charge is decreased




Fig. 2. Capacity (A h out) and recharge (A h in) for the ABSOLYTE IIP for the first 128 cycles at a C/8 rate except as noted.

from 100 to 90% by a constant current discharge), and continue until the battery reaches 70% SOC, which requires approximately 20 subcycles. An intermediate charge (constant current of 120 A to 2.35 Vpc, constant voltage to 90% SOC) is applied to return the battery to 90% SOC, assuming 100% charge return efficiency. This sequence is repeated three times, with a spinning reserve discharge added at the end of the third frequency regulation sequence. The spinning reserve test consists of a constant power (11.38 kW) discharge for 17 min, with a linear ramp to zero discharge power over the next 7 min. This sequence is followed by a

refreshing charge (300 A constant current to 2.4 Vpc, constant 2.4 Vpc until current tapers to 24 A, 24 A constant current for 2 h, then open circuit for 8 h).

Typical test data (cycle 141) are shown in Fig. 3. The spinning reserve discharge at the end decreased the battery SOC from 70 to 46%. A count of the number of frequency regulation subcycles in each set shows 23 subcycles in set 1, and 19 subcycles in sets 2 and 3, implying less coulombic efficiency or less capacity in the second two sets. This phenomenon appears to be correlated with battery temperature during the three sets.




Fig. 3. The three sets of subcycles of cycle 141 of the ABSOLYTE IIP frequency regulation and spinning reserve discharge test showing the decline in the state of charge during a set, and the increased number of subcycles obtainable in the first set.

### 3.3. ABSOLYTE IIP PV/renewable application testing

At the request of SNL's Photovoltaic (PV) Systems Application Department several tests were performed in order to characterize the ABSOLYTE IIP for an Arizona Public Service Company (APS) remote PV power system application. The characterizations provided SNL with the details it needed to make the appropriate recommendations.

A brief summary of the test regimes and results follows.

1. A constant power discharge at a 281 W rate from 100% SOC to an end-of-discharge (EOD) voltage of 1.75 Vpc (100% DOD) to determine the percentage SOC at the 2.03 Vpc level. This was cycle 145, which yielded 1645 A h total capacity, with 785 A h at the 2.03 Vpc level. The battery was then returned to 100% SOC.
2. A recharge time test for three cycles (146–148), with a constant-power, 281 W discharge to 2.03 Vpc, and recharge at 1125 W constant power rate to 2.35 Vpc, and then clamp at 2.35 Vpc to 7% overcharge (1.07 times ampere hour removed). Results of this test showed that it took 11.1 h on average for the ABSOLYTE IIP battery to reach the 2.35 Vpc point, at which point 83% of the ampere hour removed had been returned. Two hours later, 94% had been returned, and after an additional 7.1 h at the 2.35 Vpc level, 7% overcharge was reached, for a total recharge time of 20.2 h.
3. A cycling test (cycles 149–168) to determine cycling stability, beginning at full SOC with repetitious discharge at 281 W to 2.03 Vpc, then recharge at 1125 W constant power rate to 2.35 Vpc and clamp at 2.35 Vpc for 2 h. Cycle 149 discharge began at full SOC from the previous cycle, but the charge regime of this test returns less charge, so the capacity at cycle 150 shows a sharp drop. The gradual decrease in capacity from cycle 150–168 was attributed by GNB to a continual buildup of sulfation on the plates, caused by

insufficient recharge. Accumulation of lead sulfate and the corresponding loss of sulfate ions from the electrolyte caused an increase of internal resistance and consequent recharge inefficiency.

4. A discharge capacity test at a 281 W rate to 100% DOD after charging at a 1125 W rate to 2.35 Vpc and clamping at 2.35 Vpc for 2 h. This test produced a capacity of 1538 A h, 95% of the 1625 A h capacity obtained at a 281 W discharge rate from 100% SOC. A second discharge capacity test was performed using a similar charge with a 12 h clamp time, but later examination of the data indicated a discrepancy in the charge profile, invalidating the results.

### 3.4. Life cycle testing of ABSOLYTE IIP battery

After the battery completed the PV applications testing in 1996, it was placed on a life cycle test regime, beginning at cycle 171. The battery was repetitively discharged at a C/8 (150 A) rate, and recharged using various charge regimes as indicated in Table 1. While the details of the charge profiles were varied in attempts to refine and improve the charge acceptance of the batteries, all the charge regimes have in common a charge return of 7% more than charge removed on the previous discharge. Capacities measured in these life cycle tests are shown in Fig. 4. Cycles are numbered from the beginning of testing of the ABSOLYTE IIP battery, with one cycle being a discharge to a specified level, followed by a recharge. Cycles 1 through 128 previously shown in Fig. 2 are included in Fig. 4.

The charging regime was modified at cycle 171 to the F-charge regime to improve compatibility between the tester and the battery and to try to improve the charge acceptance of the battery. The result was an improvement in battery capacity from cycle 171 to cycle 180, but a gradual decline thereafter.




Fig. 4. Ampere hour removed (capacity) and returned for all cycles of the ABSOLYTE IIP battery. The horizontal line at 960 A h indicates the end-of-life at 80% of rated capacity.

At cycle 266, each cell was removed and weighed and the weights compared with the original weights. The cells showed an average weight loss of 1 kg. At cycle 270, 300 ml of deionized water were added to each cell. Tester malfunctions produced incomplete data and uncertain charging through cycle 274. An equalization charge of 1720 A h was performed at cycle 275, with slight improvement in capacity. At the end of cycle 281, 400–900 ml of deionized water was added to each cell to bring the individual cell weights back up to their original values. Cells 1, 4, and 6 vented on cycle 282, and testing was halted. All cells were examined for electrolyte level and found to be satisfactory. Also at this time, Cell 3 was bypassed because of chronic low voltage; thus the battery became eight cells in series.

Capacity life cycles were then continued during 1997 until cycle 394, when a tester malfunction halted testing. The battery was on open circuit from 19 September 1997, to resumption of life cycle testing on 23 February 1998. Testing resumed using the H-charge regime, which removed the battery temperature limits on wait, and substituted specific wait times. Testing continued to cycle 610, with the same rate of capacity decline. At this point, the capacity had decreased to 972 A h, near the defined end of life of 960 A h. Cell 5 EOD voltage, which had been low throughout life cycle testing, began to decline more rapidly through cycles 500 to 600. Testing was halted at cycle 610 on 16 September 1998, to diagnose the erratic cell 1 voltage readings, and pending decisions on continued testing. Testing was resumed on 30 November, with nine diagnostic C/8 discharge cycles that used the H-charge regime.

By cycle 693, capacity had declined to 914 A h. An 18% boost overcharge was performed on cycle 694, with slight improvement in capacity. Testing was halted on 23 May

1999, at cycle 699, pending a decision on post-service-life tests.

### 3.5. Initial evaluation and testing of ABSOLYTE II battery

In the third quarter of 1995, the ABSOLYTE II battery was placed on test with the objective of evaluating improvements from the ABSOLYTE II design to the ABSOLYTE IIP design. Initial capacity tests were made at a C/8 rate of 130 A, corresponding to the 1040 A h at C/8 discharge rating of the battery. In these capacity cycles, the battery delivered nearly 1300 A h (all cycles are shown in Fig. 5), substantially higher than its rating, and somewhat higher than the ABSOLYTE IIP. After cycle 31, the discharge rate was changed to a constant 150 A, to make a comparison at the same discharge current of the ABSOLYTE II and ABSOLYTE IIP designs. The D-recharge regime (Table 1) was used for the ABSOLYTE II for these initial tests. These early results indicated that the early-life available capacity of the ABSOLYTE II design was very comparable to the ABSOLYTE IIP design. Capacity generally decreased gradually over the first 59 cycles.

In the first quarter of 1996, measurements of the capacity of the ABSOLYTE II were also made at C/2 (actual current 422 A) and C/20 (actual current 68 A) rates to compare with the measurements of the ABSOLYTE IIP at C/2 (428 A) and C/18 (74 A). At C/2, the ABSOLYTE II averaged 857 A h over cycles 60–63, and the ABSOLYTE IIP averaged 892 A h over cycles 95–102. At the lower currents (C/20 for the ABSOLYTE II and C/18 for the ABSOLYTE IIP), the ABSOLYTE II averaged 1413 A h, and the ABSOLYTE IIP averaged 1451 A h. These capacity measurements used the E-charge regime, which began with cycle 60.




Fig. 5. Capacity (A h out) and charge returned (A h in) for the ABSOLYTE II battery for all cycles.

### 3.6. ABSOLYTE II float charge testing

In mid-1996, a special study was initiated to determine the effect on discharge capacity of float charging at specific constant voltage levels. The purpose of the study was to provide information to New Mexico State University in the setup of renewable energy systems for the US Coast Guard which utilizes the ABSOLYTE technology. The charge sequence was 100 A constant current charge until the specified float voltage was attained, then constant voltage charge until the total charge time reached 72 h.

A trend of increasing capacities with increasing float voltages was observed. This trend suggests that charging at 2.25 Vpc would provide approximately 100% of the battery's capacity, and 2.25 Vpc is the lowest recommended float voltage specified in the operating manual for the ABSOLYTE II. A tester malfunction halted testing before these tests could be done at 2.25 Vpc, and the float charge testing program ended before the tester could be repaired.

### 3.7. ABSOLYTE II life cycle testing

After the float charge tests, life cycle testing was resumed. Six cycles were performed (89–94) when a tester-to-database transfer problem occurred. Testing was suspended on 5 April 1996, and resumed on 5 November 1996. Life cycle testing continued through cycle 113 on 16 December 1996, when testing was suspended for 6 weeks. Life cycle testing resumed on 31 January 1997, following the ABSOLYTE II E-charge regime, with charge cycles occasionally interrupted by battery high temperature alarms.

To avoid the high temperatures, a change was made at cycle 118 to the ABSOLYTE II F-charge regime (Table 1),

which includes a cool down period to temperatures less than 40°C after charge 1 and two separate 24 A charge periods. The charge times proved to be unacceptably long, and at cycle 140 a change was made to the ABSOLYTE II charge regime (Table 1), in which the second 24 A charge was eliminated. One cycle (140) was done with this charge, on 11 March 1997, when a tester malfunction halted testing. At this time, the battery capacity had declined slightly to 1160 A h.

The battery remained on open circuit for 1 year. Testing was resumed on 7 March 1998, with a discharge to 1.75 Vpc, and a moderate boost charge with 1348 A h returned. Life cycle testing resumed using the H-charge regime. Capacity had declined markedly from the 1160 A h measured prior to the testing halt. Capacity increased slowly over the next 20 cycles, perhaps limited by the 7% overcharge. Capacity held reasonably steady at approximately 1100 A h, with some fluctuations, over the next 50 cycles, then began a gradual decline.

### 3.8. Temperature effects on capacity

The ABSOLYTE II battery was located in a laboratory in a temporary building, along with several other systems under test. The air conditioning was generally not sufficient, and cyclic ambient temperature fluctuations of 3–5°C were common, with occasional larger fluctuations. The air conditioning system became increasingly erratic, and by cycle 373 was causing erratic tester operation. Testing was halted at this point for air conditioning repair.

During a review of the data following the test halt, a cyclic fluctuation in the capacity of the ABSOLYTE II was noted. Comparison of the battery capacity with the ambient




Fig. 6. Comparison of the ratio of energy discharged to energy charged for the ABSOLYTE II and ABSOLYTE IIP batteries through their lifetimes.

temperature of the laboratory in which the measurements were being made showed a strong correlation between an increase in ambient temperature and an increase in battery capacity, of approximately  $0.4\%/^{\circ}\text{C}$ .

### 3.9. Continued life cycle testing to end of life

Cell 4 was especially affected by the air conditioning failure at cycle 373. Cell voltage was improved somewhat by the boost charge at cycle 441, but not up to the level of the other cells. Cell 4 was bypassed after cycle 446. Voltage levels in the H-charge regime for the ABSOLYTE II were adjusted to compensate for the bypassed cell, so after cycle 446 the ABSOLYTE II H-charge regime corresponded to the ABSOLYTE IIP H-charge regime.

Life cycle tests continued with declining battery capacity. By cycle 506 (15 June 1999) capacity was consistently below the 832 A h that corresponded to 80% of rated capacity, and testing was halted.

### 3.10. Comparisons between life tests of the ABSOLYTE II and ABSOLYTE IIP

The energy efficiencies of both batteries (Fig. 6) was approximately 81% at the beginning of testing. The efficiency of the ABSOLYTE II declined approximately linearly through the tests, while the efficiency of the ABSOLYTE IIP remained relatively constant.

## 4. Summary

Initial capacities of the two batteries were very similar, even though the ABSOLYTE IIP was rated at 1200 A h, and the ABSOLYTE II at 1040 A h. Both batteries had one cell fail during the testing. The ABSOLYTE IIP achieved approximately 40% more cycles than the ABSOLYTE II

before reaching end-of-life. The ABSOLYTE II had extended open circuit periods, although the battery was kept charged during the open circuit times. The energy efficiency of both batteries was approximately 81% at the beginning of testing, but the efficiency of the ABSOLYTE II declined approximately linearly through the tests, while the efficiency of the ABSOLYTE IIP remained relatively constant. The total energy extracted from the ABSOLYTE IIP through 699 cycles was 12.4 MW h, and for the ABSOLYTE II, the energy discharged in 506 cycles was 8.9 MW h.

## References

- [1] N. Dalarsson, Trends in telecommunications networks and their effects on power systems, in: *Intelec 98, 20th International Telecommunications and Energy Conference*, San Francisco, CA, USA, 4–8 October, 1998.
- [2] D.O. Feder, Performance measurement and reliability of VRLA batteries, in: *Intelec 95, 17th International Telecommunications and Energy Conference*, The Hague, The Netherlands, 29 October–1 November, 1995.
- [3] J. Szymborski, The maturing of a valve regulated (VRLA) battery technology: 10 years of experience, in: *Intelec 93, 16th International Telecommunications and Energy Conference*, Paris, France, September, 1993.
- [4] W.P. Cantor, et al., Performance measurement and reliability of VRLA batteries. Part II. The second generation, in: *Intelec 98, 20th International Telecommunications and Energy Conference*, San Francisco, CA, USA, 4–8 October, 1998.
- [5] P.C. Butler, Utility Battery Storage Systems Program Report for FY95, SAND96-0532, March 1996.
- [6] P.C. Butler, J.T. Crow, P.A. Taylor, Battery evaluation methods and results for stationary applications, in: *Intelec 97, 19th international telecommunications and energy conference*, Melbourne, Australia, 19–23 October, 1997.
- [7] G.P. Rodriguez, Battery Test Facility Hardware, Software, and System Operation, SAND91-1059, September, 1991.
- [8] J.D. Boyes, Lessons learned from the Puerto Rico battery energy storage system, SAND99-2232 (in English and Spanish), Sandia National Laboratories, Albuquerque, NM, September, 1999.