

Flow Calorimeter and Measurement of the Enthalpy of *n*-Pentane

J. M. LENOIR and D. R. ROBINSON

University of Southern California, Los Angeles, Calif. 90007

H. G. HIPKIN

C. F. Braun & Co., Alhambra, Calif. 91802

The enthalpies of *n*-pentane, benzene, and water have been measured by a new flow calorimeter with results that differ from literature values by an average of 1.5 B.t.u. per pound. Results are presented for *n*-pentane from 100° to 700° F., with pressures up to 1400 p.s.i.a.

THE AMERICAN PETROLEUM INSTITUTE has initiated a program to measure the enthalpies of binary hydrocarbon mixtures experimentally at temperatures from ambient to incipient cracking, with pressures from atmospheric to 1400 p.s.i.a., for pentane and heavier hydrocarbons including paraffins, olefins, naphthenes, and aromatics. This paper describes the equipment used for the API project and presents data for *n*-pentane. Subsequent papers will present the results for hydrocarbon mixtures.

CALORIMETER

The calorimeter is a modification of the flow type described by Nelson and Holcomb (11) and Smith and coworkers (5, 8, 9, 14). Similar calorimeters, modified for low temperature operation, have been described by Wiener (15) and by Sahgal *et al.* (13). On passing through the calorimeter the hydrocarbon entering at a measured temperature is cooled to 75° F., giving up the enthalpy difference to saturated Freon-11. By measuring the hydrocarbon and Freon flow rates, the enthalpy difference is established by the relation

$$\Delta H = \frac{\rho_{F-11} \Delta H_{F-11} V_{F-11}}{\rho_{HC} V_{HC}} \quad (1)$$

where V represents the volumetric flow rates of the Freon-11 and the hydrocarbon (HC), ρ the respective liquid densities, and ΔH_{F-11} the latent heat of Freon-11. The apparatus measures enthalpy differences without regard to phase condition. Figure 1 illustrates the basic shape and construction of the calorimeter.

Nelson and Holcomb (11) weighed both the hydrocarbon and Freon-11 throughputs. This new calorimeter measures both hydrocarbon and Freon flow rates volumetrically, a procedure that provides very convenient and rapid measurements. Another feature is the side inlet to introduce the hydrocarbon fluid, used to prevent dependency of the inlet temperature upon Freon liquid level. Table I shows some calorimeter inlet temperature profiles. Any of the three thermocouples closest to the Freon gives a satisfactory inlet temperature. The inlet temperature was computed as the arithmetic average of these three thermocouples to reduce random fluctuations. The details of the construction and operation of the calorimeter have been filed with the American Society for Information Science (ASIS).

The calorimeter does not require calibration, but the measurements do depend upon the densities of the




Figure 1. Detailed drawing of calorimeter

fluids and the latent heat of Freon-11. At 75° F. and atmospheric pressure the latent heat of Freon-11 was selected as 78.32 B.t.u. per pound (1, 3). The density of Freon was 1.4783 grams per cc., with a density of 0.6224 gram per cc. for *n*-pentane. Table II estimates the sources of error caused by various measurement uncertainties, with over-all predicted uncertainty of 1.1 B.t.u. per pound.

The measured enthalpy values are above a datum of liquid at 75° F. and the system pressure. The lower base value changes as the pressure rises. The relationship between enthalpy and pressure follows the relation

$$\left(\frac{\partial H}{\partial P}\right)_T = V - T \left(\frac{\partial V}{\partial T}\right)_P \quad (2)$$

Graphical integration shows a gradual increase in liquid

Table I. Measurements of Inlet Temperatures Showing Dependency on Position of Thermocouples as Hydrocarbon Enters Calorimeter^a

Distance from Freon, Inches	Temp., ° F.				
	6½	690.0	598.9	418.7	359.4
7½	690.6	599.4	418.7	359.4	201.7
8½	690.1	598.7	417.4	358.9	201.1
10¾	695.7	603.9	421.1	361.6	202.7
12½	697.3	606.0	421.6	361.9	202.5

^a Central position between inner and outer Freon containers lies 7 inches from Freon. This position should approximate correct inlet temperature position.

Table II. Estimated Accuracy of Measurement

Measured Quantity	Uncertainty, B.t.u./Pound
Inlet calorimeter temperature	0.4
Freon-11 volume in receiver	0.28
Hydrocarbon volume in receiver	0.15
Outlet calorimeter temperature	0.08
Hydrocarbon liquid density	0.06
Pressure measurement	0.05
Timing stopwatch for Freon-11	0.03
Timing stopwatch for hydrocarbon	0.03
Freon density	0.03
Calculation of pressure level correction	0.03
Estimated measurement uncertainty	1.1

Table III. Measured Values of Pentane Enthalpy in Gas Phase

Pressure, P.S.I.A.	Temp., ° F.	ΔH as				Pressure, P.S.I.A.	Temp., ° F.	ΔH as				
		Measured, B.t.u./Lb. ^a	ΔH_a , B.t.u./Lb. ^a	$\Delta H - \Delta H_a$, B.t.u./Lb.	$\frac{\Delta H_a}{\Delta H'}$			Measured, B.t.u./Lb. ^a	ΔH_a , B.t.u./Lb. ^a	$\Delta H - \Delta H_a$, B.t.u./Lb.	$\frac{\Delta H_a}{\Delta H'}$	
25	211.4	218.0	217.8	0.2	1.0009	400	593.9	430.0	431.4	-1.4	0.9968	
	252.5	235.2	237.0	-1.8	0.9924		599.8	438.1	435.5	2.7	1.0060	
	275.8	249.8	249.1	0.7	1.0028		400	366.6	259.8	262.6	-2.8	0.9894
	299.4	263.6	262.9	0.7	1.0027			368.2	262.7	263.6	-1.1	0.9958
	300.1	262.2	262.5	-0.3	1.0011			369.2	263.5	264.5	-1.0	0.9962
	300.6	263.6	263.0	0.6	1.0023			373.6	266.9	267.2	-0.3	0.9989
	326.2	276.5	276.4	0.1	1.0003			378.5	272.7	271.4	1.3	1.0048
	350.4	289.4	290.0	-0.6	0.9979			378.9	273.1	271.5	1.6	1.0059
	375.3	304.7	304.5	0.2	1.0007			383.5	277.0	274.3	2.7	1.0098
	400.5	321.6	319.1	1.5	1.0047			388.5	279.8	279.2	0.6	1.0021
	405.1	321.8	323.0	-1.2	0.9963			388.5	281.0	279.2	1.8	1.0064
	450.2	349.0	349.0	0.0	1.0000			397.3	288.3	286.1	2.2	1.0077
	477.2	367.0	365.5	1.5	1.0041			401.4	290.3	288.3	2.0	1.0070
	498.9	380.2	379.8	0.4	1.0011			417.7	303.5	301.3	2.2	1.0073
	502.6	380.7	381.3	-0.6	0.9984			417.9	301.5	301.6	-0.1	0.9997
	525.0	396.3	395.6	0.7	1.0018			418.6	300.7	302.1	-1.4	0.9954
	549.2	411.6	411.4	0.2	1.0005			437.2	316.1	315.6	0.5	1.0016
	574.0	426.9	428.0	-1.1	0.9974			437.2	318.3	315.6	2.7	1.0086
	598.4	444.7	444.1	0.6	1.0014			440.4	318.0	317.1	0.9	1.0030
	624.6	462.7	462.0	0.7	1.0015			441.7	319.5	317.7	1.8	1.0057
672.6	496.0	495.0	1.0	1.0020	457.7	333.4	330.2	3.2	1.0096			
697.8	514.4	515.0	-0.6	0.9988	476.5	343.9	343.3	0.6	1.0017			
200	294.4	243.9	242.3	1.6	1.0066	476.9	345.1	343.5	1.6	1.0047		
	295.0	243.7	242.5	1.2	1.0050	496.4	355.0	356.1	-1.1	0.9966		
	295.3	244.9	243.0	1.9	1.0078	496.7	358.7	357.0	1.7	1.0048		
	298.1	243.4	244.7	-1.7	0.9930	497.9	357.5	357.8	-0.3	0.9992		
	298.6	243.6	245.0	-1.4	0.9943	600	403.6	235.0	237.2	-2.2	0.9908	
	299.4	244.5	245.4	-0.9	0.9963		403.7	235.5	237.2	-1.7	0.9929	
	303.8	248.2	248.7	-0.5	0.9980		406.0	243.0	241.3	1.7	1.0071	
	310.1	252.9	252.6	0.3	1.0012		426.0	276.0	273.2	2.8	1.0102	
	319.7	256.5	258.2	-1.7	0.9934		441.0	299.7	294.2	2.5	1.0084	
	333.9	267.6	266.3	1.3	1.0045		473.7	325.2	323.2	2.0	1.0062	
	335.2	268.2	267.4	0.8	1.0030		475.9	326.9	324.9	2.0	1.0061	
	340.5	270.0	270.5	-0.5	0.9981		500.0	346.8	343.9	2.9	1.0084	
	341.0	271.8	270.7	1.1	1.0040		501.3	345.8	344.9	0.9	1.0026	
	348.4	277.2	275.8	1.4	1.0051		1000	400.4	216.9	217.2	-0.3	0.9986
	385.1	297.6	297.7	-0.1	0.9997			405.9	220.3	219.6	0.7	1.0032
	385.7	298.3	297.9	0.4	1.0014			450.0	263.2	263.1	0.1	1.0004
	403.8	308.7	309.0	-0.3	0.9987			506.9	318.2	318.2	0.0	1.0000
	404.2	308.6	309.3	-0.7	0.9977			506.9	318.7	318.2	0.5	1.0016
	499.5	368.0	370.1	-2.1	0.9941			695.2	480.2	480.0	0.2	1.0004
	499.7	370.3	370.2	0.1	1.0003			695.4	479.7	480.0	-0.3	0.9994
499.9	368.5	370.3	-1.9	0.9949	1400			402.5	213.6	211.6	2.0	1.0093
499.9	369.1	370.3	-1.2	0.9965				402.8	212.7	211.7	1.0	1.0046
499.9	369.1	370.3	-1.2	0.9965		500.3		296.4	297.3	-0.9	0.9960	
499.9	370.5	370.3	0.2	1.0005		500.6	294.3	297.6	-2.3	0.9924		
500.6	372.6	371.3	1.7	1.0050		531.5	325.9	324.1	1.8	1.0046		
500.9	371.5	371.5	0.0	1.0000								
523.6	386.0	385.8	0.2	1.0008								
589.9	433.4	429.1	4.3	1.0095								

^a Base value liquid phase at 75° F. and pressure of measurement.

Table IV. Smoothed Values of Enthalpy for *n*-Pentane, Base Value Liquid Pentane at -200° F. and Low Pressure, B.t.u./Lb.

Temp., $^{\circ}$ F.	Pressure, P.S.I.A.							
	0	200	400	500	600	800	1000	1400
700	646	637.8	631.3	629.4	625.4	620.1	611.4	599.4
680	630	623.9	618.4	614.4	610.4	604.9	597.4	583.5
660	616.5	609.8	603.4	599.4	595.4	589.2	581.2	567.8
640	602.9	595.9	588.9	584.4	580.3	572.8	564.4	551.5
620	589.4	582.1	573.9	569.8	565.5	556.7	547.4	534.9
600	575.6	568.4	559.7	555.3	550.6	540.4	530.8	518.1
580	562.4	554.4	545.5	540.4	535.6	524.4	513.9	500.0
560	549.4	540.5	531.4	525.9	520.6	508.4	497.2	481.6
540	536.2	526.6	517.3	511.4	505.4	492.4	479.4	463.4
520	523.4	513.4	503.2	497.4	490.4	475.9	461.9	445.5
500	510.9	500.4	489.0	482.4	475.4	459.4	443.4	428.7
480	497.9	487.4	475.4	467.4	459.4	442.5	424.4	412.5
460	485.4	474.2	461.5	452.4	443.4	420.0	407.0	395.9
440	473.2	461.4	447.4	437.2	425.4	395.0	395.4	378.9
420	461.4	448.4	433.4	421.2	398.7	371.5	367.4	361.3
400	449.5	436.1	419.3	401.2	365.2	353.0	348.9	344.4
390	443.9	430.3	412.3	381.3	353.2	344.0	341.0	334
380	437.9	424.3	404.8	346.3	343.2	335.0	332.4	328
360	426.3	412.2	325.9	324.4	322.4	318.9	315.9	313
340	414.9	400.3	305.6	304.6	303.9	302.4	301.4	298
320	404.0	388.1	289.4	289.2	289.0	288.3	287.4	283
300	393.4	376.1	273.5	273.3	273.0	272.7	271.5	268.7
280	383.0	260.5	258.5	258.2	258.0	257.3	256.6	254.4
260	372.5	245.4	244.7	244.4	244.0	243.4	242.6	240.9
240	362.5	231.6	231.2	230.9	230.6	230.1	229.5	228.3
220	352.6	217.6	217.3	217.1	217.0	216.6	216.3	215.6
200	343.6	204.4	204.2	204.1	204.0	203.9	203.7	203.4
75	289.2	129.8	130.3	130.5	130.7	131.2	131.6	132.5

phase enthalpy with increased pressure. Because 75° F. is far below the critical temperature, the amount of change in the liquid phase is moderate, amounting to 3.1 B.t.u. per pound between atmospheric pressure and 1400 p.s.i.a. for *n*-pentane.

MEASUREMENTS

Enthalpies of pentane, benzene, and water have been measured by this calorimeter. Table III shows the results for *n*-pentane in the gas phase, as well as pentane enthalpies in the vapor state predicted by API project 44 (2) in conjunction with the work of Kozicki and Sage (7) and Graue *et al.* (6). The last two columns in Table III show the difference between the measured enthalpy and API values, and the ratio of the measured to the API numbers, indicative of the percentage deviation of the measurement. The measured enthalpies deviate from the API values by an arithmetic average of 1.2 B.t.u. per pound, with a statistical deviation of 1.48 and a plus trend of 0.4. The reproducibility between sets of measurements taken at the same temperature and pressure was 0.9 B.t.u. per pound. Expressed in terms of accuracy, the measured enthalpies deviate from the API predictions by an arithmetic average of 0.41%, trending high by 0.14%.

Measurements with benzene showed values that deviated from the results of Connolly and Kandalic (4) and Organick and Studhalter (12) with an average deviation

of 2.2 B.t.u. per pound with a 2.60 statistical deviation and a plus 0.26 trend. The average measurement accuracy was 0.66%. The measured enthalpies for distilled water were compared with the published values of Meyer *et al.* (10). The measurements show an average discrepancy of 0.98 B.t.u. per pound, a statistical deviation of 1.20, and a negative trend of 0.88. The results of these accuracy studies indicate that the enthalpy measurements have an uncertainty approximating 1.5 B.t.u. per pound, representing a measurement accuracy of 0.5%. The largest difference in all the comparisons was 4.5 B.t.u. per pound.

The measured values for *n*-pentane were first graphed dependent on temperature with pressure as parameter. By cross-plotting enthalpy *vs.* pressure at fixed temperatures, smoothed values of enthalpy for *n*-pentane were visually obtained. These values are presented in Table IV placed on a zero enthalpy basis of -200° F. and the saturated liquid phase.

ACKNOWLEDGMENT

The development of this calorimeter and the measurements were performed with funds from the American Petroleum Institute.

NOMENCLATURE

- H = enthalpy, B.t.u. per pound
- ΔH = measured enthalpy difference, B.t.u. per pound
- ΔH_a = enthalpy difference as shown by API 44

ΔH_{F-11} = latent heat of vaporization of Freon-11 at 75° F.
 P = pressure, p.s.i.a.
 T = temperature, ° F.
 T_1 = inlet temperature of hydrocarbon to calorimeter, ° F.
 T_2 = outlet temperature of hydrocarbon from calorimeter, ° F.
 V_{F-11} = volume rate of flow of Freon-11, cc. per second
 V_{HC} = volume rate of flow of hydrocarbon, cc. per second
 ρ_{F-11} = density of liquid Freon-11, grams per cc.
 ρ_{HC} = density of hydrocarbon at atmospheric pressure, grams per cc.

LITERATURE CITED

- (1) Allied Chemical Co., General Chemical Division, New York, "Genetron-11 Refrigerant, Thermodynamic Properties," 1957.
- (2) American Petroleum Institute Research Project 44, "Selected Values of Properties of Hydrocarbons and Related Compounds," Thermodynamic Research Center, Texas A & M University, College Station, Tex., April 30, 1969.
- (3) Benning, A. F., McHarness, R. C., "Thermodynamic Properties of Freon-11," E. I. du Pont de Nemours & Co., Wilmington, Del., 1938.
- (4) Connolly, J. F., Kandalic, G. A., J. CHEM. ENG. DATA 7, 137 (1962).

- (5) Eubank, P. T., Smith, J. M., *Ibid.*, 7, 75 (1962).
- (6) Graue, D. J., Berry, V., Sage, B. H., *Hydrocarbon Process. Petrol. Refiner* 45 (6), 191 (1966).
- (7) Kozicki, W., Sage, B. H., J. CHEM. ENG. DATA 5, 331 (1966).
- (8) McCracken, P. G., Smith, J. M., *A.I.Ch.E. J.* 2, 498 (1956).
- (9) McCracken, P. G., Storvick, T. S., Smith, J. M., J. CHEM. ENG. DATA 5, 130 (1960).
- (10) Meyer, C. A., McClintock, R. B., Silvestri, G. J., Spencer, R. C., "Thermodynamic and Transport Properties of Steam," Am. Soc. Mech. Engrs., New York, 1967.
- (11) Nelson, J. M., Holcomb, D. E., *Chem. Eng. Progr. Symp. Ser. No. 7*, 49, 93 (1953).
- (12) Organick, E. I., Studhalter, W. R., *Chem. Eng. Progr.* 44, 847 (1948).
- (13) Sahgal, P. M., Geist, J. M., Jambhekar, A., Wilson, G. M., *Advan. Cryog. Eng.* 10, 224 (1965).
- (14) Storvick, T. S., Smith, J. M., J. CHEM. ENG. DATA 5, 133 (1960).
- (15) Wiener, L. D., 50th National A.I.Ch.E. Meeting, Dallas, Tex., 1966.

RECEIVED for review January 13, 1969. Accepted June 16, 1969. For supplementary material, order NAPS Document NAPS-00625 from ASIS National Auxiliary Publications Service, c/o CCM Information Sciences, Inc., 22 West 34th St., New York, N. Y., 10001, remitting \$1.00 for microfiche or \$3.00 for photocopies.

Enthalpies of Mixtures of *n*-Octane and *n*-Pentane

J. M. LENOIR and D. R. ROBINSON¹

University of Southern California, Los Angeles, Calif. 90007

H. G. HIPKIN

C. F. Braun & Co., Alhambra, Calif. 91802

Enthalpy measurements have been made with a flow calorimeter for *n*-octane and mixtures of *n*-octane with *n*-pentane. The results are presented in tabular and graphical form for pressures up to 140 p.s.i.a. and temperatures from 75° to 600° F.

EXPERIMENTAL MEASUREMENTS of enthalpy difference have been made for *n*-octane and for mixtures containing 21.8, 39.2, 59.7, and 80.9 mole % pentane. The data extend from 150° to 600° F., with pressures from 15 to 1400 p.s.i.a. The apparatus is a flow calorimeter previously described (3) and shown to be capable of measuring enthalpy differences of 1.5 B.t.u. per pound. Both the *n*-octane and *n*-pentane were obtained from the Phillips Petroleum Co., as the pure grade, and used as received. The *n*-octane was specified as 99% pure. The *n*-pentane was examined and found to have a purity better than 99%, containing only a trace of isopentane (2-methylbutane).

A literature search found few thermal measurements for *n*-octane and none for the pentane-octane mixtures.

McKay and Sage (4) measured latent heat of vaporization for *n*-octane from 100° to 340° F. Das and Kuloor (2) summarized the available thermal data for *n*-octane and tabulated enthalpy values for the saturated loci, the superheated vapor, and subcooled liquid, based upon computations using the Benedict-Webb-Rubin equation. The enthalpy values presented here are essentially an original measurement study.

The flow calorimeter measures the difference between the enthalpy of the fluid at some temperature higher than 100° F. at the pressure of measurement, and the fluid at 75° F. in the liquid state at the same pressure. The enthalpy differences evaluated directly from the calorimeter measurements without correction have been tabulated and deposited with ASIS.

The use of the uncorrected data requires adjustment to a common base level. The enthalpy value of the liquid phase at 75° F. is different at each composition and

¹ Present address, Chevron Research Corp., Richmond, Calif. 94804