SYMBOL LEGEND:

1. LM–6000 GAS TURBINE GENERATOR.
2. EXHAUST STACK.
3. AUXILIARY SKID.
4. TURBINE REMOVAL.
5. GENERATOR REMOVAL.
6. 15 KV BREAKER.
7. OVERHEAD CABLE TRAY.
8. LM–6000 CONTROL MODULE.
9. WATER TREATMENT/ELECTRICAL BUILDING.
10. FIRE WATER SKID.
11. AIR INSTRUMENT PACKAGE.
12. WATER TREATMENT EQUIPMENTS AREA.
13. OFFICES/CONTROL/MAINTENANCE BUILDING.
14. LUBE OIL FIN FAN.
15. GAS FUEL FILTER/REGULATOR.
16. AUXILIARY TRANSFORMER (480 V).
17. HRSG (FUTURE).
18. EMERGENCY GENERATOR.
19. LIQUID FUEL DAY TANK (CLEANED–50,000 GALS).
20. LIQUID FUEL CENTRIFUGE PACKAGE.
21. DEMIN WATER TANK (2–21,000 GAL EACH).
22. LIQUID FUEL TANK (RAW–100,000 GALS).
23. LIQUID FUEL TRANSFORMER PUMP.
24. RAW/FIRE WATER TANK (300,000 GALS).
25. LIQUID FUEL FORWARDING PUMP.
26. LIQUID FUEL OFF–LOAD PUMP.
27. LIQUID FUEL OFF–LOAD AREA.
28. OILY WASTE TANK.
29. OILY WASTE OFF–LOAD PUMP.
30. OILY WATER SEPARATOR.
31. ROAD.
32. PARKING AREA.
33. PLANT FENCE.
34. LIGHTING POLE.
35. GUARD HOUSE.
36. GATE.
37. GAS METER RUN.
38. ESD VALVE.
39. STEP–UP TRANSFORMER.
40. OFFICES/CONTROL ROOM.
41. WAREHOUSE AREA.



0 10' 20' 30' 40' 50' 100'

GRAPHIC SCALE

REVISED	CUSTOMER INFORMATION

© COPYRIGHT, 2008, ProEnergy SERVICES ALL RIGHTS, RESERVED. THIS DRAWING IS THE PROPRIETARY AND/OR CONFIDENTIAL PROPERTY OF ProEnergy SERVICES AND IS LOANED IN STRICT CONFIDENCE WITH THE UNDERSTANDING THAT IT WILL NOT BE REPRODUCED NOR USED FOR ANY PURPOSE EXCEPT THAT FOR WHICH IT IS LOANED. IT SHALL BE IMMEDIATELY RETURNED ON DEMAND, AND IS SUBJECT TO ALL OTHER TERMS AND CONDITIONS OF ANY WRITTEN AGREEMENT OR PURCHASE ORDER WHICH INCORPORATES OR RELATES TO THIS DRAWING.

NO.	DATE	BY	APP'D	DESCRIPTION
				REVISIONS

DRAWN	SL	09/22/08
CHECK		
DESIGN		
PROJ ENGR		
PROJ MGR		
QA MGR		
SCALE	1"=20'	SIZE D

ProEnergy EPC SERVICES

10820 EAST 45TH STREET
SUITE 100
TULSA, OKLAHOMA 74146
OFFICE
FAX
www.proenergyservices.com

ProEnergy EPC Services, LLC

GENERAL ARRANGMENT PLOT PLAN
ONE (1) LM–6000 GTG UNIT

XXXX JOB. NO.	DWG NO.	SH NO.	XXXX REV
TXXXX	SK	1	A