



Inspection Release Note

IRN Reference Number:
007/4519

Generating Office: HOUSTON	BIE Ref: 4519	W.O No / Req No: 2232	Inspector: Joseph Aliotta
Client: Bariven S.A. c/o PDVSA Services BV	Location: The Hague, The Netherlands	Client P.O Number: 5100077213	Date of Inspection: 02 & 03 February 2010
Vendor: Derwick Associates, S.A.	Location: Panama	Vendor Ref Number:	Punch List Attached: Yes/No *
Sub Vendor: ProEnergy Services/ Wood Group Pratt & Whitney	Location: Sedalia, MO/Chicopee MA (Westover AFB)	Sub Vendor Ref Number:	NCR's Issued: 0 NCR's Closed: 0

Item Number	Qty	Brief Description of Material
-------------	-----	-------------------------------

*Delete as appropriate

4	1 EACH TWIN-PACK	<p>Pratt & Whitney FT- GG4C -1D Twin Pack Turbine 50MW ISO DUAL FUEL FIXED, GENERATOR: SYNCHRONOUS 3P, AIR COOLED, 13.8KV, 60HZ. Turbine Serial No. 686663 Turbine Serial No. 686625</p> <p>QUALIFIED RELEASE: Release issued on instructions from PDVSA (Leiro Medina)</p> <p>GENERATORS ARE NOT INCLUDED IN THIS RELEASE.</p> <p>NO TESTING WAS WITNESSED. THIS RELEASE DOES NOT CONFIRM OPERABILITY.</p> <p>RELEASED FOR PACKING ONLY.</p>
---	---------------------	--

Inspectors Signature	Signature: <i>Joseph Aliotta</i>	Date: 7 February 2010
BIE Office Review	Signature: <i>Ralph Grenville</i>	Date: 7 February 2010

Any material released above, is for shipment to the designated destination subject to the purchaser's shipping instruction. It does not constitute an acceptance thereof and does not relieve the Vendor, Manufacturer or Contractor of any and all responsibility or obligation imposed by the purchase contract. It does not waive any rights the purchaser may have under the purchase contract including the purchaser's right to reject the above described material upon discovery of any deviations from requirements of the purchase contract, drawings and specifications after arrival at destination.