

SPECIFICATION CHANGE NOTE TO USERS

FP-TB-1/2/3 FieldPoint Terminal Bases

The following text and footnote replace the terminal wiring specification on page 13 of the *FP-TB-1/2/3 Operating Instructions*:

Installation

Terminal wiring..... 16–26 AWG copper conductor wire with 7 mm (0.28 in.) of insulation stripped from the end¹

¹ Use only copper conductor wire unless you are working with a sensing device, such as a thermocouple, that requires a different kind of wire.

FieldPoint™, National Instruments™, NI™, and ni.com™ are trademarks of National Instruments Corporation. Product and company names mentioned herein are trademarks or trade names of their respective companies. For patents covering National Instruments products, refer to the appropriate location: **Help»Patents** in your software, the `patents.txt` file on your CD, or `ni.com/patents`.

May 2002
323376A-01