

Getting Started with the LabVIEW™ Real-Time Module

This document provides steps to build a simple deterministic application and references to programming examples and documentation for more information as you build the application. Refer to the *LabVIEW Real-Time Module User Manual* for installation and configuration instructions and for information about programming deterministic applications using LabVIEW.

Contents

Launching LabVIEW and Exploring Documentation	1
Creating and Running a Deterministic Application	3
Creating the Control Loop	3
Adding Analog Input/Output and Data Processing to the Control Loop	4
Setting Priority of the VI to Time Critical	6
Adding Timing to the Control Loop	6
Sending Data Out of the Time-Critical VI	7
Downloading and Running the Application	9
Optimizing the Control Application	11

Launching LabVIEW and Exploring Documentation

The LabVIEW Real-Time Module includes a comprehensive documentation set designed to help you create deterministic applications. The *LabVIEW Real-Time Module Bookshelf*, available by selecting **Help»Search the Real-Time Module Bookshelf** from LabVIEW, is a document that contains links to and descriptions of the available Real-Time Module documentation. You must have Adobe Acrobat Reader with Search and Accessibility 5.0.5 or later installed to view the PDFs.

(Mac OS) PDF links do not work with the Apple Preview viewer. Refer to the Adobe Systems Incorporated Web site at www.adobe.com to download Acrobat Reader. Launch LabVIEW to open the **LabVIEW**

FieldPoint™, LabVIEW™, National Instruments™, NI™, and ni.com™ are trademarks of National Instruments Corporation. Product and company names mentioned herein are trademarks or trade names of their respective companies. For patents covering National Instruments products, refer to the appropriate location: **Help»Patents** in your software, the `patents.txt` file on your CD, or ni.com/patents.

April 2003
323525A-01

dialog box shown in Figure 1. Open and explore the *LabVIEW Real-Time Module Bookshelf*.




Figure 1. The **LabVIEW** Dialog Box

The *LabVIEW Help* contains VI reference information for all Real-Time VIs. You can access the *LabVIEW Help* by selecting **Help»VI, Function, & How-To Help**. Open and explore the *LabVIEW Help*.

The RT Module allows you to select the host computer or an RT target as an execution target to run VIs built in LabVIEW. The **LabVIEW** dialog box indicates the current execution target. The default execution target is the development machine, or host computer. Refer to Chapter 3, *Real-Time Module Environment*, of the *LabVIEW Real-Time Module User Manual* for information about the selecting execution targets.

When you select an RT target—an RT Series plug-in device or networked RT Series device—as the execution target, the LabVIEW development environment continues to run on the host computer but VIs run on the RT target. Refer to Chapter 1, *Introduction*, of the *LabVIEW Real-Time Module User Manual* for information about RT targets.

Creating and Running a Deterministic Application

This section describes the steps to create a deterministic PID control application. The application receives an analog input, processes the data using PID control VIs, and outputs the resulting control data. Refer to the *LabVIEW PID Control Toolset User Manual* for information about the PID control algorithm and the PID Control Toolset VIs. Refer to the *LabVIEW Real-Time Module User Manual* for information about Real-Time Module features.

Creating the Control Loop

Complete the following steps to create a control loop for the control VI.

1. Open a blank VI and display the block diagram.
2. Place a While Loop on the block diagram. Refer to the *LabVIEW User Manual* for information about using While Loops.
3. Right-click the conditional terminal and select **Create Control** from the shortcut menu to create and wire a **Stop** button control to the conditional terminal.

The block diagram should look similar to Figure 2.



Figure 2. Control Loop

The While Loop runs all code within its boundaries until the conditional terminal receives a TRUE value. Use the conditional loop as the control

loop in the next section. If you press the **Stop** button on the front panel, the button passes a TRUE value to the conditional terminal.

Adding Analog Input/Output and Data Processing to the Control Loop

Complete the following steps to add analog input/output and a PID control VI to the control loop.

1. Place the AI Sample Channel VI in the control loop on the block diagram.
(FieldPoint) Use the FP Read VI.
2. Right-click the **device** input of the AI Sample Channel VI and select **Create»Control** from the shortcut menu. This creates a control for the **device** input on the front panel.
(FieldPoint) Create a control for the **FieldPoint IO Point In** input of the FP Read VI.
3. Enter the device number or name of the data acquisition I/O device in the **device** control on the front panel. Refer to Chapter 2, *Installing and Configuring the RT Module and RT Targets*, of the *LabVIEW Real-Time Module User Manual* for information about device configuration.
4. Create a control for the **channel** input of the AI Sample Channel VI as you did in step 3 and set the control to the input channel.
5. Place the PID VI in the control loop on the block diagram. You also can create custom control VIs using LabVIEW.
6. Wire the **sample** output of the AI Sample Channel VI to the **process variable** input of the PID VI.
(FieldPoint) Wire the **Value** output of the FP Read VI to the **process variable** input of the PID VI.
7. Create controls for the **PID gains** and **setpoint** inputs of the PID VI.
8. Place the AO Update Channel VI in the control loop on the block diagram.
(FieldPoint) Use the FP Write VI.
9. Wire the **output** output of the PID VI to the **value** input of the AO Update Channel VI.
(FieldPoint) Wire the **output** output of the PID VI to the **value** input of the FP Write VI.
10. Create controls for the **device** and **channel** inputs of the AO Update Channel VI and set the controls to the device number and output channel number.
(FieldPoint) Create a control for the **FieldPoint IO Point In** input of the FP Write VI.

The block diagram for a DAQ system should look similar to Figure 3.




Figure 3. DAQ Control Loop

The block diagram for a FieldPoint I/O system should look similar to Figure 4.




Figure 4. FieldPoint Control Loop

The AI Sample Channel VI reads analog data from the specified device channel and sends the data to the PID VI. The PID VI processes the data using a PID control algorithm. The AO Update Channel VI returns the results to the specified device channel. Refer to the *LabVIEW PID Control Toolset User Manual* for information about using PID VIs. Refer to the `examples\Real-Time\RT Control.llb` for examples of control VIs.

Setting Priority of the VI to Time Critical

To ensure determinism you must assign time-critical priority to the control loop. A VI set to time-critical priority receives enough processor resources to complete time-critical tasks.

1. Right-click the connector pane icon at the top right corner of the VI and select **VI Properties** from the shortcut menu to open the **VI Properties** dialog box.
2. Select **Execution** from the **Category** pull-down menu.
3. Select **time critical priority (highest)** from the **Priority** pull-down menu.
4. Click the **OK** button to set the priority.

Refer to Chapter 4, *Building Deterministic Applications*, of the *LabVIEW Real-Time Module User Manual* for information about dividing and prioritizing application tasks. Refer to the Priority Trouble VI in the `examples\Real-Time\RT Tutorial.llb` for an example of priority settings.

Adding Timing to the Control Loop

You must add a timing mechanism that pauses, or sleeps, the control VI to ensure that other VIs in the application have enough processor resources to complete. A time-critical VI that does not have any sleep time completely monopolizes the embedded CPU resources.

1. Place the Wait Until Next ms Multiple VI in the control loop on the block diagram.
2. Right-click on the **millisecond multiple** input of the Wait Until Next ms Multiple VI and select **Create»Constant** from the shortcut menu.
3. Enter 10 into the **millisecond multiple** constant. The timing mechanism assures you that the control loop code runs and then sleeps until the time equals 10 ms from the start of the iteration. Other VIs in the application can run during the sleep time.
4. Select **File»Save As** and save the VI as `First PID Control.vi`.

The block diagram should look similar to Figure 5.




Figure 5. DAQ Control Loop with Timing

Refer to Chapter 5, *Creating Deterministic Control Applications*, of the *LabVIEW Real-Time Module User Manual* for information about the different methods for timing control loops. Refer to the `examples\Real-Time\RT Timing.llb` for examples of different timing methods.

Sending Data Out of the Time-Critical VI

The First PID Control VI can run on the RT target at time-critical priority, but you might need to monitor the status of the VI as it runs on the target. Also, you might need to update the values of control loop parameters. Use the Real-Time FIFO VIs to send data between the First PID Control VI and a normal priority communication VI that also runs on the RT target. The communication VI on the RT target can receive data from the First PID Control VI and then use network communication methods to update a host computer VI. Refer to the *LabVIEW Real-Time Module User Manual* for information about using the Real-Time FIFO VIs.

Complete the following steps to control the **Stop** button from the host computer.

1. Open the First PID Control VI in LabVIEW.
2. Remove the **Stop** button control wired to the conditional terminal of the control loop on the block diagram.
3. Place the RTFIFOCreate VI to the left of the control loop on the block diagram.
4. Right-click the **name** input of the RTFIFOCreate VI and select **Create»Constant** from the shortcut menu. Enter `Stop Control` into the **name** constant.
5. Wire a numeric constant to the **type** input of the RTFIFOCreate VI. The **type** input represents the type of data that you want the RT FIFO to contain.
6. Place the RTFIFORead VI in the control loop on the block diagram.
7. Right-click the While Loop and select **Add Shift Register** from the shortcut menu. Use While Loop shift registers to pass data from one iteration to the next. Refer to the *LabVIEW User Manual* for information about using shift registers.
8. Wire the **rt fifo** output of the RTFIFOCreate VI to the left terminal of the shift register and then wire the terminal to the **rt fifo** input of RTFIFORead VI.
9. Add another shift register and repeat step 8 to wire the **error out** output of the RTFIFOCreate VI to the **error in** input of the RTFIFORead VI.
10. Wire the **rt fifo** and **error out** outputs of the RTFIFORead VI to the right terminal of the shift registers.
11. Place the Equal? function in the control loop to the left of the conditional terminal. Wire the **element out** output of the RTFIFORead VI to the **x** input of the Equal? function. Right-click the **y** input of the Equal? function and select **Create»Constant** from the shortcut menu. Enter 1 into the constant.
12. Wire the **x = y?** output of the Equal? function to the conditional terminal of the control loop.
13. Select **File»Save As** and save the VI as `Second PID Control.vi`.

The block diagram should look similar to Figure 6.




Figure 6. DAQ Control Loop with RT FIFOs

Downloading and Running the Application

You have created the time-critical control loop that runs on the RT target. You can use the `RT Engine - Normal Priority Loop (TCP Comm) .vi` and the `Host Machine (TCP Comm) .vi` examples located in the `examples\Real-Time\RT Tutorial.llb` for the normal priority and host computer VI.

Complete the following steps to download the RT target VIs and test the functionality.

1. Without closing the Second PID Control VI, open the `RT Engine - Normal Priority Loop (TCP Comm) VI` and view the block diagram.
2. In the upper-right corner of the Second PID Control VI front panel there is a connector pane image of the VI. Click and drag the image to the block diagram of the `RT Engine - Normal Priority Loop (TCP Comm) VI` to use the Second PID Control VI as a subVI in the normal priority communication VI.
3. From the `RT Engine - Normal Priority Loop (TCP Comm) VI` block diagram, select **Browse>Show VI Hierarchy** to open the **Hierarchy** window. Notice that the thumbtack for `RT Engine - Normal Priority`



Loop (TCP Comm) VI is in the horizontal position, shown at left, indicating that you have not downloaded the VI to the RT target.

4. Select **Operate»Download Application** to download the VI. LabVIEW prompts you to save the VI. Save the VI as `Top Level Application.vi`.

The block diagram should look similar to Figure 7.




Figure 7. Communication VI



5. Select **View»Redraw** in the **Hierarchy** window to refresh the screen. Notice in the **Hierarchy** window that now the thumbtack for RT Engine - Normal Priority Loop (TCP Comm) VI is in the vertical position, shown at left, which indicates that you have downloaded the VI to the RT target.
6. Click the **Run** button. LabVIEW runs the VI on the RT target.
7. Select **File»Exit without closing RT Engine VIs** to close LabVIEW on the host computer while continuing to run the VIs on the RT target.
8. Start LabVIEW again and open the Host Machine (TCP Comm) VI. This VI publishes and controls the **Stop** button in the time-critical VI on the RT target. Test the functionality of the **Stop** button.
9. Exit LabVIEW by selecting **File»Exit** and when prompted close all VIs running on the RT target.

Optimizing the Control Application

Now that you have created a basic application, you can optimize the control application. Complete the following additional tasks to experiment with deterministic programming techniques.

- Optimize the time-critical VI further by moving all front panel control and indicator references out of the time-critical loop and to the host VI using the Real-Time FIFOs VIs. You can use the RT Communication Wizard to move all front panel controls and indicators out of a time-critical VI. Refer to Chapter 4, *Building Deterministic Applications*, of the *LabVIEW Real-Time Module User Manual* for information about using the RT Communication Wizard.
- Optimize the data acquisition. Other Data Acquisition VIs offer better performance for real-time applications. The AI SingleScan VI allows you to use hardware timing to validate that the loop is keeping real-time. Refer to the *LabVIEW Real-Time Module User Manual* for information about timing control loops using the AI SingleScan VI and for information about optimizing VIs for real-time performance.
- Use different control algorithms. The PID Control Toolset, which contains many different control algorithms, installs with the Real-Time Module. In this exercise, you used the PID VI, but you can use the other control VIs available in the toolset.