

Note to Users

Current Rating for NI SH37F-37M Cables

The National Instruments SH37F-37M cables use 26 AWG wire that has a maximum current rating of 1.2 A per line. Some devices that can be physically connected to this cable have current ratings that exceed this limitation.

The SH37F-37M cables are not intended for use with hazardous voltages (greater than 42.4 V peak or 60 VDC).

Note to DIO Users

When using the NI SH37F-37M cable to connect to National Instruments 37-pin digital I/O devices, ensure that the device does not exceed the maximum current rating by evenly distributing the current among the VCC pins on the NI 6516 and NI 6518 devices, or among the GND pins on the NI 6517 and NI 6519 devices.

For more information about wiring, refer to the *Digital I/O Help for 6509/651x/6528 Devices*, available at ni.com/manuals.

Note to Compact FieldPoint Users

When using the NI SH37F-37M cable to connect to National Instruments compact FieldPoint devices, ensure that the device does not exceed the maximum current rating of the cabling.

For information about using the SH37F-37M cable with National Instruments compact FieldPoint devices, refer to the *Compact FieldPoint Accessories Operating Instructions*. To view this document, go to ni.com/info and type `rdcfao`.

Note to All Other Users

When using the NI SH37F-37M cable with other National Instruments devices, refer to the documentation included with the device to ensure that the device does not exceed the maximum current rating.

FieldPoint™, National Instruments™ and NI™ are trademarks of National Instruments Corporation. Product and company names mentioned herein are trademarks or trade names of their respective companies. For patents covering National Instruments products, refer to the appropriate location: **Help>Patents** in your software, the `patents.txt` file on your CD, or `ni.com/patents`.

© 2004 National Instruments Corp. All rights reserved.



371311B-01

Oct04